

CII National Awards For Excellence in Energy Management, 2021



Honda Motorcycle & Scooter India Pvt. Ltd. (HMSI)

Tapukara Plant

A Presentation By : 1. Manoj Ku. Singh 2. Sachin Agarwal

Contents of Presentation


SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.

Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.



HMSI-2F (Tapukara)



Plant	Mass prod Start	Planned Capacity	Area (Acre)
1F Manesar	2001	1.55 M	52
2F Tapukara	2011	1.20 M	58
3F Narsapura	2013	2.40 M	119
4F Vithlapur	2016	1.20 M	92

SN	Particular	Details
1	Location	Tapukara, Raj.
2	Land area	239700 m2
3	Const. Area	114770 m2
4	Investment	925 M
5	Model	09 Model in 2 lines

**HMSI 2F Initially started in 2011 with L1 (SC) in Step1 & L2 (MC) in Step2
HMSI 2F have become QCD Benchmark factory with a Capacity of 1.24 million Units/year**

MA (PPT) → 241 M/c

- Crank Case
- Cylinder Head
- Cylinder Comp
- Crankshaft



Marshal Conveyor



AGV



Press Shop




ATOS



PH Line – Case KOPA



Multi Gang head M/c



Robotic Welding



Reciprocating Bell

DC (PPT) → 11 M/c

- DC – 11
- MH & TR
- ETP



Manual Deburring



Auto Deburring

PB → 880 M/c

- Press & Weld
- Paint

All the available latest technology were incorporated to enhance the level of both Quality & Quantity with optimization of resource


Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.




Mr. Soichiro Honda
(Founder)



Mr. Toshihiro Mibe
(President & CEO)

Concept for Achieving Environmental Neutrality



2016 ●
Playing a Leading Role in Reducing CO₂ Emissions



2010 ●

New Honda Environmental Logo
Blue Skies for Our Children

1992 ●

Released our First Honda Environment Statement



1970 ●

World's 1st Automaker to comply with U.S. Clean Air Act



1960 ●


Honda actively endeavoured to solve Environment problems.



1948 ●

Honda was founded

GLOBAL TARGET



Honda basic approaches to reduce environmental impacts not only in product design, development and manufacturing but in all stage of product life cycle.

HMSI – 2F ENERGY POLICY

As responsible member of society, we at Honda Motorcycle & Scooter India Pvt. Ltd - Tapukara Plant will take every possible measure to eliminate wastage & Conserve energy. Our plant is committed in each of our manufacturing activity to:

- Substitute 100 % of our total energy requirement with renewable source of energy by 2050.
- Adopt energy efficient technologies & equipment for all future expansion & renovations.
- Implement intensive energy monitoring system, periodical audit & review system.
- Review periodically & compare our specific Energy Consumption with National/ International level bench marks to further drive the drive the idea of energy conservation.
- Continually improve energy efficiency through PDCA cycles & by setting short term & long term targets.
- Ensure sufficient information & resources are available to achieve the targets for energy conservation.
- Abide by the applicable legal & other requirements related to energy consumption.
- Promote awareness on the Energy Management System & propagate the energy policy among our employees, as well as persons working on our behalf & to the generic public.

Place : Tapukara

Date : 16-07-2021




Plant Head – 2F

Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.

【Grid Electricity】



Grid Electricity - 132 KV GIS
Sanctioned Load : 12MVA

【In House Solar – 7 MW】







【Thermal Energy - LNG】

LNG
Yearly Consumption : 4MillSCM



【Overall Energy Contribution】





DG – 8 No's
2000KVA Each




HT – 68 No's
11KV Each



Trafo – 23 No's
11/415V : 21
132/11KV : 02




LT Panel – 310 No's
415V , 50Hz



UPS – 7 No's
625 KVA Each

**Power Distribution Flow is from Generation Point to User End.
Highly Efficient UPS Installed for MA and HPDC Shop.**


【Target Setting for 3 Years】




【Action Plan for achieving Targets→ Future Identified Projects】

Sr.	Themes	97 Ki (2020- 21)	98 Ki (2021 - 22)	99 Ki (2022-23)	100 Ki (2024-25)
1	Solar Step-2 (2MW Capacity)	▼	▼		
2	Heat Pump in DC Chiller	▼	▼		
3	EC Fan in Air Washers		▼	▼	
4	Plug Fan in PA ABS Blower		▼	▼	
5	Solar Power Purchase PPA			▼	▼
6	Solar Surplus sell to JVVNL		▼	▼	
7	Mini Non IBR Boiler -LNG		▼	▼	
8	Smart Kitchen - LNG	▼	▼		
9	Centrifugal PA Chiller		▼	▼	
10	EC Axial roof exhaust fan		▼	▼	
11	EC ZA fin fan in PA ASU	▼	▼		
12	EC ZA fin fan in PA ASU -2			▼	▼
13	Solar Step-3 (650KW)			▼	▼
14	Centrifugal PA Chiller-2			▼	▼
15	EC Axial roof exhaust fan -2			▼	▼
16	Energy efficient burner : PA				▼
17	Artic master in DC chiller				▼
18	PA ASU - IDAC (indirect cooling)				▼
19	Air booster replacement			▼	▼
20	Hydroxy Generator			▼	▼
21	Energy efficient valve in Chiller line			▼	▼
22	Renewable energy : Hydro, wind, hybrid				▼

Projects Identified and implemented to achieve the target and optimize the Electrical & Thermal Energy Consumption



HMSI 2F have focus on incorporating the latest technology since beginning of any new setup to reduce Power cost & CO₂ reduction. We are sharing some important project like:-



Govt. Metering : 11KV → 132KV

Standard		HMSI	Status
Load	Metering	HMSI load – 12Mva	Trans. Loss : 3% → 0% (▼ 3%)
< 5mva	@ 11 KV	11KV → 132KV	
> 5 mva	@ 132 kv		



Power House : AIS → GIS

Standard	HMSI	Status
AIS GIS Hybrid	AIS → GIS	Eff : 89 -99 % (▼ 10%)



Compressor : Screw → Centrifugal

Standard	HMSI	Status
Screw Centrifugal Reciprocating	Screw → Centrifugal	SEC : kw/Cfm 0.16 → 0.14 (▼ 12.5 %)

HMSI 2F replaced old equipment with latest available energy efficient technology, and able to get the tangible benefits in terms of energy saving, CO₂ reduction and cost saving.



PA Booth Exhaust Fan: Belt → Direct Coupled

Standard Conventional Direct Coupled Belt driven	HMSI Belt Driven → Direct Coupled	Status SEC : Kw/Cfm ⁽¹⁰⁰⁰⁾ 0.8 → 0.65 (▼ 30 %)
--	--	---




Air Washer Fan : Belt driven → EC

Standard Belt driven EC Direct Couple	HMSI Belt Driven → EC	Status SEC : Kw/Cfm ⁽¹⁰⁰⁰⁾ 0.24 → 0.12 (▼ 50 %)
---	---------------------------------	--



PA Booth Supply Fan: Belt → EC BlueFin


Standard Direct Couple EC Blue Fin EC	HMSI Belt Driven → EC Blue Fin	Status SEC : Kw/Cfm ⁽¹⁰⁰⁰⁾ 0.24 → 0.10 (▼ 58 %)
---	---	--



Roof Exhaust Fan: Propeller → EC Axial

Standard Propeller EC Axial (5 th) EC Axial (3 rd)	HMSI Propeller → EC blue Axial (5 th Generation)	Status SEC : Kw/Cfm ⁽¹⁰⁰⁰⁾ 0.15 → 0.04 (▼ 73 %)
--	---	--

HMSI 2F replaced old equipment with latest available energy efficient technology, and able to get the tangible benefits in terms of energy saving, CO₂ reduction and cost saving.



Chiller : Screw → Centrifugal with VFD

Standard
Screw
Centrifugal
Reciprocating

HMSI
Screw → Centrifugal
With VFD

Status
SEC : IKW / Tr
1.13 → 0.54
(▼ 52 %)



Motor : IE2 → IE5 (EE)

Standard
IE 2
IE 3
IE 5

HMSI
IE 2 → IE 5

Status
Eff. : 77 % → 95%
(▼ 18 %)



Monitoring : Manual → Online SCADA

Standard
Manual
Online SCADA (CMS)
Stand alone

HMSI
Manual → Online
SCADA

Status
Controlling :
Manual → Auto
(▼ 1 %)




Kitchen : Conventional → Smart

Standard
Gas Cooking
Thermic Fluid
Induction Heater

HMSI
Gas → Thermic
Fluid

Status
SEC : Mill Scm /Yr
0.16 → 0.10
(▼ 38 %)

HMSI 2F replaced old equipment with latest available energy efficient technology, and able to get the tangible benefits in terms of energy saving, CO₂ reduction and cost saving.



DC Furnace : Waste → WHRS

Standard	HMSI	Status
Conventional WHRS Electric Heater	Electric Heater → Hot water (WE Washing m/c)	SEC : Mill Kwh /Yr 0.47 → 0.09 (▼ 81 %)




DC Chiller : Waste → Heat Pump

Standard	HMSI	Status
Conventional Heat Pump WHRS	Waste → Heat Pump (DC Chiller +PA)	SEC : Mill Scm /Yr 0.81 → 0.30 (▼ 63 %)



Compressor : Waste → WHRS


Standard	HMSI	Status
Conventional WHRS LNG	LNG → Heat water (Boiler)	SEC : Mill Scm /Yr 0.67 → 0.60 (▼ 10 %)



MA Washing m/c : Electrical → Heat


Standard	HMSI	Status
Conventional WHRS Electric Heater	Electric Heater → Hot water (Washing m/c)	SEC : Mill Kwh /Yr 0.37 → 0.08 (▼ 78 %)

HMSI 2F replaced old equipment with latest available energy efficient technology, and able to get the tangible benefits in terms of energy saving, CO₂ reduction and cost saving.




Power : Conventional → SOLAR

Standard	HMSI	Status
Upto Sanction Load (12 mva)	Conventional → Solar roof top (5.9) + Solar PPA (6.1)	RE : 0 → 76 % (▲ 76 %)




AC : Conventional → Geo Thermal

Standard	HMSI	Status
Conventional Geo Thermal VRV	Conventional → Geo Thermal	RE : 0 → 80 % (▲ 80 %)



Power : Conventional → Hybrid

Standard	HMSI	Status
Conventional Hybrid Solar & Wind	Conventional → Hybrid	RE : 76 → 76.1 % (▲ 0.1 %)



Power : Conventional → Wind

Standard	HMSI	Status
Conventional Wind Solar	Conventional → Wind	RE : 76.1 → 76.2 % (▲ 0.1 %)

HMSI 2F replaced old equipment with latest available energy efficient technology, and able to get the tangible benefits in terms of energy saving, CO₂ reduction and cost saving.

Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.

S.N.	Theme	Saving (Mill Kwh/Yr)	Saving (Mill Rs/Yr))	CO ₂ Reduction (Ton / Yr)
1	Solar Step-1 (5MW)	6.50	52.33	4856
2	Solar Step-2 (2MW)	2.60	20.93	1942
3	EC Fan in All Air Washers	1.41	11.32	1050
4	Plug Fan IC in PA Shop	0.33	2.66	247
5	Plug Fan Expansion in PA Shop	0.05	0.38	35
6	PA ASU Mezz Clean to reduce heat load on PA Chiller	0.10	0.80	74
7	WE dust collector utilize in Fume exhaust by selecting Old Blowers	0.05	0.40	37
8	Energy saving through oven circulation fan speed reduction	0.04	0.28	26
9	Energy saving through booth load reduction in ABS1 & SPC1	0.03	0.26	24
10	EC Fan in HPDC AW-24	0.07	0.53	49
11	PA Shop AW Stop in C Shift	0.02	0.18	17
12	Plug Fan in ABS Blower-3nos.	0.08	0.67	62
13	Solar Hybrid Air Conditioner 4 nos	0.01	0.05	5
14	Magnetic Coupling in Pump in Cooling Tower	0.01	0.08	8
15	Cooling Tower Blade Metallic to Epoxy Resin	0.00	0.03	3
16	PA Shop Chilled Water Valve Optimization	0.28	2.24	208
17	Centrifugal C.Tower Blade to E-Glass Epoxy FRP	0.00	0.03	3
18	Magnetic Coupling in Compressor Pump	0.01	0.04	4
19	Compressor Receiver Valve Auto Air Drain Type	0.14	1.13	104
20	Cost Saving by reducing Chiller Pump Frequency	0.01	0.05	5
21	Enhance Operation of ED Chiller	0.01	0.05	4
22	SCADA system for Paint Shop	0.08	0.65	60
23	Energy saving through Washing machine Air blower speed reduction	0.01	0.11	10
24	Air Saving by modification in trimming press in HPDC	0.09	0.74	69
25	Air Saving during lunch & Dinner time in Weld Shop	0.00	0.02	2
26	High efficiency motor in Paint shop	0.00	0.01	1
27	VFD in Paint shop, PT line pump	0.02	0.20	19
28	Scale watcher & Side Screen Filtration Unit	0.02	0.15	14
29	Air saving by modification in Baker Unit	0.20	1.61	149
30	power saving through VFD installation in ETP	0.00	0.02	2

S.N.	Theme	Saving (Mill Kwh/Yr)	Saving (Mill Rs/Yr)	Co2 Reduction (Ton / Yr)
31	Inhouse preparation of ETP control panel	0.04	0.31	29
32	Power saving by providing energy efficient motor in assembly line	0.01	0.04	4
33	Air saving in AF sub-assembly, during non-working hrs.	0.02	0.14	13
34	All hydraulic press power saving mode from 15 min to 2 min hybrid mode	0.01	0.06	6
35	VFD installation at ACED line Hot water circulation pump	0.00	0.02	2
36	Energy efficient motor provided in ETP MEE Permeate pump	0.03	0.26	24
37	High watt to low watt light at MS dock	0.01	0.12	11
38	PA Air Dryer	0.06	0.46	43
39	Optimization of DC AHU	0.01	0.06	6
40	WE dust collector utilize in Fume exhaust by selecting Old Blowers	0.02	0.15	14
41	Compressed air leakage arresting	0.07	0.60	56
42	Power consumption saving in DURR machine during non working hours	0.00	0.02	2
43	Mixing of Additives in AC/ Chiller for reducing load	0.01	0.10	9
44	Air Leakage control in Shop floor	0.06	0.45	42
45	High watt to low watt light at High Mast Pole	0.00	0.01	1
46	Steam supply optimization in HPDC evaporator	0.01	0.15	12
47	Thermal paint on HPDC furnace	0.01	0.21	17
48	Smart Kitchen	0.01	0.35	28
49	Boiler Modulation	0.00	0.10	8
50	Installation of Heat Pump on DC Chiller	0.14	3.80	304
51	Cost saving by introducing waste heat based Evaporator in place of steam based.	0.04	1.06	84
52	Airtron for Air Conditioning	0.03	0.23	21
53	Roof Exhaust Fan from Propeller to Axial flow	0.00	0.02	2
54	Solar Dome Light	0.00	0.01	1
55	Coventional Blower replacement with EC in AW 17 MA	0.13	1.03	95
56	Implementation of VFD in Airwasher	0.13	1.04	96
57	Cost saving through Maintaining Power Factor up 0.99	0.53	4.27	396
58	Centrifugal Compressor	0.45	3.59	333
59	Online Monitoring System in Utility	0.16	1.30	121
60	EC Fan in HPDC AW	0.00	0.00	0

S.N.	Theme	Saving (Mill Kwh/Yr)	Saving (Mill Rs/Yr)	Co2 Reduction (Ton / Yr)
61	Yamada pump replacement in Die-Lubrication	0.01	0.10	9
62	Pressure Sensor	0.01	0.10	9
63	Energy efficient pump installation in ETP	0.01	0.09	8
64	Air Saving during lunch & Dinner time in Weld Shop	0.01	0.09	8
65	High efficiency motor in Paint shop	0.01	0.04	4
66	VFD in Paint shop, PT line pump	0.02	0.20	18
67	SCADA system for Paint Shop	0.40	3.23	299
68	Energy saving through VFD installation in ACED line touch-up booth.	0.01	0.07	7
69	Magnetic Coupling in CT Pump-1 nos.	0.00	0.03	3
70	Axial Fan in Roof Exhaust - 6 nos.	0.00	0.02	2
73	Power Saving Through Open Access	0.20	1.65	153
74	Boiler Modulation	0.00	0.01	0
75	Waste Heat Recovery System in HPDC Furnace	0.14	3.84	306
76	Installation of Heat Pump on DC Chiller and Utilize Waste heat to supply hot water for Paint Shop	0.38	10.14	810
77	Sludge Dewatering System	0.02	0.14	13
78	To reduce heat loss from melting furnace (LNG save through Aerogel Painting)	0.03	0.25	23
79	Power and steel cost saving by installing VFD on shot-blasting machine	0.13	1.04	96
80	Roof exhaust fan running linkage as per production.	0.04	0.32	29
81	Installation of tertiary RO to reduce evaporator running from 16hr to 7hr	0.10	0.77	71
82	Compressor Receiver Valve Auto Air Drain Type	0.15	1.22	113
83	Magnetic Coupling in Compressor Pump	0.00	0.02	2
84	Replacement of Sludge transfer Pump with High Efficiency Pumps in WWTP	0.01	0.06	5
85	Artic Master	0.01	0.06	6
86	PA Shop AW Stop in C Shift	0.01	0.08	7
87	Thermal Paint on HPDC Furnace	0.03	0.72	57
88	High Watt to Low Watt Light	0.02	0.16	15
89	Lighting Optimization at Logistic Mezzanine	0.02	0.15	14
90	MaxR100 Refrigerant Additive in HVAC System	0.01	0.05	4

S.N.	Theme	Saving (Mill Kwh/Yr)	Saving (Mill Rs/Yr)	CO ₂ Reduction (Ton / Yr)
91	Inline Duct EC Fan	0.02	0.12	12
92	SOLAR PPA 3 MW	0.28	2.28	211
93	ED Chiller Pump operation optimization	0.01	0.12	11
94	Intelligent Touch Manager	0.01	0.10	9
95	AHF Installation in PA Shop (Capacitor Panel)	0.04	0.30	28
96	VRV to VRV-X Technology in HPDC CMM Room	0.01	0.06	5
97	Optimisation of compressed air in Paint Shop dryer for regeneration	0.06	0.48	44
98	EC Fan in HPDC AW-24	0.02	0.17	16
99	Plug Fan in ABS Blower-3nos.	0.00	0.04	3
100	PM motor in weld cooling tower pump	0.07	0.54	50
101	Hot water Evaporator (Steam stop in DC)	0.01	0.37	29
102	Elimination Of IBR Boiler	0.01	0.27	22
103	Elimination of pumps by feeding reject water directly to Z Soft	0.01	0.04	4
104	Sludge Dewatering System (Centrifugal sys)	0.12	1.00	93
105	Energy saving by replacement of existing motor with energy efficient motor	0.01	0.08	8
106	Cost saving by introducing waste heat based Evaporator in place of steam based.	0.06	0.48	45
107	Energy saving through Washing machine Air blower speed reduction	0.01	0.12	11
108	Air Saving by modification in trimming press in HPDC	0.01	0.07	6
109	power saving through VFD installation in ETP	0.02	0.14	13
110	Power saving by providing energy efficient motor in assembly line	0.01	0.07	6
111	Air saving in AF sub-assembly, during non-working hrs.	0.02	0.14	13
112	All hydraulic press power saving mode from 15 min to 2 min hybrid mode	0.01	0.07	6
113	VFD installation at ACED line Hot water circulation pump	0.00	0.02	2
114	Power consumption saving in DURR machine during non working hours	0.01	0.08	7
115	Power saving in logistics Scissor lifter	0.09	0.71	66
116	Energy saving by through coolant pump stop in idle time in FRD	0.13	1.02	95
117	Energy saving through speed reduction of oven circulation fan during post purging	0.02	0.12	11
118	Energy saving by providing VFD in Washing machine No. 1 & 3 Spray pump	0.04	0.29	27
119	Energy efficient motor to be provide in AF Subassembly Press	0.01	0.10	9
120	Hydr.Power pack motor saving in Brother mc's	0.01	0.10	9

We have implemented 120 projects in last three year and due to this HMSI 2F able to save 152 Mil Rs. / yr, 118 Mil. Kwh/Yr and 13,837 MT CO₂/ yr.



Theme :-
Utilize wastage of air from Cooling tower fan , to generate the electricity thru “Wind Turbine”

Investment :- 0.7 Mill Rs **ROI :- 35 Months**

Power Saving	.03mill kwh/Yr	Category Reuse/ Renewa ble
CO2 Reduction	23 Ton/Yr	
Cost Saving	0.24 Mill Rs/Yr	

Before


CT Fan : Air wastage in Atmosphere



Draft Air loss Velocity	17 mm/ sec (wastage)
KWH Generation	Nil

After

Wind Turbine



Draft Air loss Velocity	Utilize in wind turbine
KWH Generation	0.01 Mill Kwh

CO₂ Reduction **23 %**

Reduce CO₂ 23 % by reduction of Power 0.03 mill kwh/yr thru installation of “Wind Turbine”




Theme :-
Replacement of Plant roof exhaust fan with Energy Efficient EC Axial Fan

Investment :- 8.4 Mill Rs **ROI :- 30 Months**

Power Saving	0.4 mill kwh/Yr	Category Reduce
CO2 Reduction	328.7 Ton/Yr	
Cost Saving	3.4 Mill Rs/Yr	

Before

Plant Roof Exhaust Fan : Propeller Type



Direct Driven

Type	Propeller
Capacity	8,000 CFM
Quantity (Pilot Project)	Total 147 (Pilot - 42)
KW / Fan	1.42 Kw/hr

After

Energy Efficient EC Axial Fan (Next Generation Fan)



Controller Driven

Type	EC Axial Fan
Capacity	16,800 CFM
Quantity (Pilot Project)	Total 70 (Pilot - 20)
KW / Fan	0.6 Kw/hr


CO2 Reduction **73 %**

Reduce CO₂ 78 % by reduction of Power 0.44 mill kwh/yr thru installation of "EC Axial roof Exhaust Fan"

Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.



Situation analysis as per Geographical condition

Resource	Feasibility in India	Feasibility in HMSI-2F	Standard Requirement	Status in HMSI 2F	Gap Analysis
Solar		●	Depend on Radiation	Implemented Roof – 5.9MW PPA – 6.1MW	-
Wind		●	12~14 km/h	Implemented (2.5 KW)	Average 5 km/h in Bhiwadi
Hydro	●	○	Need Water Reservoir		No Water Source
Bio-Energy		○		Under Study	Technical Feasibility
Geothermal		●		Implemented	-
Hybrid (Solar + Wind)		●		Under installation	3-4 KW



HMSI 2F long term target is 100% utilization of carbon free energy by 2050.

【Target Setting → Electrical Energy】

【Target Setting → Thermal Energy】

Specific & Absolute Power Targets

Specific & Absolute LNG Targets



【Action Plan To Achieve The Targets】

Solar PPA 96 Ki

From Solar Plant in Jodhpur-Bikaner Highway

Smart Kitchen

Polycarbonate Sheet with Fan

Solar Dome Light

97 Ki ●

Cost Required: 18 Millrs

Increase In Renewable Contribution : 5 %

Solar Step-3

Biogas → Kitchen waste

98 Ki ○

Cost Required: 25 Millrs

Increase In Renewable Contribution 8 %

Electrical (4%) + Thermal(4%)

Solar Dishes for Hot water

99 Ki ○


Cost Required: 29 Millrs

Increase In Renewable Contribution 36 %


Electrical (3%) + Thermal (33%)

Green Energy 2050 Ki

To achieve 100% utilization of carbon free energy by 2050 different initiatives has been taken.





[Initiatives Taken To Optimize LNG Consumption In Production Equipment]



LNG consumption in production equipment has been reduced by 21% over the yrs. To optimize further, need to focus on non production equipment like canteen

Before → Cooking Process & Vessels




High ambient working env.



Chance offire inside kitchen area

After → Cooking Process & Vessels

Thermic Oil Quantity - 3KL
Hitech Therm Food 57



Insulated Jacket

Oil Temp. → 220 ~ 250 °C
Cooking Temp. → 185 ~ 200 °C



Frying Process → Before



Frying Process → After



Technology Concept



Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.

Scope 1

- Fuel Consumption
- Air Conditioning
- Fire Extinguisher (Only CO₂ type fire extinguisher)



Fuel Consumption in Boiler, DG



Air Conditioning



Fire Extinguisher

Scope 2

- Grid Purchase

power plant generates electricity



transmission lines carry electricity long distances



transformer steps up voltage for transmission



HONDA
The Power of Dreams

Scope 3

- Employee Commute

Downstream:-

- Waste Disposal
- Logistics



Employee Commute




Waste Disposal Transportation



Logistics


Scope 1

Scope 01 Data												
Items	94 Ki			95 Ki			96 Ki			97 Ki		
	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Vehicle (Dec '19)	Data (Kg CO ₂)	Kg CO ₂ /Veh
Fuel Consumption		9985100	9.35		10482790	8.51		10047080	8.64		6383230	7.68
Refrigerants	1067416	488700	0.46	1232057	1306880	1.06	1163281	249720	0.21	831091	161060	0.19
CO ₂ Cylinders		4468	0.004186		2.5	0.000002		5	4E-06		2.07	2.5E-06
Total		10478268	9.82		11789673	9.57		10296805	8.85		6544292	7.87




Scope 2

Scope 02 Data												
Items	94 Ki			95 Ki			96 Ki			97 Ki		
	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh
Electricity Purchase	1067416	36347600	34.05	1232057	41696610	33.84	1163281	30465220	26.19	831091	20072930	24.15



Scope 3

Scope 03 Data												
Items	94 Ki			95 Ki			96 Ki			97 Ki		
	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh	Total Vehicle	Data (Kg CO ₂)	Kg CO ₂ /Veh
Waste disposal		85000	0.07		115032.5	0.09		103371	0.09		61260	0.07
Employee commute (Car)		23220	0.02		23649	0.02		23649	0.02		23649	0.03
Employee commute (Bus)	1067416	102340	0.08	1232057	104232	0.08	1163281	104232	0.09	831091	104230	0.13
Logistics trucks		6679980	5.42		6519980	5.29		6007200	5.16		4172500	5.02
Total		6890540	5.59		6762893.5	5.49		6238452	5.36		4361639	5.25



Monitoring of reduction is carried out regularly in each scope.

II. Honda Green Purchasing Policy

For Honda, activities to conserve the global environment establish an important pillar in our corporate policies. Our goal is to reduce our environmental footprint over the entire life cycle of our products, from product development to purchasing, production, administration, transportation, and to sales and recycling.

To carry out these activities effectively, we are continuing to take strong measures to reduce our environmental footprint in each area, together with our suppliers. We are also adding E (Environment) to our supplier evaluation categories⁽¹⁾ of Q (Quality), C (Cost), D (Delivery) and D (Development) to allow us to more actively encourage purchasing environmentally friendly parts and materials.

Below is a list of the individual areas in Honda green purchasing activities.

- Environmental management activities to ensure environmental control for products (parts and materials) and corporate activities
- Corporate activities⁽²⁾ to supply these products (parts and materials) (Development, Purchasing, Production, Administration, Transportation, Sales, Recycling)
- Products (parts and materials, etc.) purchased by Honda


Collectively, these are referred to as the areas of our environmental activities.

For each area, the overall purchasing activities of sharing policies with suppliers and achieving targets together are called Honda green purchasing activities.

⁽¹⁾ The results of activities at each supplier in response to these guidelines may be evaluated.

⁽²⁾ Corporate activities cover all activities related to Honda products (including not only first-tier but also sub-tier suppliers).

Honda has built its own Green Purchasing Policy



Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.



Operating Head
(Pankaj Chauhan)



Division Head-PE
(Sunil Pandita)



Department Head-Utility
(Inder Singh)

Energy Manager

Section Head
Energy Conservation



Core Team

Energy Manager

Section Head
Energy Conservation



Roles & Responsibilities:

- Target Setting & Benchmarking
- Planning of Major EE Projects
- Review of Daily & Monthly Energy Report

Team Member

Sunil Kumar
Unit Leader
Energy Conservation



- Making New EE Proposals
- Execution of Encon Ideas
- Energy Cell Co-ordination

Team Member

Anil Bhardwaj
Team Member
Ut-Mech & Inst.



- Training & Awareness

Team Member


Surender Kumar
Team Member
Ut-Elect.



- Equipment Energy Monitoring

Team Member

Satveer
Team Member
Project & Infra



- Daily Energy Reporting
- Co-ordination with all Depts.

Departmental Coordinators – CFT Team

Area	Responsible Person
MA	Shailendra Yadav
AE	Puneet Ratra
AF	Ajay Sood

Area	Responsible Person
VQ	Anand Yadav
PA	Sachidananda Pal
WE	Pradeep Pilaniya


Area	Responsible Person
LOG	Abhishek Rathore
GA	Hazari Meena
DC	Shashank Jain

Area	Responsible Person
Maint	Vishal/Sanjay
MS	Baljeet Singh
PQ	Punit Pal


For this, Well established organization available to work on energy consumption and innovation related project in this plant.

Daily Monitoring → Section/Dep't Level

Electrical Energy



Thermal Energy



CMS System

[Power Consumption Monitoring]

Monitoring Parameters :
KWH , Voltage , Frequency , KV/AH , Power Factor
Total Meters Installed for Monitoring at S/S End
19 Nos Meters , Model : ION 7650 Schneider Make

[Facility Equipment's Monitoring]

Running Hours Optimized In :

- 1) Lunch Time
- 2) Tea Time
- 3) Holidays
- 4) Shift change

Stop during less loading condition

[DG Online Monitoring]

NO	STATUS	TYPE	MODE	START TIME	STOP TIME	START DATE	STOP DATE	START TIME	STOP TIME	START DATE	STOP DATE
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0

- Changeover Grid → DG : **AUTO**
- Changeover DG → Grid : **AUTO**
- DG Monitoring : **AUTO**

[Solar SCADA Monitoring]

SCADA Dashboard

PARAMETER	GRID POWER	SOLAR POWER
VOLTAJE (V)	11.05	11.05
CURRENT (A)	370.00	126.30
POWER FACTOR	0.980	0.878
ACTIVE POWER (KW)	6900.00	2123.03
FREQUENCY (HZ)	49.87	49.85



Weather Monitoring System

String Monitoring System

NO	STATUS	TYPE	MODE	START TIME	STOP TIME	START DATE	STOP DATE	START TIME	STOP TIME	START DATE	STOP DATE
1	0	0	0	0	0	0	0	0	0	0	0
2	0	0	0	0	0	0	0	0	0	0	0
3	0	0	0	0	0	0	0	0	0	0	0
4	0	0	0	0	0	0	0	0	0	0	0
5	0	0	0	0	0	0	0	0	0	0	0
6	0	0	0	0	0	0	0	0	0	0	0
7	0	0	0	0	0	0	0	0	0	0	0
8	0	0	0	0	0	0	0	0	0	0	0
9	0	0	0	0	0	0	0	0	0	0	0
10	0	0	0	0	0	0	0	0	0	0	0
11	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0

HMSI 2F, all monitoring parameters are monitored on SCADA & Online monitoring facility available at a Glance.


Sharing of Report



Sharing of Daily Data to all HODs & Operating Head.



Sample Format

【Strategy for Employee Involvement & Awareness】



【① Trainings】

Need Identification



GLIMPSES OF TRAINING:



External Trainings Organized for Associates

1	Corrosion Under Insulation
2	Troubleshooting of DG
3	Troubleshooting of Burner
4	Maintenance of Air Dryer
5	Maintenance of Compressor
6	PLC Training
7	Troubleshooting's of Chiller

【Energy Exam Attempt】




Energy Manager Exam attempt in 2018 by HMSI "Designated Energy Manager".

Admit Card Not received

【② NHC/Kaizen Platform】

Evaluation Level



- 1 Lack of Willingness
- 2 Lack of Motivation Skill
- 3 Lack of Monitoring Skill


Lot of Activities are carried out for employee awareness and employee involvement. Encon Cell Members also being encouraged for Energy Manager Exams & Learnings

Contents of Presentation

SN	Contents	Slides	Time
1	Company Profile	1-2	1 min.
2	Energy Management	3-4	2 min.
3	Energy Data	5-13	4 min.
4	ECON Projects & Innovative Ideas	14-19	3 min.
5	Renewal & Green Energy	20-23	2 min.
6	GHG Emission, Green Supply, and Capacity Building	24-26	2 min.
7	Review Mechanism, Employee Engagement	27-29	2 min.
8	Way Forward	30	1 min.

Total 30 slides and time required for presentation is 17 Minutes.

Initiatives by HMSI 2F to Ensure Blue Skies for Future Generations



More Space
High Energy cost
High Manpower cost



Space efficient
Energy efficient
Manpower efficient



- 2013 - 14**
- 1 Air Pressure 6 Bar → 5.1 Bar
 - 2 Propane → LNG

- 2014 - 15**
- 1 Timer Based AC Exh. Fan Plant Lighting

- 2015 - 16**
- 1 Conventional Light → LED
 - 2 Condensate recovery system
 - 3 Zero Landfilling

- 2016 - 17**
- 1 Steam collection from steam trap
 - 2 Heat recovery from compressor

- 2017 - 18**
- 1 11KVA → 132 KV
 - 2 Grid Power → 5 MW Solar power
 - 3 Centralize equipment control
 - 4 RTD in cooling tower.

- 2018 - 19**
- 1 Geothermal System
 - 2 7 MW Solar power plant
 - 3 Centrifugal Compressor
 - 4 Rain water reusing system.
 - 5 Online monitoring control system
 - 6 Air networking in header
 - 7 Solar PPA

- 2019 - 20**
- 1 Hot water Supply (LNG) in place of Electric Heater Electricity
 - 2 2 stage RO → 3 stage RO
 - 3 Normal Hot water → Heat Pump
 - 4 Tech. train. centre
 - 5 WHRS in DC furnace
 - 6 Solar Dome light
 - 7 Solar Dish
 - 8 Air washer blower → EC fan
 - 9 Smart Kitchen to reduce LNG consumption

- 2021 - 23**
- 1 Centralize PA chiller -2
 - 2 Energy Efficient burner - PA
 - 3 PA ASU - IDAC
 - 4 Air booster replacement
 - 5 Hydroxy generator
 - 6 Energy efficient valve in chiller line
 - 7 Centrifugal chiller -2



HMSI Tapukara plant has been taking continual improvement initiatives to realize our future target to archive 100% utilization of carbon free energy by 2050.

Let's make a better tomorrow for our Future Generation.....



Thank You