

**Cognizant**

# **22<sup>nd</sup> National Award for Excellence in Energy Management 2021**

Siruseri STPI - Chennai

---

August 2021

# Agenda

1. Company Profile
2. Energy Consumption Overview
3. Specific Energy Consumption In Last 3 Years (2018-2020)
4. Information on Internal & National Benchmark
5. List of Major Energy Conservation Project Planned in 2021
6. Energy Saving Projects Implemented in Last 3 Years
7. Innovative Project Implemented Details
8. Utilization of renewable Energy sources
9. Waste Utilization & Management
10. GHG Inventorisation
11. Teamwork, Employee Involvement & Monitoring
12. Awards & Certifications

# Cognizant Overview



Cognizant is a multinational corporation that provides IT services, including digital, technology, consulting, and operations services. It is headquartered in Teaneck, New Jersey, United States.

**#185**

On 2021 **Fortune 500**

Fortune

**#533**

On **Forbes Global 2000** for 2020

Forbes

**#483**

On **Forbes The Best Employers for Diversity 2019**

Forbes

**12 Years**

One of **Fortune's Most Admired Companies**

Fortune

**#63**

On **Forbes Top 100 Digital Companies** for 2019

Forbes

**#19**

On **Forbes America's Best Employers 2020**

Forbes

Cognizant is included in the **NASDAQ-100** and the **S&P 500** indices. Cognizant had a period of fast growth during the 2000s

159+ delivery and operations centers globally and spread across 39 countries

The company has more than 291700 employees globally, of which, 100000 are women

Total global footprint of 24 million+ built up area, in which 13.6 million SFT is of own Facility

Majority of these operations are in hot and humid climate and operates on 24X7 basis

More than 80% of the space is air-conditioned


# Facility Overview

Description	Specification	
Facility information	<ul style="list-style-type: none"> <li>Year of Start: 2004</li> <li>Owned facility</li> </ul>	<ul style="list-style-type: none"> <li>Total area of Facility : 9 Acres</li> <li>Total Built-up area : 312,000 Sq.ft</li> <li>SDB (G+3) , Academy ( G+3), Cafeteria (G+1)</li> </ul>
Seating information	<ul style="list-style-type: none"> <li>BAU Headcount: 2800</li> </ul>	<ul style="list-style-type: none"> <li>Non R2O headcount – 100 (Apr'20 to Dec'20)</li> </ul>
Substation	<ul style="list-style-type: none"> <li>EB Sanctioned Demand 2350 kVA</li> </ul>	<ul style="list-style-type: none"> <li>Transformers Capacity: 11kV / 433 V, 5000 kVA</li> </ul>
Diesel Generators	<ul style="list-style-type: none"> <li>Total Capacity: 4500 kVA</li> </ul>	<ul style="list-style-type: none"> <li>Capacity Break up: 3 No's x 1500 kVA</li> </ul>
UPS	<ul style="list-style-type: none"> <li>Total UPS Capacity – 640 KVA</li> </ul>	<ul style="list-style-type: none"> <li>Modular UPS 2 x 180 KVA , 2 x 120 KVA</li> <li>Conventional – 1 x 40 KVA</li> </ul>
Chillers	<ul style="list-style-type: none"> <li>Total Capacity: 1610 TR</li> </ul>	<ul style="list-style-type: none"> <li>Air Cooled Chiller SDB – 3 x 350 TR, Academy -2 x 280 TR</li> </ul>
Sewage Treatment Plant	<ul style="list-style-type: none"> <li>Capacity : 200 KLD</li> </ul>	
High Speed Diesel (HSD)	<ul style="list-style-type: none"> <li>Capacity : 30 KL</li> </ul>	
Raw Water	<ul style="list-style-type: none"> <li>Capacity : 650 KL</li> </ul>	
Fire Sump	<ul style="list-style-type: none"> <li>Capacity : 240 KL</li> </ul>	




# Energy Consumption Overview - 2018 to 2020

Energy consumption comparison (kWh)  
2018 – 2020




Source wise consumption  
comparison (%) - 2020




# Specific Energy Consumption Overview - 2018 to 2020

EPI Comparison in 2018 to 2020  
(kWh/Month/SFT)




EPI (kWh/Annum/SQM)




# Specific Energy Consumption Overview - 2018 to 2020



SEC – kWh / Month / Sqft.



SEC – kWh / Month / Associate



# Specific Energy Consumption Trend Analysis - 2018 to 2020







# Comparison of SEC with Internal & National Benchmark

BEE - National Benchmark			
EPI in kWh/Sq. M. / Year			
Star Rating	Warm and Humid	Composite	Hot and Dry
1 Star	200-175	190-165	180-155
2 Star	175-150	165-140	155-130
3 Star	150-125	140-115	130-105
4 Star	125-100	115-90	105-80
5 Star	Below 100	Below 90	Below 80

## Internal Benchmark




## Approach Methodology




# List of Major Encon Projects Planned in FY 2021-22

No	Title of Project	Annual Electrical Savings (kWh)	Cost Savings (INR)	Investment (INR)	Payback Period (Months)	Inference
1	Interconnection of chilled water pipelines in SDB & Academy block	330,000	3,300,000	5,000,000	18	Techno commercial evaluation and approval is in progress
2	Surrender of Maximum demand 3250 KVA to 2350 KVA	-	3,402,000	345,180	1	MD reduction sanctioned. Implemented from June' 25, 2021 and achieved cost savings of INR 56000 for June 2021 and INR 283500 for July 2021 EB Bill
3	Deploy data analytics & machine learning tool to improve energy efficiency of chiller plant	33,760	337,600	350,000	12	Pilot activity is going on in one of our campus




# Energy Saving Projects Implemented from 2018 to 2020



# Energy Saving Projects Implemented from 2018 to 2020

## Energy Saving Comparison (kWh)




■ 2018 ■ 2019 ■ 2020

**Total Energy Savings**  
13.04 L kWh

**Total Cost Savings**  
INR 130 Lacs

## Energy Saving Impact on SEC (%)




**Overall SEC Reduction**  
0.35 kWh / Month / Sq.ft.


**Overall SEC Reduction 23%**

# Energy Saving Projects Implemented from 2018 to 2020

Utility Wise Energy Consumption Comparison  
( kWh) - 2018 to 2020



Utility Wise Reduction - 2018 to 2019 (BAU)



# Innovative Project – Effective utilization of Cafe AHU

## Café Operation

- Operation of 45 TR AHU for café & event area
- Cafeteria operation Monday to Saturday - 9 hrs
- Specific energy consumption – 0.55 kW / TR

## Brainstorming

- Café AHU not loaded as per design level
- MHC duct split unit SEC > 2kW / TR
- Café AHU SEC < 1kW / TR
- Heat load study conducted by plant team
- Decided to provide duct extension to MHC room from café AHU
- Provision of modulating actuator damper

## MHC Operation


- Operation of 11 TR duct split unit for MHC
- MHC operation Monday to Saturday - 9 hrs
- Specific energy consumption - 3 kW / TR

## Implementation


- Provided additional duct to MHC room by vendor support
- Modulating actuator installed in both unit supply air
- Control wiring and fixing of actuator done by plant team
- Control mechanism of damper (Open/Close) is done
- MHC room temperature is measured with support of AHU
- Temperature achieved 25+- in MHC room

# Innovative Project – Effective Utilization of Cafe AHU

Before – Duct & Floor Layout



After – Duct & Floor Layout



# Innovative Project – Effective Utilization of Cafe AHU



Damper Control Wiring



Actuator

## Benefits

1. Avoiding of energy losses and efficiency improvement
2. Redundancy provided to MHC room
3. Economical savings of INR 1.6 Lacs


## Savings calculation

- 1.Improvement in SEC – 1.5 kW / TR
- 2.Rated Capacity of MHC Unit – 11 TR
- 3.Energy Consumption Saved – 16.5 kW
- 4.Operation Hrs/ Day – 9 Hrs
5. Annul Operation Days – 300days
- 6.Annual Energy Savings – 44550 kWh
- 7.Annual Cost Savings – INR 445500
- 8.Invenstment Cost – INR 54500
- 9.Return on Investment – 1 Month





# Utilization of Renewable Energy Sources – (2018–2020)



- Total Renewable Energy 51 L kWh (53%)
- Total GHG Optimized 4156 MT

Technology (Electrical)	Type of Energy	Onsite/Offsite	Installed Capacity (MW)	Utilization (million kWh)	% of overall renewable energy
Electrical	Wind	Offsite	256.85	5.1	53%

# Utilization of Renewable Energy Sources - FY (2018–2021)

Year	Installed Capacity (MW)	Total Wind Energy Contracted Quantum (Lacs kWh)	Actual Supplied Wind Energy Quantum (Lacs kWh)	STPI Consumption (Lacs kWh)	Allocation contribution (%)
2018-19	256.85	525	511	18.64	3.64%
2019-20	256.85	525	509	16.09	3.15%
2020-21	256.85	525	379	8.03	2.11%

- In FY 2018-19 additional quantum of 200 Lacs kWh purchased with an investment of INR.200 Lacs
- RPO is complied in FY 2017-18 as Solar – 5% and Non-Solar – 9%
  - Solar REC purchased – 101 No's
  - Non-Solar REC purchased – 182 No's
- Allocation contribution reduction for FY 2018-21
  - Tariff – Industrial with Tax (INR.6.35/kWh)
  - Less wind generation during peak seasonal months

# Waste Utilization and Management


Cognizant choose to refuse the use of following 'One time use and throw plastics' irrespective of thickness form 13.07.2018 onwards




SI No	Type of Waste Generated	Disposal Method	Action Taken for Reduction of Waste
1	Hazardous Waste	Used and waste oil disposed to TNPCB authorized recycler	Battery waste – Extension of battery warranty (3 to 3.5 years)
2	Non-Hazardous Waste	Carton & paper waste disposed to authorized recycler Ms.ITC ltd & got 10 reams	Paper waste – 1) Limitation of printer access 2) E-fit tool implemented and manual Check list optimized 3) Paper cups usages eliminated 100%
3	E Waste	Disposed to TNPCB authorized recycler	E –Waste – CFL to LED (Lifetime enhancement)

# GHG Inventorisation & Indoor Air Quality

GHG Emission Trend (MT) - 2017 to 2020



GHG Reduction Target & Action Plan



## Indoor Air Quality (BAU)

Test Parameters	Units	Result	Permissible limit	Remarks
Carbon Dioxide (CO2)	Mg/m3	819	1800	1. Testing through NABL Laboratory 2. Frequency of sampling is quarterly once for workstations
Total Fungal Count	Cfu/m3	27	500	
Total Bacterial Count	Cfu/m3	113	500	

# Standardization of Best Practices

## Personnel Computer



Sleep mode enabled for all personnel computer



Conventional CPU replacement with compact CPU



Awareness created to Associates to switch off the monitor while leaving the workplace



PC to Laptop (95% Associates)

## Air-Conditioning

Workplace temperature policy standardized  
24 ° C to 26 ° C



Maintaining UPS/ Battery room temperature b/n  
25 ° C to 26 ° C



Hub room temperature-maintained b/n  
24 ° C to 26 ° C

## Kitchen / Pantry

Elimination of electrical hot plate

Mandatory use of BEE star rated equipment's

Scheduled operation of ventilation system


Periodical cleaning of heater in bain-marie

Standard operation temperature for all freezer equipment


Weekly deep cleaning for all type of freezer

# Teamwork, Employee Involvement, Monitoring


## FMS – Daily & Monthly Energy Tracking



## Energy Consumption Monitoring



## Chiller Monitoring



## UPS Monitoring




## Chiller SEC Measurement

		CTE STP-Sri Lanka - Chennai	
		Academy	
Chiller Model		RTAF280 HSE	
Serial No	Design	ELA 3510	ELA3509
Chiller #		4	5
Date		9-Nov-20	9-Nov-20
Time		4:00 PM	4:50 PM
Evaporator Entering Water Temp. (°F)	54	67.8	70.5
Evaporator Leaving Water Temp. (°F)	144	56.6	59.9
Ambient Temp. (°F)	104	83.7	84.5
% Chiller Load ( % Amps )	100%	95.1	96.7
Chilled water Set Point (°F)		46.4	46.4
Total Chiller Current consumption (compressor + condenser fans) - Chiller HMI - (kWh)	326.5	300.00	295.00
Water Flow ( GPM )	635	675	700
Topology = ( GPM X Evap Delta Temp. (°F) ) / 2.4	263	315.0	309.2
Input kW Per TR - (kW/TR)	1.24	0.95	0.95

Remarks: Chiller is running within the design limit.

## OEM Training on Operational Control



# Kaizen by Plant Team

Desktop Unplugging




Switching off Ideal Chiller



UPS Modular Optimization



Pull Cord Switches



Timer Based AHU Operations Control



Motion Control Sensor for Rest Room Lighting



Lighting Circuit Modification



250W MH Street Light to Solar Fixtures



# List of Certifications & Achievements



OHSAS 18001:2007 - 2019



Appendix Certificate



# Energy Awards



Excellent Energy efficient unit 2018



Energy efficient unit 2019



Energy efficient unit 2020

# Way Forward



## Energy Efficiency

- 1.Reduce power consumption through optimization of capacity utilization and validation operational parameters
- 2.Technological upgradation with higher efficiency asset replacement through retrofit projects

## Green Energy

- 1.Increase renewable energy portion from the total energy requirement through green power procurement.
2. Install rooftop solar panels in owned campuses

## IoT & Digital

- 1.Deploy data analytics & machine learning tool to improve energy efficiency of chiller plant.
2. Collaborate with IFM service partners in implementing data analytical tools in energy efficiency

**Cognizant**

# **22<sup>nd</sup> National Award for Excellence in Energy Management 2021**

Siruseri STPI - Chennai

---

August 2021