

22nd National Award for Excellence in Energy Management 2021



Presented By:-

D K Patel (Technical Head)

Pinaki Dutta (Production Head)

Yadvender Singh (Sr. Engineer-Process)

1.


- JK Cement Ltd is an affiliate of Industrial conglomerate JK Organization, founded by Lala Kamalpat Singhania. The company is the second largest manufacturer of white cement in India (third largest in the world) & second largest producer of Wall putty in the country. First cement company to install a waste heat recovery power plant.









2.

- JK Cement Mangrol with Total Clinker Capacity (5.65 mioTPA) and Total Cement Grinding Capacity (7.05 mioTPA).
- Product: OPC-43, OPC-53, PPC

3.

- JK Cement Mangrol is certified with ISO 14001, ISO 9001, ISO 45001 & ISO 50001:2018 .
- Great Place to work certified company



| JK Cement Mangrol | | Line-1 | Line-2 | Line-3 |
|------------------------------------------------------------------------------------------------------|----------------|-------------------------------------------------------------|------------------------------------------------|---------------------------------------------------------|
| Stacker  | Machine type | Twin boom stacker | Luffing stacker | Luffing stacker |
| | Make | Promac | FLSmidth | FLS |
| | Capacity | 350 TPH | 850 t/h (wet) | 1550 TPH |
| Reclaimer  | Machine type | Bridge type reclaimer | Bridge Reclaimer | Bridgre scraper |
| | Make | Promac | FLSmidth | FLS |
| | Capacity | 200 TPH | 550 t/h(wet) | 800 TPH |
| Crusher  | Machine type | Impactor APPM 1650 | Hammer Crusher with Wobbler Feeder | Impact crusher |
| | Make | L & T | Thyseen Krupp polysious | FLS |
| | Capacity | 350 TPH | 800 TPH | 1300 TPH |
| Raw Mill  | Make | Promac (VRM) 02 Nos. | Thyseen Krupp Roller Press | FLS HRP-R-2.47 Sq.m (02 Nos.) |
| | Capacity | 70 TPH | 400 TPH | 300 TPH |
| Kiln  | Make | Promac | FLSmidth | FLSmidth |
| | Machine type | 5 Stage, ILC, Single String Ø3.3M*50M long, 4.17 RPM Max | 5 Stage, ILC, Single String Ø4.35M*67M Long | 5 Stage, ILC, Double String Ø4.75M*74M Long, 5.5 RPM |
| | Capacity | 1800 TPD (Design), 2250 (Actual) | 5000 TPD (Design) & 5750 TPD (Actual) | 6500 TPD (Design), 7700 TPD (Actual) |
| | Type of cooler | Grate Cooler | Crossbar 14*47 | Crossbar 18*63 |
| | Grate area | 43.848 Meter ² /6 fan | 129.78 M ² /9 fans | 190.6 mt sq./13 fans |
| | Burner type | Pyrojet Burner | Pyrojet Burner | Jetflex burner |
| Coal Mill  | Make | Promac | FLSmidth Atox 22.5 VRM | FLS Atox 32.3 RPM |
| | Capacity | 20 TPH on coal and 10 TPH on PC | 38 TPH (Indian Coal), 22 TPH (Pet coke) | 35 TPH 100% PC, 70 TPH 100% Indian |
| Cement Mill  | Machine type | Ball Mill | Roller Press with Ball Mill (Combi circuit) | Roller Press with Ball Mill (Combi circuit) |
| | Make | FLS 1962 | FLSmidth TriboMax & Thyssenkrupp | Thyseen Krupp Polysious |
| | Capacity | 30 TPH | 280 TPH (PPC), 260 TPH (OPC) | 260 TPH (PPC), 240 TPH (OPC) |
| Packing Plant  | Machine type | Mechanical Packer | FLS ventomatic single discharge packer (4 Nos) | Electronic Packer (Ventomatic) |
| | Capacity | 60 TPH | 120 TPH Each | 150 TPH |




Line-1 Production reduced by 27%, Line-2 by 13% but Line-3 increased by 4% due to stabilization.


Line-1 SEC is approx. same, Line-2 increased by 0.29% but Line-3 decreased by 8.32% due to stabilization

Line-1 & Line-2 Production and efficiency was reduced in that period but due to initial stabilization of Line-3 it is improved.


UPTO CLINKERISATION




TOTAL PLANT POWER




CEMENT GRINDING



THERMAL ENERGY




UPTO CLINKERISATION




Kiln power increased due to HAR fan installed to increase WHR generation

TOTAL PLANT POWER




CEMENT GRINDING




Cement grinding Power decreased by 2.9% by continuous monitoring & Grinding media upgradation resulted increased output

THERMAL ENERGY




LCV waste consumption increased this year in which calorific value is approx. nil and high moisture content.


UPTO CLINKERISATION




TOTAL PLANT POWER




CEMENT GRINDING




THERMAL ENERGY



TOTAL PLANT POWER



THERMAL ENERGY



Higher Electrical Energy:

- Raw mill-3 power is on higher side due to low output.
- Kiln power increased due to HAR fan installed to increase WHR generation.
- Petcoke grinding & consumption.
- OPC-53 grinding in Cement Mill-3 for which higher blaine is required resulted in higher power consumption.

Higher Thermal Energy:

- High Alternative fuel usage resulted in high oxygen is being maintained.
- High moisture AF usage.
- 100% Petcoke Usage.
- LCV waste consumption increased this year in which calorific value is approx. nil and high moisture content.

| Sl.No. | Year | Title of Project | Annual Electrical Saving (Million kWh) | Annual Thermal Saving (Million Kcal) | Investment (Rs in Million) | Remarks |
|--------|-----------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------|--------------------------------------|----------------------------|---------------------------------|
| 1 | 2021-2022 | Replacement of existing Coal firing system in Kiln-1 by installing Coriolis system to reduce thermal energy consumption (Replacement of old generation coal screw coal firing system in line 1 by latest Schenk Coriolis system to improve consistency in coal feed rate & stable kiln operation to reduce thermal energy) | - | 337.5 | 50.0 | Will be installed in Dec'21 end |
| 2 | 2021-2022 | Replacement of Old lights: Replacement of 205 Nos.70Watt HPSV Well Glass light by 40 Watt LED Well Glass. | 0.045 | - | 0.43 | - |
| 3 | 2021-2022 | Replacement of Old lights: Replacement of 150 Nos. 150Watt HPSV Well Glass light by 40 Watt LED Well Glass | 0.095 | - | 0.32 | - |
| 4 | 2022 | 13 MW Solar plant installation to reduce the power plant | 18.65 | - | 41.90 | Location finalized |

| Year | No of Energy saving projects | Investments (INR million) | Electrical savings (Million kWh) | Thermal savings (Million Kcal/ MTOE) | Savings (INR Million) | Impact on SEC (Electrical kWh /MT cement, thermal) |
|------------|------------------------------|---------------------------|----------------------------------|--------------------------------------|------------------------|----------------------------------------------------|
| FY 2018-19 | 14 | 3.46 | 7.81 | 2263.4 | 44.65 | 6.0 kwh/Ts Cem, 1.7 Kcal/Kg Clk |
| FY 2019-20 | 9 | 34.17 | 1.02 | 89921.5 | 106.64 | 0.4 kwh/Ts Cem, 31.4 Kcal/Kg Clk |
| FY 2020-21 | 11 | 10467.58* | 80.69 | 221265.5 | 777.18 | 26.2 kwh/Ts Cem, 54.0 Kcal/Kg Clk |

*Remarks:- Investment is higher in FY 2020-21 because of New upto Clinkering Unit established and Cement Mill-2 modified into Cement Mill-4 by Ball mill to Combi Circuit.


| Sl.No. | Description of energy efficiency improvements measure | Category | Investment (Rupees) | Verified savings (Rupees) | Verified energy savings | Units | TOE saving |
|--------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------|---------------------|---------------------------|-------------------------|-------|------------|
| 1 | Reduction in Power Consumption by Increasing PRI of Kiln and replacement of Burner by Low NOx type and low primary air. Reduction in upto Clinkerisation Line-1 power from 54.2 to 53.4 (kwh/Ts of Clinker). | Optimisation upto Clinkerisation Section | 0 | 2869857 | 538435 | Kwh | 172.7 |
| 2 | Reduction in Power Consumption by Increasing PRI of Kiln and replacement of Burner by Low NOx type and low primary air. Optimization of Raw Mill-3 Output reduced to optimize power consumption.Reduction in upto Clinkerisation Line-2 power from 46.7 to 45.0 (kwh/Ts of Clinker). | Optimisation upto Clinkerisation Section | 0 | 16456712 | 3087563 | Kwh | 990.5 |
| 3 | Reduction in Power Consumption by replacement of mill liners, Better maintenance practices and Process optimization. Reduction in Cement Mill-2 power 36.1 to 32.9 (kwh/Ts of Cement). | Optimisation Cement Grinding Section | 0 | 12334964 | 2314252 | Kwh | 742.4 |
| 4 | Reduction in Power Consumption by periodic roller profiling, Grinding Media sorting and process optimization. Reduction in Cement Mill-3 power 28.6 to 28.0 (kwh/Ts of Cement). | Optimisation Cement Grinding Section | 0 | 5926938 | 1111996 | Kwh | 356.7 |
| 5 | Reduction in Thermal Energy by increasing PRI of Kiln. Reduction in Thermal Energy in Line-1 from 753.4 to 752.6 Kcal /Kg Clk. | Energy Saving | 0 | 791697 | 589324081 | kCal | 58.9 |
| 6 | Reduction in Thermal Energy by increasing PRI of Kiln. Reduction in Thermal Energy in Line-2 from 683.3 to 682.4 Kcal /Kg Clk. | Energy Saving | 0 | 2248920 | 1674052219 | kCal | 167.4 |
| 7 | Replacement of 550Nos.70Watt HPSV Well Glass light by 40 Watt LED Well Glass | Energy Saving | 1095600 | 211068 | 39600 | Kwh | 12.7 |

| Sl.No. | Description of energy efficiency improvements measure | Category | Investment (Rupees) | Verified savings (Rupees) | Verified energy savings | Units | TOE saving |
|--------|------------------------------------------------------------------------------------------|----------------|---------------------|---------------------------|-------------------------|-------|-------------|
| 8 | Replacement of 350Nos.70Watt HPSV Well Glass light by 40 Watt LED Well Glass | Energy Saving | 697200 | 67158 | 12600 | Kwh | 4.0 |
| 9 | Replacement of 200 Nos. 2X36Watt Tube Light rod by LED Tube rod 2X18Watt. | Energy Saving | 68000 | 92102 | 17280 | Kwh | 5.5 |
| 10 | Replacement of 150 Nos. 2X36Watt Tube Light rod by LED Tube rod 2X18Watt. | Energy savings | 51000 | 34538 | 6480 | Kwh | 2.1 |
| 11 | Energy saver panel installation in MRSS 1 6.6 KV sub station LINE 1 | Energy savings | 342529 | 57564 | 10800 | Kwh | 3.5 |
| 12 | Energy saver panel installation in Cooler LC LINE 1 | Energy savings | 342529 | 41574 | 7800 | Kwh | 2.5 |
| 13 | AC Energy saver installed in 50 nos of AC. | Energy savings | 360000 | 55965 | 10500 | Kwh | 3.4 |
| 14 | Optimization of Auxiliary power Consumption. Lime system modification Saving at 25MW CPP | Energy savings | 500000 | 3463902 | 649888 | Kwh | 208.5 |
| | | | 3456857 | 44652960 | | | 2731 |



| Sl.No. | Description of energy efficiency improvements measure | Category | Investment (Rupees) | Verified savings (Rupees) | Verified energy savings | Units | TOE saving |
|--------|----------------------------------------------------------------------------------|---------------|---------------------|---------------------------|-------------------------|-------|-------------|
| 1 | Continuous monitoring of process parameters, Optimum operation of Kiln in Line-2 | Energy saving | - | 3659720 | 716188 | Kwh | 234.6 |
| 2 | Usage of AFR in Line-1 by substituting primary fuel | Energy saving | 12326457 | 16434126 | 14570036045 | Kcal | 1457.0 |
| 3 | Usage of AFR in Line-2 by substituting primary fuel | Energy saving | 13460600 | 84991889 | 75351427325 | Kcal | 7535.1 |
| 4 | Replacement of 200Nos. 150Watt HPSV Well Glass light by 40 Watt LED Well Glass | Energy saving | 400000 | 404712 | 79200 | Kwh | 25.9 |
| 5 | Replacement of 150Nos.70Watt HPSV Well Glass light by 40 Watt LED Well Glass | Energy saving | 300000 | 82782 | 16200 | Kwh | 5.3 |
| 6 | Replacement of 200 Nos. 2X36Watt Tube Light rod by LED Tube rod 2X18Watt. | Energy saving | 70000 | 132451 | 25920 | Kwh | 8.5 |
| 7 | 1000 KW DC MOTOR OF SG FAN REPLACED WITH AC DRIVE | Energy saving | 7500000 | 883008 | 172800 | Kwh | 56.6 |
| 8 | Using of LED's instead of HPSV lamps. (WHR) | Energy saving | 48000 | 20144 | 3942 | Kwh | 1.3 |
| 9 | Using of LED's instead of HPSV lamps. (CPP) | Energy saving | 64000 | 26858 | 5256 | Kwh | 1.7 |
| | | | 34169058 | 106635691 | | | 9326 |

| Sl.No. | Description of energy efficiency improvements measure | Category | Investment (Rupees) | Verified savings (Rupees) | Verified energy savings in MTOE | Units (kWh) | Fuel (MT) |
|--------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------|---------------------|---------------------------|---------------------------------|-------------------|----------------|
| 1 | Usage of AFR in Line-1 by substituting primary fuel | Fuel Change | 8762971 | 15092318 | - | - | 1753.6 |
| 2 | Usage of AFR in Line-2 by substituting primary fuel | Fuel Change | 26294341 | 134107740 | - | - | 8709.1 |
| 3 | Usage of AFR in Line-3 by substituting primary fuel | Fuel Change | 7622608 | 70195102 | - | - | 1727.7 |
| 4 | Replacement of Old lights: Replacement of 100Nos. 150Watt HPSV Well Glass light by 40 Watt LED Well Glass | Illumination | 210000 | 261629 | 20.6 | 63510 | - |
| 5 | Replacement of Old lights: Replacement of 110Nos.70Watt HPSV Well Glass light by 40 Watt LED Well Glass | Illumination | 231000 | 99239 | 7.8 | 24090 | - |
| 6 | Preheater area lighting circuit modification, reduction in number of lights | Illumination | 0 | 144347 | 11.4 | 35040 | - |
| 8 | Reduction in Thermal Energy of Kiln-3: Optimization of Burner momentum, continuous monitoring of process parameters, Optimum operation of Kiln in Line-3 | Technology Absorption | 7705200000 | 152478941 | 13055.0 | 0 | 17542.7 |
| 9 | Reduction in Upto Clinkerisation Power of Kiln-3: Optimization of Burner momentum, continuous monitoring of process parameters, Optimum operation of Kiln in Line-3 | Technology Absorption | 0 | 82126034 | 6471.1 | 19935943.94 | - |
| 10 | Upgradation Of Cement Mill 2: Modification of existing ball mill along with addition of new roller press for cement grinding to increase capacity & to improve grinding efficiency. | Technology Absorption | 1204800000 | 32263226 | 2542.2 | 7831838.89 | - |
| 11 | New WHR plant capacity 29.1 MW installation: New WHR plant capacity 29.1 MW installation, WHR Generation increased by 52799432 KWH (Generation in year 2019-20 was 63486739 kwh and in year 2020-21 is 116286171 kwh), plant commissioning completed in month Oct-2020. | Technology Absorption | 1514435869 | 290396876 | 17138.3 | 52799432 | - |
| Total | | | 10467585538 | 777176821 | 48319.0 | 80692614.8 | 29733.1 |



- **Issue:** High recirculation of material in static separator, it results lower rate of fresh feed in Cement mill-4
- **Solution/Action taken:**
 - Installation of Movable guide vanes (5 + 2 nos.) at gas inlet side - CRPG-S
 - Adjustable guide vanes (5 no's) - CRPG-S in the outlet side
- **Benefits:** Fine material recirculation reduced because of proper air distribution across the separator



- **Issue:** Cake formation of HRP discharge material fed to static separator. High recirculation of material in Cement Mill-4
- **Action Taken:** Installation of cake breaker at roller press discharge chute
- **Benefit:** Homogeneous material feeding to static separator discharge belt





- **Issue:** Lower roller movement, higher vibration in Cement mill-4
- **Modification:** HRP Feed gate modification: converted the existing 2 gate operation to 4 gate operation at HRP. Roller press roller's movement optimization for effective grinding
- **Benefit:** Operation stability in terms of material distribution on rollers improved.




Operation of Cement Mill-4 in Auto loop

Normal functioning of logic




Present functioning of logic in Cement mill-4 :


Due to NDE side operating gap slide towards the minimum gap in operation where pressure tolerance increases and auto logic function become void which works in safety band value further increase leads to flush and vibration of mill




Power consumption kwh/Ts Cem.




Power consumption kwh/Ts Cem.





Output (TPH)



Output (TPH)





- **Issue:** Feed column is towards non-drive end side, No significant movement in movable roller in Raw Mill-4
- **Solution/Action taken:** Choke feed bin cone angle changed from 60 Deg to 70 degree
- **Benefit:** Slight movement in housing started and slightly reduction in vibrations



Improvement of dynamic separator efficiency

- **Issue:** To maintain the desired residue at final output
- **Solution/Action taken:** Dynamic separator rotor block by 16%
- **Benefit:** Separator RPM reduced, Material residue improved





Data before modification-

- Feed- 173 TPH
- Material recirculation- 1147 TPH
- Separator fan RPM- 984
- Separator KW- 832 KW




Data after modification-

- Feed- 295-300 TPH
- Material recirculation- 1082 TPH
- Separator fan RPM- 1024
- Separator KW- 896 KW

Production increased approx. 175%

| Year | Technology | Type of Energy | Onsite/Offsite | Installed Capacity MW | Generation (million KWh) | % of overall electrical energy |
|------------|----------------------------|-------------------|----------------|-----------------------|--------------------------|--------------------------------|
| FY 2018-19 | Waste Heat recovery System | Electrical Energy | Onsite | 10 MW | 66.22 | 22% |
| FY 2019-20 | Waste Heat recovery System | Electrical Energy | Onsite | 10 MW | 63.49 | 24% |
| FY 2020-21 | Waste Heat recovery System | Electrical Energy | Onsite | 29.1 MW | 116.29 | 37% |



Installation of 13 MW Solar Power plant (Planned)

| Equipment | Average load (MW) |
|---------------------------------|-------------------|
| Line 1 (Excluding Pyro Section) | 9.9 |
| Line 2 | 21.4 |
| Line 3 | 17.1 |
| Maliakhera Crusher | 1.7 |
| Total | 50.1 |

| Source (MW) | Max. Load | Sent-out |
|----------------------|-------------|-------------|
| CPP | 25 | 22 |
| WHRS | 29.2 | 22 |
| Grid sanctioned load | 31.5 | 31.5 |
| Total | 85.7 | 75.5 |


| | |
|-----------------------------------------------------|-------------|
| In-house source (MW) | 44 |
| Power Deficit (MW) | 6.1 |
| Running CPP at low PLF (MW) | 3.0 |
| Peak AC capacity required | 9.07 |
| DC to AC loading factor | 1.4 |
| Average PLF (%) | 17% |
| Total Solar Capacity (MW)- DC plant capacity | 13 |
| Savings (INR / Year) | 6,06,15,173 |
| Savings (MT Cement) | 17 |
| Investment (INR) | 4,19,03,400 |
| Payback (Years) | 0.69 |



Cost of electricity @ MGRL 6.25, Solar @ 3.5




D/E ratio - 70:30, & 26% equity in group captive considered

Methodology-Root cause Identification




Counter measure and Implementation


➤ Equipment Installation



3rd feeding point of low NCV feeding point at ILC TAD duct outlet duct connecting to ILC



Installation of additional Martin Blasters at coating prone zone




Weima Shredder installed



High NCV feeding point at reducing zone of calciner




1st feeding point of low NCV feeding point at oxidising zone



2nd feeding point of low NCV feeding point at oxidising zone

Data comparison Before & After

| Parameters | UOM | Apr'15-Mar'16 | Apr'16-Mar'17 | Apr'17-Mar'18 | Apr'18-Mar'19 | Apr'19-Mar'20 | Apr'20-Mar'21 |
|----------------------|------|---------------|---------------|---------------|---------------|---------------|---------------|
| AFR Usage | MT | 2933 | 31565 | 57744 | 50015 | 65580 | 88424 |
| Thermal Substitution | % | 0.8 | 7.2 | 7.5 | 5.2 | 4.5 | 3.2 |
| Saving Achieved | Lacs | 35.8 | 916.0 | 1425.2 | 1320.8 | 1246.9 | 2018.8 |




Benefits Achieved

Tangible benefits:-

- Total Saving of Rs 2118.8 Lacs from AFR usage last year.
- Total saving of 12190 MT of main fuel (Pet coke).

Intangible benefits:-

- Co-processing of AFR reduced the land filling.
- Reduction in CO2 emissions.
- To protect against global warming.




Cement Plant

| Parameter | Line-1 | | | Line-2 | | | Line-3 | |
|--------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|
| | YEAR FY | | | YEAR FY | | | YEAR FY | |
| | 2018-19 | 2019-20 | 2020-21 | 2018-19 | 2019-20 | 2020-21 | 2019-20 | 2020-21 |
| Co2Emission /Ts Clinker (Fuel) | 0.31 | 0.28 | 0.27 | 0.28 | 0.27 | 0.27 | 0.28 | 0.26 |

Power Plant

| Parameter | YEAR FY | | |
|-----------------|---------|---------|---------|
| | 2018-19 | 2019-20 | 2020-21 |
| Co2Emission /MW | 1.23 | 1.17 | 1.17 |



Environmental projects with carbon emission reduction in FY 2020-21:

| Projects | |
|-------------------------------------------------------------|------------------|
| • AFR Consumption increased from 65580 to 88424 MT | By 34.8% |
| • Reduction of OPC Clinker factor from 0.896 to 0.876 | By 2.2% |
| • Reduction of PPC Clinker factor from 0.658 to 0.624 | By 5.2% |
| • Replacement of conventional lightening with LED lights | 125400 KWH saved |
| • Reduction of CO2 from 612 to 611 kg/MT of cem | By 0.2% |
| • Reduction of total plant power from 70.65 to 62.74 Kwh/Mt | By 11.2% |
| • Reduction of Thermal Energy from 711 to 698 kcal/Kg Clk. | By 1.8% |

Installation of SNCR to reduce the Nox emissions



Installation of Liquid Firing System



Installation of Solid Feeding System



Feeding Hopper



Belt Conveyor-1




Belt Conveyor-2



Belt Conveyor-3




Feeding System at Preheater









| Reports/Presentation | Frequency |
|------------------------------------------------------------------------------------------------------|-----------|
| <ul style="list-style-type: none"> Frequency of review of energy consumption | Daily |
| <ul style="list-style-type: none"> Energy Management cell meeting | 15 Days |
| <ul style="list-style-type: none"> Frequency of review of energy conservation Project | Monthly |
| <ul style="list-style-type: none"> Energy management Review meeting | Monthly |



Keizen report



Safety Keizens



Daily Drive wise Power monitoring

| Drive Wise Power back up | | Ever Best | Month | Output (TPH/TPD) | MTBF (Hrs.) | | | | |
|--------------------------|------------------------------------------|--------------|--------------|------------------|--------------|--------------|--------------|--------------|--------------|
| Machine | DESCRIPTION | | | | | 29 | 30 | 31 | up to date |
| Crusher 1 | HT Drive | 0.74 | July'16 | 352 | NA | 0.93 | 0.91 | 0.93 | 0.82 |
| | LT Aux. | 0.29 | | | | 0.36 | 0.38 | 0.38 | 0.37 |
| | Crusher 1 Maintenance | 0.10 | | | | 0.00 | 0.00 | 0.00 | 0.02 |
| | Total | 1.03 | | | | 1.28 | 1.28 | 1.31 | 1.19 |
| Crusher 2 | L/S Crusher M.D. (H.T.) | 0.42 | Mar'19 | 621 | NA | 0.52 | 0.55 | 0.49 | 0.46 |
| | L/S and Additive Crusher PMCC 1 (L.T.) | 0.51 | | | | 0.55 | 0.59 | 0.55 | 0.54 |
| | Crusher 2 Maintenance | 0.04 | | | | 0.00 | 0.00 | 0.00 | 0.05 |
| | Total | 0.93 | | | | 1.07 | 1.14 | 1.05 | 1.01 |
| Raw Mill 1 | HT Drive | 7.98 | Apr'16 | 76 | 127 | 8.41 | 8.57 | 8.47 | 8.13 |
| | RM-1 Fan | 6.69 | | | | 7.60 | 7.63 | 7.11 | 7.07 |
| | RM-1 MCC | 0.73 | | | | 0.67 | 0.72 | 0.68 | 0.63 |
| | Common MCC | 1.23 | | | | 1.18 | 1.29 | 1.19 | 1.22 |
| | Raw Mill 1 Maintenance | 0.00 | | | | 0.00 | 0.00 | 0.00 | 0.04 |
| Total | 16.62 | 17.87 | 18.21 | 17.45 | 17.05 | | | | |
| Raw Mill 2 | HT Drive | 8.24 | Apr'16 | 75 | 34 | 8.39 | 8.35 | 8.59 | 8.12 |
| | RM-2 Fan | 6.25 | | | | 6.64 | 6.74 | 6.57 | 6.42 |
| | RM-2 MCC | 0.63 | | | | 0.63 | 0.66 | 0.62 | 0.59 |
| | Common MCC | 1.26 | | | | 1.26 | 1.27 | 1.21 | 1.22 |
| | Raw Mill 2 Maintenance | 0.00 | | | | 0.00 | 0.00 | 0.00 | 0.04 |
| | Total | 16.37 | | | | 16.92 | 17.02 | 16.99 | 16.35 |
| Raw Mill 3 | Roller Press M.D. 1 1700 KW (H.T.) | 2.95 | May'19 | 430 | 319 | 3.36 | 3.26 | 3.36 | 3.39 |
| | Roller Press M.D. 2 1700 KW (H.T.) | 3.65 | | | | 3.56 | 3.61 | 3.62 | 3.64 |
| | Raw Mill Separator Fan 1450 KW (H.T.) | 1.90 | | | | 2.10 | 2.10 | 2.09 | 2.17 |
| | Raw mill PMCC 3 (L.T.) | 1.75 | | | | 1.77 | 1.80 | 1.87 | 1.89 |
| | L/S and Additive Transport PMCC 2 (L.T.) | 0.54 | | | | 0.64 | 0.66 | 0.59 | 0.61 |
| | Utility | 0.34 | | | | 0.28 | 0.29 | 0.28 | 0.29 |
| | Raw Mill 3 Maintenance | 0.00 | | | | 0.00 | 0.51 | 0.50 | 0.03 |
| Total | 11.14 | 11.70 | 11.73 | 11.81 | 11.99 | | | | |
| Raw Mill 4 | RP Drive1 Power (HT) | 3.35 | Sep'20 | 298 | 34 | 3.91 | 3.95 | 3.84 | 3.78 |
| | RP Drive 2 Power (HT) | 3.19 | | | | 3.52 | 3.56 | 3.54 | 3.38 |
| | RM Sep Fan (HT) | 3.39 | | | | 3.79 | 3.73 | 3.49 | 3.70 |
| | RM Sep. Drive (LT From PCC2) | 0.03 | | | | 0.04 | 0.04 | 0.04 | 0.04 |
| | RM MCC-4 (LT) | 0.73 | | | | 0.84 | 0.86 | 0.83 | 0.80 |
| | 323BE170 Bucket Elevator (Calculated) | 0.54 | | | | 0.59 | 0.59 | 0.58 | 0.57 |
| | 343BE010 Bucket Elevator (Calculated) | 0.24 | | | | 0.14 | 0.15 | 0.16 | 0.16 |
| | Common MCC(LS REC,MCC-3) | 0.49 | | | | 0.44 | 0.43 | 0.45 | 0.40 |
| | Utility(15%) | 0.26 | | | | 0.32 | 0.30 | 0.30 | 0.32 |
| | RM-4 Maintenance | 0.11 | | | | 0.00 | 0.00 | 0.00 | 0.02 |
| Total | 12.21 | 13.60 | 13.62 | 13.24 | 13.15 | | | | |
| Raw Mill 5 | RP Drive1 Power (HT) | 3.37 | Nov'20 | 300 | 41 | 4.07 | 4.22 | 4.06 | 4.09 |
| | RP Drive2 Power (HT) | 3.13 | | | | 4.12 | 4.25 | 4.09 | 4.18 |
| | RM Sep Fan (HT) | 3.91 | | | | 3.94 | 3.79 | 3.72 | 3.86 |
| | RM Sep. Drive (LT From PCC2) | 0.03 | | | | 0.04 | 0.03 | 0.03 | 0.03 |
| | RM MCC-5 (LT) | 0.84 | | | | 0.85 | 0.78 | 0.76 | 0.82 |
| | 324BE170 Bucket Elevator (Calculated) | 0.55 | | | | 0.58 | 0.56 | 0.55 | 0.56 |
| | 343BE010 Bucket Elevator (Calculated) | 0.18 | | | | 0.16 | 0.14 | 0.13 | 0.16 |
| | Common MCC(LS REC,MCC-3) | 0.36 | | | | 0.50 | 0.42 | 0.42 | 0.42 |
| | Utility(15%) | 0.34 | | | | 0.37 | 0.28 | 0.26 | 0.33 |
| | RM-5 Maintenance | 0.07 | | | | 0.00 | 0.00 | 0.00 | 0.02 |
| Total | 12.70 | 14.62 | 14.48 | 14.02 | 14.45 | | | | |

| Drive Wise Power back up | | Ever Best | Month | Output (TPH/TPD) | MTBF (Hrs.) | | | | |
|------------------------------------|--------------------------------------------|-----------------------|--------------|------------------|--------------|--------------|--------------|--------------|--------------|
| Machine | DESCRIPTION | | | | | 29 | 30 | 31 | up to date |
| KILN 1 | Kiln Main motor | 1.46 | Apr'16 | 2340 | 646 | 1.35 | 1.39 | 1.34 | 1.34 |
| | CF silo MCC | 1.63 | | | | 1.57 | 1.57 | 1.53 | 1.52 |
| | ESP & DT MCC | 2.77 | | | | 3.00 | 2.93 | 3.00 | 2.73 |
| | Folax Cooler MCC | 3.51 | | | | 3.61 | 3.61 | 3.60 | 3.65 |
| | Smoke Gas Fan | 7.98 | | | | 8.24 | 8.26 | 8.43 | 8.18 |
| | Bag House Fan | 2.65 | | | | 2.61 | 2.66 | 2.75 | 2.67 |
| | Coal Firing MCC | 1.71 | | | | 1.72 | 1.72 | 1.76 | 1.69 |
| | Agrowaste MCC | 0.08 | | | | 0.05 | 0.06 | 0.06 | 0.10 |
| | Kiln 1 Maintenance | 0.50 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | Total | 21.78 | | | | 22.15 | 22.20 | 22.47 | 21.88 |
| COAL MILL 1 | Coal Mill MCC | 11.75 | Apr'16 | 10 | NA | 14.83 | 15.37 | 15.27 | 14.81 |
| | Coal Mill HT Drive | 12.59 | | | | 15.99 | 16.75 | 16.78 | 14.90 |
| | Coal Mill Maintenance | 0.81 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | Total | 24.34 | | | | 30.82 | 32.13 | 32.05 | 29.71 |
| KILN 2 | Kiln M.D. 760 KW (H.T.) | 1.70 | Dec'16 | 5663 | 306 | 1.97 | 1.98 | 1.93 | 1.98 |
| | Pre Heater Fan 1900 KW (H.T.) | 7.81 | | | | 7.86 | 7.91 | 7.87 | 7.85 |
| | Bag House Fan 1600 KW (H.T.) | 1.48 | | | | 1.31 | 1.39 | 1.45 | 1.35 |
| | Kiln and Pyro PMCC 4 (L.T.) | 2.12 | | | | 2.26 | 2.22 | 2.22 | 2.17 |
| | Coller and Clinker Transport PMCC 5 (L.T.) | 2.05 | | | | 2.23 | 2.27 | 2.29 | 2.30 |
| | Coller Fans PMCC 6 & 7 (L.T.) | 5.10 | | | | 7.94 | 7.82 | 7.82 | 8.25 |
| | Utility | 1.19 | | | | 1.02 | 1.02 | 1.03 | 1.03 |
| | Kiln 2 Maintenance | 0.03 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | TOTAL | 21.45 | | | | 24.59 | 24.61 | 24.60 | 24.93 |
| | COAL MILL 2 | Coal mill M.D. (H.T.) | | | | 13.87 | Dec'16 | 27 | NA |
| Coal Mill Fan (H.T.) | | 14.78 | 14.68 | 14.46 | 15.40 | 13.60 | | | |
| Coal Mill PMCC 8 (L.T.) | | 6.13 | 9.14 | 14.35 | 14.76 | 12.99 | | | |
| Coal Handling PMCC 9 (L.T.) | | 2.80 | 4.61 | 4.69 | 4.81 | 4.14 | | | |
| Coal Mill Maintenance | | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | | | |
| Total | | 37.58 | 43.52 | 48.27 | 50.50 | 44.31 | | | |
| Kiln-3 | Kiln Main Drive (HT) | 1.60 | Sep'20 | 7748 | 64 | 1.88 | 1.94 | 1.89 | 1.86 |
| | Pre-heater Fan-1 (HT) | 2.42 | | | | 2.66 | 2.68 | 2.62 | 2.66 |
| | Pre-heater Fan-2 (HT) | 2.37 | | | | 2.72 | 2.74 | 2.65 | 2.67 |
| | BagHouse Fan (HT) | 2.37 | | | | 1.36 | 1.35 | 1.28 | 1.42 |
| | Cooler Fan (HT) | 6.05 | | | | 6.05 | 5.98 | 5.94 | 6.15 |
| | Cooler Vent Fan (HT) | 0.91 | | | | 1.54 | 1.56 | 1.55 | 1.52 |
| | Kiln Emergency (MCC-07A) | 0.80 | | | | 1.08 | 1.04 | 1.19 | 1.00 |
| | Kiln Feed & Pre Heater (MCC-07) | 0.49 | | | | 0.63 | 0.61 | 0.61 | 0.62 |
| | Cooler & Coal Firing (MCC-08) | 1.02 | | | | 1.10 | 1.07 | 1.05 | 1.09 |
| | Cooler ESP (443EP500) | 0.35 | | | | 0.26 | 0.26 | 0.26 | 0.28 |
| | VFD For Blower (467BL310- From PCC3) | 0.00 | | | | 0.31 | 0.30 | 0.29 | 0.30 |
| | VFD For Blower (467BL360- From PCC3) | 0.22 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | VFD For Blower (467BL410- From PCC3) | 0.19 | | | | 0.24 | 0.24 | 0.23 | 0.23 |
| | 353BE225 M1 Elevator (Calculated) | 0.41 | | | | 0.41 | 0.40 | 0.40 | 0.41 |
| | 353BE225 M2 Elevator (Calculated) | 0.37 | | | | 0.41 | 0.41 | 0.40 | 0.40 |
| RM Bag House to Blend Silo (MCC-6) | 0.29 | 0.62 | 0.59 | 0.61 | 0.62 | | | | |
| Utility(70%) | 0.93 | 1.10 | 1.06 | 1.06 | 1.16 | | | | |
| Kiln3 Maintenance | 0.72 | 0.00 | 0.00 | 0.00 | 0.14 | | | | |
| Total | 20.78 | 22.37 | 22.22 | 22.01 | 22.40 | | | | |
| Coal Mill-3 | Coal Mill Drive Power (HT) | 14.68 | Sep'20 | 41 | NA | 17.07 | 16.77 | 20.21 | 15.44 |
| | Coal Mill Fan Drive (HT) | 12.18 | | | | 16.43 | 16.62 | 20.39 | 14.78 |
| | Coal Mill Sep. Drive (LT From PCC3) | 1.93 | | | | 1.84 | 1.83 | 2.21 | 1.69 |
| | Coal Transp. & Grinding (MCC-10) | 2.98 | | | | 5.29 | 4.49 | 5.10 | 4.98 |
| | Coal Mill3 Maintenance | 0.14 | | | | 0.00 | 0.00 | 0.00 | 0.24 |
| | Total | 31.77 | | | | 40.63 | 39.70 | 47.91 | 36.89 |

| Drive Wise Power back up | | Ever Best | Month | Output (TPH/TPD) | MTBF (Hrs.) | | | | |
|--------------------------|-----------------------------------------------|--------------|--------------|------------------|--------------|-------------|-------------|-------------|-------------|
| Machine | DESCRIPTION | | | | | 29 | 30 | 31 | up to date |
| Cement Mill 1 | HT Drive | 0.00 | NA | NA | NA | 0.00 | 0.00 | 0.00 | 0.00 |
| | LT MCC | 0.00 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | Cement Mill 1 Maintenance | 0.00 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| | Total | 0.00 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| Cement Mill 3 | Roller Press M.D. 1 1700 KW (H.T.) | 4.16 | Apr'21 | 262 | 103 | 3.86 | 4.54 | 4.24 | 4.40 |
| | Roller Press M.D. 2 1700 KW (H.T.) | 3.88 | | | | 3.56 | 4.28 | 4.00 | 4.11 |
| | Ball Mill M.D. 2600 KW (H.T.) | 7.18 | | | | 6.53 | 6.96 | 6.88 | 6.89 |
| | Bag House Fan 280 KW (L.T.) | 0.56 | | | | 0.53 | 0.61 | 0.61 | 0.57 |
| | C.M. Separator Fan 1200 KW (H.T.) | 3.82 | | | | 4.00 | 3.89 | 3.87 | 3.81 |
| | Separator Drive 475 KW (L.T.) | 0.77 | | | | 0.87 | 0.78 | 0.70 | 0.75 |
| | Cement Mill PMCC 10 (L.T.) | 2.27 | | | | 2.37 | 2.30 | 2.37 | 2.34 |
| | Clinker and Fly Ash Handling PMCC 10 A (L.T.) | 0.68 | | | | 0.55 | 0.73 | 0.91 | 0.76 |
| | Utility | 0.75 | | | | 0.96 | 0.98 | 1.16 | 0.85 |
| | Cement Mill 3 Maintenance | 0.17 | | | | 0.00 | 0.00 | 0.00 | 0.00 |
| Total | 24.08 | 23.23 | 25.07 | 24.72 | 24.49 | | | | |
| Cement Mill 4 | RP Main Drive -1 522MD140M1 (L02) | 2.43 | Feb'21 | 275 | 91 | 2.37 | 2.32 | 2.25 | 2.30 |
| | RP Main Drive-2 522MD140M2 (L03) | 3.06 | | | | 3.23 | 3.19 | 3.09 | 2.95 |
| | Z2M03M1 BALL MILL DRIVE -1 | 5.91 | | | | 6.36 | 6.46 | 7.14 | 6.39 |
| | Z2M03M2 BALL MAIN DRIVE -2 | 5.91 | | | | 6.41 | 6.53 | 6.97 | 6.41 |
| | Separator Fan 522FN550 (L05) | 4.14 | | | | 4.75 | 4.85 | 4.65 | 4.80 |
| | Separator drive 522MD302 | 0.27 | | | | 0.26 | 0.27 | 0.28 | 0.26 |
| | Elevator 522BE170M1 | 0.28 | | | | 0.31 | 0.30 | 0.31 | 0.30 |
| | Elevator 532BE220M1 | 0.28 | | | | 0.26 | 0.25 | 0.27 | 0.27 |
| | CM-4 MCC | 1.32 | | | | 1.45 | 1.34 | 1.45 | 1.46 |
| | CM-2 MCC | 1.01 | | | | 1.53 | 1.27 | 1.23 | 1.30 |
| | FLY ASH MCC | 0.40 | | | | 0.41 | 0.36 | 0.42 | 0.29 |
| | Utility | 0.91 | | | | 0.72 | 0.65 | 0.87 | 0.67 |
| | Cement Mill 4 Maintenance | 0.00 | | | | 0.00 | 0.00 | 1.04 | 0.40 |
| Total | 25.91 | 28.05 | 27.78 | 28.92 | 27.39 | | | | |

ISO 50001

| | |
|-------------------------------|----------------|
| ■ Current Issue Data | 28th Aug 2020 |
| ■ Expiry date | 29th July 2023 |
| ■ Certificate identity number | 10288749 |

EnCon Project budget allocation %

| | |
|----------------------------------------------------------------|----------|
| ■ Total turnover of the company/plant FY 2020-21 (Rs. Million) | 14800 |
| ■ Amount invested in EnCon Projects FY 2020-21 (Rs. Million) | 10467.58 |
| ■ Investment % | 70.73 |



Daily review meetings (PD)



Manufacturing Excellence drive



Daily site inspection



| S No. | NAME OF TRAINING | No. of Persons | S No. | NAME OF TRAINING | No. of Persons |
|-------|-------------------------------------------------------------------------------|----------------|--------------------|---------------------------------------------------------------------------------------------|----------------|
| 1 | ADVERSE IMPACT OF GAS FLOW IMBALANCE | 6 | 20 | LATEST LOW NOX PYRO PROCESSING SYSTEMS | 8 |
| 2 | AN ORIENTATION TO CEMENT MANUFACTURING PROCESS | 7 | 21 | LOW CARBON CEMENT - OPTION & CHALLENGES | 2 |
| 3 | CHEMICAL ANALYSIS OF HYDRAULICS CEMENT-1 | 3 | 22 | LOW CARBON CEMENT-OPTION & CHALLENGES | 2 |
| 4 | CHEMICAL ANALYSIS OF HYDRAULICS CEMENTS-1 | 3 | 23 | MAINTENANCE OF BEARINGS & RELIABILITY | 6 |
| 5 | DESIGNING ENERGY EFFICIENT COMPRESSED AIR DISTRIBUTION SYSTEM | 3 | 24 | MAXIMIZATION OF ALTERNATE FUELS AND RAW MATERIALS UTILIZATION IN CEMENT INDUSTRY | 2 |
| 6 | ELECTRIC CIRCUIT BREAKER | 2 | 25 | OPERATION & MAINTENANCE OF GEARBOX | 6 |
| 7 | ENHANCING PROFESSIONAL EFFECTIVENESS OF EMPLOYEES | 2 | 26 | OPERATION & MAINTENANCE OF HT MOTORS | 3 |
| 8 | ESSENTIALS OF SUSTAINABLE ZERO LIQUID DISCHARGE (ZLD) SYSTEMS | 1 | 27 | PFISTER ROTOR WEIGH FEEDERS FAR | 14 |
| 9 | FATALITY PREVENTION ELEMENTS - FPEs (PROACTIVE & REACTIVE APPROACH TO SAFETY) | 16 | 28 | PRODUCT CERTIFICATION PROCEDURE FOR BIS | 1 |
| 10 | FIRE WARDEN/ ERT TRAINING | 24 | 29 | RAW MIX DESIGN AND ITS MODULI VALUE | 1 |
| 11 | FIRST AID- ST. JOHN AMBULANCE & FIRE FIGHTING | 18 | 30 | REDUCTION OF AT & C LOSSES IN ELECTRICAL TRANSMISSION AND DISTRIBUTION SYSTEM | 1 |
| 12 | FIRST AID TRAINING | 24 | 31 | REDUCTION OF AT & C LOSSES IN ELECTRICAL TRANSMISSION AND DISTRIBUTION SYSTEMS | 1 |
| 13 | GREENCO SUMMIT 2020 (VIRTUAL CONFERENCE & EXPO) | 1 | 32 | REFRESHER TRAINING ON FIRST AID | 2 |
| 14 | IMPACT OF RAW MIX DESIGN AND BURNABILITY ON CEMENT QUALITY | 11 | 33 | SAFE WORKING IN CORONA (COVID-19) RISK PERIOD | 15 |
| 15 | INCIDENT REPORTING, INVESTIGATION AND CAPA | 11 | 34 | SELECTION, USE, MAINTENANCE, REJECTION AND CARE OF PPEs | 15 |
| 16 | INCREASING EFFICIENCY IN INDIA'S PACKING AND DISPATCH OPERATIONS | 8 | 35 | SUSTAINABLE SOLUTION FOR JUDICIOUS USE OF FLY ASH FROM DESULFURIZATION PROCESS AND POND ASH | 4 |
| 17 | KILN REPAIR AND MAINTENANCE | 10 | 36 | TRAINING ON FIRST AID | 6 |
| 18 | LARGE SIZE VERTICAL ROLLER MILLS | 20 | 37 | TRAINING PROGRAM ON FIRST AID -SNAKE BITE | 7 |
| 19 | LATEST GENERATION CROSSBAR COOLER | 7 | Grand Total | | 273 |

| Achievements | | Previous Best | FY 20-21 | UOM |
|-------------------------------------|---------|---------------|----------|--------------|
| ■ Clinker Production | Highest | 28.62 | 40.98 | Lac MT |
| ■ Cement Production | Highest | 24.55 | 30.80 | Lac MT |
| ■ Cement Despatch | Highest | 24.48 | 30.81 | Lac MT |
| ■ Clinker Factor:- | | | | |
| ○ OPC-43 Line-2 | Lowest | 89.35 | 87.27 | % |
| ○ OPC-53 Line-2 | Lowest | 91.89 | 90.76 | % |
| ○ PPC Line-2 | Lowest | 63.68 | 62.66 | % |
| ○ OPC-43 Line-3 | Lowest | 90.55 | 87.23 | % |
| ○ PPC Line-3 | Lowest | 65.62 | 62.22 | % |
| ■ Thermal Energy Kiln-3 | Lowest | 757 | 694 | kcal/Kg Clk. |
| ■ Upto Clinkerisation power Line-3 | Lowest | 56.12 | 46.50 | kwh/Ts. Clk. |
| ■ Upto Cement Grinding Power Line-3 | Lowest | 30.21 | 27.71 | kwh/Ts. Cem. |
| ■ Upto Cement Grinding Power Line-2 | Lowest | 27.52 | 27.22 | kwh/Ts. Cem. |
| ■ AFR consumption | Highest | 65,580 | 88,424 | MT |
| ■ AFR saving | Highest | 12.01 | 20.19 | Cr |
| ■ Clinker average TPD Kiln-3 | Highest | 4886 | 7351 | TPD |

JK Cement LTD.

JK Cement Works,
Mangrol adds
another feather
to its cap



1st Runner Up | Stream –
Energy Efficient Organisation
| Championship Awards
(Category - Large)



“Winner” under “Within
the Fence” category at
CII National Award for
Excellence in Water
Management 2020



THANKS

STAY SAFE