



# 21<sup>st</sup> National Award for Excellence in Energy Management 2021




**UltraTech Cement Limited**

**Unit: Dalla Cement Works**

## **Presenters:**

- 1. Prasnth Tripathi -FH-Technical**
- 2. Shishir Pali -HOD Technical Services**
- 3. Neeraj Pundir-SH WCM**


# Impact of COVID 19



**Note-** No major Impact on Plant Production & Dispatch




# Company Profile




# PLANT PERFORMANCE

## Specific Heat Consumption



GOOD


## Kiln TPD




GOOD

# PLANT PERFORMANCE


### Overall Sp. Power Cons. (KWH/MT cement)




### Sp. Power Up to Clinkerisation (KWH/MT Clk)



### Cement grinding sp.power: Total- (kWh/MT)




### Sp. Power Packing plant(KWH/MT Clk)




# PLANT PERFORMANCE

### Cement grinding sp.power: PPC- (kWh/MT)




### Cement grinding sp.power: PPCWR- (kWh/MT)




# Unit Energy Performance Comparison

With benchmark (Year 2020-21)

## Sp. Heat Consumption (Kcal/kg clinker)



## Overall sp. Power Consumption (kWh/MT cement)



Ref. For National Benchmark : - CII Energy benchmarking for cement Industry Ver-5, May 2021

Ref- For International Benchmark Report of Industrial Energy Efficiency Benchmarking Report for Cement Sector by United Nations Industrial Development Organization (UNIDO).



# Road Map for Benchmarking- FY22 projects


Action Plan	Status
Retrofitting/ replacement/ In-house modification of Energy efficient fans at Major Fans.	Proposal in progress
Increasing TSR by executing CAPEX for AFR feeding system	Capex approved/ordering started
Exploring for replacement existing Cooler with high efficiency cooler	Line-2 completed & Line-1 proposal in progress.
Retrofitting old reciprocating compressor to high efficiency screw compressor	Audit completed / proposal in progress
Upgradation line-1 preheater for 2250 TPD capacity.	Proposal in progress.
Increasing fly ash addition in PPCWR from 30 to 32% and reduction of conversion factor.	Continuously improved
Increasing Line-2 VRM output & reduction SPC by addition of RP rejects to VRM	Project started





# PAT Status-DLCW after UTCL

## GtG energy consumption status



Achieved 7.14% reduction in FY 2020-21 from given target



## **5.SUMMARY OF ENCON MEASURES TAKEN IN LAST THREE YEARS**




Energy Saving  
Sheet

## 5. Energy saving initiatives in Last Three Years


Year	No of energy saving projects	Investments (INR Million)	Electrical Saving (Million kWh)	Thermal Saving (Million Kcal)	Saving (INR Million)	Impact on electrical kWh/MT cement, Thermal (Kcal/kg clk)
FY 2018-19	13	8.20	1.84	8458.59	17.65	SEC reduced 8.65% (7.45 kWh/MT cmt) from previous FY and 6.74 kcal/kg clk saving of thermal energy.
FY 2019-20	17	7.35	1.48	7953.75	15.52	SEC reduced 3.22% (2.53 kWh/MT cmt) from previous FY and 4.41 kcal/kg clk saving of thermal energy.
FY 2020-21	15	14.30	6.05	12896.67	40.84	SEC reduced 4.70% (3.58 kWh/MT cmt) from previous FY and 2.38 kcal/kg clk saving of thermal energy.

# Unit Performance – Last Three Years


Investment in INR Million



Electrical Saving Million kWh



Thermal Saving Million Kcal





# Project 1- Energy saving by smoke chamber modification

## Objective:-

Reduction in electrical & thermal energy.

## Backdrop:-

Line-1 Kiln is having 4 stage suspension preheater without any secondary firing arrangement in preheater so Kiln output couldn't get increased due to single firing system & also higher velocity at kiln inlet due to small smoke chamber design.

Due to very old civil structure (i.e. 40 years old) of preheater building, addition in cyclones stages & modification of risers were not possible during annual shutdown.

Line-1 pre clinkerisation sp. power consumption was higher 83.72 kWh/MT clk.

Line-1 sp. heat consumption also higher 783.75 kcal/kg clinker.

Higher Preheater exit temperature & lower kiln output due to old design

# Project 1- Energy saving by smoke chamber modification

## Approach:

- For improving the performance of line-1 Kiln, a cross functional team formed & discussed the best possible modification within annual shutdown.
- Based on the discussion team proposed to modify the kiln smoke chamber by 500 mm of size enlargement and secondary firing in kiln inlet.
- During the annual shutdown (April'20) of Line-1 kiln area following jobs done-
  - Area enlargement of smoke chamber.
  - Installation of secondary firing in smoke chamber.

After the modification done, it was decided to run the kiln without secondary firing for optimum Sp. Heat Consumption & kiln output and we get the benefit of ~50 TPD without increase in heat.

We continued with enlarged area for optimizing the feed.



# Project 1- Energy saving by smoke chamber modification

## Results:

- Kiln output increased by 44 TPD from previous FY
- Achieved saving in sp.heat consumption by 13.64 kcal/kg clk from previous FY
- Achieved saving in kiln sp. power cons. is 4.21 kWh/MT clk from previous FY

Parameter	UOM	Before (FY 2019-20)	After (FY 2020-21)	Saving
Production	MT	423987	447829	23842
Output	TPD	1481	1525	44
Sp.heat Cons.	Kcal/Kg clk	784	770	13.64
Total Sp.power Cons.	kWH/MT Clinker	30.47	26.26	4.21
Line-1 Pre Clinker SPC	kWH/MT Clinker	83.72	76.25	7.47
Cost of power	Rs/Kwh			3.5
Cost of heat	Rs/MCV			1150
<b>Saving in (INR Lakhs/Annum) from energy saving</b>				<b>136.22</b>

**Benefits Achieved:**

- **Saving: 136.22 Lakh INR.**
- **ROI within 2 Months.**
- **GHG Emission reduced by 8.94 kgCO<sub>2</sub>/MT Clk.**
- **PH exit temperature reduced by ~17 Deg C.**

## Project 2- Energy saving grinding media optimisation

### Objective:-

Electrical energy saving by optimising grinding media in open circuit ball mill for cement grinding.

### Issues:-

- Unit have 02 nos. very old design open circuit ball mills with capacity of 35 tph in PPC grade
  - Main drive itself consumes 85% of total cement grinding power consumption. To reduce Sp.power in cement grinding either main drive load should be reduced or mill output to be increased in same loading.
  - Mill auxiliary specific power consumption including mill vent fan was on higher side due to low output.



# Project 2- Energy saving grinding media optimisation

## Approach:

Brainstorming session done with departmental teams and Team finalised the following ideas for grinding media optimisation & production improvement and the same was implemented.

- 1) 15 mm grinding media removed & 17 mm & 20 mm increased in second chamber of mill. Media loading reduced by 6% from previous (33% to 27%).
- 2) Higher percentage of Line-2 clinker mixed as C<sub>3</sub>S is higher in Line-2 clinker.



A.LINE POWER

RESOURCE	SUB SECTION	YTD_TPH	YTD/MT_CMT	YTD_LOAD_KW
NPPCWR:TOTAL		27.333	35.747	977.094
SD_POST	SHUTDOWN POST PWR		0.145	
TOTAL			0.145	
Cement mill:Overall	<b>Before</b>	30.669	32.245	

A.LINE POWER

RESOURCE	SUB SECTION	YTD_TPH	YTD/MT_CMT	YTD_LOAD_KW
SUB TOTAL		29.441	32.429	954.754
NPPCWR:TOTAL		29.377	32.527	955.569
SD_POST	SHUTDOWN POST PWR		0.029	
TOTAL			0.029	
Cement mill:Overall	<b>After</b>	33.104	29.049	

## Project 2- Energy saving grinding media optimisation

### Results:

- Cement Mill output increased by 2.44 TPH from previous FY
- Achieved saving in cement grinding sp.power consumption by 3.20 kWh/MT Cement from previous FY

Parameter	UOM	Before (FY 19-20)	After (FY 20-21)	Saving
Production	MT	443864	509804	65940
Output	TPD	30.67	33.10	2.44
Total Sp.power Cons.	kWH/MT Cement	32.25	29.05	3.20
Cost of power	Rs/Kwh			3.5
<b>Saving in (INR Lakhs/Annum) from energy saving</b>				<b>57.03</b>


### Benefits Achieved:

- Saving: 57.03 Lakh INR.
- ROI with in 5 Months.
- GHG Emission reduced by 2.62 kg CO<sub>2</sub>/MT Cement

# Utilization of Renewable Energy sources


Year FY	Technology (Electrical)	Type of Energy	Onsite/ off site	Installed capacity (MW)	Generation (Million kWh)	% Of overall elect energy
FY 2018-19	-	-	-	-	-	-
FY 2019-20	-	-	-	-	-	-
FY 2020-21	-	-	-	-	-	-

- Solar lights installed in colony street lights
- Solar water heater installed in colony guest houses 12 KW
- WHRS project (13.5 MW) erection in progress, Expected commissioning Aug'2021
- Proposal submitted for 2.5 MW Solar plant



# Utilisation of Waste Material as Fuel


S.No.	Year FY	Total Alf fuels Quantity (MT)	Wt. Avg NCV (kcal/kg clk)	Waste as percentage of total fuel
1	FY 2018-19	3006	1284	0.30
2	FY 2019-20	3070	1878	0.41
3	FY 2020-21	2930	2840	0.65



# Utilisation of Waste Material as Fuel FY 2020-21



FY 2020-21-UTCL DALLA CEMENT WORKS							
COAL	QTY	NCV	Heat (Mkcal)	QTY (Total)	NCV (kcal/kg)	Heat (Mkcal)	AFR in Heat %
CARBON POWDER	25.00	6,111.69	152.79	2,930	2840	8322.58	0.65
CLOTH WASTE	81	3,523.97	285.44				
FMCG WASTE	1,378.89	2,139.34	2949.91				
MSW RDF	101.56	2,897.28	294.25				
OWN WASTE	24.7	2,639.36	65.19				
PLASTIC WASTE	1,182.13	3,442.05	4068.95				
SOLID WASTE	67.78	3,794.03	257.16				
WOODEN DUST	69.02	3,606.00	248.89				




# Utilisation of Waste Material as Additive

## Waste material used as Alternative Raw Material (Additive)

Sl.No	Waste Material	Quantity Used (MT)		
		FY 2018-19	FY 2019-20	FY 2020-21
1	Fly Ash Dry	90,292	97,484	1,11,959
2	Fly Ash TPP	52,725	53,602	53,998
3	Fly ash TPP Coarse	9,920	1,868	8,398
4	Pond ash	0	0	423
5	Chemical Gypsum	98	5,685	6,222
6	Gypusm imported	14,409	6,293	5,999
7	Gypsum Phoshpo	392	693	0
8	Red mud	64,262	79,671	86,347
9	Iron refines	2,168	337	0
Total		2,34,266	2,45,634	2,73,345
% Waste used against natural resource consumption		11.30	11.37	9.51

# GHG Inventorisation

## CO<sub>2</sub>-Emissions-kgCO<sub>2</sub>/MT Cement



## CO<sub>2</sub> Emissions (kg CO<sub>2</sub>/ton of Cementitious product)



# CO<sub>2</sub> Emission Reduction Action Plan

## Target Reduction for CO<sub>2</sub> emission intensity by 25% by 2025

Action Plans	Status
Increasing fly ash addition up to 32% in PPCWR	Started
WHRS installation (13.5 MWh)	Erection in progress
Increasing alternative fuel consumption up to 10% TSR from 1%	Ordering in Progress
Installation OLBC to reduce diesel consumption and TAT	Project finalised
Installation 2.5 MWh Solar plant in plant boundary	To be finalised
Upgradation Line-1 cooler to reduce Thermal energy consumption	Audit completed & Proposal in progress.




# Green Belt Development (Plant, Colony & Mines)

1

## Tree Plantation



FY-18



FY-19

## Tree Plantation




FY-20




FY-21

**Up to FY 2020-21 survived Trees 38621 Nos.**  
Cumulative Survival rate = 79.895%

# Learning from CII Award



# Team Work, Employee involvement & Monitoring




Online process parameter & Energy monitoring through KM



Energy Consumption (SPC & SHC) monitoring through CCR Desk


Particular	ICM	Target	TOT	MTD	Loss	TOT Output	Yesterday	Variance YD
Coalstar		1.31	1.88	1.84	-0.52	825	1.85	0.05
WPM Raw Mill		28.56	35.25	33.51	-4.19	310	34.03	-4.70
WPM Coal Mill		5.70	5.89	3.05	-3.59	35	5.34	0.05
Kin		18.56	19.10	19.55	-0.63	407	19.53	-0.15
Utility Services	W/MTC Ok	3.00	3.05	3.54	-0.63		3.34	-0.21
<b>Total Pre-Operation (Excl. shutdown)</b>		<b>54.01</b>	<b>80.15</b>	<b>81.49</b>	<b>-6.15</b>		<b>81.23</b>	<b>-1.07</b>
Shutdown		0.00	0.00	0.00	0.00		0	
Power - Pre-Op (incl. shutdown)	W/MTC Ok	54.01	80.15	81.49	-6.15		81.23	-1.07
Cement grinding	W/MTC On	28.56	26.79	27.68	-3.27	43.08	28.88	-4.11
Packaging plant	W/MTC On	0.80	0.80	1.82	-3.13	43.75	0.86	-0.82
<b>Power - Total (Pre &amp; Post Op)</b>	<b>W/MTC On</b>	<b>85.36</b>	<b>87.43</b>	<b>83.34</b>	<b>-2.43</b>		<b>83.15</b>	<b>-3.07</b>
Compressor L-1	W/No Day	-	2296	12135			2506	-105
Compressor L-2	W/No Day	-	4337	47011			4837	-196
Compressor Total	W/No Day	-	8732	58946			8307	65

Daily Production Report and Power consumption Report.





# Approach, Deployment & Review- Improvement Projects /Kaizen/Suggestions



# Involvement of Employees and Recognitions

Mechanical Workshop



Power Plant



Wage board Employee Interaction



Mines Function



# System Adopted



We are proud to  
achieve the  
certification without  
any major  
observations

ISO 5001 : 2018

# National Energy Conservation Award 2017 (First Prize)

Dalla Cement Works awarded as “Excellent Energy Efficient Unit” under CPP Cat.





## UltraTech Cement Limited - Dalla Cement Works (CPP)

Excellent Energy Efficient Unit







Rahul Saigal  
Unit Head- DLCW

Team Members



Unique Achievements

- Benchmark in Group Units in Aux. power Cons.
- Lowest Cost Power producer in UTCL
- Lowest LOI (3-4%) in AFBC Boiler category

“

CII Energy management awards is a excellent platform for exchanging the knowledge and improving the efficiency

”

21<sup>st</sup> National Energy Award for Excellence in Energy Management

2020



Confederation of Indian Industry  
125 Years - Since 1895