






**CII-National Award for
Excellence in Energy Management
2021**

JSW Energy Ltd, Ratnagiri



1. Brief Introduction – JSW Energy Ltd.














SALIENT FEATURES OF THE PLANT :


- 1st TPP installed at *Konkan* belt of Maharashtra {MOU}
- India's largest covered coal shed with 3 lakh MT cap.
- Gas Insulated Switchyard (GIS)
- Sea Water Based FGD system installed since inception
- Closed loop sea water cooled condenser & FRP cooling tower
- Power evacuation through 4 x 400 kV transmission line

Total Present Operational Capacity : 4559 MW
Upcoming Capacity Addition : 1275 MW (Renewables)

2. Energy Consumption Overview – FY 2020-21




3. Specific Energy Consumption in last 3 years



Reason for variation :


- There was a change in coal GCV by more than 100 kCal/kg for FY19 & FY20, also the loading factor was less by 5 % in FY20 compared to FY19
- In spite of lower PLF in FY21 compared to the previous year, with number of improvements, the heat rate was successfully reduced by 0.93 %



Reason for variation :


- In spite of lower PLF in FY 21 compared to that in previous year, the aux power consumption was successfully reduced with number of improvement steps.

3. Specific Energy Consumption in last 3 years



Reason for variation :

- The major decrement in availability is due to planned shutdown of units (AOH)



Reason for variation :

- Lower demand from captive consumers as a result of prevailing market conditions resulted in lower plant load factor

4. Information on Competitors & Benchmark

Parameter	UOM	JSWEL Ratnagiri	GWEL Warora	RPG Dhariwal	Lanco Amarkantak
Availability	%	73.57	84.1	98.28	94.12
Plant Loading Factor	%	58.97	74.87	80.46	86.93
Loading Factor	%	80.16	88.99	81.86	92.36
Aux Power Consumption	%	8.41 (8.15 excluding FGD)	8.20	7.67	8.16
Sp Oil Consumption	ml/kWh	0.09	0.15	0.05	0.09
DM Water make up	%	0.48	0.14	0.20	0.32
Heat Rate	kCal/kWh	2337	2310	2332	2363

4. Information on Competitors & Benchmark

Roadmap to achieve benchmarks

AVAILABILITY




- **RLA study** of critical equipment's
- Change in **AOH/COH philosophy**

GROSS HEAT RATE

- Replacement of **CT Fans in U-3 & 4**
- Replacement of **APH baskets in U-3 & U-4**

SPECIFIC OIL CONSUMPTION

- Installation of **mini oil gun**
- Conversion of **HFO to LDO**



PLANT LOAD FACTOR

- Increase in PLF by **augmentation of CPP power.**

AUX POWER CONSUMPTION

- Installation of **VFD in Primary Air Fans.**
- Installation of **ESP smart controller**
- Installation of **VFD in LDO pumps**

SPECIFIC DM CONSUMPTION

- Conversion of **HFO to LDO**

4. Major *Encon* Projects Planned for FY 21-22

Sr No	Title of project	Annual Electrical Savings	Annual Thermal Savings	Total Annual Savings	Investment Made	Payback	Status / Timelines
		kWh	MT	Rs million	Rs million	Months	
1	Improvement in air pre heater performance by changing profile of baskets in Unit-3	2102400	3209	28.22	18.4	8	Completed
2	Improving Unit-3 cooling tower efficiency by redesigning cooling tower fan blades	0	1099	7.14	11.5	19	March-22
3	Improvement in air pre heater performance by changing profile of baskets in Unit-4	0	3209	20.86	18.4	11	In Progress
4	Reduction in power consumption of boiler feed water pump by de-staging	1430333	0	5.01	2.50	6	Oct-21
5	Solarization of Raw Water (Nivali) Pump House	438000	0	3.07	9.10	36	March-22
6	Replacement of RH spray CV with modified design (single stage to multistage) so as to avoid its passing and reduce RH spray & RH temperature losses	0	1025	6.66	1.60	3	Completed in U3, Work in progress for U4
7	Elimination of HFO guns by replacement with LDO guns in Unit-4	0	1831	11.90	0.02	0	Implemented in U1 & U4

5. Energy Saving Projects Implemented in last 3 years

Summary of Energy Saving Projects

FY	Number of Proposals	Investments (INR million)	Savings (INR million)
2018-19	22	78.57	719.98
2019-20	11	22.30	97.82
2020-21	08	0.52	101.65

5. Energy Saving Projects Implemented for FY 18-19

Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)	Payback Period (Month)
1	Improvement in air pre heater performance by high pressure water jet cleaning and changing profile of baskets.	3689	2673311	36.51	12.00	4
2	Improving HP Heater performance by refurbishment of tube bundle	3644	-	27.29	13.05	6
3	Improving Unit-1 cooling tower efficiency by redesigning cooling tower fan blades	2999	-	22.38	11.5	6




Defective APH baskets



High pressure water jet cleaning of basket



Installation of new basket



Installation of HPH-6 after refurbishment of tube bundle



5. Energy Saving Projects Implemented for FY 18-19

Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)
1	Inspection & replacement of port plate flap in Vacuum Pump to attend air short circuit inside pump. (Carried out in two units)	3712	171593	28.27	Nil
2	Cleaning of CW suction screen by mixture of air & water to reduce fire water consumption	-	33250	0.11	Nil
3	Use of stored rain water and RO plant for plant purpose instead of river water so as to reduce MIDC pump power consumption	-	34366	0.24	Nil
4	Saving in aux power of Sea Water pump by optimizing its running hours	-	4886640	16.42	Nil
5	Reducing PA fan loading by optimizing its header pressure	-	4847040	16.29	Nil
6	Saving in cooling tower auxiliary power consumption by optimizing running hours	-	2867040	9.63	Nil
7	Optimization of ACW pump running hours	-	1853280	6.23	Nil
8	Coal mill LOP power optimization	-	300960	1.01	Nil
9	Coal feeder COC running hours optimization	-	237600	0.80	Nil
TOTAL		3712	15231769	50.73	Nil

5. Energy Saving Projects Implemented for FY 19-20

Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)	Payback Period (Month)
1	Replacement of Unit-2 cooling tower fans with redesigned fans	1509	0	9.81	11.5	14
2	Replacement of APH baskets for APH-B in Unit-1	1478	1116900	13.51	8.40	7
3	Installation of RC control valve with redesigned trim set in four BFPs to attend passing of RC control valve	0	5977824	20.92	2.40	1



Replacement of CT Fan blades with redesigned blades



Upgradation of BFP RC valve trim set from single stage to multistage

5. Energy Saving Projects Implemented for FY 19-20





Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)
1	Improvement in Vacuum Pump-2B performance by replacing its valve plates	0	52240	0.18	Nil
2	Optimization of CW Pump power consumption by running common pump for two units at partial load	0	237600	0.83	Nil
3	Optimization of Coal Mill power consumption by optimizing number of running mills	0	3379287	11.83	Nil
4	Optimization of SWIP power consumption by optimizing running hours	0	484763	1.70	Nil
5	Optimization of CT Fan power consumption by optimizing running hours as per condenser vacuum	0	557348	1.95	Nil
6	Optimization of CEP power consumption by reducing discharge pressure	0	1675419	5.86	Nil
7	Optimization of ESP power consumption by changing charge ratio & hopper heater settings	0	5861210	20.51	Nil
8	Optimization of PA Fan power consumption by reducing discharge header pressure	0	3064010	10.72	Nil
TOTAL		0	15311877	53.58	Nil

5. Energy Saving Projects Implemented for FY 20-21

Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)	Payback Period (Month)
1	Internal inspection of HPH-6 & 7 in Unit-3 and rectification of passing parting plane	732	-	4.76	0.20	0.50
2	Internal inspection of HPH-6 in Unit-1 and rectification of passing parting plane	736	-	4.78	0.10	0.25
3	Improvement in performance of Vacuum Pump-1B by internal cleaning & servicing	2927	-	19.02	0.20	0.13
4	Elimination of HFO guns by replacement with LDO guns in Unit-1	1831	-	11.90	0.02	0.02



HPH parting plane rectification



5. Energy Saving Projects Implemented for FY 20-21



Sr No	Title of Project	Annual Thermal Savings (MT of coal)	Annual Electrical Savings (kWh)	Total Annual Savings (INR million)	Investment (INR million)
1	Modification in deaerator station CV control logic to optimize the discharge pressure of condensate extraction pump	-	490560	1.72	0.00
2	Stoppage of one ash handling plant compressor by optimizing cycle gap & conveying time	-	162000	0.57	0.00
3	Stoppage of one out of two Sea Water Intake pump at partial load for 24 hours by monitoring forebay COC, CW Inlet temperature & condensor vacuum	-	12420000	43.47	0.00
4	Optimization of draught fans load, so as to reduce its power consumption at partial load	-	4017600	14.06	0.00
5	Optimization in main plant compressor power by reducing the IFC set point as well as isolating instrument & service air for shutdown unit, thereby stopping one compressor	-	177120	0.62	0.00
6	Reduction in primary air fan power consumption by optimizing its header pressure from 8 kPa to 7.5 kPa	-	212760	0.74	0.00
TOTAL		0	17480040	61.18	Nil

6. Innovative Project Implemented


Reduction in power consumption of CEP by reduction in its discharge pressure

- At JSWEL, Ratnagiri, number of PDCA cycles were carried out to optimize the CEP discharge pressure & reduce its power consumption

PDCA-1

Replicability : Yes



- After VFD installation CEP power optimization done from 932kWh to 636kWh by reducing motor speed. And also CEP discharge pressure reduced from 3.2Mpa to 2.2MPa.(The predicted APC reduction after VFD installation was 550 KWH).
- At full load (315 MW) below 2.2MPa discharge pressure vibration in motor NDE bearing observed higher than the alarm value (i.e. 80um).
- VFD Speed reduced up to 1290 rpm. Further speed reduction getting restricted as Motor NDE vibration going higher side as shown in Graph-1.
- However reduction of power consumption with respect to speed shown in Graph-2.




6. Innovative Project Implemented

Reduction in power consumption of CEP by reduction in its discharge pressure



PDCA-1



Shim plates provided at discharge pipe support.



Wedges Installed at CEP Base Frame




6. Innovative Project Implemented

Reduction in power consumption of CEP by reduction in its discharge pressure

PDCA-2

Replicability : Yes





- In traditional setup, the CEP speed was controlled by discharge header set point
- The deaerator level was controlled by deaerator control station CVs for which the level set point was defined in the logic block (by operator)
- This logic was resulting in operation of CEP discharge header pressure and hence the speed of CEP independent of deaerator level

6. Innovative Project Implemented

Reduction in power consumption of CEP by reduction in its discharge pressure


PDCA-2

- The logic block have been developed so as to control the CEP speed by deaerator level
- This has enabled further optimization of CEP power consumption by bringing the discharge pressure set point as low as 1.0 MPa at partial loads



7. Utilization of Renewable Energy Resources

Installation of sky lights in Central Stores (Solar Energy)



Rating (Watt)	Electrical lights (No.)	Total annual saving (kWh)
400	12	21024
170	8	5957
Number of electrical units saved annually		26981

Recycle of biodegradable waste



Biodegradable wastes are utilized for producing bio-gas and being utilized at plant & associate canteen	
Bio gas production	> 14 m ³ / day

Equivalent to approx. 145 LPG cylinders per year

8. Environment Management – Ash Utilization

Particulars	UOM	2018-19	2019-20	2020-21
Ash Stock in Plant (yard+pond)	Tons	53612	55537	47853
Ash generated	Tons	425415	378352	264689
Ash Utilization	%	100	99.49	101.44
Ash utilized in manufacturing of cement	%	9.0	19.5	29.45
Ash utilized in fly ash bricks	%	13.5	23.29	33.35
Ash utilized in RMC	%	77	56.7	37.33

Ash handling done through various methods		
Ash handled (Wet method)	%	0.2
Ash handled (Dry method)	%	99.8
Ash handled (Semi method)	%	0

100 % Ash utilization by supplying ash on FOR basis

8. Environment Management – Ash Utilization

Upcoming Project (November-21) : Bulk Export of Fly Ash

About the Project :

- Fly ash from plant will be stored in a 45000 MT RC silo by means of pneumatic conveying pipe lines
- The ash stored in the silo shall be pneumatically conveyed to *Marine Vessels* and will be exported to various locations in *Gulf & European* countries

Salient Features of Project:

- 45000 MT capacity huge RCC Silo with 45 m ID & 60 m in height
- The ash from plant will travel a distance to 2.5 kms to reach the silo
- The ash from silo to marine vessel will travel a distance of 1 km
- Approx. 90% Ash export tied up with commitment from November-21



45000 MT RCC Silo

Total Investment ~ INR 100 Cr

8. Environment Management – Emission




Particulars	UOM	Limit	2018-19	2019-20	2020-21
Total CO2 emissions per kW of generation	Ton/kW	-	889	895	965
current SOx emissions at full load	mg/Nm3	600	505.8	536.6	545.23
current NOx emissions at full load	mg/Nm3	450	312.2	308.5	310.77
Particulate Matter at full load	mg/Nm3	50	33.4	34.3	34.73
Mercury	mg/Nm3	-	<0.03	<0.3	<0.3

Public Disclosure :



1. GHG data is submitted to Central Electrical Authority (CEA) **(Scope-1)**
2. The data is also included in BRR (Business Responsibility Report) and available on company website for public interest.
3. Refer link below:

<https://www.jsw.in/investors/energy/jsw-energy-financial-information-business-responsibility-reports>

Practices adopted for emission control & monitoring



8. Environment Management – Water



Best practices in water management:

Sr. No	Description
1	<p>Rain water harvesting : We've constructed number of check dams where rain water is collected and stored. The same is utilized as a fresh water for plant process as well as company township. In FY 2020-21, we consumed highest amount of fresh water from these dams (This year : 2.81 Lakh Cum, Previous highest : 1.73 Lakh Cum)</p>
2	<p>All volatile Treatment: - To Reduce boiler blow down water quantity, conventional Boiler water treatment was changed over to all volatile treatment.</p>
3	<p>Use of treated effluent for Horticulture in plant: - Sewage water is treated in Reed bed system and treated water is used for horticulture purpose. Fresh water requirement is reduced by use of this water.</p>
4	<p>Cleaning of CW pump screen cleaning: - Huge quantity of treated water was used to remove debris stuck on screens of Cooling water pumps. High pressure air was used along with water by fabricating in house cleaning device.</p>
5	<ol style="list-style-type: none"> Automation of make up water to all the tanks in plant viz. service water tank, CCW make up tank, Potable water tank, etc so as to avoid overflowing of water Installation of RTD in high pressure steam drain line so as to quickly identify passing of valve & attend the same Drain temperature survey & thermography on regular intervals. Ensuring proper functioning of steam traps

8. Environment Management – Water

Water Contamination Control



Oil-Water Separator Pit



CW ARV Pit


Check dams to store rain water



Sewage Treatment





STP having NEERI patented **Phytorid** technology is installed in plant as well as in township for treatment of domestic effluent. **Treated water** is used for horticulture & gardening purpose.




9. Best Practices in the Plant

Analytics Dash board in Qlick Sense for KPI monitoring



Digitization



Salient Features:

- All the management as well as plant level KPIs are tracked
- The data is SAP linked, hence no manual intervention required
- Analytics helps for projections and corrections of KPIs

9. Best Practices in the Plant

S.No	DESCRIPTION	UNIT	UNIT1	UNIT2	UNIT3	UNIT4	Station	
1	Generation	DAY	MU	5.90	4.54	0.00	4.30	14.74
		MONTH	MU	69.40	53.32	0.00	55.39	178.10
		F.YEAR	MU	937.08	503.19	114.77	665.21	2220.25
Generation Target For The Month	TARGET	MU	195.40	126.62	186.91	96.47	605.39	
	ACHIEVED	%	35.52	42.11	0.00	57.42	29.42	

Digitization



Centralization of following control stations :

- 1. Coal handling system**
- 2. Ash handling system**
- 3. ESP**
- 4. HCSD system**

Flexibilization



Common command control room for vigilance

9. Best Practices in the Plant



Plantation data for last 10 years

Sr. No	Species	Planted Qty.	Survived Qty.	Survival %	Area (Acre)
1	Mango	9773	9753	99.80	52.9
2	Cashew	440	429	97.5	7.51
3	Forest	35200	35178	99.94	51.629
4	Coconut	465	459	98.70	1.936
5	Kokam	358	352	98.32	0.329
6	Betel Nut	433	432	99.77	0.138
7	Miscellaneous Plantation	59100	59085	99.97	10.056
	Total Qty.	105769	105688	99.92	124.49



Afforestation

Developed & Maintained green belt in & around the plant.

Converted more than 30 acres of barren rocky land into lush greeneries.



10. Team Work

First MoM of Performance Optimization Group		Location :	VC with VJNGR / RTNG / HBPLC / RWPL	
Date :	3-Aug-18	Time :	10:30 hrs to 13:30 hrs	
Members Present: Mr.Gyan Bhadra Kumar, Mr.Adiya Agarwal, Mr.Shantharam Pai, Mr.Rajesh Vasudevan, Mr.Sudharshan Majji, Team VJNGR Leading by Mr.Kartikeya Misra, Team RTNG leading by Mr.Vijay Likhitkar, Team HBPLC leading by Mr.Ajay Nath, Team RWPL leading by Mr.C.V.Reddy				
Sr. No.	Details of Discussion	Action by Location	Responsibility	Status
1	Monetary gain need to be verified for all the performance activities which are completed	All Stations	Station Finance HoD's	
2	Cooling Tower and Condenser performance need to be reviewed. All actions for reducing losses need to be shared with Corporate along with supporting documents	Ratnagiri/Vijayanagar/Barmer	PoG Heat Rate Team	
3	Issues related to measuring of Efficiency of CW Pumps / SWIP need to be discussed with professors from IIT Mumbai	Ratnagiri/Vijayanagar/Barmer	Team Corporate	
4	Trending of Hydro Turbine performance with parameters like water inlet flow, generation, guide vane opening etc. need to be recorded on regular frequencies	HBPLC	PoG Team	
5	SBU-2, Unit-1 defects needs to be addressed before taking into service	Vijayanagar	Head O&M - VJNGR	
6	Protocol for sootblowing need to be shared among the locations	Ratnagiri/Vijayanagar	PoG Heat Rate Team	
7	R2 Conveyor (Vessel discharge conveyor) Load cell instrument healthiness to be ensured and to be taken up with the port for any deviation	Ratnagiri	RTNG PoG Coal Team	
8	Issues related to performance deterioration after COH need to be taken up with Siemens / Alstom	Ratnagiri/Vijayanagar	PoG Heat Rate Team	
9	Plant wise categorization of performance issues need to be listed out based on their monetary impact	All Stations	PoG Team	

POG teams

- **Cross functional teams** formed at plant level to work for improvement in performance parameters viz. GHR, APC, Coal Loss & UI.
- Review meetings chaired by HoP & HoT

QUALITY IMPROVEMENT PROGRAM-II																
Task	Description	Leader	Members	Start Date	End Date	Progress	Remarks	Priority	Owner							
Quality Circle detail -Ratnagiri																
Sl. No	Registration No	Month of Registration	Department	Name of QC	Role	Name										
1	JSWEL/RATNAGIRI/QC-01	Oct-18	OPERATION	Better Everyday	Facilitator	Mr. ANSHUL AGRAWAL	Leader	Mr. ANANT KUMAR	Member	Mr. JAGDISH CHALAGERTI	Member	Mr. NILESH ADAV				
ENERGY MANAGEMENT CELL																
CORE TEAM																
Sr No	Name	Dept	E-mail													
1	PEDDANA RAMAYANAM	Head-O&M	peddanna.ramayanam@jsw.in	SAR	Superv											
2	TUSHAR PANDE (PLANT EM)	MMD	tushar.pande@jsw.in	HAV	Inventory											
3	DIPAK PATIL	OS&TS	dipak.patil@jsw.in	MA	Master											
4	SHIVAKUMAR NARGUND	MMD	shivakumar.nargund@jsw.in	MCAR	Control											
5	SANJAY HARDIKAR	EMD	sanjay.hardikar@jsw.in	RF	Reliability											
6	VIJAY LIKHITKAR	OPN	vijay.likhitkar@jsw.in	ZMBILT	Special											
7	NAVEEN GUPTA	EMD	naveen.gupta@jsw.in	G	General											
8	RANJAN SINGH	BOPMD	ranjan.singh@jsw.in	BUDHANKAR	Special											
9	CHINMAY THAKUR	CO-ORDINATION	chinmay.thakur@jsw.in	E	Energy											
10	ADHISH DEVASTHALI	CO-ORDINATION	adhish.devasthali@jsw.in	JRVE	Special											
SUPPORT TEAM																
1	SANDESH GHATKAR	BMD	sandesh.ghatkar@jsw.in	SKAR	Special											
2	SHAKEER AHMED SS	TMD	shakeer.ahmed@jsw.in	DADE	Special											
3	AJAY PATIL	EMD	ajay.patil@jsw.in	GHARKAR	Special											
4	AVADHUT KELKAR	OPN	avadhut.kelkar@jsw.in	SAO	Special											
5	SATISH BISURE	ICM	satish.bisure@jsw.in	ALE	Special											
6	RAMESH NANDAWADE	EMD	ramesh.nandawade@jsw.in	LEKAR	Special											
7	SOURABH SHIRDHANKAR	OPN	sourabh.shirdhankar@jsw.in	KAR	Special											
8	VIKAS HULSURE	OPN	vikas.hulsure@jsw.in	AR M	Special											
9	MUNEED MOHAMMED	OPN	muneed.mohammed@jsw.in	HURY	Special											

EMC & QC Teams

- **Energy Management Cell** – Core team along with Support team formed with objective of improvement projects for *energy conservation*.
- **24 QC teams** for *continuous improvement projects under KAIZEN* (One KAIZEN/month)

4i-J2 & J3 Projects

- Identified & trained 27-J2 candidates & 8-J3 candidates to work for a cross functional project involving high end statistical tools & analysis
- The projects adopts our unique **4i** improvement methodology (Identify, Ideate, Implement, Institutionalize)

10. Team Work & Employee Involvement

Individual awards including Employee of the Month

Best KAIZEN awards for various categories to teams & individual

VIRTUAL CELEBRATION OF REWARD & RECOGNITION JULY 2021 @ JSWEL, RATNAGIRI

R&R July-21

Congratulations!

Employee of the Month

Mr. S K Vishal
For displaying **Commitment** by observing the oil leakage from turbine GV#1 dump valve and informing the same on time to MMD which helped in avoiding the unit outage, generation loss, oil spillage, fire hazard.

Effective Learners

Mr. Shallesh Vashistha
C&I

Mr. Samarth Gosavi
Operation

Mr. Ramesh Nandawade
Electrical

Awards will be distributed during Monthly Birthday Celebration July 31st, 2021 @ 4:30 pm
Awarders are requested to ensure their availability

Monthly Safety Rewards & Recognition Program

Congratulations

Safety Hero for the month of July -21

Mr. Akash Suresh P. G. Sat. (Oil leakage emergency handling of OMS, CTS-ER with safety precaution focused presentation)

Mr. Vikas Suresh P. G. Sat. (Near Miss Reporting)

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

Near Miss Reporting Award - July -21

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

Mr. Anurag Suresh P. G. Sat. (Near Miss Reporting)

TQM Employee Engagement Rewards & Recognition - July'21

1 Process Kaizen

STARCATCHER - Increased Russian coal consumption by adding the chemicals during vessel unloading

- Harshal Joshi, Nilesh Shinde, Sandeep Malgave, Vithal Sagvekar (Associate)

3 Safety Kaizen

DAZZLERS - Enhancing Safety while operating 6.6 kV UIP Tie Feeders

- Vineeth Pilot, Satish Bisure, Siddhesh Chavan, Zahur Mazgaonkar, Farah Divekar

5 Visual SOP

VSOP for control room Fire

- Juned Guhagarkar

2 Process Kaizen

CIVIL WARRIORS - Enhancement in time saving by using 1.4m MS pipe for road crossing at silo project

- Hanmant Patil, Gaurav Dali, Sachin Surve, Shailendra Patil, Shivraj Navgire (Associate)

4 One Point Lesson

BETTER EVERYDAY- Display of coal feeder air canon operating steps for operators

- Ankur Das

6 Poka Yoke

CHAMPIONS- Providing Generator overload current alarm values in DCS

- Hem Prakash Rawat, Naresh Verma, Manoj Verma, S K Vishal, Vaibhav

.WINNERS Congratulations!

All these monthly celebrations are conducted virtually

10. Employee Involvement & Areas of Concern

Energy Efficiency Training & Awareness Programs

FY 2020-21

Program	No. of participants	Duration (Mandays)
Internal	140	140
External	66	99

Regular knowledge sharing sessions within & between the departments

Projects implemented through KAIZEN

Level	Raised	Implemented	Under Progress
Supervisor	148	140	08
Workmen	102	90	12

Major areas of concern

Sr. No	Description
1	Variation in quality of coal in different lots of same shipment (marine vessel)
2	Variety of imported coal based on the price & availability as the plant is designed for 100% imported coal
3	Controlling cost of generation to be competitive in market as the plant is 100% imported coal based
4	Lower utilization factor of plant due frequent back downs, unavailability of load schedule in open market & lower demand from captive customers
5	Spontaneous combustion of coal due to higher volatile matter

10. Employee Involvement & Monitoring

Employee Involvement



- **Energy Conservation Week** is celebrated every year in the form of various competitions and activities with involvement of company employees, associate employees.
- Active participation & involvement of Students from near by schools and employee families at townships

Monitoring Systems

Daily Aax Consumption Analysis in MW per hour													
Description	UOM	Unit 1				Unit 2				Unit 3			
		16/08/19	15/08/19	14/08/19	13/08/19	16/08/19	15/08/19	14/08/19	13/08/19	16/08/19	15/08/19	14/08/19	
LOAD	MW	247.87	271.21	274.12	214.58	213.33	231.75	224.02	216.9	235.7	230.62	217.7	233.5


JSW ENERGY LIMITED, RATNAGIRI													
GENERATION REPORT FOR 30-Aug-2019													
S.No	DESCRIPTION	UNIT	UNIT # 1	UNIT # 2	UNIT # 3	UNIT # 4	STATION						
1	Generation	DAY	MU	8.75	4.28	4.18	0.91	16.12					
		MONTH	MU	191.21	166.21	162.81	114.72	634.95					
		FY	MU	986.12	848.48	847.69	774.50	3456.78					
2	PLF	Generation Target For The Month	TARGET	MU	187.15	145.08	145.08	145.08	622.39				
		Achieved	%	102.17	114.57	112.22	79.07	102.02					
		DAY	%	93.78	59.42	58.06	12.69	55.99					
3	Deemed PLF	DAY	%	88.52	76.95	75.38	53.11	73.49					
		F.YEAR	%	90.11	77.53	77.46	70.77	78.97					
		DAY	%	104.09	59.42	58.06	63.62	71.10					

Daily APC report with equipment wise break up & comparison

Daily heat rate report with break up of THR & Boiler Efficiency

Daily Generation Report reviewed by all HODs, meeting chaired by HOP

Monthly review is conducted by 10th of every month where plant performance is reviewed under various areas viz. **S**afety, **P**roductivity, **Q**uality, **C**ost, **M**orale & **E**nviron.



10. Monitoring

UNIT-3 - DBEXform Player 4.3.8

GENERATION	Blk No. 86	Rev No. 77	Elapsed 06:56	Rem 08:04
GT3 260.11	SCH 268.75	ACT 271.24	DIFF 2.49	Date 28/02/2018
Other Unit EXP	Freq. 49.94	UI RATE 201.5	CUM(UI) 0	Time 21:21:56
GT1 -0	Pre Blk 49.88	Cur. Blk 49.94	Instant 49.93	
GT2 4.78	Blk No. 87	Blk Time 21:30-21:45	DC 290	SG 268.75
GT4 256.87	Blk No. 88	Blk Time 21:45-22:00	DC 290	SG 268.75
Target Exp 100%	266.61			
Day Mu 5.05	UI Rate 248	201.5	217	
Day UI MW 0	Ex-Bus 277.57	271.24	260.11	
Day UI(Rs.) 0	UI(MW) -1.18	2.49	-8.61	
	UI(Rs.) -1379.67	5.01735	-18.6837	
GT(3+4)	Pre Blk 544.56	Schedule 527.26	Cur Blk 531.05	DIFF 3.79
GT(2+3+4)	544.78	527.26	531.17	3.91
GT(1+2+3+4)	544.78	527.26	531.17	3.91
	Instant 516.98	523.9	523.9	
	Target Exp 100% 524	523.9	523.9	
	SG 100%	Ramp Up 0	Ramp Down 0.58	
	REPORTER	DC ENTRY	GRAPH	


ABT : To maintain load schedule

Real Time Monitoring System

4 X 300 MW JSW ENERGY LIMITED, RATNAGIRI

GRID FREQUENCY 50.03 Hz 09-Jun-2019 01:43:43 PM

Parameter	UNIT-1	UNIT-2	UNIT-3	UNIT-4
GROSS GENERATION, MW	225.55	246.13	220.01	205.46
NET GENERATION, MW	200.86	220.12	203.54	189.15
COAL FLOW, T/Hr	86.93	95.10	81.54	77.18
UNIT HEAT RATE, KCal/Kg	2304.55	2280.58	2291.20	2260.57
TG HEAT RATE, KCal/Kg	2066.10	1993.59	2010.47	2085.59
BOILER EFFICIENCY, %	88.83	87.13	88.27	89.82
Power Export, MW	201.24		613.15	



OSI PI : Real time plant performance monitoring system

UNIT OVERVIEW

29-03-2018 10:24:52

	UNIT 1		UNIT 2		UNIT 3		UNIT 4	
	A	B	A	B	A	B	A	B
BFP A/B	0.6	0	629.05	-0.05	4220.2	4183.05	4070.9	4013.9
DFP A/B	0.28	0	34.82	634.8	1181.44	1109.18	928.94	867.24
ESPT A/B	0	0	-0.01	3.84	411.29	488.25	420.11	455.6
UR1 A/B	64.29	0	0.03	0.33	56.38	61.01	128.52	119.61
UR2 A/B	134.67	0	134.67	215.45	488.64	389.5	268.73	340.82
UR3 A/B	0.02	0	763.62	0.12	611.12	-0.08	0.05	602.6
DFP A/B	0.01	0	74.28	0.05	252.26	280.6	266.03	257.43
DFP A/B	0.15	0	0.09	0.02	1869.06	1909.38	1840.9	1858.26
FGD	14.3	-	23.86	-	25.78	-	23.15	-
DFP A/B	0.03	0	0.24	0.85	1025.52	1306.11	987.43	1168.48
COALMILL A/B	0.03	0	0.05	0.03	258.76	251.04	277.73	241.51
COALMILL B/E	0.09	0	0.02	0	362.86	285.95	273.89	268.55
COALMILL C/F	0.01	0	0.01	0.01	296.54	0	277.72	0.03
TIE FEEDER	268.1	0	173.3	-118.5	0.5	1.5	1.7	5
UMP TIE FEEDER	-326.1	0	-1829.3	-	358.4	4074.5	1833.2	2182.3
INCUMER	0	0	0	0	11222.7	14186	11211.9	12547.7
NET BUS AUX	82	0	1658.5	118.5	10863.7	10110	9997	10277.4
STN UNIT LOAD	-0.32		211.33		431.26		447.67	
STN CMN LOAD	0		0		841488.77		841533.85	
UNIT AUX	81.68	0 %	1986.33	0 %	862863.73	293.76 %	862156.02	293.4 %
GEN GROSS MW	0		0		293.79		293.81	

STATION SWITCHGEAR

29-03-2018 10:27:37

C2A		C2A		C1B		C2B	
INCOMER	0	INCOMER	0	INCOMER	0	INCOMER	0
CCW-3C	213.18	CCW-3A	0	CCW-2A	0	CCW-4A	0
CCW-1B	0.99	CCW-3B	217.18	CCW-2B	0	CCW-4B	214.29
CCW-1A	0	CCW-1C	0	CCW-4C	232.82	CCW-2C	210.94
AIR COMP-2	342.67	AIR COMP-3	0	AIR COMP-5	63.73	AIR COMP-6	0
AIR COMP-1	339.58	AIR COMP-4	0	BFP-2C	0	BFP-4C	0
BFP-1C	0	BFP-3C	0	SS1-1B	92.66	SS1-2B	217.83
SS1-1A	93.88	SS1-2A	394.79	AHS/CMP-2A	389.87	AHS/CMP-2B	346.06
AHS/CMP-1A	225.02	AHS/CMP-1B	344.65	SWITCHYARD-1	28.7	SWITCHYARD-2	78.62
DM PLANT-1	-40.72	DM PLANT-2	33.17	SS-1	1677.721	SS-4	124.4
JSW TOWNSHIP-1	0	JSW TOWNSHIP-2	269.06	TIE TO C2D	-788.2	TIE TO C1B	1000.5
SWIPH-1	11.05	SWIPH-2	1718.15	TIE TO LMB		TIE TO LMB	1931.4
CWP-12C	0	INDSD PUMP-2	0	NET BUS AUX	788.2	NET BUS AUX	900.9
TIE TO C2A	2950.8	CWP-3C	0	STN UNIT-2 LOAD	210.94	STN UNIT-4 LOAD	447.11
TIE TO USB	-4218.4	TIE TO C1A	0	STN CMN LOAD	1678295.96	STN CMN LOAD	797.1
NET BUS AUX	1257.6	NET BUS AUX	0				
STN UNIT-1 LOAD	0.99	STN UNIT-3 LOAD	430.36	TOTAL STN CMN LOAD	1682674.6		
STN CMN LOAD	1051.72	STN CMN LOAD	2729.82	UNIT COMMON LOAD	420718.65		

EMS : Real time online monitoring of auxiliary power consumption of individual equipment

Other monitoring systems include :

- Daily Management Board
- Evening O&M Meeting
- Monthly Report
- Quarterly Report
- Monthly EC Meeting (Chaired by JMD of JSW Energy)
- Unit performance test on regular interval
- Monthly review of equipment & unit tripping and its RCFA & recommendation status
- ❖ All performance related reports & documents are kept in common folder with access to all the employees

11. Implementation of ISO 50001



Received ISO 50001 certification from July 2015

Upgraded to ISO 50001 : 2018



ISO 9001 (Quality)



ISO 14001 (Environment)




ISO 45001 (OH & S)

Chemistry lab is NABL accredited

12. Learning from CII Energy Award

Installation of sky lights (Solar Lighting)

Status – Implemented



De-staging of Boiler Feed Pump for reduction in power consumption

Status – Under Implementation

Application of 'HeatX' coating to heat exchanger tubes

Status – Under Implementation

13. Awards & Accolades



Energy Efficient Unit by CII (2020, 2019)

MEDA awards for Excellence in Energy Conservation and Management (2020, 2019, 2017)

The best operating thermal power plant by IPPAI (2020, 2019)

National Energy Management Award by SEEM (2020) – Gold Category

Excellent Energy Efficient Unit by CII (2018)

Successfully cleared *diagnosis* exam for challenging Deming's Prize in TQM

You did it!
Congratulations

IT'S NOT ENOUGH TO DO YOUR BEST; YOU MUST KNOW WHAT TO DO, AND THEN DO YOUR BEST.
-- W Edwards Deming

JSW ENERGY LTD. CLEARS THE TQM DIAGNOSIS AND TAKES THE FIRST MAJOR STEP TOWARDS CLINCHING THE PRESTIGIOUS DEMING PRIZE

QUALITY RUNS IN OUR DNA.

- Prashant Jain
JMD & CEO

www.jsw.in




THANK YOU

Mr Dipak Patil (AGM & Head-OSTS)



Dipak.patil@jsw.in



9552577031