


ADITYA BIRLA




GRASIM

Welcome to CII
22nd National Award for Excellence in
Energy Management 2021

Participants

- ***Mr Ramesh Rao (AGM-Operation)***
- ***Mr Ummed Verma (Deputy Manager)***




Integrated Operations for Cost Effectiveness

Product	Capacity	Uses
VFY	60.75 TPD	Textile Apparel , Satin, Sarees
Sodium Sulphate	35 TPD	Dye, Organic Chemical
Sulfuric Acid (H ₂ SO ₄)	100 TPD	Captive for VFY
Carbon di Sulphide	27 TPD	Captive for VFY
Captive Power Plant	38 MW	Captive (VFY + Caustic)
Caustic	250 TPD	In process, Dye, Detergent Chemical

Other than Pulp and Zinc, key Raw Materials are produced in house

Process Flow Diagram




Energy Consumption Overview


Parameter	UOM	FY 2020-21
Annual Power generation	MW	25.85
PLF	%	79.96
Availability	%	97.69
Gross Heat Rate	Kcal/KWh	3152
Auxiliary Power	%	10.43
Boiler Efficiency	%	83.44
Turbine Heat Rate	Kcal/KWh	2630
DM Water Consumption	%	3.81
Raw Water Consumption	%	1.88
Specific Oil Consumption	L/MWH	0.018

Key Performance Indicators


Auxiliary Power (%)




Plant Availability Factor (%)




PLF (%)




Turbine and Station heat Rate (Kcal/Kwh)



Aux Power % in Diff Unit




Gross Heat Rate



Auxiliary Power Roadmap

Aux power Consumption



- ESP-3/3 TR set & retrofitting from 2 Phase to 3 Phase
- LED light fixing work
- Applying corrocoat in MCT Pumps
- MCT fan motor replaced with higher energy efficient motors

- Replacement of 2x100 % HT motors run fans with 2x50% Fans with VFD run LT motors in Boiler no#3
- Installation of VSFC in Boiler Feed pump
- Reduction in SA header pressure of Boiler no#3
- Energy IE-3 Motor Installation in main cooling water pump

- Installed & commissioned energy efficient auxiliary cooling water pump in unit-2
- Stoppage of one instrument compressor by optimizing the air vent of dryer & air blaster operation
- Incorporated start-stop logic in ACT fan on cooling water temperature of unit-2

- Installation of New efficient TG-3 in place of old TG 1. Aux power reduction would have been better but due to low PLF its appearing slightly lesser
- Overhauling of HFTG & Improved specific steam consumption from 11.4 Kg/KWH to 10.8 Kg/Kwh after overhauling
- Stoppage of Ash handling compressor for 4 hrs /shift in accordance to low ash

- Installation of new 110 TPH CFBC Boiler and stop old inefficient 2X50 TPH CFBC Boilers & 1x25 TPH stoker fired boiler
- Installation of VFD in main cooling water pumps for 18 MW TG –Condenser
- Installation of energy efficient single auxiliary cooling water pump instead of two pumps


Energy Savings Projects (2021-22)

SN	Energy Saving Projects	Saving Achieved			Investment (Rs. Million)	Pay back Month
		Electrical Energy (KWH)	Thermal Energy (Million Kcal/Year)	(Rs. Million)		
1	Installation of new 110 TPH CFBC Boiler and stop old inefficient 2X50 TPH CFBC Boilers & 1x25 TPH stoker fired boiler.	0	23928	274	700	30
2	Installation of VFD in main cooling water pumps for 18 MW TG -Condenser	126000	0	0.69	0.6	10
3	Installation of energy efficient single auxiliary cooling water pump instead of two pumps	33000	0	1.81	4.2	28
4	Recovery of condensate water from VFY plant & utilize its energy to save steam & DM water in deaerator	0	1200	25.94	0.5	0

Energy Savings Projects Implemented

Year	No of Energy Saving Project	Investment (INR Million)	Electrical Energy (Million Kwh)	Thermal Energy (Million Kcal/Year)	Saving (INR Million)
FY 2018-19	4	16.15	4.07	0	22.39
FY 2019-20	7	15.9	1.12	38003	23.12
FY 2020-21	12	196.6	2.75	111204	188.28

Electrical And Thermal Energy Savings




Trigger for implementing the project:

- During ESP conveying system monitoring on routine basis , we observed that the ESP hoppers are mostly empty & conveying system are operating in idle.

Modification Adoption:

- Since our unit is operated on imported coal with low ash % & the total ash generation throughout the day is low. To utilize this opportunity, We have analyzed and found that idle time was more than 50% in all the conveying system.
- We started intermittent stoppage of compressor with safe ESP hopper level . To ensure safeguard of our system, we installed draft transmitters in ESP hopper for Real-time monitoring of hopper level drafts. further installed pressure transmitter to indicated vessel back pressure, so that conveying system healthiness can be monitored on real-time basis.
- Provided separate arrangement for service air requirement other than pneumatic conveying



System ON Command

**Conveying Air valve opens
60 Sec**

**Dome valve Opening 10
Sec**

Conveying Air valve Closed

Dome valve closing

Gap time timer starts 80 Sec

Innovative Projects Implemented

Idea Sharing:

We shared this idea in our synergy meeting and now it is being replicated in our sister companies at their Rehla and Renukoot Units

Saving:

We successfully achieved stopping service air compressor for 10 hrs in a day


Electrical Energy Saving = 452 KWH/Day

Cost Saving = Rs. 8.5 Lakhs/Annum

Electrical energy saving at Renukoot unit = 227 Units/Day


Electrical energy saving at Rehla unit = 309 Units/Day

Auxiliary Power Consumption in compressors (Kwh/Day)



Usage of renewable energy for lighting at TPP HSD Area:

- *Installed Solar Power Generation : 50 KiloWatts*
- *Solar energy : 0.03 % of total power share*




Solar Unit Generation (kwh)




Use of Waste as Fuel (Biomass)

Usage of Biomass:

- *Explored biomass usage & started using it as fuel*




Fly Ash generation & Utilisation



100 % fly ash utilization in cement manufacturing & is sent to our unit UltraTech Cement/Ambuja Cement

Method of Ash Unloading: 100% Dry ash unloading through Telescopes spout




Green Belt Development (Plant & Colony)





No of tree planted




TONS OF GHG EMISSION



TONS/MWH OF GHG EMISSION




- 01 Stopped feeding high Sulphur content coal (lignite coal) to reduce Sox emission
- 02 Installed Wheel washing system to reduce dust emission in road side area



- 03 Using limestone to control Sox Emission
- 04 Using battery operated vehicle for movement in factory premises



Water consumption



- Replacement of valves
- Orifice provision in Dearator
- Recovery of soot blowing steam in dearator

- Installation of RO System at inlet to DM Plant and taking its reject water to Cooling Tower under wave
- Dain trap condensate recovery in deaerator through condensate recovery tank-15-20 m3/day

- SSY plant condensate recovery & utilization - 120 m3/day
- Drain trap condensate recovery in deaerator through condensate recovery tank-5 m3/day
- ETP RO recovering water usage in cooling tower as make-up -300 m3/day

Implementation of ISO 50001



Energy Management

DNV
MANAGEMENT SYSTEM CERTIFICATE

Certificate no: 1000257406-MSC-RVA-IND Initial certification date: 11 June 2015 Valid: 11 June 2021 - 10 June 2024

This is to certify that the management system of
Grasim Industries Limited, Unit - Indian Rayon
Junagadh - Veraval Road, Veraval, District: Gir Somnath - 362266, Gujarat, India

has been found to conform to the Energy Management System standard:
ISO 50001:2018

This certificate is valid for the following scope:
Manufacturing of viscose rayon filament yarn, sulphuric acid, carbon di sulphide anhydrous sodium sulphate, sodium sulphide, caustic soda lye, caustic flakes, hydrochloric acid, liquid chlorine, compressed hydrogen, sodium hypo and power generation for captive use

Placement date: 06 November 2024
For the location: DNV - Business Assurance, Zandweg 1, 3901 LB, Breda, The Netherlands

IAF
MANAGEMENT SYSTEMS CERTIFICATION

1864

Signature: _____
Title: _____

Link of all documents and files awarded in the Certification Agreement may be verified on Certificates website
ADDRESS: DNV GL, Business Assurance, V., Zandweg 1, 3901 LB, Breda, The Netherlands - TEL: +31 (0) 20 2020 200 - www.dnvgl.com

ADITYA BIRLA
GRASIM

Grasim Industries Limited,
(Unit: Indian Rayon)
Veraval, 362266

ENERGY & CARBON POLICY

We, Grasim Industries Limited, Unit Indian Rayon, Veraval recognize energy consumption and carbon emissions as the most important issues currently affecting the planet. We understand the risk of dependence solely on fossil fuels and associated carbon emissions related to our operations. We are committed to demonstrate excellence in Energy and Carbon Management Performance on continual basis.

To achieve this, we shall endeavor to:


- Maintain positive legal compliance to energy and carbon regulations and other requirements;
- Raise awareness to encourage efficient use of energy resources, with a focus on reducing its energy intensity and carbon footprint;
- Increase the use of renewable energy wherever possible;
- Promote research and development for cleaner and efficient technologies to support the adoption of low carbon solutions;
- Evaluate technically and financially feasible and cost-effective options to reduce potential carbon emissions during the construction and operation of new projects;
- Conserving the natural resources in Power generation and reducing significant energy usage of VFY and chlor-alkali processes;
- Continuous up-gradation of process with energy efficient and Eco-friendly technology to optimize the energy cost;
- Continually improve energy and carbon management within and across the supply and value chains by adopting internationally accepted and economically viable Management Systems and best practices;
- Engage internally and externally with its stakeholders and wider communities to understand and collaborate on actions promoting reduced energy intensity and low carbon approaches to benefit both the Business and associated communities;
- Actively communicate and disclose our approach and achievements to stakeholders and regularly seek feedback through stakeholder forums;
- Provide necessary resources and information to achieve objective and targets and support the purchase of energy efficient product or services; and
- Monitor measure and report energy usage and carbon emissions in compliance with internationally recognized protocols.

This policy shall be reviewed periodically for its suitability and updated as necessary.

Date: 01.12.2020

Signature: _____
Shashank Pareek
Unit Head

10.2 % investment in energy Saving projects



Best Practices – Daily Monitoring

Continuous monitoring of losses due to various performance parameters


Description	Gain/Loss	Impact B1&2	Impact B3	B-1		B-2		B-3	
				Actual/Target	Impact	Actual/Target	Impact	Actual/Target	Impact
20°C Increase in Comb Air Temp	Efficiency Increase by 1%	35	80	221.10 210.00	19.36	221.81 210.00	0.03	190.08 200.00	40.06
6°C Increase in ECO Inlet Temp	Efficiency Increase by 1%	35	80	190.82 194.00	18.40	188.41 194.00	32.47	185.23 204.00	246.96
21°C Decrease FG APH OL Temp	Efficiency Increase by 1%	35	80	157.41 150.00	12.30	157.41 150.00	17.61	143.20 150.00	25.92

Description	Gain/Loss	Impact TG1 & TG2	TG-1		TG-2	
			Actual/Target	Impact	Actual/Target	Impact
0.01 Vacuum in Turbine	13.29 kcal/kwh	20	-0.00 -0.89	1772.57	-0.90 -0.89	24.41
5°C Decrease in Main Steam Temp	13.29 kcal/kwh Loss in Heat Rate	28	412.73 494.00	477.52	499.65 494.00	9.24


Total Impact	2538.99
--------------	---------

Daily online monitoring of auxiliary power by using cockpit


Unit-1 : Boiler Losses Fault Tree 10/27/2020 4:07



Project implementation through Kaizen



1st Prize in Annual Kaizen Competition Kaizen Award



Kaizen Submission

NATIONAL ENERGY CONSERVATION DAY CELEBRATION 14TH DEC'2020




Energy Oath



Employees Using bicycle

- Well Established energy management cell headed by FH-PP
- Daily monitoring of Heat rate and Aux. power deviation report.
- Analysis of equipment performance for deviation.
- Identification of energy conservation scope.
- Theme base suggestions/Kaizens scheme under “Energy Saving ”.”Bachat scheme”
- Feasibility study of suggestions & submit proposal for sanction.
- Preparation of detail action plan.
- Benefits analysis after project implementation.




1. All meetings start with safety contact ,followed by Energy contact
2. Energy saving Thumb Rules display across the plant
3. Idea portal- Z idea
4. Ad-hoc budget of 50 Lakhs for Energy Saving
5. Teams like Bachat, PMG, Sustainers & Sanchayan
6. On the spot award & Shabbash card distribution
7. Installation of wireless trans receiver call bell with 200 mtr range at weighing station
8. Installation of remote vibration monitoring sensors in cooling water pumps for online condition monitoring
9. Installation of anemometer with alarm for generating alert during high winds for safe work practice
10. Installation of in house constructed stone removal wheel for online removal of stones, plastics from the belt conveyor without manual interruption.

Grasim Industries Limited
Unit - Indian Rayon, Veravalur - 362 266

THUMB RULE FOR ENERGY SAVING

SR. NO.	DESCRIPTION	GAIN/LOSS	IMPACT PROBLEM-1.2 IN LACS/ANNUM	IMPACT PROBLEM-1.2 IN LACS/ANNUM
1.	20° C Increase in combustion air temp	Efficiency increase by 1%	35	80
2.	6° C Increase in Economizer inlet tem	Efficiency increase by 1%	35	80
3.	1 % Reduction in excess air	Efficiency increase by 1%	35	80
4.	10 Kcal saving in TG1 heat rate	15 lac/annum		15
5.	10 Kcal saving in TG2 heat rate	18 lac/annum		18
6.	0.01 Vacuum increase in Turbine	13.29 kcal/kwh		20
7.	LP Steam Increase by 1 Ton	20 kcal / kwh saving in heat rate		30
8.	5°C Decreases in Main Steam temp. then design temperature	18.57 kcal / kwh Loss in heat rate		28
9.	Leakage from 1/2" dia hole from air line	8.5 lac/annum		8.5



Energy Conservation awareness & world Environment Day



Energy Conservation & Carbon Emission Campaign in Industry

World Environment Day Celebration



Indian Rayon CPP won Energy Efficient unit at 20th National Award for Excellence in Energy Management 2019: at Hyderabad on dated 18.09.2019

Indian Rayon Team Awarded gold at ICQCC'19 held at Tokyo Japan on dated 23.09.2019



Learnings from CII energy awards


Installation of online cleaning system in condenser:

We have installed online ball cleaning system in condenser-2. We took trial with different ball sizes. But system has failed due to stuck-up of balls at corner points

Reviving the Boiler water treatment to improve quality & reduce cost.


Refurbishing existing flange joint valves by weld end valves to prevent frequent breakdowns

Installation of venti light pipe in new TG building



Way forward

- 01** Installation of new 110 TPH CFBC Boiler and stop old inefficient 2X50 TPH CFBC Boilers & 1x25 TPH stoker fired boiler.
- 02** Installation of water cooled BAC and utilizing its heat for heating DM water through PHE
- 03** Installation additional ESP field in Boiler-3 to sustains emission norms even with one field out of service
- 04** Installation of SOx reduction system with flue gas heat recovery system and heating DM water



Sincere Thanks..

Madhukar Dutt Sharma

Email:- madhukar.sharma@adityabirla.com

Mo:- +91-9904291444

Grasim industries Limited

Unit: Indian Rayon

Power Plant

T H A N K Y O U