

G M R K A M A L A N A G A E N E R G Y L T D

22nd National Award For Excellence in Energy Management

FY-2020-21

A journey towards improved energy performance with approach of sustenance and innovation

Presenting by :

1. Puspahash Mohanty (Manager OS&E)
2. Ashish Jena (AGM - OS&E)
3. Manoj Mishra (O&M head)



CONTENTS

1. GMR at a glance
2. Energy management policy and certificates.
3. Energy consumption overview.
4. Specific energy consumption last 3 years
5. Benchmarking of KPI
6. Energy conservation projects in last 3 years
7. Innovative project in FY 21
8. Renewable energy project
9. Environment management .
10. Green supply chain management
11. Best practices –Non energy efficiency
12. Energy management System
13. Budget allocation.
14. Award and accolades.
15. Learning from CII

VALUES & BELIEFS



Mahatma Gandhi

Humility
We value intellectual modesty and dislike false pride and arrogance

Sardar Vallabhbhai Patel

Deliver the Promise

We value a deep sense of responsibility and self-discipline, to meet and surpass on commitments made



Swami Vivekananda

Learning & Inner Excellence

We cherish the life long commitment to deepen our self awareness, explore, experiment and improve our potential

TenAzing & Hillary

Teamwork & Relationships

Going beyond the individual-encouraging boundary less behaviour



Mother Teresa

Social Responsibility

Anticipating and meeting relevant and emerging needs of society

Dr. APJ Abdul Kalam

Respect for Individual

We will treat others with dignity, sensitivity and honour



JRD Tata

Entrepreneurship

We seek opportunities – they are everywhere

1. GMR AT A GLANCE



AIR PORT




ENERGY



HIGHWAY



URBAN INFRA



GMR Kamalanga Energy Limited is a wholly owned subsidiary of GMR Energy LTD and is a step down subsidiary of GMR Infrastructures LTD.

Products/Businesses of organization : Electricity Generation

Capacity : 1050 MW - (3x350 MW)

Operational since: April 2013.

FSA

GKEL is having FSA with MCL

- FSA LINKAGE - 2.14 Million MT
- SAKTI LINKAGE - 1.50 Million MT

WATER SOURCE – 24 Cusec - BRAMHANI RIVER




Plant Facility

- BOILER – HARBIN
- TURBINE – Donfang Turbine company
- GENERATOR - Donfang Electric company
- BFP - Turbine – Donfang Turbine company

PPA

- DISCOM BIHAR PPA - 260 MW – 25 Years
- DISCOM HARYANA PPA - 323 MW -25 years
- DISCOM GRIDCO PPA – 247 MW – 25 years
- BALANCE POWER -150 MW



2. ENERGY MANAGEMENT POLICY AND CERTIFICATES

Bureau Veritas Certification

GMR KAMALANGA ENERGY LIMITED

VILLAGE KAMALANGA, CITY-DHENKANAL - 750 121, ODISHA, INDIA.

Bureau Veritas Certification Holding SAS - UK Branch certifies that the Management System of the above organization has been audited and found to be in accordance with the requirements of the Management System standard detailed below.

Standard
ISO 50001:2018
Scope of certification

GENERATION OF ELECTRICITY IN COAL BASED THERMAL POWER PLANT OF 3X360 MW

Original cycle start date: 20 May 2020
Expiry date of previous cycle: Not Applicable
Recertification Audit date: 28 February 2020
Recertification cycle start date: 20 May 2020
Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 19 May 2023
Certificate No.: IND02.2496/ENU Version: 1 Revision date: 20 May 2020

Signed on behalf of BUREAU VERITAS - UK Branch
Ajithesh K. MANDAM
Head - CERTIFICATION, South Asia
Connectivity, Industry & Facilities Division

Bureau Veritas Certification

GMR KAMALANGA ENERGY LIMITED

VILLAGE KAMALANGA, DISTRICT DHENKANAL, STATE: ODISHA - 750 121, INDIA.

Bureau Veritas Certification Holding SAS - UK Branch certifies that the Management System of the above organization has been audited and found to be in accordance with the requirements of the Management System standards detailed below.

Standards
ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018
Scope of certification

GENERATION OF ELECTRICITY IN COAL BASED THERMAL POWER STATION OF 3 X 360 MW

Original cycle start date: 14 May 2020
Expiry date of previous cycle: Not Applicable
Certification Audit date: 15 February 2020
Certification cycle start date: 14 May 2020
Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 13 May 2023
Certificate No.: IND.20.3067/ENU Version: 1 Revision date: 14 May 2020

Signed on behalf of BUREAU VERITAS - UK Branch
Ajithesh K. MANDAM
Head - CERTIFICATION, South Asia
Connectivity, Industry & Facilities Division

National Accreditation Board for Testing and Calibration Laboratories
(A Constituent Board of Quality Council of India)

CERTIFICATE OF ACCREDITATION

GMR KAMALANGA ENERGY LIMITED CHEMICAL LABORATORY

has been assessed and accredited in accordance with the standard
ISO/IEC 17025:2017
"General Requirements for the Competence of Testing & Calibration Laboratories"

for its facilities at
P.O. KAMALANGA, P.S. BHUSHAN, DHENKANAL, ODISHA, INDIA

In the field of
TESTING

Certificate Number: TC-5366
Issue Date: 28/05/2019 Valid Until: 28/05/2021

This certificate remains valid for the Scope of Accreditation as specified in the annexure subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.
(To see the scope of accreditation of this laboratory, you may also visit NABL website www.nablindia.org)

Signed for and on behalf of NABL
N. Venkateswara
Chief Executive Officer

National Productivity Council
Certificate

This is to certify that **GMR Kamalanga Energy Ltd., Dhenkanal** is awarded 'उत्कृष्ट' (Utkrishi) Category under 5S Certification Scheme of National Productivity Council.

Group Head (TM & Training)

Certificate No.: NPC/HR/TM/SSCS/GMR/SP-01/2021
Issue date: 1st Feb 2021
Certificate Expiry date: 1st Feb 2022

GMR Kamalanga Energy Limited

Energy Management Policy
(ISO 50001:2018)

GMR Kamalanga Energy Limited is committed to establish, implement and maintain Energy Management system to build world class capabilities in every aspect of its business operations. To achieve this GKEL is committed to:

- Adopt energy efficient and clean technologies in process design, maintain and operate the plant so as to make it a more efficient power utility among similar & comparable capacity power plants.
- Minimize the losses and Continual improvement upon the energy performance.
- Comply with related standards, legal and other requirements which relate to energy use, consumption and efficiency.
- Ensure availability of information and necessary resources to achieve energy management objectives and targets.
- Establish effective frame work and communicate responsibilities, authorities and obligations in order to facilitate effective energy management.
- Carryout regular energy audits to identify areas for improvements and proactively exercise controls in purchase of energy efficient products and services for new or modified projects for improvement in energy performance.

Date: 1-Aug-19
Ramesh R Pai
COO & Plant Head
GMR Kamalanga Energy Limited

To Adopt Energy efficient and clean technology

To Minimize the losses

To Comply legal and other requirements

To allocate resource

To frame Roles and responsibility

To purchase energy efficient product and Regular Energy audit




3. ENERGY CONSUMPTION OVERVIEW FY 2020-21.

Annual Generation	: 7101.09 MU
PLF	: 77.6 %
Availability	: 85.16 %
Gross Heat Rate	: 2323 kcal/kwh
Auxiliary Power	: 6.68 %
UHR (UNIT 1/2/3)	: 2322/2319/2328 Kcal/kwh
BOILER EFFICIENCY	: 86.52/87.1/86.9 %
DM Water consumption	: 0.2%
Raw Water Consumption	: 2.23 M3/ MWh generation
Specific Oil Consumption	: 0.097 ml/ KWh generation









4. SPECIFIC ENERGY CONSUMPTION LAST 3 YEARS.

Financial year	Specific energy consumption			Improvement in specific consumption w.r.t base line		
	Electrical	Thermal		Electrical	Thermal	Oil
	Kwh/kwh gen	Heat rate (kcal/kwh)	Specific oil (ml/Kwh)	(%)	(%)	(%)
FY -17-18	0.07341	2332	0.220			
FY -18-19	0.06826	2331	0.240	7.015	0.043	-9.091
FY -19-20	0.07338	2312	0.160	0.041	0.858	27.273
FY -20-21	0.0668	2323	0.097	9.004	0.386	55.909



5. BENCHMARKING OF KPI

5.1 Internal Benchmarking




NOTE: Heat rate is compared with corrected design heat rate with aging (as per OEM curve). Increase in heat rate is due to drop in HP and IP turbine efficiency and increase in APH O/L temp. which to be addressed in next overhauling cycle


5. BENCHMARKING OF KPI

5.2 External Benchmarking


NET HEAT RATE (kcal/kwh)



APC (%)




HEAT RATE (kcal/kwh)




SOC (ml/kwh)



DM water (%)



PLF (%)



GKEL is equipped with TDBFP so benchmarking done with Net heat rate.

5. BENCHMARKING OF KPI

5.3 Road Map to create benchmarking

FUTURE TARGET FOR APC:

- GKEL presently achieved 5.83 % APC at full load against 7.55% design & normative APC 6.25% .
- GKEL aims to achieve 5.75 % by 2022.

FUTURE TARGET FOR HEAT RATE:

- GKEL presently achieved 2315 kcal/kwh Heat rate at full load against 2227 design.
- GKEL aims to achieve 2305 Kcal/kwh by 2022 considering aging of machine.

- External and internal benchmarking
- Set Energy objective and target
- Identification of EC project
- Budget allocation EC projects
- Establishment of better monitoring system
- Action plan development

- Deviation analysis
- RCA for each deviation
- Monitoring CAPA through distal ATR
- Project effectiveness study
- Sustenance




5.4 WAY FORWARD PLAN FOR ENERGY CONSERVATION .

SL No.	Description of energy conservation measures	Investment (Lakh)	Verified Energy saving (Lakh)	Verified energy saving unit (L Kwh)	Fuel (TPH)
1	APH basket replacement (0.5% BE improvement)	25	225	0	11114
2	Installation of IFC	40	39.3	13.1	0
3	ESP hopper heater power consumption optimization.	0.5	24	08	0
4	VFD in Seal air fan	15	36.3	12.1	0
5	Migration from Conventional to LED	13	9	3	0
6	HIP overhauling (unit 1)	200	422	0	18336
Total		293.5	755.6	41.3	29450


6.ENERGY CONSERVATION PROJECT LAST 3 YEARS

Financial Year	No of energy conservation project	Investment (Million)	Electrical energy saving (MU)	Thermal energy saving (G kcal)	Financial saving. (Million)
FY 19	7	22.95	3.163	17.562	32.44
FY 20	10	10.26	12.81	29.060	64.54
FY 21	11	17.78	9.06	45.02	73.48


FY 19



FY 20



FY 21



7. INNOVATIVE PROJECT IN FY 21

Specific oil consumption reduction by reducing oil nozzle diameter.

- **Why innovative:** GKEL is equipped with mechanical atomized oil gun which is having low turn down ratio. In house design and modification of oil nozzle diameter done and effective use of lower capacity oil gun during start up results in achieving lower specific oil consumption.
- **Energy Savings achieved:** Reduced oil consumption 1.9 KL/gun to 1.2 KL/gun.
- **Financial saving achieved:** 1.55 Crore
- **Investment :** 2 Lacs
- **Replicability :** Yes (For mechanical high pressure atomized oil gun)

IDENTIFICATION OF OPPORTUNITY



- During idle period of rolling high oil flow is not required where oil consumption can be optimised
- During mill stabilization after synchronization oil consumption rate can be optimized after coal mill proven. High pressure oil gun turn down ratio is low which constraints for optimization. To maintain steam parameter steam dumping was being done which is a loss.

POSSIBLE SOLUTION

- Conversion of high pressure system low pressure air atomization.
- Procurement low flow oil gun.
- Diameter reduction of existing oil gun

IMPLEMENTATION

- Oil gun diameter reduced by 30% with in-house design and local workshop assistance.
- Oil gun diameter reduced from 5 mm to 3.5 mm.
- Oil gun trail taken during start up with observation of flame intensity ,frequency.



7. INNOVATIVE PROJECTS IN FY 21

Specific oil consumption reduction by reducing oil nozzle diameter.

EFFECTIVE USE OF OIL GUN

- During start up activity up to Rolling parameter High pressure oil gun is used.
- During rolling 2 oil gun is changed to low pressure oil gun.
- During mill stabilization all oil gun changed to low pressure oil gun.

PRECAUTION MEASURES TAKEN.

- In-house preparation of APH Oil carry over probe .
- Flame intensity and frequency monitoring
- Flame observation in local
- Oil trace monitoring in bottom ash water.

ADAPTIBILITY


- This solution can be implemented in high pressure mechanical atomized gun .Up-to 30% diameter reduction there is no abnormality process deviation.

RESULT ACHIEVED


This solution helped in creating internal benchmark in oil consumption and start up time.

- Cold start up oil consumption reduction 36%
- Warm start up oil consumption reduction 20%
- Hot start up oil consumption reduction 33%

Apart from oil saving use of lower capacity oil gun in 2nd elevation edge in maintain rate of rise of boiler temp parameter before rolling leads to reduction of start up time



START UP OIL CONSUMPTION IN KL DESIGN VS BEST



8. RENEWBLE ENERGY PROJECT .

SL no.	Projects implemented	Capacity	Type of energy	(Generation Million KWh)
01	Wind operated Turbo ventilator installed (188 nos.) on TG Building and hydrogen builing.	250 Kwh	Wind	1.44
02	Security hub power supply from solar panel.	129 watt	Solar	0.001




Turbo ventilators




Solar panel at security post

9.1 ENVIRONMENT MANGEMENT - ASH UTILIZATION


Ash generation/ Stock (Million Ton)




Ash utilization in %



Ash handling modes (%)



Areas of ash utilization in MT



Modes of Ash Conveying

- Dry Ash conveying System with storage Silos
- Bottom Ash slurry conveying system with hydrobin water decanted system make it semi dry condition
- HCSD systems and ash pond with Ash water recovery System

9.2 ENVIRONMENT MANGEMENT - ASH UTILIZATION



01

In house Bricks/blocks making unit – products is being sold to other and also used in-house for repairing & construction work of Township.



02




Supply to NH Authority for road construction project through trucks and bulk discharge through rakes



03

Supply to bricks/block and cement manufacturing unit by bulkers

9.3 ENVIRONMENT MANGEMENT – EMISSION



Best Practices for Emission control

- Low NOx Burner and Over fire damper operation.
- Periodic checking of SADC for combustion control.
- Improvement in Fineness of coal particle
- Periodic replacement of Bag filters to control PM.
- Oxygen optimization for NOx control.
- Periodic monitoring of stack parameters.
- Daily ESP field healthiness monitoring.
- Online CEMS/ CEQMS is installed and data transmission to SPCB and CPCB
- Daily review of emission by EHS team

FGD installation is process and it will be commissioned by JULY-2023 as per CPCB direction .

9.4 ENVIRONMENT MANGEMENT -WATER




WHEEL WASHING




DFDS



FOG CANNON



RAW water(m3/MWh)



DM WATER

Best Practices for reducing water load

- Replacement of drift eliminator .
- Water SCADA implementation .
- Rain water Harvesting by Rain water pump.
- Recuse of MFST blowdown
- Reduction of DM water.

Best Practices for waste water utilization

ETP and STP for treating the water and used in


- Makeup to bottom ash handling system.
- Make up to Fire fighting storage tank.
- Truck wheel washing spray system.
- Ash Conditioning during loading .
- Boiler seal trough charging.
- Floor and road cleaning.
- Coal yard sprinkling
- DS system in CHP.
- Horticulture.

9.5 ENVIRONMENT MANGEMENT – WASTE UTILIZATION

1. Organic waste is being converted to manure through Mech bio-digester and utilized in organic farming and horticulture



Solid waste management(MT)



10. GREEN SUPPLY CHAIN MANAGEMENT .



Started Bulk ash disposal by rake as 2nd plant in ER thus reducing truck transport emission.

- **82102 tons** transported
- 2737 truck eliminated
- 5.47 lakh km
- 182 kl Diesel consumption
- 488 TCO2 by truck
- 156 TCO2 by rail
- 332 TCO2 Net reduction



Spare part development and indigenization (SPDI) of 275 Nos of item.

Local vendor development reduces energy consumption in transportation




100% rake materialization reducing truck transport emission and energy consumption




E cart for goods transport inside plant which reduced 2.2 kl diesel consumption .

11. BEST PRACTICE –NON ENERGY EFFICIENCY




CFT – Turbine & Auxiliary
Feed water ,Condensate system ,Hydrogen system



MENTOR :
HARESH PATTNAIK / RAGHUNATH PV

LEADER :
BASUDEV SWAIN / JITENDRANATH SARKAR

MEMBERS :
KAUSHIK PRADHAN
ASUTOSH
ANSHUL DUBEY
SREEKANTH/CHENNA SANKETH
BIBHU
KHARAVELA ROUT



LUBRICATION PROGRAM DEVELOPMENT

Under LPD 25% Lube oil consumption reduced over last 2 years 55KL to 42KL. Lube oil no reduced to 25 from 28.

This initiative reduced the recourse depletion



RELIABILITY ENGINEERING

ABIRAL–A reliability improvement program initiated where 200 Nos of reliability issues identified under banner of ABIRAL. 20 no's of CFT formed to asses all processes.

1. Repeated failure analysis
2. Critical spare management
3. Identification of process bottleneck.
4. RCA trough Six sigma approach.



abiral
WORKSHOP NO # 3

Lube Oil Quality Improvement through
Lubrication Programme Development

Date : 10.12.2020 15:00 PM
Venue: Coral

USE OF DIGITAL PLATFORM

1. Compliance management, EHS management, Management Review & Sustainability reporting.
2. SARATI portal for internal audits .
3. Idea Factory for registration of individual idea
4. SIP digitalization for change management
5. ATR digitalization for tracking of CAPA.

11. BEST PRACTICE –NON ENERGY EFFICIENCY



AFFORESTATION


GKEL has fulfilled statutory requirement by effective plantation in 335 Acres

1. Plantation of 3.9 Lakh saplings
2. Mass plantation in plant premises
3. Seedlings distribution to community
4. Plantation in community.
5. 35 Acres landscape development
6. 2 Acres of organic farming

CSR

Web page and app developed named “krusaka bandhu” to facilitate farmers on.

1. Aggregation on information on various government schemes and links.
2. E-resources for farming like Govt. newsletters, notifications, E-books.



Our whole and sole motto behind developing this APP was to utilize basic modern digital technology for the welfare of Farmers in society, especially those who belongs to the deprived class towards this humongous development in field of digital world. We tried to link these people with digital platform in every sense that was possible for us to.



ASSET MANAGEMENT

1. SAP based maintenance
2. Preservation methodology
3. Min max process
4. Structure stability test.
5. Regulatory compliance
6. Waste management
7. Certification of ISO 55001 (Stage-1 in progress)


12. ENERGY MANGEMENT SYSTEM .

12.1 ENERGY MANGEMENT CELL

- **Energy review committee** : For overall review & support
- **Energy management Cell** : For Monitoring and developing
- **Zonal members** : For field level execution .
- **No of zones** : 6 zones better targeting and monitoring
- **Involvement -** : 31 Nos of employees associated.
- **Competency-** : 7 BEE Certified energy auditors
- **Review** : Energy review chaired by plant head
- **No of zones .** : 6 no's of zones for better focus

Objective of EMC to

- Monitoring of specific energy consumption area wise
- Deviation analysis of SEU and objective
- Preparation of action plan.
- Identification and cost benefit analysis of ENCON projects
- Awareness. And Training
- Ensure sustenance action plan.
- ISO 50001 standard requirement.



12. ENERGY MANGEMENT SYSTEM .

12.3 WORKMEN INVOLVEMENT THROUGH SGA .

1. Half yearly Boiler and turbine insulation temperature survey.
2. Furnace pressurization test for air in-leakage identification.
3. PA duct pressurization test for air in- leakage identification.
4. Monthly high energy Drain passing survey.
5. Instrument and service air leakage survey
6. Furnace velocity mapping.
7. Compressor FAD testing.
8. Illumination study.
9. Ventilation system audit.

Boiler Right Side									
Elevation	55	50	48	52	48	47	45	48	50
69 mt	55	50	48	52	48	47	45	48	50
62 mt	42	50	46	47	56	44	51	45	48
52 mt	59	65	43	52	46	45	52	65	50
48 mt	61	64	71	83	57	50	56	48	45
46 mt	61	59	61	63	58	63	52	48	69
42 mt	62	65	130	64	48	72	52	40	65
40 mt	90	60	61	41	69	55	72	60	65
38 mt	34	34	62	62	111	52	54	51	63
30 mt	63	67	53	75	61	82	83	130	60
24 mt	68	92	77	90					
22 mt	58	65	65	92					
20 mt	52	68	77	90					
18 mt	130	63	62	64					
15 mt	104	72	77	60					
12 mt	145	54	57	58					
9 mtr	60	80	75	70					

BOILER INSULATION SURVEY .

TURBINE DRAIN PASSING SURVEY			Date	05.08.2020
AUX HEADER DRAIN STATION (MIV)				
1	Aux header to condenser		6 MTR AUX HEADER DRAIN STATION	150
2	Aux header to condenser (steam trap)			150
3	Aux header to ATM.			70
4	Supply MOV drain to ATM			75
5	BFPT steam supply before drain to ATM			63
6	BFPT Steam supply drain (trap) to cond.			57
7	BFPT Steam supply drain to cond.			81
8	Common drain to Atm			53
8.1	Atomising safety valve drain		6 MTR Behind the aux header	43
8.2	Atomising line drain.			66
8.3	Interconnection MOV before drain.			78
8.4	Interconnection MOV before drain			
BFPT STEAM DRAIN STATION				
1	CRH after mov. (cond)(B)		6 MTR	180
2	CRH after mov. (cond) steam trap(B)			55
3	CRH after mov. (ATM)(B)			58
4	AST after NRV. (cond) (B)			80
5	AST after NRV. (cond) steam trap (B)			115
6	AST after NRV. (ATM) (B)			81
7	AST AFTER MOV drain (B)			54
8	AST header drain.			73
9	AST header after MOV (A)			55
10	CRH header drain.			60
11	AST after NRV. (ATM) (A)			61
12	AST after NRV. (cond) steam trap (A)			55
13	AST after NRV. (cond) (A)			67
14	CRH after mov. (ATM)(A)			31
15	CRH after mov. (cond) steam trap(A)			39
16	CRH after mov. (cond)(A)			117

HIGH ENERGY DRAIN PASSING SURVEY .


Unit-2 Velocity Mapping of Boiler 2nd Pass													
UPPER BANK LTSH													
Hanger No	LHS Wall to 1st coil gap	1	5	10	15	20	25	30	35	40	45	RHS Wall to 1st coil	Average
Row A bottom	3.7	3.2	3.3	3.5	3.4	3.4	3.2	3.5	3.5	2.6	3.0	3.1	3.3
Row B bend top	0.7	1.3	0.6	0.9	1.0	1.1	1.2	1.3	1.2	1.1	1.1	1.3	1.1
Row B bottom	2.7	2.4	2.3	2.3	2.5	2.5	2.6	2.2	2.3	2.3	2.2	2.5	2.4
Row C	2.5	1.4	1.8	1.5	1.6	2.8	2.8	2.7	4.0	4.0	3.4	3.4	2.6
Row D	2.6	2.4	2.3	2.5	2.7	2.5	2.7	2.7	2.6	2.4	2.3	2.5	2.5
MIDDLE BANK LTSH													
Hanger No	LHS Wall to 1st coil gap	1	5	10	15	20	25	30	35	40	45	RHS Wall to 1st coil	Average
Row A	3.6	1.6	2.3	2.0	2.1	2.0	2.1	2.2	1.8	1.9	1.6	3.8	2.2
Row B	3.1	1.5	1.8	2.0	2.0	1.9	1.9	2.2	2.2	2.3	1.8	4.0	2.2
Row C	3.5	1.8	2.3	1.9	2.4	2.4	2.3	2.4	2.4	2.6	1.8	2.7	2.4
													2.5

BOILER VELOCITY MAPPING .

13. BUDGET ALLOCATION .

SL No.	Expenditure towards ENCON projects (Lakh)	Financial year
1	229	FY-19
2	102	FY-20
3	177	FY -21

Budget allocation w.r.t turn over = 0.05%



14.AWARD AND ACCOLADES



2017-18

2018-19

2019-20



State Energy conservation award



State safety innovation award



Safety innovation award



People initiative award



State Energy conservation award



ICC Environment award -19



Kalinga safety award



Community initiative award



CII national Energy award



CII -ER ENCON Award



ICC Env excellence Award



Pollution control Award

15. LEARNING FROM CII

GKEL participated in CII National level award for energy management in FY-20 and awarded as excellent energy management unit Which turns to be great motivational factor for work force towards energy conservation. It helped the organization in following aspects

Adoption of best practices in energy conservation

Adoption of best practice in environment aspects

KPI benchmarking

Motivations towards energy efficiency

National level recognition.

Employee engagement towards energy conservation

GKEL listed and reviewed 120 Nos best practices from CII portal from various business and registered 6 projects for future implementation

G M R K A M A L A N A G A E N E R G Y L T D

THANK YOU

We have rights to use national resources but have no rights to waste it. Save energy save environment