

23rd National Award for Excellence in Energy Management 2022

ISC-1 Hyderabad

August 2022

© 2022 Cognizant

Contents

- 1. Company Profile
- 2. Energy Consumption Overview
- 3. Specific Energy Consumption in Last 3 Years (2019-2021)
- 4. Information on Internal, External, National & Global Benchmark
- 5. List of Major Energy Conservation Project Planned in 2021
- 6. Energy Savings Project Implemented in Last 3 Years
- 7. Innovative Project Implemented Details (2019-2021)
- 8. Waste Utilization & Management
- 9. GHG Inventorisation
- 10. Teamwork, Employee Involvement & Monitoring
- 11. Other Innovative Technologies Implemented
- 12. Awards & Certification



Cognizant Overview

Cognizant (Nasdaq-100: CTSH) is one of the world's leading professional services companies that engineers modern businesses. We help our clients modernize technology, reimagine processes and transform experiences so they can stay ahead in our fast-changing world. Together, we're improving everyday life.



194 Fortune 500 May 2022

550 Forbes World's Best Employers for Diversity April 2021



113 Fortune's World's Most Admired Companies Feb 2022 **567** Forbes Global 2000 May 2022

327 Forbes 2021 World's Best Employer list Oct 2021



Facility Overview

- Operations from 1st Apr 2006, Owned Facility
- Total Built Area : 2,25,108 SFT
- Phase 1- 3 Floors, Phase 2 8 Floors
- Seating Capacity: 2009
- Head Count: 1875 Associates & 200 Vendor Staff (in BAU Situation)
- Contract Demand is 1600 KVA and Incoming is 33 KV
- Transformer is 1600 KVA 2nos
- DG is 750 KVA 6nos
- Chiller 250TR 3nos and 375TR 1no
- UPS 300KVA 1no, 270KVA 1no and 120KVA 2nos
- STP 120KL Capacity





Energy Consumption Overview - 2019 to 2021

Year	TSPDCL Energy Consumption (kWh)	DG Energy Consumption (kWh)	Total Consumption (kWh)
2019	5113328	188172	5301500
2020	2996528	65472	3062000
2021	1915739	30161	1945900







Specific Energy Consumption Overview- 2019 to 2021







Specific Energy Consumption Overview- 2019 to 2021





Specific Energy Consumption Overview- 2019 to 2021

Comparison of SEC With Internal & National Benchmarks

BEE - N	ational Benchmark E	PI in kWh/Sq. N	M/Year
Star Rating	Warm and Humid	Composite	Hot and Dry
1 Star	200-175	190-165	180-155
2 Star	175-150	165-140	155-130
3 Star	150-125	140-115	130-105
4 Star	125-100	115-90	105-80
5 Star	Below 100	Below 90	Below 80

Internal Be	enchmark
Owned Campus	EPI/sqm/annum
CHN - Siruseri	32.3
CHN - Siruseri - SEZ	42.3
CHN - CKC	42.9

Encon Project Planned in FY 2022-23

No	Year	Title of Project	Annual Electrical Saving (Million kWh)	Savings (INR Million)	Investment (Rs in Million)	Payback (Months)
1	2022-2023	Variable primary pump (SKID pumps) for air cooled chillers	0.77	7.94	4.952	7
2	2022-2023	Chiller replacement with 125TR chiller	0.12	1.24	0.4932	5
3	2022-2023	Retrofit of VRF with existing 22HP VRF	0.508	5.24	0.723	2

Energy Saving Projects Implemented - 2019 - 2021

Year 2019	Year 2020	Year 2021
 No of initiatives - 1 Energy Saving - 2.25 L kWh Cost Savings - INR 23.1 Lakhs 	 No of initiatives - 2 Energy Saving - 7.31 L kWh Cost Savings - INR 75.3 Lakhs 	 No of initiatives - 3 Energy Saving - 0.81 L kWh Cost Savings – INR 8.35 Lakhs
 Investments – INR 27 Lakhs ROI – 10 Months 	 Investments – INR 68.8 Lakhs ROI – 13 Months 	 Investments – INR 10.85 Lakhs ROI – 9 Months

Energy Saving Projects Implemented - 2019 - 2021

Innovative Project : Chiller Retrofit

- 1. Conventional Air-cooled chillers at our facility are 14+ years old, facing frequent breakdown & cooling issues
- 2. These chillers are beyond economical repairs
- 3. Due to the technological obsolescence of these chillers, utility costs have also high
- 4. By considering all these challenges we have installed energy efficient 1X375TR Air-Cooled chiller (IUT)

Chiller Positioning at ISC1

Conventional Chiller	New Chiller	Specific Power
Specific Power Consumption 1.59 kW/TR	Specific Power Consumption 1.34 kW/TR	Specific Power Optimization 0.25 kW/TR (18 %)

Innovative Project : Blower Type AHU Motor Replaced with EC Fan 2/3

Existing AHU replaced with EC Fan based AHU

- 1. Conventional AHU in our facility are 14+ years old
- 2. Conventional AHU capacity 352 kW (19 Nos x 18.5 kW)
- 3. EC fan installed capacity 287 kW (82 Nos x 3.5 kW)
- 4. Total capacity optimization 65 kW(18 %)
- 5. EC fan standalone operation to reduce the energy based on return air temperature

- Summary of savings -Energy Savings – **1.65 L kWh**
- Cost Savings INR 16.5 Lakhs
- Investments INR 25
 Lakhs
- ROI 8 Years

Conventional AHU	EC Fan	Specific Power
Specific Power Consumption 1.03 Watts/CFM	Specific Power Consumption 0.62 Watts/CFM	Specific Power Optimization 40 %

Innovative Project : VRF Retrofit

Existing HVAC units replaced with VRF

- 1. All HVAC units in our facility are 14+ years old
- Existing HVAC units' capacity 77.24 kW (8 Nos x 8.6 kW)
- VRF installed capacity 49.55 kW (10 Nos x 4.955 kW)
- 4. Total capacity optimization 27.69 kW(35 %)

- Summary of Savings -Energy Savings – **0.711 L kWh**
- Cost Savings INR 10 Lakhs
- Investments INR 10.38
 Lakhs
- ROI 1 Year

Existing HVAC Units	VRF Unit	Specific Power
Specific Power Consumption 8.6 kWh	Specific Power Consumption 4.95 kWh	Specific Power Optimization 35%

3/3

Waste Management

SI. No	Type of Waste Generated	Disposal Method	Action Taken for Reduction of Waste
1	Hazardous Waste	Used and waste oil disposed to TSPCB authorized recycler	Battery waste – Extension of battery warranty (3 to 3.5 years)
2	Non-Hazardous Waste	Carton & paper waste disposed to authorized recycler Ms. ITC ltd & got 10 reams saved	Paper waste – 1) Limitation of printer access 2) E-fit tool implemented and manual Check list optimized 3) Paper cups usages eliminated 100%
3	E Waste	Disposed to TSPCB authorized recycler	E –Waste – CFL to LED (Lifetime enhancement)

GHG Emission and Indoor Air Quality

GHG Reduction Target & Action Plan

- 1. Energy Efficiency projects implementation
- 2. Cognizant will source 100% renewable energy by 2026
- 3. Absolute emissions reduction by 50% in 2030
- 4. Absolute emissions reduction by 90% in 2040

Indoor Air Quality (BAU)

Test parameters	Units	Result	Permissible limit	Remarks
Carbon Dioxide (Co2)	ppm	400	< 1000	1. Testing through NABL Laboratory
Total Fungal Count	Cfu/m3	0	500	2. Frequency of sampling is quarterly for
Total Bacterial Count	Cfu/m3	115	500	WORKSTATIONS

Standardization of Best Practices

Teamwork, Employee Involvement and Monitoring

10 initalianse en de la companya de	izveren 🗗 minati	b :	Q. 2.444	· 🎒 :
🚺 **5 🛛 #*#	ert (aar		🗘 tau 🕐	_
ford + grin-got			161aton	-
Ma P. B. C.	kolte anne 📲			7
- 9 m - 5 m	-}a fa	ee - Zeran		5
0.000		Y.A.	561	
Disarcante for 1		•	ð.	
	112	20	<i>a</i>	
N Annual State	atter	N	<i>a</i>	
	11-1	27	0	
	si••	80	a.	
Product 1		.4	e.	~
			1	0

FMS - Daily Energy Tracking

Energy Consumption Monitoring

CILULESCOMMAT 23 minutescommation 2.4 minutescommation 2.4 minutescommation
Aberton 200
Josefica Maria winell and 600000 600000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000 60000
Addition
Faill Game SDEK ADDE STATE Ke 3.61 3. 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62 62
Collection Collect
start - Perspe
the stronge Benefit Stronge

Chiller Monitoring

an an fair an ann an tar Calaigh an an an Ann an Calaigh an Ann an Ann an Ann an Ann ann an An qalaat Didoolog tõnda sõhi fy D No.41 Rentra Ritrigalegiera JANDARA IN CHILDRIP MANDES 17518 Dentis -120000 et autor Dev bint WEITERS. 0.000 COLUMN STATES LOOM DR. CHE IN A REPORT 1000 01017104 . A00.00102 4116111 OMPTER 4 DOM: NOT THE OWNER. 30,76 al-outries 🔽 STREPTOTE 1.5 CHLERE HARAS DOVID 10,027.0 100 OUT OF TRADE 3-11,785 SCLIP 64 . . 1.00 1724 NHO IN CASE ange ood too to to to ear an taking a sig 252 122

Chiller SEC Measurement

-55		tar i	bne:				lator P
al Gio ;	b;dd.e.a						
salta é	ытр. т	e kil Pa	a y bi	81 (23)	1		
Reve De suactive Birts - Jane 2005 (n. 1914)					Able By school		
904	1092	"31C0"	2007	80**	91.02	310"	h e o pe
n		54	#1	15	n	77	15/5 ² 27-0%
in a later set and the set of the							it perjor Vuni2: acete
				1			

FMS - Monthly Energy Tracking

Awards & Recognitions

Awards & Recognitions

CII 3 Star Excellence Award -2019 CII SR EHS Excellence 3 Star Rating - 2020

KANAN MENANDA

Certificate of Appreciation This is to certify that

Cognizant Technology Solutions India Pet Ltd (ISC -1 Financial District)

Byderichad, Telangana

has secured a

in Appreciation to EHS Practices in the CII-SR EHS Excellence Awards for the year 2020

Gothulonan, Alt-SR Edit Excellence doord 2020 A

Chief Mesupersystem (Miller, Dam Company 114

ter wen 12 St Inf Burdlaste hear di 7818 A

the Director Toyana Ridwiller Minter Post of

ENS

CII

CII-SR EHS Excellence Awards 2021_Gold Award

II-SR EHS Excellence Awards 202

10000

Way Forward

Three Way Approach

Energy Efficiency

 Reduce power consumption through optimization of capacity utilization and validating operational parameters
 Technological upgradation with higher efficiency asset replacement through retrofit projects

Green Energy

 Increase renewable energy portion from total energy requirement through green power procurement
 Install rooftop solar panels in owned campuses

IOT & Digital

1.Deploy data analytics & machine learning tool to improve energy efficiency of chiller plant

2. Collaborate with IFM service partners in implementing data analytical tools in energy efficiency

23rd National Award for Excellence in Energy Management 2022

ISC-1 Hyderabad

August 2022

© 2022 Cognizant