



# 23<sup>rd</sup> National Award for Excellence in Energy Management 2022

MBP F2 & F3 - Bengaluru

August 2022

# Contents


1. Facility Overview
2. Energy Consumption Overview
3. Specific Energy Consumption in Last 3 Years (2019-2021)
4. Information on Internal & National Benchmarks
5. Energy Saving Projects Implemented in Last 3 Years
6. Innovative Projects Implemented
7. Utilization of Renewable Energy Sources
8. Waste Management
9. GHG Emission and Indoor Air Quality
10. Teamwork, Employee Involvement and Monitoring
11. Standardization of Best Practices
12. Implementation of IGBC Certification
13. Kaizen by Plant Team
14. Awards & Certifications

# Cognizant Overview



Cognizant (Nasdaq-100: CTSI) is one of the world's leading professional services companies that engineers modern businesses. We help our clients modernize technology, reimagine processes and transform experiences so they can stay ahead in our fast-changing world. Together, we're improving everyday life.





# Facility Overview



# Energy Consumption Overview - 2019 to 2021




# Specific Energy Consumption in Last 3 Years - 2019 to 2021



**Inference** : Specific energy consumption reduction 3% in 2019,45% in 2020 & 32% in 2021

**Reason** : In 2020 & 2021 facility was in non BAU operations

# Major Initiatives - Causes for Reduction in Specific Energy



**2019**

- UPS room AHU supply air damper operation control – 0.31 L kWh / Annum
- Provision of pull chord switch & lighting sensor – 2.6 L kWh / Annum
- Configured auto open/close of 2-way AHU Valve –0.53 L kWh / Annum



**2020**

- Desktop power switching OFF activities – 0.59 L kWh / Annum
- Workstation light retrofit activities (T5 to LED at F3) – 4.9 L kWh / Annum
- Dedicated AC unit for dormitory – 0.15 L kWh / Annum

**2021**

- UPS consolidation activities: 3.78 L kWh/Annum
- Lighting sensor for restricted critical room and cafe - Phase-1- 7154 kWh/Annum
- Dedicated AC unit for dormitory-Phase-1-15188 kWh/Annum



# Month-wise Specific Energy (EPI) in kWh/Sq.ft and Consumption Trend






# Comparison of SEC With Internal & National Benchmarks

BEE - National Benchmark EPI in kWh/Sq. M/Year			
Star Rating	Warm and Humid	Composite	Hot and Dry
1 Star	200-175	190-165	180-155
2 Star	175-150	165-140	155-130
3 Star	150-125	140-115	130-105
4 Star	125-100	115-90	105-80
<b>5 Star</b>	<b>Below 100</b>	<b>Below 90</b>	<b>Below 80</b>



# Major Encon Project Planned in FY 2022-23



# Energy Saving Projects Implemented in Last 3 Years

## Year 2019

- Energy saving projects **7**
- Electrical savings in kWh **5.25 L**
- Cost savings **₹47.3 L**
  
- Investments **₹5.5 L**
- Return on investment: **2 month**



## Year 2020

- Energy saving projects **7**
- Electrical savings in kWh **24.4 L**
- Cost savings **₹225 L**
  
- Investments **₹91.7 L**
- Return on investment: **2 month**

## Year 2021


- Energy saving projects **6**
- Electrical savings in kWh **5 L**
- Cost savings **₹57.66 L**
  
- Investments **₹30 L**
- Return on investment: **6 month**

# Energy Savings Trend (2019 to 2021)



# Innovative Project : UPS Consolidation Activities





1/3



<p><b>Idea description</b></p>	<ul style="list-style-type: none"> <li>• Consolidation, capacity optimizations and Retrofit of UPS</li> <li>• UPS Consolidation - Estimate the required UPS capacity of existing UPS systems and identify opportunities to optimize the capacity in order to reduce energy consumption and cost..</li> </ul>
--------------------------------	--

<p><b>Option Considered</b></p>	<ul style="list-style-type: none"> <li>• UPS capacity optimization based on the load study and future addition loads, and subsequent commissioning/decommissioning.</li> <li>• Retrofit of UPS (Conventional to Modular) by using the decommissioned UPS</li> </ul>
---------------------------------	---

Benefit
<ul style="list-style-type: none"> <li>• UPS capacity optimized: 2980 KVA to 2280 KVA = 700 KVA</li> <li>• Energy saved : 5.10 L kWh/annum</li> <li>• Energy cost saved : ₹56.10 L/annum</li> <li>• Cost saved : ₹200 L (energy + operational + capex)</li> <li>• Batteries optimized: 1192 to 840 = 352 No's</li> <li>• Battery waste generation reduced every 3 years</li> </ul>

Environmental Benefit	
 <p>Carbon emission saved</p>	
 <p>Energy <b>402 ton</b></p>	<p>Equivalent trees planted</p>
 <p>Batteries <b>0.33 ton</b></p>	<p><b>5967</b></p>

# Innovative Project : Automation of AHU Supply Air Damper for Avoid 2/3 Energy Losses

## Background


Observed that three duct able AC units were not sufficient to cool UPS room during nonbusiness hours, weekends, and holidays

## Identification

There are N+N+1 AC supports, a common plenum for both an AHU and duct able AC unit, and the damper on the supply air duct of the AHU does not close after the DX AC unit is turned on, Due to this loss in the DX unit supply air and energy loss

## Option Considered

Post identification and brainstorming session, option explored as auto operation of the AHU side damper while AHU operation by using the AHU starter panel & DDC panel.



## Benefit

- Energy savings/annum : **3,1824 kWh**
- Investment : **Zero**
- Cost savings/annum : **31,8240 INR**

# Innovative Project : Chiller Secondary Pump Synchronization

3/3

## Background

The chiller pumps are not operating auto mode even though VFD are installed, leading to energy losses.


## Identification

A VFD panel does not have pressure inputs, and pumps are manually turned on and off by the operator


## Solution

Installing the DP sensor and connecting it to the VFD panel.

## Before



## After



## Annual Saving

Energy Savings: 3.84 L kWh

Cost Savings : 38.4 L

Investment : 3 L

ROI : 15 month

# Utilization of Renewable Energy Sources



Utilization of Renewable Energy Sources (kWh)				
	EB	DG	Solar	Solar Energy
<b>2019</b>	3203214	1833932	10707433	Utilization vs EB - 77%
<b>2020</b>	870807	347258	4576406	Utilization vs EB - 86%
<b>2021</b>	842772	172104	4846829	Utilization vs EB - 85%




# Waste Management

 **E- waste**

- CFL
- Tube
- Lamps
- IT Waste

 **Hazardous Waste**

- Waste Oil
- Battery waste

 **Non-Hazardous Waste**

- Paper
- Food
- Plastic
- Metal

## Disposal Method




- Segregating the waste
- Disposing to KSPCB authorized vendor

- Collected and stored in designated area
- Disposing to KSPCB authorized vendor

- Food waste is collected in the facility converted as manure by using OWC by builder
- Paper, plastic and metal waste is disposed to cognizant registered vendor

# GHG Inventorization & Indoor Air Quality



## GHG Reduction Target & Action Plan

100% green energy utilization 2026

Net zero green house gas emission by 2030

Energy efficient project implementation

Test parameters	Units	Result	Permissible limit	Remarks
Carbon Dioxide (Co2)	ppm	400	< 1000	1. Testing through NABL Laboratory 2. Frequency of sampling is quarterly for workstations
Total Fungal Count	Cfu/m3	0	500	
Total Bacterial Count	Cfu/m3	115	500	

# Standardization of Best Practices

## Air-conditioning

Workplace Temperature policy standardized:  
24 °C to 26 °C



Maintaining UPS/Battery room Temperature b/n  
25 °C to 26 °C



Hub room temperature-maintained b/n  
24 °C to 26 °C


## Personnel Computer

**1** Conventional CPU replacement with compact CPU

**2** Created awareness to Associates to Switch off the monitor when they leave from office

**3** PC to Laptop

## Kitchen/ Pantry



# Teamwork, Employee Involvement & Monitoring

1/2

### Monitoring system in BMS

- Hub Room Temperature
- AHU RA Temperature
- UPS Monitoring
- Fire Alarm System status
- Energy Meter
- Trend and Reports
- RAW Water Management
- Weather Broadcast

### UPS Monitoring in BMS

Cognizant

6F 275KVA UPS 1

UPS Parameters	UPS	UPS Parameters	UPS	Alarm Status	UPS
UPS_Battery_Power	2500W	UPS_Input_Volt_B-R	410V	Load on Battery	None
%_Load_B_Phase	48%	UPS_Input_Volt_R-Y	410V	tan power intexption	None
%_Load_R_Phase	54%	UPS_Input_Volt_Y-B	410V	Load on bypass	None
%_Load_Y_Phase	72%	UPS_KVA_B	600KVA	UPS output Overload	None
PF_Output_B_Phase	0.95	UPS_KVA_R	600KVA	UPS load drop	None
PF_Output_R_Phase	0.95	UPS_KVA_Y	600KVA	Battery failure	None
PF_Output_Y_Phase	0.95	UPS_Total_Load_KVA	600KVA	Battery Temp/leak	None
UPS_Battery_Capacity	101.0%	UPS_Load_B	44.0%	Battery charge failed	None
UPS_Battery_Current_positive	0.0A	UPS_Load_R	14.0%		
UPS_Battery_Current_negative	0.0A	UPS_Load_Y	12.0%		
UPS_Battery_regiue_V	100.0	Output_Current_B_Phase	170Amp		
UPS_Battery_positive_V	280.0	Output_Current_R_Phase	50Amp		
UPS_Energy_Meter	60000	Output_Current_Y_Phase	30Amp		
UPS_Input_Frequency	50.0Hz	Output_Volt_B	231V		
UPS_Output_Frequency	49.9Hz	Output_Volt_R	231V		
UPS_Total_Output_Load	50%	Output_Volt_Y	231V		



### Periodic Equipment Service

6F 275KVA UPS 1

Handwritten notes: Online preventive maintenance, Checked all parameters, Fan function found normal, UPS parameters mentioned below.

Parameter	Unit	Value	Unit	Value	Unit	Value	Unit	Value	Unit	Value
V <sub>in</sub>	V	414	V <sub>in</sub>	V	410	V <sub>in</sub>	V	410	V <sub>in</sub>	V
I <sub>in</sub>	A	400	I <sub>in</sub>	A	57	I <sub>in</sub>	A	18	I <sub>in</sub>	A
V <sub>out</sub>	V	418	V <sub>out</sub>	V	231	V <sub>out</sub>	V	231	V <sub>out</sub>	V
I <sub>out</sub>	A	400	I <sub>out</sub>	A	70	I <sub>out</sub>	A	15	I <sub>out</sub>	A



### Equipment Monitoring

#### F2 A-Wing AHU SUMMARY

Parameters	First Floor			Second Floor			Third Floor		
	Temp	Humidity	Pressure	Temp	Humidity	Pressure	Temp	Humidity	Pressure
AHU Temp	28.0 C	65.0 %	1013.0 hPa	28.0 C	65.0 %	1013.0 hPa	28.0 C	65.0 %	1013.0 hPa
AHU Humidity	65.0 %	65.0 %	65.0 %	65.0 %	65.0 %	65.0 %	65.0 %	65.0 %	65.0 %
AHU Pressure	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa	1013.0 hPa

Location	Temp	Humidity	Pressure	Location	Temp	Humidity	Pressure
F2 AHU_L2B_1	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_1	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_2	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_1	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_3	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_2	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_4	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_3	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_5	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_4	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_6	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_5	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_7	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_6	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_8	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_7	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_9	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_8	28.0 C	65.0 %	1013.0 hPa
F2 AHU_L2B_10	28.0 C	65.0 %	1013.0 hPa	F2 AHU_L2B_9	28.0 C	65.0 %	1013.0 hPa

# Teamwork, Employee Involvement & Monitoring

2/2



Demo Room  
for Training



# Kaizen by Plant Team

## Pullcord Switch for light by in-house team



## Timer for bain-marie and exhaust fan by In-house team



## Remote Controlled equipment for HVAC ducts



## Motion Sensors for ODC and switch room lighting control



## Auto operation of AC unit via motion sensors



# IGBC Certification



# Awards

Energy efficient unit Awards 2021



EHS Excellence Awards 2019 (4 Star)



EHS Excellence Awards 2019 (Digitalization)







# **23<sup>rd</sup> National Award for Excellence in Energy Management 2022**

MBP F2 & F3 - Bengaluru

August 2022