



CII 23RD NATIONAL AWARD FOR EXCELLENCE IN ENERGY MANAGEMENT 2022

Honeywell Technology Solutions Lab Pvt. Ltd Campus 02

Bellandur - Doddakannelli Rd,
Adarsh Palm Retreat, Bellandur,
Bengaluru. Karnataka 560 103

23rd, 24th & 25th August 2022

Honeywell

MR. SRIDHAR NATARAJAN
- DIRECTOR GRE

MR. SUBRATA BALIARSINGH
- DIRECTOR IFM

MR. C RAVI KUMAR
- OPERATIONS LEADER

MR. VIJAYAKUMAR SHOLAPUR
- FACILITIES & ENERGY LEAD

HONEYWELL INDIA



8

Decade
legacy

\$1B

Domestic sales
and exports

4

Technology
development centers

- Bengaluru
- Madurai
- Hyderabad
- Gurugram

3


Manufacturing
centers

- Gurugram
- Dehradun
- Pune

20

Facilities in major
cities

- Pune
- Bengaluru
- Gurugram
- Chennai
- Dehradun
- Mumbai
- Kolkata
- Madurai
- Hyderabad
- Jamshedpur
- Vadodara



13000

Employees

3000+

Products, solutions,
applications engineered
in India



5500


Engineers

HONEYWELL COMMITTED TO BE CARBON NEUTRAL BY 2035

TARGETED SOLUTIONS FOR SECTORS PRODUCING

About 2/3's

OF THE WORLD'S GREENHOUSE GAS EMISSIONS



~ 30% = Agri, Forest, Land use, Others

~70% = Industry, Tpt, Building, Electricity / Heat

SITE INFRA - HTS CAMPUS 02, BANGALORE



- Facility details : Owned
- Year of operation : 2017
- Built up area : 7,86,821 sq.ft
- Towers : Tower 01 & 02
- Tower 01 : GF to 9 floors
- Tower 02 : GF to 4 floors
- Seating Capacity : 3,887
- Sanctioned Demand : 5.10 MVA
- Transformer Capacity : 8.75 MVA
- Diesel Generator Capacity : 11.01 MVA
- UPS Capacity : 4.09 MVA
- Chiller Capacity : 2,000 TR
- Inhouse Solar roof top : 103 kWp



IGBC

PRE - GOLD

certified

Annual energy use is 13.34 million kWh with the spend of INR 11.09 crores, including diesel cost in FY 2021 - 22

BUILDING SALIENT FEATURES

SUSTAINABILITY CONCEPTS CONSIDERED IN BUILDING

Priority to passive design to reduce energy demands

1. Compact envelope shape
2. Optimized orientation, Solar protection
3. Under roof thermal insulation
4. Optimized air tightness

Include passive

1. UV protected glazing
2. 70 % access to-day light exposure

Occupant comfort and well being

1. Achieving indoor comfort requirements (visual / thermal / acoustic)
2. Maintaining good IAQ (indoor air quality)

More sustainable elements


1. In-house Solar PV System – 103 kWp




ENERGY CONSUMPTION OVERVIEW IN 2019 - 2022

Year	Source of Energy – Energy Consumption, Lakhs kWh				Total Energy Consumption	Energy Cost
	Grid – EB	DG	RE (PPA - Solar)	RE (inhouse – Solar)	Lakhs kWh	INR
FY 2019 – 20	71.41	4.13	85.80	0.59	161.93	14,19,44,683
FY 2020 – 21	32.71	1.70	95.40	1.53	131.35	10,89,21,437
FY 2021 - 22	41.78	2.70	87.55	1.38	133.40	11,09,45,496

Energy Consumption, Lakhs kWh




Energy Source - Breakup – FY 2021 - 22




ENERGY CONSUMPTION – UTILITY WISE OVERVIEW

Energy Consumption		
Utility	Lakhs kWh	%
Chillers & Pumps	30.68	23.0
AHU	12.01	9.0
PAC	17.34	13.0
UPS & Lab	61.37	46.0
Lighting & Raw	12.01	9.0
Total	133.40	100.0



Specific Energy Consumption 2019 - 2022

Year	Total Energy Consumption		Area	Energy Performance Index	Improvement
	kWh	Lakhs kWh	Sq.m	kWh / Sq.m	%
FY 2019 – 20	161,92,723	161.93	73,098	221.5	Base data
FY 2020 – 21	131,34,875	131.35	73,098	179.7	18.9
FY 2021 - 22	133,40,255	133.40	73,098	182.5	- 1.56



Load addition in 2021 & 2022

375 kW Lab equipment addition in Lab area; which operates for 24 x 7

This additional lab equipment's accounts for 15 Lakhs kWh consumption increase in following years


COMPARISON SEC WITH INTERNAL & NATIONAL BENCHMARKING

Internal Benchmarking	Location	Zone	SEC (kWh / m ² / y)
Honeywell	Campus 02, Bangalore	Composite	182.5
Honeywell	Gurugram campus	Composite	355.8

Benchmarking	Reference	SEC (kWh / m ² / y)	
		Standard	Actual
National level	Bureau of Energy Efficiency (BEE)	179	182.5

Climate Zone	AC	
	< 50.0 %	> 50.0 %
EPI (kWh / m ² / year)		
Composite	86	179
Moderate	94	179
Warm & Humid	101	182
Hot & Dry	90	173


EPI (kWh / m ² / y)	Star Label
190 – 165	1 star
165 – 140	2 star
140 – 115	3 star
115 – 90	4 star
Below 90	5 star



★ **Bangalore**

Energy Saving projects implemented in 2019 - 2022

Year	No. of Energy Saving projects	Investment	Electrical savings	Cost savings	Impact on SEC
		million INR	Lakhs kWh	million INR	%
FY 2019 - 20	04	19.3	13.5	12.4	7.7
FY 2020 – 21	05	18.3	4.6	4.3	3.4
FY 2021 - 22	03	16.4	6.1	5.2	4.4



ENCON PROJECT PLANNED IN FY 2022 - 23

Title of the Project	Annual Electrical savings	Annual Cost savings	Investment	Status
	Million kWh	Million INR	Million INR	
Bloom Energy (Fuel Cell)	0.33	2.89	53.5	
Replacement of belt driven fans with Energy Efficient EC fans in AHUs and other fans units	0.32	2.65	12.1	WiP
Replacement of existing motors with Energy Efficient motors for Lab Air compressors	0.01	0.08	3.3	WiP

INNOVATIVE PROJECT - HONEYWELL - FORGE

STRATEGIC IMPERATIVES FOR BUILDING PORTFOLIOS

MAXIMIZE ASSET VALUE AND RETURN

Capital planning and just-in-time maintenance for lifecycle optimization

OPERATIONAL EFFICIENCY

Processes continually monitored and optimized

RELIABILITY AND READINESS

Systems available when needed through minimizing failures

SAFETY AND PRODUCTIVITY

Maintaining high safety standards while improving productivity

COMPETITION FOR TENANTS

Increasing the attractiveness of the building to attract and retain tenants

SUSTAINABILITY STRATEGY

Environmental and social responsibility demanded by shareholders and occupants

ADVANCE FAULT DETECTION

PERFORMANCE ANALYTICS

Detect issues before they turn into complaints. Optimize uptime and availability

BENCHMARKING AND COMPARISONS

Understand KPI improvements vs. historical and targeted levels

OPERATIONAL READINESS

Increase confidence that your facility will be optimally working when needed

CONTINUOUS OPTIMIZATION

TARGETED RESPONSE

Understand where to allocate resources to deliver the most beneficial results

TUNING TO ACTUAL USE

Continuous tuning as the building is repurposed and how it is used

BENEFIT FROM GLOBAL EXPERIENCE

Your building benefits from Honeywell's depth of experience


DIGITIZED MAINTENANCE

Keep Building More Competitive Through a Honeywell Forge Enabled Service Contract


TO MORE RAPIDLY DELIVER OUTCOMES FROM DATA YOU

NEED ALL THE LINKS IN THE CHAIN

- Connected building assets
- Analytics and Machine Learning
- Efficient workflow process
- Visibility and control
- Knowledgeable field staff



The Journey to 25% Opex Savings



Annual savings = INR 3.0 Lakhs

Innovative projects – SCALE BIO REMOVER SYSTEM

SBR System:

- Non-chemical treatment of cooling tower water - Deploys electrolysis reaction that breaks down and controls the elements that pollute water quality
- The chemical reactions on the cathode provoke the accumulation of scale particles on the cathode surface. The anodes create free radicals and molecules of chlorine, oxygenated water and ozone.
- The derived reactions create molecules of hypochlorite and chlorine. A pH alkaline coating is created, which causes the oxidation of eroded elements and their accumulation as suspended solids, which accumulate on the cathodes and the bottom of the tank.


Benefits

The SBR system maintains Cooling Tower circuits free of incrustations and biological dirt to improve operational efficiency and to provide the following benefits:

- Non-Chemical based and eco friendly
- Saves Electrical Consumption
- Saves Water
- Provides Clean Water
- Saving of Chemical Cost
- Reduces Corrosion



Scale Bio Remover – Non - Chemical based




Cost Savings benefits	
	INR
SBR Project cost (Investment)	43,00,000
Savings – Cooling Towers	
Blowdown water cost avoidance (104 kL / month)	1,56,000
Chemical cost	11,99,984
Cooling tower maintenance cost / annum	1,44,000
Savings - Chillers	
Energy savings through Chiller Delta T(Chiller plant 1)	89,855
Energy savings through Chiller Delta T(Chiller plant 2&3)	1,34,785
Total Savings	17,24,624
ROI	2.5

Key points

- 2,74,521 Gallons of water saved annually
- 24,960 kWh of Energy saved annually
- 20.7 Mtons of CO₂ emission reduced annually.

UTILIZATION OF RENEWABLE ENERGY SOURCE

Year	Renewable Energy Source, Lakhs kWh			Total Energy Consumption, Lakhs kWh	% Renewable Energy	CO ₂ emission avoided, tons of CO ₂
	PPA – Solar	Inhouse Roof top	Sub total			
FY 2019 – 20	85.80	0.59	86.39	161.93	53.3	6,859.4
FY 2020 – 21	95.40	1.53	96.93	131.35	73.8	7,628.4
FY 2021 - 22	87.55	1.38	88.93	133.40	66.7	6,998.8




65.0 %

**21,486.5
Tons of CO₂**

WASTE MANAGEMENT

S. No	Type of Waste	Approximate Quantity	Disposal method
1	Food Waste	4,000 kgs / month	Wastes are processed and converted as organic compost, used for inhouse gardening, packed and given to employees for home gardens
2	E-Waste	300 kgs / month	Wastes are collected, segregated and stored at our inhouse E-Waste yard. These wastes are disposed to KSPCB Authorized vendors.
3	Non-Hazardous Waste	2,000 kgs / month	Wastes (Plastic, Wood, Metal, Carton boxes) are collected, segregated and stored at our inhouse Garbage/scrap Yard. These wastes are disposed to BBMP Authorized vendor.
4	Hazardous Waste	760 kgs / Quarter	Wastes are collected, segregated and stored at our inhouse Hazardous storage area. These wastes are disposed KSPCB approved vendor.
5	Battery Waste	169 Nos / annum	Wastes are collected, segregated and stored at our inhouse battery storage area. These wastes are disposed KSPCB approved vendor.



WATER MANAGEMENT



Installation of water saving aerators in all taps

Implemented year : 2021

- Total Water savings in kL : 2,554 kL / annum
- Estimated Cost Savings in INR : 0.319 M
- Total Investment in INR : 0.175 M
- Estimated ROI : 07 months

The facility has own STP plant.


The waste-water is treated in STP and reused for gardening and Toilet purpose.

The facility is Zero liquid discharge facility.



GHG EMISSION TREND

	Scope 01	Emission factor CO ₂ e / unit = 2.69	Scope 02			Total Emission CO ₂ in tons
CO ₂ e year	Fuel consumed in liters	Total GHG emission in TCO ₂ e	Energy consumption in kWh	Emission factor CO ₂ e / unit	Total GHG emission in TCO ₂ e	
FY 2019 – 20	145,598	391.7	71,41,223	0.794	5,670.13	6,061.79
FY 2020 – 21	64,346	173.1	32,71,274	0.787	2,574.49	2,747.58
FY 2021 – 22	96,210	258.8	41,78,075	0.787	3,288.15	3,546.95



DG set operation

- **Optimization in DG set daily test**
- *Implemented in 2020*
- *A check frequency test reduced from daily to weekly once.*
- *Annually 25.0 kL of Diesel consumption reduced.*
- *Approx. 67.4 Tons of CO₂ emission reduction*

RE purchase

- **RE purchase – PPA - Solar**
- *On an average 65.0 % energy consumption drawn from RE*
- **21,486.5 Tons of CO₂ off-set**

INDOOR AIR QUALITY - HONEYWELL - HEALTHY BUILDING INITIATIVE

AIR QUALITY IMPROVEMENT AT 9A 4F:

- Installation of EAC (Electronic Air Cleaner) in AHU's in place of MERV 13 Filters
- Introduction of UV Sterilizer Lights for AHU's
- Installation of IAQ sensors to monitor **Temperature, Humidity, CO₂, PM 2.5 and TVOC**
- Installation of DP sensor in toilets to monitor the **negative pressure to understand fresh air circulation to avoid pungent odor in rest rooms**
- Deployment of HB Dashboard and integration with EBI
- Installation of UV batten and Upper UV solutions in 9A 4F Rest rooms and 9B 2F respectively
- Installation of VESDA system to monitor the IAQ parameters such as **Temperature, Humidity, CO₂, PM 10, PM 2.5, PM 1.0 and TVOC**



UVGI



EAC




IAQ SENSOR



DP SENSOR

- MERV 14** Filtration
- UL Listed** for Safety
- BMS compatible



AHU return duct mounted



UV return duct mounted

- UV Light with Cumulative Average intensity of **4647 microwatt / cm²**
- Lamp Life of **12000hrs**
- Distributed arrangement for better spread

- Dual-stage electrostatic precipitators include two parts: the charging and the collecting sections.
- Since opposite charges attract, the positively-charged contaminants collect on the negatively charged aluminum plates, removing them from the air stream.

- Low-pressure drop.
- Low operating expenses.
- Approximate 15% of Energy savings observed in HVAC

Pressure Drop (in mm)	Media Filter			Honeywell EAC (MERV 14)	
	Pre Filter	MERV 13	Total	Pre Filter	EAC
Initial	4	7	11	Not Required	6
Design	10	17	27		7
Final	12	22	34		

HBI - DASHBOARD

Station - Default - Healthy Building Dashboard(HB_HTSI_BMS_DB.htm)

STATION EDIT VIEW ACTION CONFIGURE HELP

#HB Home Alarm Settings Zoom To Fit Command

Healthy Building Dashboard Good Afternoon - Administrator Emergency Contacts 21.6 °C 78.4 %RH

AIR QUALITY KPI'S ZONE WISE SUMMARY

HEALTHY BUILDING ALARMS

5
Total Alarms

0 Urgent 5 High 0 Low

TOILET NEGATIVE PRESSURIZATION

1
Zones out of range

INDOOR AIR QUALITY

Temperature **GOOD**
All Zones

CO2 **GOOD**
All Zones


Humidity **3**
Zones out of range

PM 2.5 **GOOD**
All Zones

Outside Air CO2 **GOOD**
All Zones

TVOC **1**
Zones out of range

HTS CAMPUS 2



HEALTHY BUILDING ALARMS

PRIORITY	DATE & TIME	LOCATION	SOURCE	ALARM TYPE	LIVE VALUE
H 12	11/18/2020 11:55:38	HB_9A_VOC	9A_4F_AHU3_ZONE_TVOC	Zone TVOC	026
H 12	11/16/2020 2:52:17	HB_9A_Hum	9A_4F_AHU2_ZONE_RH	Zone Rh	70.12
H 12	11/12/2020 9:58:05	HB_9A_Hum	9A_4F_AHU4_ZONE_RH	Zone Rh	62.46
H 12	11/11/2020 6:42:00	HB_9A_Hum	9A_4F_AHU3_ZONE_RH	Zone Rh	67.97
H 12	11/11/2020 6:09:07	HB_9A_TNP	9A_4F_AHU2_TOILET_PR	Toilet Negative Pressure	15.00

27-Nov-20 14:35:17 Facility 00001_N005_L02_D089 Fire Alarm U 15 Active

Honeywell | EBI R500.1 27-Nov-20 16:31:21 ALARM SYSTEM MESSAGE DOWNLOAD

htsbtsbmsbebia Str01 administrator (Mgr)

Station - Default ... 10.1.1.150 - Remo... 10.1.10.4 - Remot... Untitled - Notepad

4:31 PM 11/27/2020


Station - Default - HB - 9A - 4th Floor - AHU 03(HB_9A_HTSI_AHU03.htm)

STATION EDIT VIEW ACTION CONFIGURE HELP

#HB Home Alarm Settings Zoom To Fit Command

Healthy Building Dashboard - AHU 03 Good Afternoon - Administrator Emergency Contacts 21.6 °C 78.4 %RH

4th Floor AHU 01 AHU 02 AHU 03 AHU 04



Operator Cmd On/Off Cmd VAV City AHU-4 AHU-3 AHU-2 AHU-1 Delta T Cooling Energy Pandemic Mode

Summary

27-Nov-20 14:35:17 Facility 00001_N005_L02_D089 Fire Alarm U 15 Active

Honeywell | EBI R500.1 27-Nov-20 16:32:26 ALARM SYSTEM MESSAGE DOWNLOAD

htsbtsbmsbebia Str01 administrator (Mgr)

Station - Default ... 10.1.1.150 - Remo... 10.1.10.4 - Remot... Untitled - Notepad

4:32 PM 11/27/2020

AIR QUALITY KPI'S ZONE WISE SUMMARY

Zones Overview

STATUS	ZONE NAME	TEMP	HUM	CO2	PM 2.5	TVOC
	RECOMMENDED VALUES	21-26 °C	40-60%RH	<800 PPM	<50 µg/m3	<0.5 mg/m3
GOOD	9A-4F-Zone AHU-1	21.3 °C	69.7 %	453 PPM	240 µg/m3	0.16 mg/m3
OUT OF RANGE	9A-4F-Zone AHU-2	20.5 °C	70.1 %	490 PPM	1.80 µg/m3	0.31 mg/m3
OUT OF RANGE	9A-4F-Zone AHU-3	26.0 °C	68.0 %	760 PPM	3.00 µg/m3	0.26 mg/m3
OUT OF RANGE	9A-4F-Zone AHU-4	24.5 °C	62.5 %	451 PPM	250 µg/m3	0.09 mg/m3

VIEW TREND

TEAMWORK, EMPLOYEE INVOLVEMENT & MONITORING

Energy Team


- Certified Energy Managers – 2 Nos.
- Weekly and monthly Energy review
- Energy Dashboard
- Dedicated Energy CAPEX budget
- Periodical Energy Training

BMS Team :

- monitor & control
- scheduling of utilities (Chillers, AHUs)
- monitoring of equipment's
Viz., Transformer, DG, HVAC, UPS, Energy meters etc.,
- Energy consumption data analysis for critical equipment's

KAIZEN



- Reduced the air compressor pressure from 13 kg /cm² to 10 kg /cm²; Energy saving of 88170 kWh / annum
- DG A Check optimization from daily to weekly
- Timer optimization in Lighting sensor



Energy Monitoring
- Daily & monthly



Solar Energy
Monitoring



Chiller Plant Room
Monitoring



AHU Monitoring



UPS Monitoring



Battery Room
Monitoring

IMPLEMENTATION OF ISO 50001 / IGBC RATING



LEED
&
WELL Certification
aimed for
Bangalore campus 02
by
December 2022

Bangalore Campus 02 - certified by IGBC for GOLD

Honeywell Facility Team

Name	Designation	Email ID
Vijayakumar Sholapur	Energy and Projects Head	Vijayakumar.Sholapur@Honeywell.com

**THANK
YOU**

Honeywell