

# 23<sup>nd</sup> National Award for 2022 Excellence in Energy Management 23 - 26 August 2022



Sr. No	Name	Designation	Mobile Number	Email address
1	G S Sudhakar Varma	General Manager	7036292727	Srinivasasudhakarvarma.Gadiraju@aurobindo.com
2	B Sree Rama Sarma	Asst. General Manager	9848604295	Sreeramasarma.bommaraju@aurobindo.com
3	P Harshavardhan	Senior Manager	9948842880	Harshavardhan.Parachuri@aurobindo.com

# **Brief Introduction on Company/Unit**







Unit-l

	Total Factory area		05 m <sup>2</sup> Acres.)
Facility	Build up Area (m <sup>2</sup> )	252645	54%
lacinty	Roads (m <sup>2</sup> )	65114	14%
	Green Belt area (m <sup>2</sup> )	139531	30%
	Open area (m <sup>2</sup> )	7815	2%

Utility


Equipment

*	FBC boiler	: 35 & 27.5 TPH
*	Air Compressors	: 4592 CFM
*	Chillers( +5°C)	: 3927 TR
*	Chillers (-20°C)	: 1090 TR
*	Chillers (-35°C)	: 220 TR
*	Cooling towers	: 18475 TR





### **Details of the Products / Processes**




# **Energy Consumption Overview – Last 4 Years**

PRODU	JCTION	SPECIFIC E	NERGY	Production
YEAR	VALUE (MT)	YEAR	VALUE (m kcal/MT)	17.7 %
FY 2018-19	4582	FY 2018-19	48.63	
FY 2019-20	4906	FY 2019-20	42.02	
FY 2020-21	3601	FY 2020-21	59.10	
FY 2021-22	2963	FY 2021-22	79.85	
YEAR	VALUE (m kcal)	YEAR	VALUE (m kWh)	
FY 2018-19	153,501	FY 2018-19	81	Specific Energ
FY 2019-20	141,300	FY 2019-20	75	35.1%
FY 2020-21	148,860	FY 2020-21	74	
FY 2021-22	175,824	FY 2021-22	71	
THERMA	L ENERGY	ELECTRIC	AL ENERGY	

**AUROBINDO** 

# Specific Energy Consumption Overview – Last 3 Years




SEC of the Plant

Sanitization

াদ্দ'

SANITIZER





■ Manufacturing ■ SRS ■ ZLDF ■ Utility, HVAC & Water System ■ Others



#### **Refrigeration Plants :**

Description	Design Temp (oC)	Design SEC (kW/TR)	Operating SEC (kW/TR)	Target SEC (kW/TR)
	+5	0.86	0.91-1.1	0.87
Reciprocating Chillers	-20	1.59	1.65-1.72	1.60
(Water Cooled)	-30	1.83	2.1-2.5	1.9
	-35	1.95	2.52-2.71	2.0
Screw Chillers	+5	0.63	0.68 - 0.82	0.65

Description	Design SEC (kW/CFM)	<b>Operating SEC (kW/CFM)</b>	Target SEC (kW/CFM)
Air Compressors	0.16	0.22-0.29	0.17

Description	Design SFR (KG/KG)	Operating SFR (KG/KG)	Target SFR (KG/KG)
Boiler	4.8	3.8	4.3

# Major Encon Projects Planned in FY 2022-23





Installation of Vent Steam Heat Recovery System in Cogeneration Power Plant

Investment: ₹ 3.43 millionSavings: ₹ 6.0 millionPayback: 6.8 Months



#### E Glass Epoxy FRP Blades for Cooling Towers

Investment	:	₹ 6.68 million
Savings	:	₹ 6.4 million
Payback	:	12.5 Months



WC Screw Chiller by Replacing Reciprocating Chiller in Sub Zero Temperature Applications

Investment: ₹ 14.9 millionSavings: ₹ 10.5 millionPayback: 17 Months



Vertical Inline Energy Efficiency Pumps by Replacing Energy Intensive Pumps

Investment	:	₹ 1.55 million
Savings	:	₹ 4.85 million
Payback	:	4 Months

# Encon Projects Planned in FY 2022-23




No	Title of Project	Annual Electrical Saving (Million kWh)	Annual Coal Saving (Tons)	Investment (Rs in Million)	Monetary Savings (Rs in Million)	ROI
1	Proposal for Installation of VFD for Feed Water Pump 180 kW in Cogeneration Power Plant for adjusting flow or pressure to the actual demand.	0.33	0	1.98	2.1	11.4
2	Proposal for Installation of VFD for CT FAN MOTR 11 KW in Cogeneration Power Plant for adjusting air flow as per the requirement	0.02	0	0.09	0.1	8.6
3	Proposal for Installation of VFD for CT PUMP MOTR 22 kW in Cogeneration Power Plant for adjusting flow or pressure to the actual demand	0.03	0	0.15	0.2	9.5
9	Install VFDs for secondary pumps and Process RT Pumps to regulate the flow as per the requirement for reducing the pump consumption.	1.33	0	5.93	8.4	8.5
4	Replacement of pumps with Energy Efficient Pumps for improving the operational efficiency and conservation of energy	0.94	0	4.85	5.9	9.8
5	Replace CMU 014, 100 TR, -20 oC with energy efficient water-cooled screw system with -20 , 87 TR system	0.71	0	6.5	4.5	17.4
6	Replace CMU 023 & CMU 024, 80 TR, -20 oC with energy efficient water-cooled screw system with - 20 , 87 TR system	0.6	0	5.2	3.8	16.5
8	-50°C 15TR chilling plant with all accessories required for D&E blocks Cefprozil, Ceftibuten and Cefdoxime proxetil products	0.36	0	3.21	2.3	17.0
10	Cooling tower CT fan blade replaced with E Glass Epoxy FRP blades, in place of Aluminium blades, Qty : 09 No's	1.02	0	6.68	6.4	12.5
7	Replacement of higher size (kW) motors with Premium Efficiency Optimum Size Motors (CMU 504 & 505) for conservation of energy	0.07	0	0.64	0.4	17.4
11	Installation of Vent Steam Heat Recovery System for Avoiding the Bleeding of Steam in Cogeneration Power Plant	0	703	3.43	6.0	6.8
12	Installation of Automatic Pump Trap (APT)- 50NB for condensate Stall Prevention on Stripper	0	42	0.22	0.4	7.3
13	Installation of Flash Pump and 8 Nos TOFT for Closed loop condensate management & Twin Orifice Float Trap	0	164	2.02	1.4	17.2
14	Installation of Automatic Pump Trap (APT)- 50NBfor condensate Stall Prevention on MEE	0	864	0.44	7.4	0.7
	Total	5.4	1829.8	41.5	49.8	10.0

# Energy Saving projects implemented in last 3 Years




**EMISSION** 

REDUCTIONS



# Oil Free Refrigeration Systems – State-of-the-art Technology




# Oil Free Refrigeration (OFR) Systems – State-of-the-art Technology



Other Benefits:	Design o	of the Sys	tem : -65 °	C , 50 TR		
Lower maintenance / reduction in	Particular	Unit	Befor	e OFR	Afte	r OFR
Compressor overhauling		Omt	CMU 523	CMU 524	CMU 523	CMU 524
> Higher reliability due to increased	Suction Temperature	°C	- 0.3	- 4.5	- 9	- 19.5
equipment life	Suction Pressure	kg/cm <sup>2</sup>	0.1	0.1	0.2	2
Low environmental impact	Discharge Temperature	°C	242	71.8	149	56.8
	Discharge Pressure	kg/cm <sup>2</sup>	15	14.4	12.5	11.5
	Oil Temperature	°C	51	1.4	42	2.6
	Compressor Operating Load	kW	86.0	98.4	75	70.5
	Evaporator (Delta T) (Brine)	°C	4	.6	4	.7
	Refrigeration load	TR	45	5.3	4	6.3
	Specific Energy Consumption (SEC)	kW/TR	3.	83	3.	.14
Commission	Decrement in SEC	%		~ 1	8%	
		INGS million	INV ₹ 17	estment 7.2 milli		AYBACK 9 Years

# Major Encon Projects Implemented – High Investment - FY 21-22





: ₹ 54.5 million

: 19 months

Investment

Payback



#### 8 No's of 200 CUMPH Vertical Inline pumps

- Installed 08 No's Vertical Inline pumps with low speed motor of 30 HP in place of Conventional centrifugal pumps having high speed motor of 40HP For the same pump specifications.
- Cost of each pump is 2 Lakhs, Savings per annum is 3.8 Lakhs ROI is 6 Months.





#### **IPA Dehydrator**

- IPA Recovery is being done Flash distillation in Reactor and in Distillation column for 60% recovery and process was repeated for second crop recovery
- Installed an Absorption type Dehydrator to improve the recovery
- Single pass recovery improved from 60 % to 92 %.
- Steam consumption for recovery reduced from 4 Kg/ Kg to 1 Kg / Kg.




#### **Co-Gen capacity Utilization**

- Co-Gen plant installed for meeting the Plant steam requirement and generate Power from this capacity
- Reduction in production has led to poor capacity utilization and inefficient operations
- Installed VAM's and increased the Steam consumption
- Increased the Co-Gen load from 2 MW to 3 MW.
- Captive generation improved by 8 Million Units reducing cost by Rs. 2.64 Crores


#### Major Encon Projects – Medium / Low Investment - FY 21-22








## **OFR Technology in Brine Chillers**




#### **Innovative Projects - II**






#### Waste utilization and management










# **Green Supply Chain Management**



Single Achieved benefits of Rs 190 Million Stuffing/ Increased loading by 30% by optimizing with shipper stuffing, Double Saved freight on additional container with 50% extra space Stacking Project Enabled no dependency on the wooden pallets. **Paperless** / **Decreased Paper consumption and** ٠ **Digital** paper less / Digital transactions Logistics Invoice information will be transferred ۰ from the portal in real-time. First Pharma company in India to adopt OTM. GST – e **Cloud based Solution** Invoicing Freight Payments linked from OTM to ERP. **Increased Sea transportation over Air AIR vs SEA** – Mode transportation by pallet systems. Control Decreased air Tonnage from 572 Tonnage to 456 Tonnage

#### **Energy Management System - Procedures**





# Teamwork, Employee Involvement & Monitoring





#### Teamwork

- Block level teams responsible for Energy monitored on KPI.
- Awards & appreciations for best programs.
- Implementing 5S programmes by the same teams



#### Employee Involvement

- Organized Energy Conservation Week Celebrations and involved all employees
- Energy KPI review



#### Training Programmes

- Given training programmes on
  Root cause analysis (RCA), 5S,
  Good Engineering Practices
- Training on steam / utility systems


Itors			
DESCRIPTION	CENTRALUT YMUOD8	LITY WAM VMUED7	
LID_INFIG_DUIT_TEMP	810 %	14.00 °C	
LID. WER, OILD. PM	5.00 °C	9.00 %	
ILING AN ARC INCLUDED	29.01 °C	32.00 %	
a.rs_wane_aan.m_new	31.01 10	36.00 ×C	
0.009.003000.000.000.009	21.00 %	04.00 °C	
or jeva generator jetuno jena	135430 °C	133.00 %	
ROCHART_CONCENSATE_TEMP	92.00. 9C	87.00 XC	
REGAR_MARADOL_194	4.00 %	10.00 °C	
ND_STAN_TOP	36.00 %	50.00 °C	
CH, TEMP, GENERATOR, JM 67, JEMP	108.00 K	114.00 %	
SHI, MET, THP	1276.00 %	151.00 %	
UTOS ANNARI, DITEL THP	31.00 %	39.00 %	
WUTOWINTER	1.01 kg/tr	0.00 kg/ht	
LID MURITUM MURI	0.00 m3/m	10 m3/fm	
.94Q	25.00 Hz	29.00 liz	
	40,00 %	35.00 %	
	258100	319.00	
ADVERTIGATION DELETION OF ADVERTIGATION	36.0 1.00	\$5.03 1.00	

# Monitoring


- Daily / weekly monitoring of Energy Consumption areas / major equipment.
- Review of KPIs, Performances in the presence of plant heads.

# **Daily Monitoring & Reporting System**

- Co-gen being operated a max capacity utilization based on steam demand.
- Benchmarks for each block power consumption established and being tracked on daily basis.
- Specific energy consumption of all Utility equipment being routinely monitored and reviewed on monthly basis.
- Water conservation and monitoring. All streams of water are studied and recycled. Purified Water RO reject are used for Cooling Tower make up.







## Energy Week / Energy Conservation Day Celebrations –



#### Awards & Recognitions





**Global Healthcare Awards** 

Most Collaborative Hiring Team Innovation in Employee Engagement

#### Awards & Recognitions

AUROBINDO



#### **CSR** Activities









- 14 Villages Adopted
- 48 Water Drinking Plants
- 350 + Healthcare Programme
- 21 Educational Institutions









