

23rd National Award for Excellence in Energy Management - 2022

Team Member: S.K.Janghel (C.M.) Nav Verma (Sr.Mgr.) Shankar Singh (Dy.)

Presented By: Indian Farmers Fertiliser Cooperative Ltd. Phulpur- II Unit 23rd – 25th August, 2022

PROPERTY OF

II II I

IFFCO: At a Glance



- IFFCO was established as the farmers' own initiative in Cooperative Sector on 3rd Nov. 1967
- Largest producer of fertilisers in the country.
- □ Nos. of Plant : Five (Kandla, Kalol, Phulpur, Aonla, Paradeep)
- Installed/Revamped Annual Capacity (Lakh MT)

: 42.4
: 43.3
: 26.3
: 17.2
: 0.15
: 0.30







IFFCO Phulpur Unit-II : Profile




Plant	Ammonia	Urea
Process Licenser	Haldor Topsoe, Denmark	Snamprogetti, Italy
Commissioned	December	, 1997
Daily Capacity (MTPD)	1740	3030
Annual Capacity (Lakhs MT)	5.7	10.0
Till Date Production (Lakhs MT)	134	233




IFFCO Phulpur Unit-II : Production Outline





Phulpur-II: Production Performance






4

On-Stream Efficiency

प्रिनिटि पूर्णतः सहकारी स्वामित्व Wholly owned by Cooperatives




One of the important factor which effects the Productivity / Energy of the fertiliser plant is the Downtime of the plant. On-stream efficiency is less due to extended Annual Turnaround which was taken in April, 2021 on account of COVID 19. Again, Annual Turnaround was taken on the same year to carry out Stripper shortening job because frequent strippers leakage occurred of both unit of Urea-II Plant.

- Poor Reliability of Plant & Equipment leads to:
 - ↑ Duration of Downtime days
 ↓ Productivity
- ↑ No. of Downtimes
 ↓ Productivity / Energy Efficiency

Phulpur-II : Sp. Energy Consumption

प्रि**मिटि** पूर्णतः सहकारी स्वामित्व



Major Energy Conservation Measures in Phulpur-II Unit in the year 2021-22



Wholly owned by Cooperatives

Name of Energy saving Projects	Investment (INR Million)	Electrical Savings (kWh)	Thermal Savings (Million Kcal)	Saving (INR Millons)	Pay Back (Month)
Replacement of DM water Pump (P-4511 B) from Back Pressure Turbine Drive with 110 kW Motor drive in Ammonia-II Plant	0.58	0.0	13718.2	62.90	0.1
Replacement of Low Temperature Shift (LTS) Converter Catalyst in Ammonia-II Plant	50.13	0.0	13167.8	58.61	10.3
Replacement of Rotor in Induced Draft (ID) Fan Turbine in Ammonia-II Plant	6.00	0.0	12380.4	33.29	2.2
Replacement of 400 Nos of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke with 2X2 feet, 20 W Surface Mounted LED Fixtures at Central School in Township	0.42	65564.0	0	1.31	3.9
Replacement of 400 Nos of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke with 2X19 W LED Fixtures at Ammonia & Urea MCC Buildings	0.35	135102.0	0	2.70	1.6
Replacement of 200 Nos 250 W SON-T Fittings with 120 W Street Light at Bagging area & Plant Roads in Offsites	0.49	64571.0	0	1.29	4.6
Replacement of 2400 Nos 36 W, 4 Feet Tube Lights with 19 W, 4 feet Tube Lights at Bagging floor & Offsite area	0.55	101326.0	0	2.02	3.3
Replacement of 15 Nos 1000 W Tower Light Fixtures from Towers of Boundary wall with 300 W Flood Light	0.21	26077.0	0	0.52	4.9

Major Energy Conservation Measures in Phulpur-II Unit in the year 2020-21



Name of Energy saving Projects	Investment (INR Million)	Electrical Savings (Million kWh)	Thermal Savings (Million Kcal)	Saving (INR Millons)	Pay Back (Month)
Installation of Higher capacity Ammonia Condenser (E-3522) in place of existing Ammonia Condenser to reduce the Ammonia content at the outlet from Off Gas Absorber in Ammonia-II Plant	2.0	0.0	119.4	0.32	75
Replacement of 150 Nos of 400 W HPMV / Metal Halide Bay Light Fixtures from Township Street light with 200 Nos. 70 W Crompton make LED Street light fixtures	0.19	111048.0	0.0	1.91	1.2
Replacement of 30 Nos of 400 W HPMV / Metal Halide Bay Light Fixtures from Utsav Griha and A type quarters in Township with 250 W Crompton make LED Flood light fixtures	0.15	10863.0	0.0	0.19	9.5
Replacement of 100 Nos 150 W old High Pressure Sodium Fixure from Township with 70 W Crompton make LED Street light fixtures	0.18	19313.0	0.0	0.33	6.5
Replacement of 10 Nos 80 W Fluorescent tube Lamp from Administration Building with 40 W Recess / Suspended LED Fitting	0.013	1053.0	0.0	0.018	8.7
Replacement of 47 Nos 80 W Fluorescent tube Lamp from Central Canteen Building with 40 W Philips make Recess Mounting LED Luminaire	0.06	9902	0.0	0.17	4.2

Major Energy Conservation Measures in Phulpur-II Unit in the year 2019-20



Wholly owned by Cooperatives

Name of Energy saving Projects	Investment (INR Million)	Electrical Savings (kWh)	Thermal Savings (Million Kcal)	Saving (INR Millons)	Pay Back (Month)
Optimum Load Operation, Maximization of on-stream days & optimization of Process Parameters	0.00	0	118881.7	325.72	0.0
Revamping of Power Plant Cooling Tower-II in Phulpur-II Plant	16.60	0	2875	7.75	25.5
Online replacement of drift eliminator in Ammonia-II Cooling tower	5.95	222501	0	2.22	32.2
Replacement of 385 Nos of 80 Watt HPMV Well Glass Fixtures with 45 Watt LED Well Glass Fixtures in Urea-I, Ammonia-I Cooling Tower, Offsite-I Plant in Phulpur-I Unit	0.93	73237	0	1.07	10.2
Replacement of 150 Nos of 125 Watt HPMV Well Glass Fixtures with 45 Watt LED Well Glass Fixtures in Ammonia-II Cooling Tower	0.58	105408	0	1.54	4.5
Replacement of 550 Nos of 80 Watt HPMV Well Glass Fixtures with 45 Watt LED Well Glass Fixtures in Ammonia-II (33 and 35 area) and Urea-II Plant.	1.33	104625	0	1.53	10.4
Replacement of 30 Nos of 400 Watt HPMV Bay Light Fixtures with 120 Watt LED Bay Light Fixtures at below the Ammonia-II Compressor House	0.12	73786	0	1.08	1.3
Replacement of 110 Nos. of 72 Watt Recess Mounting Luminaire Fluorescent lamp with 38 Watt 90 Nos. Recess Mounting Luminaire LED Lamp at Power Plant Control room in Phulpur-II Plant	0.11	24458	0	0.36	3.7
Replacement of 120 Nos. of 22 Watt Recess Mounting Luminaire of compact Fluorescent lamp with 38 Watt 60 Nos. Recess Mounting Luminaire LED Lamp at Purchase Section of Phulpur-II Plant	0.08	1957	0	0.03	32.0
Replacement of 385 Nos of 35L Storage Type Old Geysers with 35L Storage Type 5 Star Geysers in Ghiyanagar Township	0.85	24322	0	0.36	28.3
					0

- DM water pumps (P-4511 A & P-4511 B) provided to pump DM water to Deaerator after getting preheated in DM water preheater.
- P-4511 A is a Motor drive and P-4511 B is back pressure Turbine Drive Pumps.
- But the Turbine drive pump (P-4511 B) was very old and inefficient. Steam consumption by the Turbine was on higher side and frequent steam leaking was there.
- To reduce the energy consumption old back pressure Turbine is replaced with Motor drive during the Annual Turn around in March & April, 2021.
- Annual thermal saving of the scheme is 13718.2 Gcal. The investment for the scheme to be around 5.8 Lakhs.





11

- 2. Replacement of Low Temperature Shift (LTS) Converter Catalyst in Ammonia-II Plant: Wholly owned by Cooperatives
- The LTS converter is a two bed catalytic Reactor loaded with a copper based catalyst. The purpose LTS Converter is to convert Carbon monoxide (CO) in the reformed gas to carbon dioxide in presence of steam and to gain one mole of hydrogen for every mole of CO converted.
- The differential pressure was increased to 0.8 Kg/cm2 against PFD value of 0.3 Kg/cm2 and CO slip increased to 0.26 % (mole) resulting plant load limitation.
- After replacing the catalyst, the differential pressure came down to design figure and the CO slip reduced to 0.11% (mole). Thereby gaining of hydrogen production resulting increase of ammonia production.
- Annual thermal saving of the scheme is 13167.8 Gcal. The investment for the scheme to be around 501.3 Lakhs






3. Replacement of Rotor in Induced Draft (ID) Fan Turbine in Ammonia-II Plant:



- The ID Fan is used to maintain draft in Primary Reformer by drawing flue gases through the convection section and discharging to CDR Plant / atmosphere.
- The Fan is normally driven by back pressure Steam turbine. The Steam Turbine is driven by MP Steam at 39 kg/cm2g and 394 deg C. During normal operation load limitation observed in ID Fan and MP steam consumption was high.
- During annual shutdown it has been noticed that turbine rotor blades got damaged. The old rotor has been replaced with spare rotor.
- After replacement, MP steam consumption in ID fan Turbine is reduced.
- Annual thermal saving of the scheme is 12380.4 Gcal. The investment for the scheme to be around 60 Lakhs.



- 4. Installation of Higher capacity Ammonia Condenser (E-3522) in place of existing Ammonia Condenser to reduce the Ammonia content at the outlet from Off Gas Absorber:
- Earlier, the existing Ammonia Condenser at the upstream of Ammonia OH Drum was not performing. The design heat duty of the exchanger was 0.25 Gcal/Hr corresponding to 25 m3/hr of CW flow.
- But, due to increased plant load after CEP & ESP-III, the heat load of the Condenser increased to more than 1.2 Gcal/Hr which corresponds to 120 m3/hr of CW.
- Earlier, it was tried to increase the CW flow by increasing CW supply line from 3" to 4" but performance of Condenser was not satisfactory.
- The ammonia percentage in the off-gases to the primary reformer burners was around 2.0 %.
- By replacing the condenser with higher capacity, the NH3 % is reduced in off gas and saving of ammonia in off gas which has been used as fuel in Primary Reformer.
- Yearly saving achieved from this scheme is 119.4 Gcal with investment cost of 20 Lakhs and saving of 3.2 lakhs as the on-stream days after implementing the scheme is around 2.5 months.







Wholly owned by Cooperatives

14

5. Innovative way for on-line replacement of drift eliminator in Ammonia-II Cooling tower in Phulpur-II Plant:



IFFCO

पूर्णतः सहकारी स्वामित्व Wholly owned by Cooperatives

Before Replacement



- In every cooling tower, drift is the undesirable loss of liquid water to the environment via small droplets that become entrained in the leaving air stream.
- The drift loss through the cooling Tower was on higher side resulting the water droplets carry with them chemicals and minerals which impacting the surrounding environment.
- Thus, the old and inefficient drift eliminator replaced with latest designed efficient drift eliminators.
- The Project was implemented successfully in running plant without tripping of Ammonia –II Plant.
- Thereby reducing the drift losses in cooling tower and power consumption in motor of Bore-well Pumps.
- The chemicals Consumption and make up water is reduced.
- The yearly Power saving was 222501 kWh and in terms of Rs. 22.2 Lakhs.

- 6. In-house modification of LTS out Separator Condensate Pump drive changed from Back Pressure Turbine to old spare Motor in Ammonia-II Plant:
 - Previously LTS outlet separator condensate Pump was driven by back pressure Turbine.
 - But the Turbine was very old and inefficient. Steam consumption by the Turbine was on higher side.
 - There was frequent steam leakage from the Steam inlet valve & Gland etc.
 - To reduce the energy consumption old back pressure Turbine was changed to old spare Motor drive during last Annual Turn-around of Phulpur-II.
 - In this in-house Modification no investment was required because the Motor was old and kept as spare.
 - Yearly energy saving was 5048.2 Gcal. The cost saving is 175 Lakhs.

Motor Driven LTS out separator condensate Pump (MP-3323B)





- 7. In-house modification of Bulk Absorber Inlet Separator condensate Pump drive changed from Back Pressure Turbine to old spare Motor in Ammonia-II Plant:
 - Previously Bulk Absorber inlet separator condensate Pump was driven by back pressure Turbine.
 - But the Turbine was very old and inefficient. Steam consumption by the Turbine was on higher side.
 - There was frequent steam leakage from the Steam inlet valve & Gland etc..
 - To reduce the energy consumption old back pressure Turbine was changed to old spare Motor drive during last Annual Turn-around of Phulpur-II.
 - In this in-house Modification no investment was required because the Motor was old and kept as spare.
 - The yearly energy saving was 9129.8 Gcal. The cost saving is 316 Lakhs.

Motor Driven Bulk Absorber Inlet Separator condensate Pump (MP-3323B)






Electrical Energy saving during 2021-22



1. Replacement of 400 Nos of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke with 2X2 feet, 20 W Surface Mounted LED Fixtures at Central School in Township

To reduce the energy consumption, 400 Nos. of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke replaced with 2X2 feet, 20 W Surface Mounted LED Fixtures at Central School in Township. Annual saving comes 65564 kWh.



2. Replacement of 400 Nos of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke with 2X19 W LED Fixtures at Ammonia & Urea MCC Building:

To reduce the energy consumption, 400 Nos. of 2X36 W, 4 feet Tube light Fittings & 17 W per Choke replaced with 2X19 W LED Fixtures at Ammonia & Urea MCC Buildings. Annual saving comes 135102 kWh.



Electrical Energy saving during 2021-22



3. Replacement of 200 Nos 250 W SON-T Fittings with 120 W Street Light at Bagging area & Plant Roads in Offsites:

To reduce the energy consumption, 200 Nos 250 W SON-T Fittings replaced with 120 W Street Light at Bagging area & Plant Roads in Offsites. Annual saving comes 64571 kWh.



4. Replacement of 2400 Nos 36 W, 4 Feet Tube Lights with 19 W, 4 feet Tube Lights at Bagging floor & Offsites:

To reduce the energy consumption, 2400 Nos 36 W, 4 Feet Tube Lights replaced with 19 W, 4 feet Tube Lights at Bagging floor & Offsites. Annual saving comes 101326 kWh.



5. Replacement of 15 Nos 1000 W Tower Light Fixtures from Towers of Boundary wall with 300 W Flood Light:

To reduce the energy consumption, 15 Nos 1000 W Tower Light Fixtures from Towers of Boundary wall replaced with 300 W Flood Light. Annual saving comes 26077 kWh.



UTILISATIONS OF RENEWABLE ENERGY RESOURCES







Raw water Pump House

Bagging Top Floor

अतिथिगृह



Plant

Roof of Central Canteen Roof of Control Room Solar Unit at Plant

Solar Power Pack:

installed in **Guest House.**

- 800 KWp Solar power pack installed in plants and is connected to the LT Grid. \geq
- The Solar Power Units are in continuous operation generating Electric Power there by reduction of CO2 emission. >
- Solar light installed at different locations inside the plant and as well as also township. \succ

Year	Technology (Electrical)	Type of Energy	Onsite / Offsite	Installed Capacity (MW)	Generation (Million kWh)
FY-2019-20	Solar PV System	Electrical	Onsite	0.8	0.967
FY-2020-21	Solar PV System	Electrical	Onsite	0.8	1.014
FY-2021-22	Solar PV System	Electrical	Onsite	0.8	0.971
Solar Water Heaters 6 Nos. of Solar Water Heater			Last La	ethanation	

20

Carbon Foot Print

Our endeavours for every year is to reduce specific energy consumption, which will also result in lesser CO2 emissions. We have also installed solar power plants which also reduce CO2 emission.





Phulpur-II Unit has already installed a Carbon Di Oxide Recovery (CDR) Plant of 450 MTPD capacity in the year 2006-07, to recover CO2 from flue gases of Ammonia-II Plant primary reformer furnace. We have also installed solar power plants at different locations inside the Plants such as at the roof of Bagging Plant, Raw water storage tank, roof of central canteen and roof of plant control rooms to reduce CO2 emission.





WASTE MANAGEMENT AND WASTE UTILISATION

YEAR	ΤΥΡΕ	OF WASTE	QUANTITY OF WASTE GENERATED (KL)	DISPOSAL METHOD	TYPE OF WASTE	QUANTIT WASTE GENERAT		DISPOSAL METHOD	
FY- 2019-20	-	OIL & ISFORMER	47.25	Sent to Authorise Vendor	SPENT CATALYST	56.67		Sent to Authorise Vendor	
FY- 2020-21	-	OIL & ISFORMER	52.50	Sent to Authorise Vendor	SPENT CATALYST	NIL		Sent to Authorise Vendor	
FY- 2021-22		OIL & ISFORMER	52.50	Sent to Authorise Vendor	SPENT CATALYST	50.92		Sent to Authorise Vendor	
YEAR	NAME OF F		EL		TITY OF WAST SED (MT/YEA			NG VALUE I KCAL/YEAR	
FY- 2019-20	D TAIL GAS A		ND FLASH GAS		59441.328			27481	
FY- 2020-21		TAIL GAS AN	ND FLASH GAS		54648.262)9138	
FY- 2021-22		TAIL GAS AN	ND FLASH GAS		44505.206		170321		

Environment & Sustainability



Liquid Effluent Treatment

Rejection water of Reverse Osmosis Plant used in Coal yard in Phulpur Unit:



We are using cooling tower blowdown for RO Feed. The recovered RO product is being used in softening plant as make-up water and the reject water is being used in coal yard to supress the coal dust. The Plant Capacity is 3000 M3 /day (Recovery 85 %).

Sewage Treatment cum Recycle Plant:



The sewage generated in Plant Township is treated in Sewage Treatment Plant and is being used for irrigation purpose at Farm Land. The Plant Capacity is 125 M3 / hr.

Waste Disposal:



Bio degradable wastes from kitchen and horticulture are converted into very good manure by vermi composting System. The manure is used in horticulture, green belt area & 150 Acres farm land at Cordet

Rain water Harvesting System:



Total 5 Nos. Rain Water Harvesting systems are installed in township. IFFCO is also planning to install more Rain water harvesting systems at different locations.

Installation of Online Environment Monitoring System (IFFCO

Liquid Effluent Monitoring:

IFFCO Phulpur Unit continuously monitored the pH, Ammonical Nitrogen at guard pond area and Flow in pipe line of liquid effluent generated in the complex. After treatment, the liquid effluent reused effluent in horticulture & irrigation of farmland within IFFCO's premises.



Flow Instrument & local display

Local display for pH & TAN

Installation of Ammonia Sensor at strategic locations of Plants:



To monitor ammonia leakage, ammonia sensor is installed at strategic locations of Ammonia-II, Urea-II and Ammonia Storage Tank area of IFFCO Phulpur Unit. In case of any leakages in the plants, the Panel operator shall identify the location of Ammonia Leakage and take action accordingly to arrest the leakage. Water curtain has been provided at the periphery of the control room as well as ammonia feed pumps for safety of the Plant personnel.

पूर्णतः सहकारी स्वामित्व Wholly owned by Cooperatives

Procurement Process



IFFCO Phulpur has taken care of Energy optimization right from Procurement process among Vendors / Suppliers / Contractors

- The Evaluation of a Bid is done on the basis of Operating Cost
- Loading is being done to take care of the Performance and Productivity of equipment offered.
- In case the consumption of utilities is different for different Bidders. Extra operating cost over the minimum one shall be calculated as below for loading.

Operating cost = Difference in utilities consumption x Unit cost of Utility x 8760 x 0.9 x 5.5860 x N

Where:

- 8760 is number of available hours in a year
- 0.9 is availability factor
- 5.5860 is discount factor at an interest rate of 10% per annum for
- one year erection/commissioning and ten years operational period.
- N is the number of operating equipment items.



Teamwork, Employee Involvement & Monitoring

- Energy is monitored daily in presence of Unit Head, to facilitate this various reports are prepared and corrective actions are taken immediately to rectify the problem area.
- Various types of Reports are generated on daily/weekly/monthly/ quarterly and yearly basis for Reporting & Monitoring the Energy Consumption:

Phulpur Unit-II					EM-PRO-F-02
- nutput unit-in	Performanc	e Report for	:03.05.202	2	LIN-PROPERTY
		ut Norms per		-	
	over an mp	or norms per	MIT OF CITES		
			ACTUAL		
reputs	Unit	Dwy	Menth	Year	
UNG	000 SM3 KWH	0.0005	0.6021	0.6023	
POWER PURCHASED HSD	MT	0.0000	4.0519	0.0000	
CD.44.	MT	0.0159	0.0151	0.0000	
	MT				
PURCHASED AMINONIA		0.0000	0.0000	0.0000	
BAGS ENERGY	NO GCAL	22.2228	22.2228	22.2228	
LINE PERFORMANCE	OCAL	5.2392	5.2351	5.2156	
	Ingrats	Unit	Day	Month	Year
AMMONIA	Feed #LNG	0005M3/WT	0.6144	0.6363	0.6183
	Fuel RLNG	000SM3/WT	0.3792	0.3790	0.3799
	Total R-LNG	000SMR/WT	0.9926	0.9952	0.9982
	HP STEAM IMP	MT/MT	0.0000	0.0000	0.0000
	HP STEAM EXP	MT/MT	1.5164	1.5223	1.5708
	MP STEAM EXPORT	MT/MT	0.0763	0.0763	0.0783
	LP STEAM EXPORT	MT/MT	0.0689	0.0663	0.0641
	EMERSY (B.L)	GCAL/MT	7.2042	7.2007	7.3637
	EMERGY (OVERALL)	GCAL/MT	7.5555	7.5502	7.2957
UREA-1	AMIMONIA	MT/MT	0.5700	0.5700	0.5700
	HP STEAM (WITHOUT CDR)	MT/MT	0.9481	0.9386	0.9589
	HP STEAM (WITH CDR)	MT/MT	1.0691	1.0644	1/0779
	LP Steam Export	MT/MT	0.0227	0.0179	0.0330
	ENERGY B.L.	GCAL/MT	5.0035	5.0090	5.0000
	ENERGY (OVERALL)	GCAL/MT	5.2392	5.2351	5.2156
UNEA-II	AMMONIA	MT/MT	0.5700	0.5700	0.5700
	HP STEAM (WITHOUT COR)	MT/MT	0.9436	0.9388	0.9574
	HP STEAM (WITH CDR)	MT/MT	1.0695	1.0645	1.0758
	LP Steam Export	MT/MT	0.0227	0.0179	0.0880
	ENERGY B.L.	GCAL/MT	5.0039	5.0031	5.0055
	ENERGY (OVERALL)	GCAL/MT	5,2392	5,2351	5.2156
STEAM GENERATION					
	RUNG	DODSMR/WT	0.0000	0.0000	0.0000
	HP Steam internal	MT/MT	0.0000	0.0000	0.0000
	LP STEAM IMPORT	MT/MT	0.0000	0.0000	0.0000
	ENERGY (B.L)	GCAL/MT	0.0000	0.0000	0.0000
					JGM (TECH.)

Sample Performance Reports

Employee Engagement:

- IFFCO Phulpur Unit encourages its employees through Suggestion Scheme to give ideas of energy conservation.
- In our Unit, the have a suggestion scheme for all Employees. All Employees (Workman & Supervisor Level) participated the Suggestion Scheme Awards.

																												***	10.00
_				(MTP)					IERA3											мт/н	(r)						(MT/H		_
-m	ANNA	ALLIN	TOTAL	UREA 1	UNEA	TOTAL	123	or	SUB TOTAL		ANI		TOTAL	ANUMA I	1000	orea l	UPER A	TO	10	BHT	m	CER	TOTAL	AMM 1	LPS AMM 2	UPS UPEA 1	UPS UPEA 2	LPS TOTAL	5TE 100
1	1147.0	1886.7	2122.3	2246.1	3309.0	3335.1	323	50	179		104	354	283	52	- 25	- 72	324		15	34	-	29	203	29		in name	Cran's [35	1 100
	1289.0	1826.1	3064.6	1641.2	2852.7	6478.9	209	6.7	161		101	201	262	64	- 18	52	817	ě	14	11	ă	26	262	30	-		ě	30	
	1248.0	1881.6	3129.3	2326.0	3342.8	1000.7	127	1.45	1.04	0	10%	305	203	5.5	- 28	72	1218	0	24	18	0	218	283	29		0	0	34	
	1248.0	1884.7	3132.2	2253.3	3323.5	0074.8	128	1.6	182		100	309	288	5.5	- 33		324	0	2.0	24	0	28	288	29				33	
	1244.0	1889.5	2122.7	2280.1	3323.0	5549.1	129	5.0	101		105	375	285	54	- 27		2175		28	125		28	285	29				22	
	1245.0	1891.1	31.25.9	1155.2	3335.7	5561.9	122	5.7	1.79		104	334	283	50	- 25		315		28	15	0	29	283	29				34	
	1242.0	1891.P	0100.5	1152.4	3302.1	5554.2	222	5.7	1.79	0	1494	334	265	54	- 125	22	122		15	15	0	208	283	29	5	0		34	
	1248.0	1889.3	3136.7	2262.0	8908.2	1016.0	128	5.6	180	0	10%	305	265	81	- 28		1216	0	24	2/6	0	27	285	29	4	0	0	33	
	1248.0	1889.0	3135.8	2288.2	3306.0	1061.2	128	8.7	180	0	104	304	285	81	- 24	72	325	0	2.0	28	0	28	285	29		0	0	33	
	1045.0	1890.7	2122.5	2223	3294.3	3040.0	124	50	3.93		101	371	289	51	- 275	7.2	324		27	15	0	28	289	29				22	
	1244.0	1889.6	0100.2	2253.6	3300.5	5551.9	138	59	1.77	0	104	334	293	50	- 26	70	3175		25	15	0	28	283	29				35	
	1240.0	1092.7	0102.0	2252	9914.5	5566.5	337	54	175	0	105	305	276	54	- 125	71	125		15	34	0	28	278	29				85	
	1241.0	1890.4	3131.8	2258	3304.4	1010-4	116	5.6	174	0	104	304	278	50	- 26	72	324	0	24	1.8	0	29	278	29	4		0	36	
	1244.0	1882.1	3136.3	2248.7	3305.1	1014.8	118	60	175	0	104	304	279	50	- 26	72	324	0	2.0	2.4	0	29	278	29	4	1	0	3/5	
	1241.0	1899.2	2124.4	2253.5	3303.Z	2004.2	118	2.01	170		104	354	280	50	- 28	7.2	327		27	12	0	28	280	29	5			279	
	1259.0	1889.5	自由公司 带	2242.7	3305.5	5549.2	122	59	101	0	104	334	285	51	- 25	75	324		29	18	0	27	285	29	5	5		259	
	1257.0	1898.9	0105.9	2240.1	9912.0	5552.1	3.2.9	59	170	0	105	305	293	51	- 25	75	125		19	1.8	0	28	283	29	5	6		-90	
	1289.0	1886.0	3135.0	2298.8	3315.1	1014.9	114	5.6	173	0	10%	309	277	81	- 28	71	324	0	28	12	9	28	277	29	4	0	0	3(3)	
	1248.0	1883.8	3120.8	2287.1	3303.6	1040.7	118	544	174	0	104	304	278	82	- 21	7.8	321	0	12	12	0	218	278	31	4		0	-90	
	1243.0	1882.3	3124.8	2324.0	3315.0	1040.8	118	1.0	177		104	304	282	102	- 23		32.8	0	27	2.4	0	28	282	29			0	37	
	1244.0	3882.1	9125.9	2205.9	3347.Z	5555.1	138	59	1.77		106	395	285	50	- 22		325		27	17	0	28	285	29	+		0	37	
	1244.0	1892.6	9196.7	2208.4	9951.0	5559.1	3.29	60	1.79		105	305	264	- 55	- 25		825		12	1.5	0	28	284	29	5	12		56	
	1241.0	1807.1	3148.1	2236.6	3352.0	1168.5	338	1.4-	174		10%	309	279	5.5	- 24		326	0	17	11	0	28	278	29		1	0	36	
	1241.0	1800.6	3141.3	2238.0	3309.5	1040.4	118	60	173		104	304	277	82	- 28		324	0	28	12	0	28	277	29		2	0	36	
	1241.0	1898.3	2128.8	2189.0	3351.2	1040.B	114	5.0-	173		109	309	278	5.0	- 289		329	0	27	1.8	0	27	278	29		2	0	37	
	1242.0	1895.0	0107.4	2180.1	9920.0	5500.1	234	59	1.75		106	395	279	50	- 25		3.05		29	12	0	29	279	29				37	
	1240.0	1090.6	3131.0	2299.5	5290.4	5529.9	5.6.6	59	171		105	905	556	52	- 27		855		10	50		29	556	29				59	
	1241.0	1003.5	0104.6	2263.6	8290.5	5552.4	115	5.0	172		104	834	534	52	- 27		822		82	50	0	29	326	29	5	0	0	0.4	
	1244.0	1886.7	3130.8	2180.2	3360.7	1040.9	117	6D	170		109	309	281	82	- 24		329	0	17	11	0	29	283	29			0	37	

Sample Steam Balance Reports

								IFF00 - PHU	CHOIC CHEL								
							902	KLY PRODUCT	ION AND DIS	ROY							
weekly Della (FTel 67%). A	lag. 2022)																
				pur-l	_					pur-li			Overall (Pt	selper-1+11)			
Date	Ammonia Production, MT	Ammenia Drengy (D.L.). Goal/MT	Energy (Overall), Goulert	Unee Production, MT	Unix Drivingy (D.L.), OcarMT	Unes Shergy (Oversit), GoatMT	Anmonts Production, BT	Anmonia Energy (S.L.), OcaMIT	Animonia Energy (Overlan), Gesater	Urea Preduction, MT	Unio Energy (B.L.), GCO/MT	(Dversit), (Dversit), Gos/MT	Totar unea production (MT)	Complex Energy (CoalMT)		Renarks	
Theorical Minimum Energy		4.67			2.53			4.0			2.85						
ESP Reveng Case	1215		2.17	2150		5750	1858		7.07	3250		\$.17	5380-00		Stuttown Details I Energy	Finance for High	Got
81 August 2022	1250.7	1.126	7.828	2178.5	5.2%	5.762	1982.8	7.195	7.345	2384.5	4.955	5.109	1963.5	5.312			
R2 August 2022	1271.3	7.718	1.786	2240.0	5.374	5.762	1946.3	7.157	7.308	3352.0	4.958	5.101	5592.0	8.874			
83 August 2022	1270.1	7.718	1.716	2247.1	5.285	6.760	1945.1	7.077	7.341	1960.0	4.954	5.000	5607.1	5.312			
84 August 2022	1271.0	170	T.801	2265.3	5.385	5.761	1939.0	7.160	7.3%	2342.8	4.951	5.102	9608.1	0.079			
III Augusi 2022	1270.1	1.710	T 829	2298.1	8.287	8.798	1036.3	7.182	7.825	7825.2	4.951	6.113	881.3	1.000			
BC August 2022	1270.8	1718	T.803	2292.7	8.286	8.793	1926-8	7.148	7.290	2314.0	4.980	8.108	8876.7	5.354			
87 August 2022	1270.6	178	T.805	2279.8	5.269	5.761	1929.3	7.149	7.292	2210.0	4.954	5.079	5550.5	1.348			
Awakiy Data (Piel - 67th Awg. 2022)	8763	1718	T.888	15741.5	5.314	5.785	10585.6	7.987	7.216	22204.5	4.952	5.101	20120.0	5.3N			
Anneby Data (Aug., 2022)	0076.3	2.718	T.888	15741.5	5.314	5.785	12585.8	7.987	7.216	22204.5	4.952	5.101	22128.0	5.374			
Nearly Data (Apr., 2022 fo March, 2023)	91007.7	6,295	5.405	171686.9	5.417	4.211	24/091.1	7,212	7,875	421450.7	4.955	1,295	10004.0	5.802			\square



KiM(Tech.)

Sample Weekly Energy Reports

INTERNATIONAL CERTIFICATIONS



IFFCO



ENCON PROJECT BUDGET ALLOCATION



Details	2018-19	2019-20	2020-21	2021-22
Total turn over of company/plant (Rs. Million)	25431.8	27003.0	21140.6	26257.7
Amount Invested in ENCON Projects (Rs. Million)	120.92	26.55	2.693	58.73
Investment %	0.48	0.10	0.01	0.22

Learning from CII Energy Award 2021 or any other award program:

- The objective of the awards is to recognise and Award "Excellence" in Energy Management in Industries and to facilitate sharing of information by excellent energy efficient companies.
- It is a sense of competition to motivate other plants to achieve excellence and establish futurity by pinpointing Carbon Emission Reduction initiatives focused on energy conservation.
- The Awards evaluate all kinds of new processes, products, services, technologies, and other types of innovations in a common platform. They also assess new ideas and approaches along with tangible results.

Awards & Recognition









itige elabert HIRST PRIZE

"National Energy **Conservation** Awards-2020"



FAI Best Production Performance Award-2020

22nd National Award for Excellence in **Energy Management** in 2021 by CII.

Greentech Energy Conservation Award - 2021

Platinum Award-Grow Care Energy Conservation 2021

