



Confederation of Indian Industry



23rd
National Award for 2022
Excellence in Energy Management

JSW *Steel Coated Product Limited, Vasind*

Presenters:
Mr. Anish Karahe- AGM

1. Brief introduction on Company – Founder of JSW

FOUNDER OF JINDAL GROUP



Shri. O. P. Jindal

“Where others see walls.....,
I see doors.....”

Legacy



Shri. Sajjan Jindal



Mr. Sajjan Jindal

- ✓ JSW Steel
- ✓ JSW Steel Coated Products Ltd
- ✓ JSW Energy
- ✓ JSW Infrastructure
- ✓ JSW Cement
- ✓ JSW GBS
- ✓ JSW Sports
- ✓ JSW Foundation

Whatever we do, the aim is
always to bring positive
change and make things
Better Everyday

1. Brief introduction on Company – Process & Product



Vijayanagar – 13 MTPA

Salem – 1.2 MTPA

Dolvi – 10 MTPA

JSWBPSL – 3.5 MTPA

JSWISPL – 1 MTPA



Engaged in producing the Coated Products

First facility of JSW Group in 1982

GI/GL 1.5 MTPA,

PPGI/GL 0.475 MTPA

CAL 0.5 MTPA

Export oriented, located near port and west Indian market

Kalmeshwar – 0.96 MTPA

Tarapur – 1.2 MTPA

Vasind
2.0
MTPA

100%
Subsidiary of
JSW Steel.
India's Leading
Coated Steel
Producer (4.2
MTPA)

MAIN
PRODUCTS
1. Galvanizing
2. Galvalume
3. Colour coated
coil & sheets
4. CAL

Vasind
2 MTPA

Rolling

CRM3
CRM4
PLTCM

Galvanizing

CGL - 1
CGL - 2
CGL - 3
Slitting - 2
CTL - 2
Profiling - 3

Colour
Coating


CCL - 1
CCL - 2
CCL - 3
Embossing Line

Continues
Annealing Line



Energy Consumption


Distribution Energy Used %



Process Wise Energy Consumption of Vasind FY-22


Area	Power(Lac kWh)	RLNG(Lac MMBtu)	Energy in Gcal
Pre-Rolling	85	2.82	78435
Rolling	843	0.06	73976
Galvanizing(GL/GI)	679	6.31	217420
Colour Coating	184	2.10	68871
Auxiliary	70	0.00	6263
Grand Total	1862	11.29	444965

Energy Sources




Total : 444725 GCal


Process Wise Power Consumption kWh



Process Wise RLNG Consumption MMBtu






Process Wise Energy Consumption GCal



3. Specific Energy Consumption in last three years

Plant Energy Consumption					
Energy	Unit	FY 19	FY 20	FY 21	FY 22
Electricity	Lakh Kwh	851	832	855	1862
Thermal	Million Kcal	156371	153442	154224	284823
Specific Energy Consumption	MTOE/t	0.0412	0.0399	0.04	0.041

Plant Capacity Utilization					
Year	Unit	FY 19	FY 20	FY 21	FY 22
Installed Capacity	Lacs ton	4.5	4.5	4.5	8
Actual Production	Lacs ton	4.51	4.07	4.23	8.18
Capacity Utilization	%	100.2	90.4	94.0	102.3




3. Specific Energy Consumption in last three years

Perform Achieve Trade (PAT) Cycle

PAT-1					PAT-2				
Energy Consumption (MTOE/T)			Energy Saving MTOE	ESCerts Awarded	Energy Consumption (MTOE/T)			Energy Saving MTOE	ESCerts Recommended
Notified	Notified Target	Achieved and Verified			Notified	Notified Target	Achieved and Verified		
0.0594	0.0575	0.0545	2042.3	1875	0.044	0.0414	0.042	0	-294

Specific Energy Consumption MTOE/t

SEC Reduction in PAT-1 8.2%





SEC Reduction in PAT-2 4.54%

SEC Reduction in Last 6 Years 12.75%



4. Information on Competitors / National & Global Benchmark




Tata BSL Khapoli CII Data of 2018-19

4. Information on Competitors / National & Global Benchmark

	Initiatives	Expected Energy Savings GCal / t
FY 22	<ol style="list-style-type: none"> 1. PLTCM Commissioning-World class technology 2. Capacity enhancement – new upcoming lines CGL3, CGL4, CCL3 3. IE 3 motors 	0.035
FY 23	<ol style="list-style-type: none"> 1. Use of Solar Power (4.5 MWp) 	0.036
FY 24	<ol style="list-style-type: none"> 1. Conversion of 14 MW DC Motors to AC with common DC Bus 2. Energy Efficient Equipment 	0.015
FY 25	<ol style="list-style-type: none"> 1. Installation of 35 MW Solar Power plant by JSW Energy for Coated Business. 2. Replace all old motors with IE 3 motors 	0.025

Expected Saving Mega Cal/t







Total 26% SEC will be reduced (From- 0.411 to 0.301 G Cal/t)

5. Energy Saving project implemented in last 4 years

FY	No. projects	Investment in INR Million	Electrical Saving in Million kWh	Thermal Saving in Million Kcal	Saving in INR Million	Impact On SEC in %
FY18-19	9	90	4.7	24796	41	12.0
FY19-20	15	160	2.93	14233	47	7.5
FY20-21	9	16.8	1.7	1260	15.7	1.1
FY21-22	5	170	7.8	0	63.27	1.5

5. Energy Saving project implemented in last 3 years



5. Energy Saving project implemented in last 3 years

ENCON Measures FY 20

ENCON Measures	Electrical Savings (kWh)	Thermal Savings (GCal)	Savings (Rs Million)	Investment (Rs Million)	Payback (Months)
Cooling tower pump to be replaced with high efficiency pump	149052	0	1	0.56	6.3
Reduce speed of CRM 4 Coolant pump during idle running and reduce the pressure to 5 bar during normal operation	71000	0	1	0	0.0
Replacement of water cooled damper with non water cooled damper	0	283.5	1	0.2	2.8
Burner optimization in 5 t boiler	0	519.372	2	0.4	3.1
Replacement of old motor ,55 KW of HP Pump with Energy efficient motors.(IE 3)	14256	0	0	0.13	15.2
Oxygen analyzer to be installed at CGL-2 Stack	0	257.04	1	0.5	7.8
Oxygen analyzer to be installed at CGL1 Stack	0	1379.7	4	0.5	1.5
Replacement of inefficient ventilation blowers of mill motor with high efficiency blowers.	229000	0	2	1.5	10.9

ZERO INVESTMENT Projects

5. Energy Saving project implemented in last 3 years

ENCON Measures FY 20

ENCON Measures	Electrical Savings (kWh)	Thermal Savings (GCal)	Savings (Rs Million)	Investment (Rs Million)	Payback (Months)
Provision of local burner at CCL-2 oven to reduce fuel consumption	0	9072	27	16	7.1
Fixed power optimization by speed increased from 120 to 150 mpm	1800000	2721	20	140	84
Optimize terminal voltage of the transformers by adjusting tap position	177000	0	1	0	0.0
Pilot Blower of 9.3 kw made off after line start	50000	0	0	0	0.0
Replacement of old motors Two nos,45 KW of Pump house and One no 30 KW of Exit Hydraulic Pump with Energy efficient motors.(IE 3)	45990	0	0	0.3	10.9
Stop CGL-1 Pump house and use CCL pumphouse after modification of Piping and installtion of Spare Pump	365000	0	3	0.5	2.3
Replacement of old motors Two nos ,45 KW of Pump house with Energy efficient motors.(IE 3)	35040	0	0	0.3	14.3
Total	2936338	14233	62.2	160.89	31

Zero Investment Projects

5. Energy Saving project implemented in last 3 years

ENCON Measures FY 21

ENCON Measures	Electrical Savings (kWh)	Thermal Savings	Savings (Rs Million)	Investment (Rs Million)	Payback (Months)
Installation of VFD in Crane LT and CT to reduce power consumption	22000	0	0.15	0.30	23.99
Improve power factor from 0.965 to 0.999 by installing APFC	1200000	0	8.18	16.00	23.46
Installation of VFD at CCL1 RTO combustion blower	80000	0	0.55	0.00	0.00
CCL-1 , All steering / staggering unit pump motor off Auto after line stopped due to any reason.	20461	0	0.14	0.00	0.00
CCL-2 , All steering / staggering unit pump motor off Auto after line stopped due to any reason.	18105	0	0.12	0.00	0.00
CGL-1, All steering / staggering unit pump motor off in Auto after line stopped for more than 15 Min.	30769	0	0.21	0.00	0.00
CCL Pump house connect with New pump of CGL-1 and CCL pump house stop. Combined use of New cooling tower pump for CGL-1 and CCL	47538	0	0.32	0.00	0.00
CCL-2 RTO is to be made off during sample testing and idle hrs	363000	0	2.48	0.50	2.42
Recoiler Staggering 1&2 Pump Motor On/off in auto according to recoiler selection.	0	1250	3.60	0.00	0.00
Total	1781873	1250	15.75	16.80	11.3

Zero Investment Projects

5. Energy Saving project implemented in last 3 years

ENCON Measures FY 22

ENCON Measures	Electrical Savings (kWh)	Thermal Savings (GCal)	Savings (Rs Million)	Investment (Rs Million)	Payback (Months)
Installation of 1.5 million ton PLTCM with advance energy efficient technology	5000000	0	40.5	100	29.6
Fixed power optimization by speed increased from 65 to 100 mpm	1875000	0	15.2	70	55.3
CGL-1, Br5 M1 and Recoiler Motor cooling blowers to be replaced with low power high efficiency blowers.	25538	0	0.2	0.2	11.6
Reduction in Compressor Power by 1700 kWh/Day. A. Installation of Flow meter in air lines B. Leakage arrest at all unit. C. effective loading /unloading setting.	561000	0	4.5	0.7	1.8
Installation of pyrometer and close loop control of Induction oven and blower	340000	0	2.9	0.5	2.1
Total	7801538	0	63.33	171.40	4.4

5. Energy Saving project implemented in last 3 years

Objectives (FY-23)	Potential Saving				Investment Required Rs Lac
	kWh/A	RLNG (MMBtu/A)	G Cal/A	Rs Lac/A	
Rectify the steam traps and increase the condensate recovery (2% Reduction in RLNG)	0	4080	1028	84	50
Install ControlAIR Intelligent Flow Control (IFC) System for air compressors (10% Red in Compressor Power)	620500	0	534	43	100
Replacement of Old inefficient motors with IE3/4 Motors (4% Red)	79200	0	68	6	20
Replacement of CT/LT of 5 nos Old cranes slipping control with VFD (20 Units/Day)	36500	0	31	3	25
CGL-2 CAG D1 blower to be replaced with high efficiency blower	323000	0	278	23	15
CRM-3 Fume Exhaust blower to be replace with high efficiency motor	269000	0	231	19	15
CRM3-Conversion of DC to AC motors and speed increased from 450 to 1400 rpm to optimize power & increase productivity.	1250000	0	1075	88	3500
Installation of Inverted U type furnace at CGL 2	0	14011	3531	287	1000
DC to AC drive conversion system at RW 4	6558	0	6	0	60
Installation of roof top solar panels in Opex model at Vasind	4032000	0	3468	282	0
Total	6616758	18091	10249	834	4785

No 1 Projects Implemented

Use of Pyrometer to close loop control of Induction Oven Power


PROBLEM STATEMENT

At CGL2 Galvalume sheet dry after Chemical Coating by using Induction Oven

Induction oven running at fixed power

If line speed low or thinner size material processed sheet passed away from Oven carry high temperature then required as per process

Induction Oven Control (Before)



No 1 Projects Implemented

Use of Pyrometer to close loop control of Induction Oven Power

Solution Proposed

Installation of Online Pyrometer for sheet temperature measurement at exit of Oven


Measure the Tons per hour output from oven by calculating Sheet Width*Thickness*Line Speed

Set the process required sheet temperature after the Oven

Control the Oven heating reference in close loop with the sheet actual temperature

Total investment required INR 5 Lac and potential saving per Annum 3.4 Lac kWh Electrical power, and INR 2.89 million per year.

Induction Oven Control (After)






Pickling Linked Tandem Cold Mill

BEFORE

Investment Rs.800 Cr

IN FY - 19



HRS

Pickling

Cold Rolling

Pickling Linked Tandem Cold Mill (PLTCM)

Power
107 kWh/t

RLNG
0.1
MMBtu/t

**Power
70 kWh/t**

**RLNG
0.05
MMBtu/t**

**Energy Consumption
0.081 Gcal/t**

**Energy Consumption
0.064 Gcal/t**

Estimated Energy Saving-42792 Gcal/A @ 1.3 Million Ton Production

Combination of three process

Use of Energy Efficient AC motors

MV VFD drives & advance Level-II automation

7. Utilization of renewable Energy Sources

Renewable Energy generation

Financial year	Technology (Electrical)	Type of Energy	Onsite/ Offsite	Solar System (kWp)	Solar Power	Total power used Million kWh	% Used
FY 20	PV	Solar	Onsite	5.5	93294	80	0.11
FY 21	PV	Solar	Onsite	5.5	92294	85.5	0.11
FY 22	PV	Solar	Onsite	5.5	90294	186.2	0.05


RPO Target

FY	Total Power (MU)	RPO TARGET		REC PURCHASED		Value Rs Lac
		SOLAR	NON SOLAR	SOLAR	NON SOLAR	
FY 20	78.6	2751	9969	2751	9969	228
FY 21	87.3	874	7863	0	0	0
FY 22	161.73	2021	15364	0	0	0
TOTAL	327.6	5646	33196	2751	9969	228


8. Waste Utilization and Management

S. No.	Year	Waste Details	Quantity	GCV kCal	Heat Value M kCal	Waste as percentage of total fuel
1	2019-20	Paint VOC	5246	7000	36722	16.32
2	2020-21	Paint VOC	5409	7000	37863	16.06
3	2021-22	Paint VOC	8388	7000	58720	13.83

Waste as percentage (%) of total fuel



Qty of Waste generated (MT/year)



9 GHG Inventorization – Carbon Neutrality

Carbon Neutrality refers to achieving net zero carbon dioxide emissions by balancing carbon emissions with carbon removal by carbon offset or eliminating carbon emission altogether


PARAMETERS	VSD	TPR	KLM	COATED
Energy Consumption (GJ)	903588	1602358	1408565	3914511
CO2 Emission (tCO2)	78937	148550	143774	371261

**1.8 MTPA
to
4 MTPA**

PARAMETERS	VSD	TPR	KLM	COATED
Energy Consumption (GJ)	7835359	5660080	3135920	17296061
CO2 Emission (tCO2)	409692	296236	190078	930291

9 GHG Inventorization – Carbon Neutrality

Parameter	Unit	VASIND	Reduction in 10% Energy Consumption	Replacement of 90% Electrical Power by Renewable Energy	Replacement of 90% Thermal Energy Emission by Carbon Offset	Final Carbon Emission
CO2 Emission	tCO2	409692	40969	195070	173652	0
	%	100	10	48	42	0





Target - 2030

9 GHG Inventorization – Inventorization

Sr No	Detail of Area Green Zone	Area (Sq Mtr)	Total Trees	Shrubs	Lawn Sq Mtr
1	Factory inside	40676	1800	8500	25800
2	R.C Farm House, Guest House	91475	2500	8000	85000
3	SVTC, Other open Space	42000	350	100	1500
4	Colony 1,2,3	21866	650	1500	21866
		196017	5300	18100	134166

As on Date --->	8568	17235	102555
Total Tree planted ->	128358		
CO2 t / year Offset	25671.6		

Calculation based on Carbonify.com
5 trees for 1 ton of CO2 /year




Sustainability and GHG CO2 emissions

Target to reduce the CO2 Emission by 3% in FY-23 and to become Carbon neutral plant by Fy-30, by adopting following initiatives-

1. Installation of 4.5 MWp solar power plant.- FY-23
2. Conversion of DC to AC for both the Old Cold rolling Mills- FY-23
3. Installation of 35 MWp Solar power plant by JSW Energy for coated business-FY-25
4. Replacement of all the old AC motors with IE-3 Motors- FY-26
5. Plantation of 50000 trees till FY-30 every year - 5000


10. Team Work, Employee Involvement & Monitoring

Monitoring system -----



10. Team Work, Employee Involvement & Monitoring

Supplier Meet



Stake Holders	Initiatives
Employee	Energy Awareness, Paper less Invoicing, EnFA,
Customer	Awareness, product catalogue, CCMS Customer Audit , Desk top Audit , Google meetings
Supplier	ARIBA, EnMS -ISO 50001
Society	Awareness – Skit, Training

LED CONVERSION - CSR

Impact	Quantity	Power Consumption	Saving
BEFORE	Total HPSV Lights Installed 1800 Nos.	173 kW	Power Saving 4.54 Lacs kWh / Annum
AFTER	Installed LED Lights 958 Nos.	84 kW	Potential saving Rs.26.37 Lacs/Annum

10. Team Work, Employee Involvement & Monitoring

Society – Energy Week



Energy week Celebration



Energy Exhibition



Energy Conservation Skit





Energy Exhibition



Recognition



11. Implementation of ISO 50001



Energy Conservation Awareness Society
2250 Nos. Energy Efficient Chulla Distribution
40 Nos Solar Street lights in near by Villages
2500 Nos LED Bulbs distributions

Review

- S** Safety Systems, Compliance & Governance
- P** People
- I** Innovation & Quality Management
- C** Customer Delight
- E** **Energy**, Environment & Safety

13. Long term Vision on EE



- 1. PLTCM Commissioning – World Class Technology
- 2. Capacity enhancement – new upcoming lines CGL3, CGL4, CCL3
- 3. IE 3 motors

FY 22

- 1. Use of Solar Power (4.5 MW)


FY 23

- 1. Conversion of 14 MW DC Motors to AC with common DC Bus
- 2. Energy Efficient Equipment

FY 23

- 1. Installation of 35 MW Solar Power plant by JSW Energy for Coated Business.
- 2. Replace all old motors with IE 3 motors

FY 24



FY 30

Awards, Achievement & Recognition in Energy

**MEDA 14th State Level
Energy Conservation Award**

**MEDA 13th State Level
Energy Conservation Award**



**MEDA 12th State Level
Energy Conservation Award**



**Global Energy
Award by CEM**



**Platinum in APEX India
Energy Award 2019**



CII National Energy Leader Award 2020



**CII-
19th/20th/21st
National Award
-Excellent
Energy Efficient
Unit**





**What we Earn is not important,
but what we Save is most important...**

Conserve Energy ..!!!! Save Earth.....!!!



Thank You