



23<sup>rd</sup> National Award for Excellence  
in Energy Management 2022

---

# ADTPS – Last 20 years Performance



Description	Remark
Plant Load Factor ( PLF)	92.32 %
Availability	95.04 %
Specific Oil consumption	0.131 ml/kwh
Aux Consumption without FGD	7.797 %
Aux Consumption with FGD	9.131 %
Heat Rate	2286 Kcal/kwh


**ADTPS achieved Plant load factor > 100% For 9 financial years**

# 2.0 Energy Consumption Overview




## Plant Performance

Generation in MUs



Reduction in generation due to influx of RE, Back down and coal shortage


PLF in %



Reduction in PLF Back down -11.38% Coal shortage - 3.0%


**Backing down -498,7484 MUs**

APC in %



Use of raw coal by 10% Reduction in imported coal - by 35% DSM implementation


Heat rate Kcal/Kwh Vs PLF %



Sustainable heat rate even though tech minimum reduced to 55%


# Plant Performance

**Availability in %**




U1 overhaul  
U1 Turbine  
Balancing  
work

**DM Water consumption in %**



Suspected  
condenser  
tube  
leakage,  
blow down  
repeated


**Sp oil consumption in ml/KWh**



Additional  
Cold start  
Up


# 3.0 Bench marking- Performance against Regulatory Targets **adani** Electricity

## ADTPS FY 21-22



MERC MYT Target	
Heat rate	2430 kcal/kwh
Aux Power	8.5 % + 1.2 % for FGD

**MERC SEC Target for FY Year 2021-22**



**Without FGD**

**National SEC Benchmark**

Source- CEA Recommendations for thermal generating stations for tariff period 2019-24

**Aux Power consumption in %**

**Backing down by 498.7484 MUs**

## Bench Marking with Peer Companies for FY 2021-22




Description	UoM	ADTPS-Dahanu	GWEL-Warora	JSW-Ratnagiri	Reliance-Rosa	RPG-Dhariwal	Lanco-Amarkantak
Plant Capacity	MW	2*250	2*300	4*300	4*300	2*300	2*300
Availability	%	90.75	79.01	64.79	85.1	90.5	90.57
PLF	%	76.21	66.2	57.31	54.9	75.93	76.56
Loading Factor	%	83.97	83.6	88.45	64.51	83.9	84.53
Aux. Power consumption	%	8.691	8.2	8.08	8.2	7.82	7.98
Sp. Oil consumption	mL/Kwh	0.112	0.17	0.13	0.14	0.19	0.14
DM Water Make-up	%	0.41	0.15	0.48	0.2	0.45	0.29
Heat Rate	Kcal/Kwh	2261	2310	2329	2350	2341	2377

# Benchmarking within Organization


Thermal Stations Ranking for Month Jun-2022			
Rank	Station	State	Achieved Score
1	ADTPS Dahanu	Maharashtra	85.50%
2	APMuL Mundra	Gujarat	84.00%
3	REGL Raigarh	Chhattisgarh	69.50%
4	APRL Kawai	Rajasthan	62.50%
5	APML Tiroda	Maharashtra	61.00%
6	MEL Mahan	Madhya Pradesh	52.00%
7	REL Raipur	Chhattisgarh	48.50%
<b>Note:</b> Station having PLF lower than 40% are excluded from ranking. UPCL Udupi was under RSD for complete month			

Thermal Stations Ranking - YTD			
Rank	Station	State	Achieved Score
1	ADTPS Dahanu	Maharashtra	91.00%
2	APMuL Mundra	Gujarat	84.00%
3	APRL Kawai	Rajasthan	80.00%
4	APML Tiroda	Maharashtra	69.00%
5	REGL Raigarh	Chhattisgarh	67.50%
6	MEL Mahan	Madhya Pradesh	64.50%
7	REL Raipur	Chhattisgarh	59.00%
<b>Note:</b> Station having PLF lower than 40% are excluded from ranking. UPCL Udupi have PLF less than 40%			

MTD Score




YTD Score




## 4.0 Energy Saving projects implemented


### Summary of Investment and Energy saving




**Coal saving in 4 Years - 66839 MT**



**Energy saving in 4 Years - 90.86 Million Kwh**



**Investments in 4 Years - 8188 Rs Lacs**



**Financial Impact in 4 Years - 5904 Rs Lacs**



## Energy Conservation Projects 2021-22

<b>Energy Saving Project</b>	<b>Savings /Year (Rs. Lacs)</b>	<b>Investments (Rs. Lacs)</b>
Replacement of HP & IP Turbine - OH of LP Turbine	1657.00	1238.65
Reduction in slip loss of BFP 1B hydraulic coupling in U-1	101.00	0.63
De-staging -CEP 1B	3.54	9.0

## Energy Conservation Projects 2020-21

<b>Energy Saving Project</b>	<b>Savings /Year (Rs. Lacs)</b>	<b>Investments (Rs. Lacs)</b>
HP Heater Performance improvement by attending parting plate leakage	249.00	0.25
Replacement of BFP Cartridge in BFP 1A	160.60	58
Installation of Energy Efficient Lighting	15.70	30.33

## Energy Conservation Projects 2019-20

<b>Energy Saving Project</b>	<b>Savings /Year (Rs. Lacs)</b>	<b>Investments (Rs. Lacs)</b>
Unit-2 Replacement of IP turbine by new one and Overhauling of LP Turbine.	1007	3212
Unit-2 Heat rate improvement due to HP Heater Performance attending of parting plate leakage	75	1
Unit-2 Air Preheater – Seals are upgraded by double seal and Flue gas duct leakage and replacement of flue gas duct expansion bellows	265	44
De – staging of impeller Condensate Extraction Pump in Unit-2	1	10
Installation of CEP VFD in Unit-1	33	40
Improvement in Heat rate by jet cleaning of APH basket in unit-2	183	0.75

# Energy Saving Project Implemented in FY 2021-22

## Replacement of HP & IP Turbine - OH of LP Turbine



Refurbished HP turbine




Refurbished IP turbine




Servicing LP turbine

# Performance improvement in Heat Rate




**2.08 % Reduction in TG Heat Rate**



**1.80 % Reduction in Unit Heat Rate**

Improvement in Heat rate in Kcal/Kwh	Investment in Rs Crs	Net saving in Rs Cr	Saving of coal in MT	CO <sub>2</sub> Reduction in MT
41	16.57	12.10	20568	29885

## Reduction in slip loss of BFP 1B hydraulic coupling in U-1





Modified Gear ratio  
retrofitted in existing  
hydraulic coupling

Gear Ratio changed  
from 165/41 to 133/36

Improvement in APC in KW	Investment in Rs Crs	Net saving in Rs Crs	Saving of coal in MT	CO <sub>2</sub> Reduction in MT
584	1.05	1.61	1003	1457



# De-staging -CEP 1B



Improvement APC in KW	Investment in Rs lacs	Net saving in Rs Lacs	Saving of coal in MT	CO <sub>2</sub> Reduction in MT
83	9.0	2.54	16	23

## 5.0 Innovative projects

---



# Reduction in CEP MV VFD Tripping



## Problem Statement

**Increase in the tripping of Medium Voltage Variable Frequency Drive (MV VFD) installed for Condensate Extraction Pump (CEP) encountered in last 3 years resulting in loss of energy saving opportunity of 1.126 Mus and generation loss of 1.303 Mus.**






# Reduction in CEP MV VFD Tripping



## Cause Effect Diagram




Ishikawa Diagram (Fish-bone Analysis)




# Reduction in CEP MV VFD Tripping

## IGBT Terminal Connection Modification



### BEFORE

Existing IGBT connections with no insulating sleeves at gate terminal



### AFTER

Covering with the Insulating Sleeves at gate terminal



# Reduction in CEP MV VFD Tripping



## Cooling System Modification



### BEFORE

Cooling system duct design was not proper and open circuit cooling system was used



### AFTER

Cooling system duct design modified and converted to closed circuit



# Reduction in CEP MV VFD Tripping



## Overhauling of VFD

### SOP for Overhauling of MV VFD Power Cells

- 1) Remove power cell fiber optic cables and power cell connection links
- 2) Dismantle and remove all power cells from VFD panel
- 3) Carry out thorough cleaning of power cell internals using vacuum cleaner and manually using cloth
- 4) Ensure connection tightness of power cell internal components e.g., IGBT and control cards
- 5) Ensure there is no power cell component damage, deformation, discoloration and rectify same if required.
- 6) Carefully assemble all power cells in place again and restore all connection links and fiber optic cables






# Reduction in CEP MV VFD Tripping



## Result Monitoring Dashboard


Million units

Energy Savings




Rs.

Maintenance Cost




Hours

CEP VFD Non-availability



Nos.

CEP VFD Tripping Trend





## 6.0 Renewable Energy

### Installation of 55 KW solar Power at ADM Building



- FY 2021-22 Solar Generation -68393.50 KWh
- FY 2021- 22 PLF – 14.20%
- Total Solar energy generation since inception -244022 KWh

#### New Initiative

- ADTPS also identified place for installation of another **550 KW Roof Top solar (Project Cost @ 360 Lacs)**
- **Roof Top solar at AAQM station**
- In plant, 160MW solar power generation area identified. This will be reduced 149 Mus of auxiliary power consumption. ( Assuming 17% PLF)

## 7.0 Environment Management-Ash Utilization

### Dry Evacuation system 2005

It is the first of its kind of system installed in India. In classifiers – mixture of fly ash is separated into fine ash

### Ash Gridding Unit 2011

First unit being used in the any power plant in Asia for improving coarse ash utilization

To grind the coarse ash into finer size of less than 45  $\mu\text{m}$ , thus improved total ash utilization

### 300 MT Ash Storage Silo 2014-15

To counter day - to - day fly ash demand variation in availability of ash lifting vehicle


100% ash utilization since FY 2014

# Dry Ash Silo's & Ash Grinding Unit

**Fine & Coarse Ash Silo's**



**Ash Grinding Unit & 300 MT Silo**




Particulars	UOM	2019-20	2020-21	2021-22
Ash Generated	Tons	425076	375348	634391
Ash Utilization	%	128.06	112.65	105.79
Ash Utilized in manufacturing of cement/concrete	%	68.35	56.18	58.38
Ash Utilized in Fly Ash Bricks	%	59.72	56.47	47.41



# 8.0 Environment Management Emission



## Assurance on AEML GHG Emissions & Renewable Energy Mix FY22



- Successfully completed and published AEML GHG Emissions & Renewable Energy Mix Assurance statement.
- Showcase our progress against committed sustainability KPI's.

**DNV**

**GHG Emissions (Scope-1 & Scope-2) Summary**

Scope	Emission Source	Total GHG Emissions 2021-22 (tCO2e)
Scope-1	Fossil fuels (Coal, Diesel, Petrol, LDO, LPG) used in stationary and mobile equipment's and coal used in electricity generation process. SF6 and Refrigerants used in operations & maintenance activities	2,690,622
Scope-2	Emissions arising from consumption of purchased electricity towards auxiliary power consumed in generation, transmission and distribution assets owned by ADML and T&D losses incurred	547,204

**GHG Emission Intensity (KPI-2):**

	Boundary of emission within the company	FY-2018-19	FY-2021-22
GHG tCO2e	AEML: Scope 1 & Scope 2	3,750,060	3,237,826
EBITDA in INR- in Crore	ADML	1,664	2,063
Emission Intensity (tCO2e)/ EBITDA in INR in Crore		2,254	1,554

**Statement of Competence and Independence**

DNV applies its own management standards and compliance policies for quality control, in accordance with ISO IEC 17021:2015 - Conformity Assessment Requirements for bodies providing audit and certification of management systems, and accordingly maintains a comprehensive system of quality control including documented policies and procedures regarding compliance with ethical requirements, professional standards and applicable legal and regulatory requirements.

We have complied with the DNV Code of Conduct<sup>2</sup> during the assurance engagement and maintain independence where required by relevant ethical requirements as detailed in DNV VeriGustain. The engagement work was carried out by an independent team of sustainability assurance professionals. DNV was not involved in the preparation of any statements or data included in the Report except for this Verification Statement. DNV maintains complete impartiality toward stakeholders interviewed during the assurance process. DNV did not provide any services to AEML or its subsidiaries in the scope of assurance during FY 2021-2022 that could compromise the independence or impartiality of our work.

For DNV




<b>Vadakepath Nandkumar</b> Digitally signed by Vadakepath Nandkumar Date: 2022.06.27 13:13:48 +05'30' Vadakepath Nandkumar Lead Verifier DNV Business Assurance India Private Limited, India.	<b>Radhakrishnan, Kiran</b> Digitally signed by Radhakrishnan, Kiran Date: 2022.06.27 16:50:02 +05'30' Kiran Radhakrishnan Technical Reviewer DNV Business Assurance India Private Limited, India.
---	---

Bangalore, India, 27<sup>th</sup> June 2022.

**AA1000**  
Licensed Report  
000-10/V3-22PDF

DNV Business Assurance India Private Limited is a part of DNV - Business Assurance, a global provider of certification, verification, assessment and testing.

# Stack Parameters



# PAT Cycle

**ESCerts ISSUED\ENTITLED TO BE PURCHASED**


PAT Cycle	ESCerts Claimed	ESCerts Issued	Entitled to be Purchased	Eligibility Type	Sr.No. From	Sr.No. To
PAT(1) 2012-2015	4591	4591		Seller	01-03087601-TPP0073MH-160217	01-03092191-TPP0073MH-160217
PAT(2) 2016-2019	8749	8749	0	Seller	02-01621152-TPP0073MH-180821	02-01629900-TPP0073MH-180821

**TRADING**

PAT(1)|2012-2015      PAT(2)|2016-2019

Banked ESCert: From Previous Cycle	Eligibility Type:	ESCerts Issued:	Opening Balance: (Banked ESCerts From Previous Cycle + ESCerts Issued)	Closing Balance:	Total Sold:
0	Seller	4591	4591	4591	0




Reduction in SHNR by 24 Kcal/Kwh

Successful completion of PAT-1 & PAT -2 Cycle with gain of 4591 and 8749 Escerts

# Certificate

## Single Use Plastic Assessment Certificate



## Zero Waste to Landfill Certificate



## Water Efficiency Management System








# 9.0 Best Practices in the plant

## Functionalities of Video Analytics

- ❖ Identify & capture the PPE related deviations through AI based application software
- ❖ Alerts immediately send to Monitoring PCs in Safety dept & PCR
- ❖ SMS / WhatsApp alert is be given to safety In-charge
- ❖ Auto Announcement is done in that area



# Digitization

SAP



Digital Logbooks



QR code-based  
Safety &  
Environment Data  
sheet.



Knowledge  
Management through  
MS teams



Digital approval  
portal - Esign



Remote Operation of  
Stack analyzer moisture  
removal system



# Maintenance and Reliability

- Use of modular concept that allows the replacement of major assemblies in a minimum amount of time and expenditure (e.g. HP turbine module, CW debris filter, Primary & Secondary fans rotor, Boiler feed pump cartridge, vacuum pump, CW pump)
- Modular Scaffolding for Boiler Overhauling



IP Turbine Module



Scaffolding



# Best Practices – Safety -Precaution Boards at Site



**ADANI DAHANU THERMAL POWER STATION (ADTPS)**  
**PRIMARY AIR (P.A.) FAN**

**EQUIPMENT DESCRIPTION:** PA fans (AP2-17/12) used at ADTPS are of axial reaction two stage type. Primary air is used to lift pulverized coal from coal mill to the furnace. During the transportation, it is also responsible for removing moisture from pulverized coal. PA takes ambient air; & its discharge is divided into two parts. One part is made to pass through the air pre-heater and the other part form Cold PA header. Both hot and cold air is then mixed in desired proportion to maintain suitable mill temperature.

**HAZARDS:** Exposure to high pressure air flow, confined space, exposure to moving machinery, slippage due to oil, fall from height, fire/explosion, due to hot work, contact with electrical source, electrocution, exposure to dust/ash etc.

It must be ensured that all required energy sources are completely isolated and tagged, before initiating the work

**EQUIPMENT ENERGY SOURCES LOCK OUT DETAILS**

ENERGY TYPE & SOURCE	LOCKOUT PROCEDURE	LOCKOUT LOCATION	PROCEDURE VERIFICATIONS
ELECTRICAL (HT)	PA FAN MAIN MOTOR = MOTOR OFF & BREAKER RACKED OUT & LOCKED.	UNIT SWICH 15A/15B 15A/15B (6.6 KV ROOM)	= BREAKER "OFF" INDICATION, = RACKING MECHANISM LOCKED
ELECTRICAL (LT)	PAD-1/2 = MODULE OFF & LOCKED PA FAN LOP = MODULE OFF & LOCKED.	PA FAN MCC 19A/20A (Boiler Basement)	= MODULES OFF INDICATION = MODULE LOCKED
THERMAL (HOT AIR)	DISCHARGE DAMPER = CLOSE DISCHARGE DAMPER (PAD-3/4) = MODULE OFF & LOCKED	BOILER MCC 19A/20A (13.5 MPa TG FLOOR)	= MODULES OFF INDICATION = DISCHARGE AIR PRESSURE INDICATION IN HMI

**ADANI DAHANU THERMAL POWER STATION (ADTPS)**  
**BOILER**

**EQUIPMENT DESCRIPTION:** In boiler, the chemical energy stored in pulverized coal is used to convert feedwater into superheated steam from radiant heat obtained from coal. The boiler is a natural circulation, single boiler rated capacity is 605 t/hr.

**HAZARDS:** Exposure to high temp/ pressure steam, fire, fall from height, hot work, slippage due to oil spillage, confined spaces, exposure to moving machinery, contact with electrical source, electrocution, exposure to dust/ash etc.

It must be ensured that all required energy sources are completely isolated and tagged, before initiating the work

**EQUIPMENT ENERGY SOURCES LOCK OUT DETAILS**

ENERGY TYPE & SOURCE	LOCKOUT PROCEDURE	LOCKOUT LOCATION	PROCEDURE VERIFICATIONS
THERMAL (COAL/HOT AIR & FLUE GAS)	COAL MILLS / ID, FD & PA FANS: = MOTOR OFF = BREAKER RACKED OUT & LOCKED.	UNIT SWICHES (6.6 KV ROOM)	= BREAKER "OFF" INDICATION = RACKING MECHANISM LOCKED
THERMAL (HOT WATER)	BOILER FEED PUMP (BFP) = MOTOR OFF = BREAKER RACKED OUT & LOCKED.	UNIT SWICH 15A/20A 15A/20A (6.6 KV ROOM)	= BREAKER SHOWS "OFF" INDICATION = RACKING MECHANISM LOCKED
THERMAL (STEAM)	METS: = BOILER FEED PUMP (BFP) LOCKED = COFFERED = SPOT BLOWER = AUTHORIZED VALVE CLOSE & LOCKED	DRUM FLOOR LP DRAIN HEADER	= MODULES OFF INDICATION = DRAIN / VENTS OPENED = NO WATER / STEAM FROM DRAINS / VENTS
THERMAL (OIL)	LOO MAIN ISOLATING VALVE: = CLOSED & LOCKED = ALL CORNER ISOLATING VALVE CLOSED	FIRING FLOOR	= VALVE CLOSED & NO OIL
ELECTRICAL (LT)	LY AUXILIARIES: = APH MAIN ASH DRY MOTOR, = RC SCANNER FAN, = AC SCANNER FAN = MODULES OFF & LOCKED	13.5 MPa MCC 19A/20A 19A/20A 00A/20B	= MODULES OFF INDICATION = MODULE LOCKED

## Legatrix

Statutory Compliance monitored through Legatrix

- Legal
- Commercial
- Human Resources
- Regulatory

legatrix+ compliances solution

legatrix is an IT-enabled legal support service relating to legal and regulatory compliances. It enables management with an one-stop view of the organization's compliances & control mechanism through comprehensive compliance dashboards & provides necessary information at the operating level by creating comprehensive Matrix on laws and it's management.

Login ID:   
 Password:   
 Login

Retrieve Credentials  
 Whistleblower's Login  
 V 8.0.62  
 Unauthorized access is strictly prohibited (Attorney Client Communication)

Dashboard | Calendar | Task Administration | Tasks | Utility | Administration | Reports



# ADTPS – Biodiversity assessment by CII

## Biodiversity Assessment Report of Adani DTPS Dahanu 2022



Report prepared by



India Business & Biodiversity Initiative (IBBI)  
CII-ITC Centre of Excellence for Sustainable Development

### Highlights of the assessment

1. Total floral diversity of ADTPS after second assessment is 224 which includes 91 tree species, 28 shrub species, 57 herb species, 22 grass species and 26 climber species.
2. Four nos. of mangrove species documented.
3. Total of 90 species of birds belonging to 42 families have been documented from the Plant premises and study area.
4. The mammalian diversity of Plant premises and study area was represented by 8 species. The Indian Fruit bat was the most common mammalian species recorded.
5. Pugmark of Small Indian Civet (*Viverricula indica*) found
6. Scat of Leopard (*Panthera pardus fusca*) found
7. 7 Species of reptiles were recorded in the Plant premises and study area. It included 4 snake species, 2 lizards & a gecko species
8. 29 species of butterflies were recorded during the study.
9. The most recorded butterfly species are Common Grass Yellow (*Eurema hecabe*) and Common Emigrant (*Catopsilia pomona*).

# Innovation – Inhouse development of technology



Online Vibration Monitoring of Boiler Clinkering



Wireless rechargeable Hand Lamp



# Safety improvement by providing safe load operation on wheel loader



Demo: [Wheel Loader Safe Operation](#)

## Model development

Sr. No.	Model Description
1	Solar PV Generation Demo Kit
2	Hydro Power Generation Demo Kit
3	Wind Power Generation Demo Kit
4	Transmission Line Safety Kit
5	Level Control Demo Kit
6	Sound System Demo Kit
7	Internet of Things (IoT) Demo Kit
8	Mobile Tower Unit for Communication Sys Demo
9	De-mineralized (DM) Plant Kit
10	Faraday's Law of Electromagnetic Ind. Demo Kit
11	RLC Circuit for Grid Modelling Demo Kit
12	Loco Engine with Rail Track Kit
13	Wheatstone Bridge Demo Kit
14	ELCB testing Demo Kit
15	Air conditioner Demo Kit
16	Bus Changeover Model
17	Lead Acid Battery Demo Kit
18	Road Model Civil



# Model Developed for college students

Working model residential rooftop solar energy system



Working model of D.M. PLANT



# ADTPS CSR Initiatives - Integrated Tribal development project

- **Livelihood Support:** ADTPS in association with “NABARD” initiated a program “Integrated Tribal Development Project “ in selected 11 villages of Dahanu
- Project is to cater economic upliftment of tribal covering 1000 land owing families
- Landless tribal registers for livelihood support in Saloon shop, Goat farming, Aata-Chakki (Ghar ghandi), Tailoring shop, Kirana shop & Carpentry business.





# ADTIPS CSR Initiatives



# 10.0 Teamwork Employee involvement & Monitoring


## Energy Oath in Daily Plant Meeting

## Drawing Competition for Colony children





# Energy Quiz and KM for ADTPS Employees



Tue 14/12/2021 14:35  
**PANDURANG JALKOTE**  
 Energy Conservation Quiz -2021

To: Dahanu Users

Energy Quiz-2021 Answer Sheet.xlsx 16 KB  
 Energy Quiz Question 2021.docx 1 MB

Dear All,

Energy Management Cell is celebrating Energy Conservation Week from 14<sup>th</sup> December - 2021

We have arranged Quiz competition to refresh the knowledge about energy conservation.

Your participation will be highly appreciated.

**Rules:**

1. More than one answer for any question shall be treated as wrong.
2. Deadline for sending entries is 17:30 hrs 20<sup>th</sup> Dec-2021
  - a) e.mail **answer sheet** to [ravi.patil@adani.com](mailto:ravi.patil@adani.com) or [suhas.patil@adani.com](mailto:suhas.patil@adani.com)
  - b) Those who do not have email facility can send through Colleague's/friend's email account

**Energy Management Cell**



The Greenhouse Gas Protocol (GHG Protocol) is the most widely used international accounting tool for government and business leaders to understand, quantify, and manage greenhouse gas emissions. Yearly Sustainability measurement of Business on various parameters like Environment, safety, Governance, etc & accordingly Business ranking is now followed widely in India & worldwide.

On the occasion of "Energy Conservation Week", to know more on the subject, TTC along with O&E Department has arranged a KM as detailed below:

**KM – Climate change and GHG accounting methodology.**

Facilitator : Sh. Ravi Patil – O&E Dept.

Date :- 18/12/2021.  
 Time :- 15:15 to 16:15.

# Energy & Environment Samwad with children






# World Environment Day Celebration – 5th June'21




Tree Plantation – More than 600 nos of Mango, Jamun & Casuarina plants were planted



Ashwin Vijay  
1st prize: 5th to 7th Std category

Drawing & Quiz Competition for Colony Children



Ayushi Jalkote  
1st Prize: 8th to 10th std category

# Energy management system at ADTPS



# MIS for Performance Monitoring

**Daily Energy Deviation Report**

**Generation Loss Classification Report**

**Monthly Performance test**

**Monthly Building Energy Deviation Report**

**Critical Management report**

**Daily Heat Rate Break Up Loss Report**


**Mill and BFP changeover report**

**Area wise Auxiliary Monitoring Report**

**Preoutage survey before overhauling**

**Post outage survey after overhauling with economical impact**

# Performance Review






## 10.0 Long Term Vision on Energy Efficiency

Schemes	Dept	Cost Rs Crs
IP Turbine - New casing procurement & rotor refurbishment	Mech	27
Refurbishment of BFP system	Mech	2.00
Procurement of APH baskets	Mech	2.30
Refurbishment of flue gas duct	Mech	0.75
Renovation of lighting system	ELM	0.70
Procurement of energy efficient HT/LT motors	ELM	0.40
Procurement of energy efficient sump pumps for Conveyor tunnels	CHP	0.30
Replacement of LT VFDs	ELM	0.30
<b>Total Cost</b>		<b>33.75</b>

# 11.0 Implementation of ISO 50001



- ✓ ADTPS is the first power plant in the world to implement Energy Management System (ISO 50001:2011).
- ✓ ADTPS has integrated all its business processes through Enterprise Resources Planning system SAP.
- ✓ The plant has established a comprehensive fuel management system. In view of logistic, economics, O&M challenges and environmental issues

# Award - QCFI

**Quality Circle Forum Of India**  
(A Non-Profit, National Body For Propagation Of Concept And Quality 1000 Quality Circles As An Integral Part, Registered Under A.P. Public Societies Act 1956)

**MARKSHEET**  
 for Allied Quality Concept presentation in  
 NCQC 2021, Coimbatore

Registration No : V1600  
 Team/Circle Name : URJA  
 Organization Name : ADANI ELECTRICITY MUMBAI LIMITED

S.No	Section	Maximum Marks	Marks Obtained
1	Pre- Evaluation	100	91
2	Presentation Marks	50	39
3	Knowledge Test	50	22
<b>Total Marks</b>			<b>152</b>
<b>Total Marks(Rounded)</b>			<b>152</b>

**Result : Par Excellence Award**

30-Dec-2021  
 Date of Issue

Executive Director

**Quality Circle Forum Of India**  
(A Non-Profit, National Body For Propagation Of Concept And Quality 1000 Quality Circles As An Integral Part, Registered Under A.P. Public Societies Act 1956)

**MARKSHEET**  
 for Allied Quality Concept presentation in  
 NCQC 2021, Coimbatore

Registration No : V1597  
 Team/Circle Name : VIRAT  
 Organization Name : ADANI ELECTRICITY MUMBAI LIMITED

S.No	Section	Maximum Marks	Marks Obtained
1	Pre- Evaluation	100	80
2	Presentation Marks	50	42
3	Knowledge Test	50	24
<b>Total Marks</b>			<b>146</b>
<b>Total Marks(Rounded)</b>			<b>146</b>

**Result : Excellent Award**

30-Dec-2021  
 Date of Issue

Executive Director

From Adani, ADTPS, Dahanu, 02 teams won Par Excellence ( Urja Team ) & Excellence ( Virat ) Award in NCQC & trailing mail received for participation in ICQCC

# Adani Dahanu Thermal Power Station- CSR





# We're listening.

adani<sup>™</sup>  
Electricity

