

G M R K A M A L A N A G A E N E R G Y L T D

23rd National Award For Excellence in Energy Management

FY-2021-22

A journey towards improved energy performance with approach of sustenance and innovation

Presenting by :

1. Saurabh Kumar (AM OS&E)
2. Puspahash Mohanty (Manager OS&E)
3. Raghunath P (VP Operation & OE)



Confederation of Indian Industry



CONTENTS

1. GMR at a glance
2. Energy management policy and certificates.
3. Energy consumption overview.
4. Specific energy consumption last 3 years
5. Benchmarking of KPI
6. Energy conservation projects in last 3 years
7. Innovative project in FY 22
8. Renewable energy project
9. Environment management .
10. Green supply chain management
11. Best practices –Non energy efficiency
12. Energy management System
13. Budget allocation.
14. Award and accolades.
15. Learning from CII

VALUES & BELIEFS



Mahatma Gandhi

Humility
We value intellectual modesty and dislike false pride and arrogance

Sardar Vallabhbhai Patel

Deliver the Promise

We value a deep sense of responsibility and self-discipline, to meet and surpass on commitments made



Swami Vivekananda

Learning & Inner Excellence

We cherish the life long commitment to deepen our self awareness, explore, experiment and improve our potential

TenAzing & Hillary

Teamwork & Relationships

Going beyond the individual-encouraging boundary less behaviour



Mother Teresa

Social Responsibility

Anticipating and meeting relevant and emerging needs of society

Dr. APJ Abdul Kalam

Respect for Individual

We will treat others with dignity, sensitivity and honour



JRD Tata

Entrepreneurship

We seek opportunities – they are everywhere

1. GMR AT A GLANCE



AIR PORT




ENERGY



HIGHWAY



URBAN INFRA



GMR Kamalanga Energy Limited is a wholly owned subsidiary of GMR Energy LTD and is a step down subsidiary of GMR Infrastructures LTD.

Products/Businesses of organization : Electricity Generation

Capacity : 1050 MW - (3x350 MW)

Operational since: April 2013.

FSA

GKEL is having FSA with MCL

- FSA LINKAGE - 2.14 Million MT
- SAKTI LINKAGE - 1.50 Million MT

WATER SOURCE – 24 Cusec - BRAMHANI RIVER




Plant Facility

- BOILER – HARBIN
- TURBINE – Donfang Turbine company
- GENERATOR - Donfang Electric company
- BFP - Turbine – Donfang Turbine company

PPA

- DISCOM BIHAR PPA - 260 MW – 25 Years
- DISCOM HARYANA PPA - 323 MW -25 years
- DISCOM GRIDCO PPA – 247 MW – 25 years
- BALANCE POWER -150 MW



2. ENERGY MANAGEMENT POLICY AND CERTIFICATES

Bureau Veritas Certification

GMR KAMALANGA ENERGY LIMITED

VILLAGE KAMALANGA, DISTRICT DHENKANAL, STATE: ODISHA – 750 121, INDIA.

Standards
ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018

Scope of certification
GENERATION OF ELECTRICITY IN COAL BASED THERMAL POWER STATION OF 3 X 360 MW

Original cycle start date: 14 May 2020
Expiry date of previous cycle: Not Applicable
Certification Audit date: 18 February 2020
Recertification cycle start date: 14 May 2023
Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 13 May 2023
Certificate No.: IND.20.20878WU Version: 1 Revision date: 14 May 2020

J. J. J.

Signed on behalf of BUREAU VERITAS – UK Branch
Jagdishwar A. MANJAN
Head – CERTIFICATION, South Asia
Consumer Services, Industry & Facilities Division
100 Place de France Street, London, E1 1NS, United Kingdom
Tel: +44 (0)20 7706 0000
www.bureauveritas.com

National Accreditation Board for Testing and Calibration Laboratories
(A Constituent Board of Quality Council of India)

CERTIFICATE OF ACCREDITATION
GMR KAMALANGA ENERGY LIMITED CHEMICAL LABORATORY

has been assessed and accredited in accordance with the standard
ISO/IEC 17025:2017
"General Requirements for the Competence of Testing & Calibration Laboratories"

For its facilities at
P.O. KAMALANGA, P.S. BITHORIK, DHENKANAL, ODISHA, INDIA

In the field of
TESTING

Certificate Number: TC-0266
Issue Date: 28/05/2019 Valid Until: 28/05/2021

This certificate remains valid for the Scope of Accreditation as specified in the annexes subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.
(Go to the scope of accreditation of this laboratory, you may also visit NABL website www.nabl.co.in)

Signed for and on behalf of NABL
N. Venkateswararao
Chief Executive Officer

Bureau Veritas Certification

GMR KAMALANGA ENERGY LIMITED

VILLAGE KAMALANGA, CITY- DHENKANAL – 750 121, ODISHA, INDIA.

Bureau Veritas Certification Holding SAS – UK Branch certifies that the Management System of the above organization has been audited and found to be in accordance with the requirements of the Management System standard detailed below.

Standard
ISO 50001:2018
Scope of certification
GENERATION OF ELECTRICITY IN COAL BASED THERMAL POWER PLANT OF 3X360 MW

Original cycle start date: 20 May 2020
Expiry date of previous cycle: Not Applicable
Recertification Audit date: 25 February 2020
Recertification cycle start date: 20 May 2023
Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 18 May 2023
Certificate No.: IND20.2496/ENU Version: 1 Revision date: 20 May 2020

J. J. J.

Signed on behalf of BUREAU VERITAS – UK Branch
Jagdishwar A. MANJAN
Head – CERTIFICATION, South Asia
Consumer Services, Industry & Facilities Division

Certification body address: 100 Place de France Street, London, E1 1NS, United Kingdom
Local office: Bureau Veritas (India) Private Limited (Certification Business)
T2 Business Park, Sector Industrial Area, MIDC Cross Road, T2,
Andheri West, Mumbai - 400 058, India

Further information regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.
To check this certificate validity please call +91 22 4274 2000.

GMR Kamalanga Energy Limited

Energy Management Policy (ISO 50001:2018)

GMR Kamalanga Energy Limited is committed to establish, implement and maintain Energy Management system to build world class capabilities in every aspect of its business operations. To achieve this GKEL is committed to:

- Adopt energy efficient and clean technologies in process design, maintain and operate the plant so as to make it a more efficient power utility among similar & comparable capacity power plants.
- Minimize the losses and Continual improvement upon the energy performance.
- Comply with related standards, legal and other requirements which relate to energy use, consumption and efficiency.
- Ensure availability of information and necessary resources to achieve energy management objectives and targets.
- Establish effective frame work and communicate responsibilities, authorities and obligations in order to facilitate effective energy management.
- Carryout regular energy audits to identify areas for improvements and proactively exercise controls in purchase of energy efficient products and services for new or modified projects for improvement in energy performance.

Date: 1-Aug-19

Ramesh R Pai
COO & Plant Head
GMR Kamalanga Energy Limited

Bureau Veritas Certification

GMR KAMALANGA ENERGY LIMITED

VILLAGE KAMALANGA, DISTRICT DHENKANAL, STATE: ODISHA – 750 121, INDIA.

Bureau Veritas Certification Holding SAS – UK Branch certifies that the Management System of the above organization has been audited and found to be in accordance with the requirements of the Management System Standard detailed below.

Standard
ISO 55001:2014
Scope of certification
GENERATION OF ELECTRICITY IN COAL BASED THERMAL POWER STATION OF 3 X 360 MW

Original cycle start date: 08 August 2022
Expiry date of previous cycle: Not Applicable
Certification Audit date: 21 May 2022
Recertification cycle start date: 08 August 2023
Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 07 August 2026
Certificate No.: IND20.2086G Version: 1 Revision date: 08 August 2022

J. J. J.

Signed on behalf of BUREAU VERITAS – UK Branch
Jagdishwar A. MANJAN
Head – CERTIFICATION, South Asia
Consumer Services, Industry & Facilities Division
100 Place de France Street, London, E1 1NS, United Kingdom
Tel: +44 (0)20 7706 0000
www.bureauveritas.com

National Productivity Council Certificate

This is to certify that **GMR Kamalanga Energy Ltd., Dhenkanal** is awarded **उत्कृष्ट (Utkrishi)** Category under 5S Certification Scheme of National Productivity Council.

Certificate No.: NP/506/236/2022/4984/01-09-2022
Issue date: 27 Feb 2022
Certificate Expiry date: 07 Feb 2027

To Adopt Energy efficient and clean technology

To Minimize the losses

To Comply legal and other requirements

To allocate resource

To frame Roles and responsibility

To purchase energy efficient product and Regular Energy audit




3. ENERGY CONSUMPTION OVERVIEW FY 2021-22

Annual Generation	: 7530.21 MU
PLF	: 81.87 %
Availability	: 90.89 %
Gross Heat Rate	: 2318 kcal/kwh
Auxiliary Power	: 6.74 %
UHR (UNIT 1/2/3)	: 2323/2317/2316 Kcal/kwh
BOILER EFFICIENCY	: 87.13/87.15/87.08 %
DM Water consumption	: 0.16 %
Raw Water Consumption	: 2.15 M3/ MWh generation
Specific Oil Consumption	: 0.08 ml/ KWh generation









4. SPECIFIC ENERGY CONSUMPTION LAST 3 YEARS.

Financial year	Specific energy consumption			Improvement in specific consumption w.r.t base line		
	Electrical	Thermal		Electrical	Thermal	Oil
	Kwh/kwh gen	Heat rate (kcal/kwh)	Specific oil (ml/Kwh)	(%)	(%)	(%)
FY -17-18	0.07341	2332	0.220			
FY -18-19	0.06826	2331	0.240	7.015	0.043	-9.091
FY -19-20	0.07338	2312	0.160	0.041	0.858	27.273
FY -20-21	0.0668	2323	0.097	9.004	0.386	55.909
FY -21-22	0.0674	2318	0.0820	8.19	0.60	62.73



5. BENCHMARKING OF KPI

5.1 Internal Benchmarking




NOTE: Heat rate is compared with corrected design heat rate with aging (as per OEM curve). Increase in heat rate is due to drop in HP and IP turbine efficiency and increase in APH O/L temp. which to be addressed in next overhauling cycle


5. BENCHMARKING OF KPI

5.2 External Benchmarking


NET HEAT RATE (kcal/kwh)




APC (%)




HEAT RATE (kcal/kwh)




SOC (ml/kwh)



DM water (%)



PLF (%)



GKEL is equipped with TDBFP so benchmarking done with Net heat rate.

5. BENCHMARKING OF KPI

5.3 Road Map to create benchmarking

FUTURE TARGET FOR APC:

- GKEL presently achieved 5.83 % APC at full load against 7.55% design & normative APC 6.25% .
- GKEL aims to achieve 5.75 % by 2023.

FUTURE TARGET FOR HEAT RATE:

- GKEL presently achieved 2305 kcal/kwh Heat rate at full load against 2227 design.
- GKEL aims to achieve 2300 Kcal/kwh by 2023 considering aging of machine.

- External and internal benchmarking
- Set Energy objective and target
- Identification of EC project
- Budget allocation EC projects
- Establishment of better monitoring system
- Action plan development

- Deviation analysis
- RCA for each deviation
- Monitoring CAPA through distal ATR
- Project effectiveness study
- Sustenance






5.4 WAY FORWARD PLAN FOR ENERGY CONSERVATION .

SL No.	Description of energy conservation measures	Investment (Rs in Million))	Annual Electrical Saving (Million kWh)	Benefit due to heat rate improvement (Kcal)
1	HIP overhauling	6		13.36
2	APH Basket removal	4.5		10.47
3	APH additional basket addition in unit	1.728		8.8
4	Replacement of burner, Boiler tube buffing , Soot blower effectiveness			2
5	IFC installation in compressor	5	1.022	
6	Replacement of RC valve to eliminate passing.	0.5		10
7	Seal air fan VFD installation	2.5	1.028	
8	Sonic soot blower installation in unit 1 & 2	2.2		0.77
9	ESP hopper power consumption optimization	0.5	0.96	
10	Coro coating of pump CW Pumps	0.25	2.63	
Total		23.178	5.64	45.4

- GKEL tested unit operation at 40% Loading Factor for assessment of Heat rate & APC degradation and working for optimization of Heat rate , APC , stable operation and smooth ramp up.

6.ENERGY CONSERVATION PROJECT LAST 3 YEARS

Financial Year	No of energy conservation project	Investment (Million)	Electrical energy saving (MU)	Thermal energy saving (G kcal)	Financial saving. (Million)
FY 20	10	10.26	12.81	29.060	64.54
FY 21	11	17.78	9.06	45.02	73.48
FY 22	6	97.7	3.79	13.52	25.71



7. INNOVATIVE PROJECT IN FY 22

Reduction of Specific Raw water consumption

- **Why innovative:** LC cement is adopted for Boiler. In initial design, Water is continuously overflowed from seal through to refractory.
- **Savings achieved:** Reduction of monthly allocation quantity from 24 Cusec to 20 Cusec
- **Financial saving achieved:** 2.91 Crore
- **Investment :** 9.2 Lacs
- **Replicability :** Yes

IDENTIFICATION OF OPPORTUNITY


- Specific raw water consumption reduction is a strategic objective of GKEL for sustenance concern. Raw water cost also has significant impact on O&M cost . Reduction of SRWC will aid Zero discharge , Raw water cost and auxiliary power consumption. With analysis it is observed that CT blow down is the most controllable contributor for Raw water consumption and Root cause for the Raw water consumption is Boiler hopper refractory cooling and it also disturbs the Water balance of AHP. This resulted in difficulty in maintaining zero discharge.

POSSIBLE SOLUTION

- Refractory metallurgy was changed to improved quality refractory
- refractory application Seal trough overflow line modified to eliminate cooling water
- SOP finalized and training provided to field operator

IMPLEMENTATION

- Complete replacement of refractory



Water flow 210 Tons/hr.

Water flow 40 T/hr.



8. RENEWBLE ENERGY PROJECT .

SL no.	Projects implemented	Capacity	Type of energy	(Generation Million KWh)
01	Wind operated Turbo ventilator installed (188 nos.) on TG Building and hydrogen builing.	250 Kwh	Wind	1.44
02	Security hub power supply from solar panel.	129 watt	Solar	0.001




Turbo ventilators




Solar panel at security post

9.1 ENVIRONMENT MANGEMENT - ASH UTILIZATION


Ash generation/ Stock (Million Ton)




Ash utilization in %



Ash handling modes (%)



Areas of ash utilization in MT



Modes of Ash Conveying

- Dry Ash conveying System with storage Silos
- Bottom Ash slurry conveying system with hydrobin water decanted system make it semi dry condition
- HCSD systems and ash pond with Ash water recovery System

9.2 ENVIRONMENT MANGEMENT - ASH UTILIZATION



01

In house Bricks/blocks making unit – products is being sold to other and also used in-house for repairing & construction work of Township.



02




Supply to NH Authority for road construction project through trucks and bulk discharge through rakes



03

Supply to bricks/block and cement manufacturing unit by bulkers

9.3 ENVIRONMENT MANGEMENT – EMISSION




Best Practices for Emission control


- Low NOx Burner and Over fire damper operation.
- Periodic checking of SADC for combustion control.
- Improvement in Fineness of coal particle
- Periodic replacement of Bag filters to control PM.
- Oxygen optimization for NOx control.
- Periodic monitoring of stack parameters.
- Daily ESP field healthiness monitoring.
- Online CEMS/ CEQMS is installed and data transmission to SPCB and CPCB
- Daily review of emission by EHS team

FGD installation is process and it will be commissioned by Dec -2023 as per MOEF direction.


9.4 ENVIRONMENT MANGEMENT -WATER




Water SCADA for Online Monitoring



Modification of drift eliminator



RAW water(m3/MWh)



DM WATER

Best Practices for reducing water load

- Replacement of drift eliminator .
- Water SCADA implementation .
- Rain water Harvesting by Rain water pump.
- Recuse of MFST blowdown
- Reduction of DM water.

Best Practices for waste water utilization

ETP and STP for treating the water and used in

- Makeup to bottom ash handling system.
- Make up to Fire fighting storage tank.
- Truck wheel washing spray system.
- Ash Conditioning during loading .
- Boiler seal trough charging.
- Floor and road cleaning.
- Coal yard sprinkling
- DS system in CHP.
- Horticulture.

9.4 ENVIRONMENT MANGEMENT –WATER CONSERVATION OTHERS PROJECTS

Recovery of rain water, floor cleaning water by connecting to storm water drain and automatic start stop facility provision rain water harvesting pump based on sump level.

Relocation of underground utility pipes to over ground to reduce underground water leakages.

Reuse of Mixed flow sedimentation tank blow down water back in to the system

Installation of automatic level transmitters in all utility water tanks inside the plant and associates living area.

Utilization of Guard pond Waste water in Boiler , ESP area floor cleaning, DFDS System, Coal pre wetting system, and fog cannon instead of service water

Utilization of township STP waste water for gardening purpose after treatment.



All Overhead tank level switch installation



FOG Cannon



Automation of Rain water harvesting pumps




Waste water utilization

9.5 ENVIRONMENT MANGEMENT – WASTE UTILIZATION

1. Organic waste is being converted to manure through Mech bio-digester and utilized in organic farming and horticulture



Solid waste management(MT)



10. GREEN SUPPLY CHAIN MANAGEMENT .



Started Bulk ash disposal by rake as 2nd plant in ER thus reducing truck transport emission.

Spare part development and indigenization (SPDI) of 98 Nos of item.


100% rake materialization reducing truck transport emission and energy consumption

E cart for goods transport inside plant which reduced 1.82 kl diesel consumption .


- **56574 tons** transported
- 1885 truck eliminated
- 3.65 lakh km
- 125 kl Diesel consumption
- 333 TCO2 by truck
- 106 TCO2 by rail
- 227 TCO2 Net reduction

Local vendor development reduces energy consumption in transportation and carbon foot print in its overall product life cycle

11. BEST PRACTICE –NON ENERGY EFFICIENCY




CFT – Turbine & Auxiliary
Feed water ,Condensate system ,Hydrogen system



MENTOR :
HARESH PATTNAIK / RAGHUNATH PV


LEADER :
BASUDEV SWAIN / JITENDRANATH SARKAR

MEMBERS :
KAUSHIK PRADHAN
ASUTOSH
ANSHUL DUBEY
SREEKANTH/CHENNA SANKETH
BIBHU
KHARAVELA ROUT



SIX SIGMA PROJECT

- Generation loss minimization by repeated failure analysis
- Life enhancement of frequently failing components
- CHP belt loading factor improvement
- Bottom ash quantity reduction
- Heat rate improvement
- Non-moving spare inventory reduction



RELIABILITY ENGINEERING

ABIRAL–A reliability improvement program initiated where 200 Nos of reliability issues identified under banner of ABIRAL. 20 no's of CFT formed to asses all processes.

1. Repeated failure analysis
2. Critical spare management
3. Identification of process bottleneck.
4. RCA trough Six sigma approach.



GMR KAMALANGA ENERGY LIMITED



**LEAN
SIX SIGMA
GREENBELT
TRAINING PROGRAM**

USE OF DIGITAL PLATFORM

- 1.Compliance management, EHS management, Management Review & Sustainability reporting.
2. SARATI portal for internal audits .
3. Idea Factory for registration of individual idea
4. SIP digitalization for change management
- 5.ATR digitalization for tracking of CAPA.

11. BEST PRACTICE –NON ENERGY EFFICIENCY



AFFORESTATION


GKEL has fulfilled statutory requirement by effective plantation in 335 Acres

1. Plantation of 3.9 Lakh saplings
2. Mass plantation in plant premises
3. Seedlings distribution to community
4. Plantation in community.
5. 35 Acres landscape development
6. 2 Acres of organic farming

CSR

Web page and app developed named “krusaka bandhu” to facilitate farmers on.

1. Aggregation on information on various government schemes and links.
2. E-resources for farming like Govt. newsletters, notifications, E-books.



Our whole and sole moto behind developing this APP was to utilize basic modern digital technology for the welfare of Farmers in society, especially those who belongs to the deprived class towards this humongous development in field of digital world. We tried to link these people with digital platform in every sense that was possible for us to.



ASSET MANAGEMENT

1. SAP based maintenance
2. Preservation methodology
3. Min max process
4. Condition monitoring
5. Regulatory compliance
6. Waste management
7. Certification of ISO 55001


12. ENERGY MANGEMENT SYSTEM .

12.1 ENERGY MANGEMENT CELL

- **Energy review committee** : For overall review & support
- **Energy management Cell** : For Monitoring and developing
- **Zonal members** : For field level execution .
- **No of zones** : 6 zones better targeting and monitoring
- **Involvement -** : 31 Nos of employees associated.
- **Competency-** : 7 BEE Certified energy auditors
- **Review** : Energy review chaired by plant head

Objective of EMC to

- Monitoring of specific energy consumption area wise
- Deviation analysis of SEU and objective
- Preparation of action plan.
- Identification and cost benefit analysis of ENCON projects
- Awareness. And Training
- Ensure sustenance action plan.
- ISO 50001 standard requirement.




12. ENERGY MANGEMENT SYSTEM .

12.2 ENERGY MONITORING AND MEASUREMENT

ELECTRICAL ENERGY MONITORING

UNIT	UNIT 1	UNIT 2	UNIT 3	STATUS
GENERATION	289.0	289.90	286.56	1
TE EXPORT	271.62	267.63	245.56	7
NE EXPORT	268.65	270.75	245.62	7
RC IN %	7.16	7.12	7.30	
RC IN MW	21.08	20.36	19.46	
RC MAIN PLANT	1168.54	1123.87	1030.03	204
CD FANS	28140.1	2815.56	2443.07	76
BA FANS	1868.19	2039.76	2048.56	98
FD FANS	112.21	109.63	406.87	76
CONDENSATE EXTRACTION PUMPS	601.86	549.2	861.93	21
FWD WATER PUMPS	369.74	367.46	375.11	11
MILLS	1628.68	1701.29	1745.71	53
LP TRANSFORMER LOAD	626.7	626.8	633.12	16
ESP LOAD	772.4	805.64	710.79	22
COMMON TRANSFORMER LOAD	62.65	24.48	3.27	
HWAC	489.96	345.62	542.47	11
LIGHTING LOAD	16.92	14.43	18.96	


ONLINE POWER CONSUMPTION



AREA WISE SP ENERGY ANALYSIS

AREA	EPPI	DEPS	DEV	REMARKS
L#10 System
L#11 System
L#12 System
L#13 System
L#14 System
L#15 System
L#16 System
L#17 System
L#18 System
L#19 System
L#20 System
L#21 System

SEU DEVIATION ANALYSIS




RCA FOR DEVIATION

THERMAL ENERGY MONITORING

S. No.	Parameter	Unit	Design	Actual	Deviation	Remarks
1	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	2323.79	2323.49	
2	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	2023	2029	
3	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
4	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
5	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
6	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
7	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
8	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
9	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
10	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
11	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
12	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
13	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
14	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
15	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
16	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
17	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
18	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
19	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
20	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
21	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
22	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
23	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
24	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
25	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
26	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
27	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
28	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
29	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	
30	Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1940	1940	

DAILY HEAT RATE DEVIATION ANALYSIS



ONLINE HEAT RATE MONITORING

Parameter	UOM	Design Val.	Actual Val.
Overall Turbine Cycle Heat Rate	KCal/KWh	1940	1988
Gross Heat Rate	KCal/KWh	2223	2310
Generator Output	MW	350	349.5
Main Steam Flow	TIHr	1101	1122
Cold Reheat SF	TIHr	987	995
Hot Reheat SF	TIHr	987	995
Condensate Vacuum	KPa	-91.17	-90.89
HP Turbine Cyl. Eff.	%	85.5	81.0
IP Turbine Cyl. Eff.	%	92.0	90.0

ONLINE EQUIPMENT PERFORMANCE

12. ENERGY MANGEMENT SYSTEM .

12.3 WORKMEN INVOLVEMENT THROUGH SGA .

1. Half yearly Boiler and turbine insulation temperature survey.
2. Furnace pressurization test for air in-leakage identification.
3. PA duct pressurization test for air in- leakage identification.
4. Monthly high energy Drain passing survey.
5. Instrument and service air leakage survey
6. Furnace velocity mapping.
7. Compressor FAD testing.
8. Illumination study.
9. Ventilation system audit

Boiler Right Side									
Elevation	55	50	48	52	48	47	45	48	50
69 mt	55	50	48	52	48	47	45	48	50
62 mt	42	50	46	47	56	44	51	45	48
52 mt	59	65	43	52	46	45	52	65	50
48 mt	61	64	71	83	57	50	56	48	45
46 mt	61	59	61	63	58	63	52	48	69
42 mt	62	65	130	64	48	72	52	40	65
40 mt	90	60	61	41	69	55	72	60	65
38 mt	34	34	62	62	111	52	54	51	63
30 mt	63	67	53	75	61	82	83	130	60
24 mt	68	92	77	90					
22 mt	58	65	65	92					
20 mt	52	68	77	90					
18 mt	130	63	62	64					
15 mt	104	72	77	60					
12 mt	140	54	57	58					
9 mt	60	80	75	70					

BOILER INSULATION SURVEY .

TURBINE DRAIN PASSING SURVEY		
	Date	05.08.2020
AUX HEADER DRAIN STATION (MIV)		
1 Aux header to condenser		3150
2 Aux header to condenser (steam trap)		3150
3 Aux header to ATM		3150
4 Supply MOV drain to ATM	6 MTR AUX HEADER DRAIN STATION	79
5 BFPT steam supply before drain to ATM		75
6 BFPT Steam supply drain (trap) to cond.		63
7 BFPT Steam supply drain to cond.		57
8 Common drain to atm		81
8.1 Atomizing safety valve drain	6 MTR Behind the aux header	53
8.2 Atomizing line drain.		43
8.3 Interconnection MOV before drain		66
8.4 Interconnection MOV before drain		78
BFPT STEAM DRAIN STATION		
1 CRH after mov. (cond)(B)		489
2 CRH after mov. (cond) steam trap(B)		65
3 CRH after mov. (ATM)(B)		56
4 AST after NRV (cond) (B)		80
5 AST after NRV (cond) steam trap (B)		115
6 AST after NRV (ATM)(B)		81
7 AST AFTER MOV drain (B)		84
8 AST header drain		73
9 AST header after MOV (A)	6 MTR	55
10 CRH header drain.		60
11 AST after NRV (ATM) (A)		61
12 AST after NRV (cond) steam trap (A)		55
13 AST after NRV (cond) (A)		67
14 CRH after mov. (ATM)(A)		31
15 CRH after mov. (cond) steam trap(A)		33
16 CRH after mov. (cond)(A)		117

HIGH ENERGY DRAIN PASSING SURVEY .


Unit-2 Velocity Mapping of Boiler 2nd Pass													
UPPER BANK LTSH													
Hanger No	LHS Wall to 1st coil gap	1	5	10	15	20	25	30	35	40	45	RHS Wall to 1st coil	Average
Row A bottom	3.7	3.2	3.3	3.5	3.4	3.4	3.2	3.5	3.5	2.6	3.0	3.1	3.3
Row B bend top	0.7	1.3	0.6	0.9	1.0	1.1	1.2	1.3	1.2	1.1	1.1	1.3	1.1
Row B bottom	2.7	2.4	2.3	2.3	2.5	2.5	2.6	2.2	2.3	2.3	2.2	2.5	2.4
Row C	2.5	1.4	1.8	1.5	1.6	2.8	2.8	2.7	4.0	4.0	3.4	3.4	2.6
Row D	2.6	2.4	2.3	2.5	2.7	2.5	2.7	2.7	2.6	2.4	2.3	2.5	2.5
MIDDLE BANK LTSH													
Hanger No	LHS Wall to 1st coil gap	1	5	10	15	20	25	30	35	40	45	RHS Wall to 1st coil	Average
Row A	3.6	1.6	2.3	2.0	2.1	2.0	2.1	2.2	1.8	1.9	1.6	3.8	2.2
Row B	3.1	1.5	1.8	2.0	2.0	1.9	1.9	2.2	2.2	2.3	1.8	4.0	2.2
Row C	3.5	1.8	2.4	1.9	2.4	2.4	2.4	2.4	2.4	2.6	1.8	2.7	2.4
Row D													2.5

BOILER VELOCITY MAPPING .

13. BUDGET ALLOCATION .

SL No.	Expenditure towards ENCON projects (Lakh)	Financial year
1	229	FY-19
2	102	FY-20
3	177	FY -21
4	170.7	FY -22

Budget allocation w.r.t turn over = 0.05%



14.AWARD AND ACCOLADES



2017-18

2018-19

2019-20



State Energy conservation award



State safety innovation award



Safety innovation award



People initiative award



State Energy conservation award



ICC Environment award -19



Kalinga safety award



Community initiative award



CII national Energy award



CII -ER ENCON Award



ICC Env excellence Award



Pollution control Award

15. LEARNING FROM CII & OTHERS

GKEL participated in CII National level award for energy management in FY-21 and awarded as excellent energy management unit Which turns to be great motivational factor for work force towards energy conservation. It helped the organization in following aspects

Adoption of best practices in energy conservation

Adoption of best practice in environment aspects

KPI benchmarking

Motivations towards energy efficiency

National level recognition.

Employee engagement towards energy conservation

GKEL reviewed 50 Nos best practices from CII portal of various business and 02 Nos selected for implementation in which 1 project are completed and 1 project for further implementation

G M R K A M A L A N A G A E N E R G Y L T D

THANK YOU

We have rights to use national resources but have no rights to waste it. Save energy save environment



Confederation of Indian Industry

