

**UltraTech Cement Limited** 

(Unit: Sewagram Cement Works-Thermal Power Plant)

### **Welcomes Assessors**

# 23<sup>rd</sup> National Award for Excellence in Energy Management 2022





# **Business Overview-UltraTech Cement Limited**





# Unit At Glance-Sewagram Cement Works

| Units               | Month & Year of Commissioning                    | Installed Capacity       |
|---------------------|--|--------------------------|
| Thermal power Plant | TPP 1-Sept'09 /TPP 2-Jul'11                      | TPP1-35 MW, TPP2-22.5MW  |
| Desalination Unit   | Jul'09   | 6600 M <sup>3</sup> /Day |
| Solar Power Plant   | Aug'18   | 5MW                      |
| Clinkerization      | Line I-Sept'09/Line II-Feb'11                    | 3.60 MTPA                |
| Cement grinding     | CM1-Mar '09 /CM2-Dec'10 /CM3- May'12             | 3.10 MTPA                |
| Packing Plant       | Packing Plant 1-Mar '09 /Packing Plant 2- Jul'10 | 4 Nos. x 180 TPH         |



| 1-Mar '09 | 9 /Packing Plant 2- Jul'10 | 4 Nos. x 180 IPH |         |  |
|-----------|----------------------------|------------------|---------|--|
| Sr no.    | Parameter                  | UOM              | Value   |  |
| 1         | Annual Generation          | Lac kWh.         | 2164.12 |  |
| 2         | PLF                        | %                | 61.15   |  |
| 3         | Availability               | %                | 89.58   |  |
| 4         | Gross Heat Rate            | Kcal/Kwh         | 3156    |  |
| 5         | Auxiliary Power            | %                | 9.15    |  |
| 6         | DM Water consumption       | m3/MWh           | 0.087   |  |
| 7         | Raw Water Consumption      | m3/MWh           | 0.289   |  |
| 8         | Specific Oil Consumption   | ml/kWh           | 0.11166 |  |
|           |                            |                  |         |  |



# FY'22 Performance

| Particulars                        | UoM      | TG#01   | TG#02  | Total   |
|------------------------------------|----------|---------|--------|---------|
| Annual Generation                  | Lac kWh  | 1478.62 | 685.50 | 2164.12 |
| PLF                                | %        | 59.45   | 65.19  | 61.15   |
| Availability                       | %        | 81.12   | 98.03  | 89.58   |
| Gross Heat Rate                    | kCal/kWh | 3153    | 3164   | 3156    |
| APC without S/D                    | %        | 9.14    | 8.05   | 8.79    |
| APC with S/D                       | %        | 9.37    | 8.68   | 9.15    |
| Boiler Efficiencies (station wise) | %        | 85.94   | 85.10  |         |
| Turbine Heat Rates (station wise)  | kCal/kWh | 2709    | 2693   | 2704    |
| DM Water consumption               | m3       | 4908    | 1526   | 6434    |
| Raw Water Consumption              | m3       | 18516   | 3752   | 22269   |
| Specific Oil Consumption           | ml/kWh   | 20.955  | 3.209  | 24.164  |

### Sp. Energy Consumption in last 3 years (FY 2020-22)

ADITYA BIRLA



### **Comparison with Benchmark & Cluster Units**

ADITYA BIRLA

UltraTech



### Roadmap to achieve Target Auxiliary % in FY'23



#### **Target Auxiliary-8.75%**



### **Roadmap to achieve Target Heat Rate for FY'23**



#### Sewagram Cement Works

ADITYA BIRLA



### Major Encon project planned in FY 2022-23



| SI. No. | Auxiliary Saving projects for FY'23                                | Proposed Savings<br>kWh/Day | Target Dates                  |
|---------|--|-----------------------------|-------------------------------|
| 1       | Installation of SRC Bundle in TPP-1 ACC (Air Cooled Condenser)     | 2904                        | Proposed in Capex FY'23       |
| 2       | Reduction in Fan power by Boiler-1 APH tube replacement & Cleaning | 4000                        | Completed in Jun'22           |
| 3       | Energy efficient BFP installation in TPP-1                         | 1992                        | Under Discussion with<br>TPMC |
| 5       | ACC fin Cleaning to be done in Every 6 Month                       | 480                         | Dec'22                        |
| 6       | Optimization of Bed height and maintain the O2 as per design       | 450                         | Continuous                    |
| 7       | Optimization in Ash conveying system power consumption             | 380                         | Oct'22                        |
| 8       | Installation Intelligence Air Flow Controller in Instrument air    | 182                         | Capex Approved                |
| 9       | VFD installation in Mechanical spreader in Boiler-2                | 72                          | Proposed in Capex FY'23       |
| 10      | VFD installation in DCF 11-15 in Boiler-2                          | 24                          | Proposed in Capex FY'23       |
|         | Total Saving in kWh  | 10484                       |                               |
|         | Sewagram Cement Works  |                             |                               |



# **Energy Savings Projects in FY'19-20**

| Sr. | Project Details  | Investment<br>(Rs. Lacs) | Saving<br>(Rs.Lac) | Payback<br>(Months) |
|-----|--|--------------------------|--------------------|---------------------|
| 1   | Solar Renewable Power utilization  | 0.00                     | 52.11              | 0.0                 |
| 2   | APH high pressure hydro jet cleaning and Tube replacement  | 3.50                     | 33.74              | 1.2                 |
| 3   | Pipe line laying for Harvesting Mines pit water Utilization                                      | 23.16                    | 29.57              | 9.4                 |
| 4   | AFBC boiler's ESP-2 <sup>nd</sup> field ash conveying line diverted to Boiler-1 furnace to reuse |                          |                    |                     |
| •   | unburnt carbon   | 0.00                     | 20.03              | 0.0                 |
| 5   | Reducing APC after TPP-1 ACC Fin cleaning  | 2.56                     | 10.69              | 2.9                 |
| 6   | Reducing APC after TPP-2 ACC Fin cleaning  | 1.92                     | 9.27               | 2.5                 |
| 7   | Turbo ventilator installation on TG Roof to reduce exhaust fan power                             | 9.60                     | 5.91               | 19.5                |
| 8   | BFP Power Optimization while running it alternate unit.  | 0.00                     | 2.59               | 0.0                 |
| 9   | Idle Bed Ash Cooler Fluidization Air Isolation as per Ash % in coal                              | 0.00                     | 2.47               | 0.0                 |
| 10  | Increasing CFBC boiler reliability by prevention of cyclone jamming using service air.           | 0.05                     | 2.19               | 0.3                 |
| 11  | Ash conveying probe mode with line block timer   | 0.50                     | 1.94               | 3.1                 |
| 12  | Standby VFD power OFF  | 0.00                     | 1.78               | 0.0                 |
| 13  | CEP Logic Modification to reduce discharge valve throttling loss                                 | 0.00                     | 1.41               | 0.0                 |
| 14  | Service Water Pump Running Hour optimization   | 0.00                     | 1.23               | 0.0                 |
| 15  | ESP power optimization by changing its field milliamp as per boiler load                         | 0.00                     | 1.22               | 0.0                 |
| 16  | Feed water station logic modification to reduce throttling feed water loss                       | 0.00                     | 1.08               | 0.0                 |
| 17  | Installation of Air Blower for Cleaning  | 0.00                     | 0.87               | 0.0                 |
| 18  | SOV installed in CHP Inst. Air line and open it from CCR only                                    | 0.20                     | 0.77               | 3.1                 |
|     | TOTAL :  | 41.49                    | 178.86             |                     |



# **Energy Savings Projects in FY'20-21**

| S.No. | Title of Project   | Investment<br>Made<br>(Rs Lacs) | Total<br>Annual<br>Savings<br>(Rs Lacs) | Payback<br>(Months) |
|-------|--|---------------------------------|---|---------------------|
| 1     | Modification of CT make-up water Line for reducing degasser pump running hours.        | 0                               | 0.24                                    | 0.0                 |
| 2     | Utilization of Cooling water pump-A instead of Raw water pump for drinking tank makeup | 0                               | 0.72                                    | 0.0                 |
| 3     | Installation of Energy Efficient Pump In place of existing Raw Water Pump              | 1.9                             | 1.21                                    | 18.8                |
| 4     | Reduction in Idle running hours of TPP Coal Handling Plant L2 group                    | 0                               | 0.85                                    | 0.0                 |
| 5     | Solar Renewable Power utilization  | 0.00                            | 44.06                                   | 0.0                 |
| 6     | Reducing APC after TPP-1 ACC Fin cleaning  | 2.82                            | 8.73                                    | 3.9                 |
| 7     | Reducing APC after TPP-2 ACC Fin cleaning  | 2.22                            | 6.99                                    | 3.8                 |
|       | Total  | 69.400                          | 628.07                                  |                     |



# **Energy Savings Projects in FY'21-22**

| S.No. | Title of Project  | Investment<br>Made<br>(Rs Lacs) | Total<br>Annual<br>Savings<br>(Rs Lacs) | Payback<br>(Months) |
|-------|---|---------------------------------|---|---------------------|
| 1     | PHR improved by TG-1 Overhauling  | 9                               | 46.77                                   | 2.3                 |
| 2     | Installation of Energy Efficient Pump In place of existing Raw Water Pump | 1.3                             | 0.97                                    | 16.0                |
| 3     | RO reject water utilized by Reject water Pump in place of Raw water Pump  | 0.4                             | 1.15                                    | 4.2                 |
| 4     | PHR Improvement by arresting Start-up Vent passing                        | 1.8                             | 18.974                                  | 1.1                 |
| 5     | PHR Improvement by ACC leakage arresting work                             | 8                               | 23.72                                   | 4.0                 |
| 6     | APH high pressure hydro jet cleaning and Tube replacement                 | 27                              | 66.72                                   | 4.9                 |
| 7     | Reducing APC after TPP-1 ACC Fin cleaning                                 | 2.98                            | 33.59                                   | 1.1                 |
| 8     | Reducing APC after TPP-2 ACC Fin cleaning                                 | 2.2                             | 8.47                                    | 3.1                 |
| 9     | Solar Renewable Power utilization   | 0.00                            | 185.55                                  | 0.0                 |
|       | Total   | 526.800                         | 3859.16                                 |                     |



### **Energy Savings Projects of last 3 FYs**

| Year       | No of Energy<br>saving projects | Investments<br>(INR Million) | Electrical savings<br>(Million kWh) | Thermal savings<br>(Million Kcal/ MTOE) | Savings<br>(INR Million) |
|------------|---------------------------------|------------------------------|-------------------------------------|---|--------------------------|
| FY 2019-20 | 18                              | 4.149                        | 1.90                                | 12                                      | 17.89                    |
| FY 2020-21 | 7                               | 0.694                        | 8.34                                | 0                                       | 6.28                     |
| FY 2021-22 | 9                               | 5.268                        | 10.64                               | 1590                                    | 38.59                    |



### Reduction in Throttling loss by Installation of VFD in DM Plant RO high pressure pump

#### Opportunity

 In DM Plant, RO high pressure pump was running at full RPM.
 Valve was being throttled for controlling flow of Pump. Hence Throttling loss was increasing its power consumption.

| Modification   | Benefits   |
|--|--|
| <ul> <li>VFD was installed in<br/>Motor of RO high<br/>pressure pump of DM<br/>Plant.</li> <li>Thereby throttling loss<br/>was reduced due to VFD<br/>being operated at low<br/>RPM when less flow is<br/>required.</li> <li>Investment made was<br/>Rs. 0.88 Lac</li> </ul> | <ul> <li>Power saving<br/>achieved of 25.52<br/>kWh/day</li> <li>Saving of Rs. 0.42<br/>Lac per annum.</li> <li>Reduction in<br/>vibration of its<br/>discharge line is<br/>also there.</li> </ul> |





### ACC tube bundles leakages in-house Arresting Work.

#### Opportunity

 Two Ejectors were needed to keep in line to maintain Turbine-1 Vacuum and vacuum was not getting maintained at higher load due to leakage in ACC tube bundles. Due to this, TG-1 Auxiliary Steam Consumption was higher (1 TPH)

#### Modification

- Leakages in ACC tube Bundles were identified by helium leak test.
- After identification of leakage points, leakages tubes were made dummy by taking care of proper removal of NCG gases during TPP-1 shutdown with in-house by online consultation with M/s ACC Praharpur.

#### Benefits

- Improvement in TG-1 Reliability.
- Auxiliary steam consumption in ejector reduced and recovered by 0.50 TPH.
- Financial Savings by Recovery of Rs. 38.76 Lac per annum

Gemba Investigati on/ Brain Storming



Helium Leak Test & Leakage arrested

Optimization of ACC Fan Power



### Enhancement in coal capacity of Silo-2 Apron

#### Opportunity

- Coal silo-2 Apron capacity was only 110MT per hour hence running hours of coal plant was high.
- Coal handling circuit was running with under load

#### Modification

- Operating Frequency of Motor of coal silo-2 apron motor of was increased from 50Hz to 60Hz.
- Thereby we achieved coal transfer capacity of 160 MT per hour which was 110 MT per hour previously.

#### Benefits

- Power saving achieved of 80.1 kWh/day
- Saving of Rs. 1.2 Lac per annum.
- Reduction in running time of coal Plant by 50 minutes/day



Sewagram Cement Works



#### Utilisation of Renewable Energy sources

| Year       | Technology | Type of<br>Energy | Onsite/<br>Offsite | Installed Capacity<br>(MW DC) | Generation<br>(million kWh) | % of overall electrical energy |
|------------|------------|-------------------|--------------------|-------------------------------|-----------------------------|--------------------------------|
| FY 2019-20 | Electrical | Solar             | Onsite             | 4.00                          | 8.26                        | 3.97                           |
| FY 2020-21 | Electrical | Solar             | Onsite             | 4.00                          | 7.92                        | 3.85                           |
| FY 2021-22 | Electrical | Solar             | Onsite             | 4.00                          | 8.13                        | 3.85                           |

# FY'22 Solar Power Generation (Lac kWh





# Firing of Alternate Fuel FY 21-22





# 8a. Environment Management- Ash Utilization

### 1. Annual Ash Utilization of past 3 years (FY 19-20 to FY 21-22)

| Particulars     | UOM  | 2019-20 | 2020-21 | 2021-22 |
|-----------------|------|---------|---------|---------|
| Ash Generated   | Tons | 46186   | 35777   | 56887   |
| Ash Utilization | %    | 100     | 100     | 100     |

- 2. Modes of Ash Conveying Dry (Pneumatic Conveying)
- 3. Distribution of Areas of Ash Utilization Cement Plant







# 8b. Environment Management- Ash Utilization

| Particulars                             | UOM        | 2019-20  | 2020-21  | 2021-22  |
|---|------------|----------|----------|----------|
| Ash Stock in Plant (2 no.s of Silos)    | Tons       | 600      | 600      | 600      |
| Ash Generated                           | Tons       | 46186    | 35777    | 56887    |
| Ash Utilization                         | %          | 100      | 100      | 100      |
| Ash Utilized in Cement                  | %          | 80       | 80       | 80       |
| Ash Utilized in Kiln Raw mix            | %          | 20       | 20       | 20       |
| Expenditure on Ash Utilization (annual) | INR (Lacs) | 25.01    | 25.01    | 25.01    |
| Ash Conveying method                    | Dry / Wet  | 100% DRY | 100% DRY | 100% DRY |





# 8c & 8d. Environment Management-Emission

| Particulars                                 | UOM                | 2019-20 | 2020-21 | 2021-22 |
|---|--------------------|---------|---------|---------|
| CO <sub>2</sub> Emissions<br>Per Generation | Ton/kW             | 0.0011  | 0.0013  | 0.0012  |
| SOx Emissions at<br>Full Load               | mg/Nm <sup>3</sup> | 454     | 396     | 412     |
| NOx Emissions at<br>Full Load               | mg/Nm <sup>3</sup> | 209     | 164     | 196     |
| Particulate<br>Matter                       | mg/Nm <sup>3</sup> | 28      | 27      | 36      |
| Mercury                                     | mg/Nm <sup>3</sup> | <0.01   | <0.025  | <0.025  |

# Best Practices Adopted for emission Control and Monitoring:

Continuous emission Monitoring system

Ambient Air Quality Monitoring System

### Current Emission:

### SOX- 402 mg/Nm3; NOx- 158 mg/Nm3; SPM- 28 mg/Nm3

#### Detailed plan for achieving the current emission norms for thermal power plants:

- Premix Limestone taken with coal in coal bunker to control Sox in Boiler.
- □ Continuous Limestone dosing in boiler to control Sox
- □ ESP Tuning as per Particulate matter emission
- □ To clean and inspect ESP, Rappers and its plates whenever get opportunity..
- □ Recirculating fly ash with high petcoke usage for maintaining bed temperature and thereby Nox



# 8e. Environment Management- Water

| Particulars           | UOM   | 2019-20 | 2020-21 | 2021-22 |
|-----------------------|-------|---------|---------|---------|
| DM water Consumption  | %     | 1.70    | 1.35    | 2.014   |
| Raw Water Consumption | m3/MW | 0.29    | 0.28    | 0.29    |
| Liquid discharge      | m3    | ZERO    | ZERO    | ZERO    |

### Best Practices in Water Management

- ✓ Reusing RO reject water as Service Water at Silo Ash Unloading, Gardening etc.
- ✓ Daily monitoring of Service water pump running hours and its optimization by installation of local switch at various locations.
- ✓ Circulating Daily defect list twice a day to attend any leakages.
- ✓ Daily checking of water balancing.
- ✓ Steam dumping is preferred rather than venting to recover DM water during load cut off condition
- $\checkmark~$  Roof Rain water harvesting at shopping complex. .



# **9. Best Practices**

# Energy monitoring system installation for better analysis of Aux. Power consumption

#### Shift wise report generating and sharing for monitoring

- ✓ Auxiliary power
- ✓ Environment Parameters like Sox, Nox and SPM
- ✓ Turbine inlet Steam pressure and temperature
- ✓ Steam Venting & Dumping
- ✓ Turbine Vacuum
- Energy efficient Motors & LED Illumination System
- Installed Alarm to identify idle running of CHP.
- Maximum utilization of AFBC boiler high LOI fly ash in CFBC boiler as a fuel.
- Daily Power cost monitoring report generation and its sharing to all.
- 100% ash of boiler, utilized for Cement Manufacturing .
- Disturbance recorder in DCS for quick identification of fault during abnormality.

# 10. Teamwork, Employee Involvement & Monitoring

- Daily Performance Monitoring of Auxiliary, PHR, Boiler Efficiency, Water Consumption and other critical parameters of Plant is done.
- Daily Performance Monitoring meeting is chaired by HOD- TPP

ADITYA BIRLA

UltraTech

- Energy Awareness Training Program by Energy Manager and Auditors.
- 101 Kaizens implemented at worker and supervisor level.
- Boiler Fans and ACC are the areas whose Power Consumption is to be optimized.



IZEN Team aw





### Energy efficiency / awareness training program

| SL. | TITLE OF THE PROGRAMME  | VENUE                   | DATE (S)           |
|-----|---|-------------------------|--------------------|
| 1   | Electrical Energy Conservation & Management   | J.K. Cement WORKS (RTC) | June 10 - 11, 2019 |
| 2   | Electrical, Cable, Energy Management, Mining Solution, HT motors                        | Virtual Training        | 03.04.2020         |
| 3   | Energy reduction and Productivity improvement through plant upgrades                    | Virtual Training        | 03.04.2020         |
| 4   | Energy efficiency in cement manufacturing & certified green cement expert               | Virtual Training        | 13.04.2020         |
| 5   | Latest solution for Energy Management System with Live demo                             | Virtual Training        | 04.04.2020         |
| 6   | Energy Sustainability, Best Practice adopted all over the Industries.                   | Virtual Training        | 04.04.2020         |
| 7   | Energy & Carbon Management Technical Standard   | Virtual Training        | 04.04.2020         |
| 8   | Energy management through Aluminum metal spraying and Aluminum based polymeric coatings | Virtual Training        | 05.05.2020         |
| 9   | CII Certified Professional in Energy Efficiency (Cement Sector) from 8 -12 March 2021   | Virtual Training        | 8 -12 March 2021   |
| 10  | Energy Management System  | Sewagram Cement Works   | 16.05.2020         |
| 11  | Awareness Session on ISO 50001  | Sewagram Cement Works   | 02.06.2021         |
| 12  | Energy Conservation & Management  | Sewagram Cement Works   | 8.11.2021          |
| 13  | Energy reduction awareness session  | Sewagram Cement Works   | 14.03.2022         |



### Energy Management System ISO50001:2018 & Green Products



SCW has got "Certification from International organization for standardization for Integrated Management systems for Energy Management System (ISO 50001:2018) from certification agency DNV.

#### Sewagram Cement Works

GreenPro and LCA studies helped assess various initiatives taken by the company for reducing the environmental impact of manufacturing cement at every stage of its lifecycle.



### Learnings from CII Energy Award

| Knowledge                   | <ul> <li>Helped in building technical knowledge to increase<br/>energy efficiency of plant</li> </ul>  |  |  |
|-----------------------------|--|--|--|
| Troubleshooting of Problems | <ul> <li>Different case studies acts as a ocean of knowledge<br/>helped in trouble shooting of problems</li> </ul>   |  |  |
| Best Practices              | <ul> <li>We have implemented many best practices which<br/>have improved the performance of our plant.</li> </ul>  |  |  |
| Recognition                 | <ul> <li>The Awards give an opportunity to companies to<br/>shine and be known nationally and internationally for<br/>their innovative products and services and its<br/>commitment towards Energy Conservation</li> </ul> |  |  |





### **Quality Circle Awards**





# **CSR Focus Area**





| Education   | Health   | Sustainable<br>livelihood   | Infrastructure<br>Development                                      | Social<br>Empowerment  |
|---|--|---|--|--|
| Initiating and<br>Supporting<br>Education<br>programs | Facilitating the<br>strengthening<br>of<br>Health<br>Services<br>and the health<br>delivery<br>network | Providing<br>training<br>in various<br>vocational<br>skills<br>and<br>opportunities<br>for<br>community | Supporting the<br>development<br>of<br>community<br>Infrastructure | Develop<br>Positive<br>attitude<br>among the<br>villagers<br>towards Social<br>evils |
|   |  |   |  |  |

We are committed to the overall development of the villages around our factories/projects through multi-stakeholder partnerships

Government

**NGO Partnerships** 

**Employee Engagement** 



**Thank You** 

### **Team Members:**

- 1) Kamlesh Verma- 9922413023 (<u>kamlesh.verma@adityabirla.com</u>)
- 2) Gopesh Kumar Sharma- 7069091338 (gopesh.kumar@adityabirla.com