



# 24<sup>th</sup> National Award for Excellence in Energy Management 2023

CCC, Coimbatore

Sep 2023

# Contents

1	Cognizant overview	3
2	Facility overview	4 – 5
3	Architectural design of the building	6
4	Certifications & achievements	7
5	We committed	8
6	Energy consumption overview	9
7	Benchmarking & energy conservation approach	10 – 13
8	Energy saving projects implemented in last three years	14 – 16
9	Innovation project	17 – 19
10	Utilization of renewable energy sources	20
11	Waste management	21
12	GHG emission and indoor air quality	22 – 24
13	Measuring, monitoring & training	25 – 26
14	IGBC – LEED certificate	27
15	Net zero goal	28
16	Way forward	29

# Cognizant Overview

Cognizant (NASDAQ – 100: CTSB) is one of the world’s leading professional services companies that engineers modern businesses. We help our clients modernize technology, reimagine processes and transform experiences so they can stay ahead in our fast – changing world. Together, we’re improving everyday life.



# Facility Overview

CCC (Cognizant Coimbatore Campus) is an owned facility.

Commencement of operation from:

- SDB1 – 2009
- SDB2 – 2014 (Tower – 2)  
– 2016 (Tower – 1)

Campus area :

- SDB1 – 6.56 Lakhs ft<sup>2</sup> with G+7 floors
- SDB2 – 6.50 Lakhs ft<sup>2</sup> with G+7 floors(Tower – 1&2)
- Green belt spread across 4.0 Lakhs ft<sup>2</sup>

Seat capacity : 14,049





- SDB1 – 5,775 seats
- SDB2 – 8,274 seats

1st Facility in Cognizant to attain “LEED India Gold Certification”.


ISO 45001:2018 Certified Facility



# Utilities Overview

Description	Specification
Substation 	<ul style="list-style-type: none"> <li>• EB Demand : 7,400 kVA</li> <li>• Transformers Capacity : 2,500 kVA x 6 Nos (Oil cooled transformers)</li> </ul>
Roof Top Solar 	<ul style="list-style-type: none"> <li>• Total Capacity : 750 kW<sub>p</sub> ( 2 x 375 kW<sub>p</sub>)</li> </ul>
Diesel Generators 	<ul style="list-style-type: none"> <li>• Total Capacity : 15,000 kVA</li> <li>• Capacity Break up : 10 Nos x 1,500 kVA</li> </ul>
UPS 	<ul style="list-style-type: none"> <li>• Total Capacity : 2,860 kVA (Workstation – 2,300 kVA)</li> </ul>
Chillers 	<ul style="list-style-type: none"> <li>• Total Capacity : 6090 TR</li> <li>• Type - Water Cooled : 3 Nos x 950TR   3 Nos. X 900TR   2 Nos. x 270TR</li> </ul>
Sewage Treatment Plant 	<ul style="list-style-type: none"> <li>• Capacity : 2 Nos x 375 kL per day</li> </ul>
High Speed Diesel (HSD) 	<ul style="list-style-type: none"> <li>• Capacity : 60 kL</li> </ul>
Rainwater Sump 	<ul style="list-style-type: none"> <li>• Capacity : 70 kL</li> </ul>

# Architectural design of the building



# Awards & Recognitions



**Cognizant**

**Best Energy Saving Facility 2011**



**Cognizant**

**Best Energy Saving Facility 2012**



**CII**

**Excellent Energy Efficient Unit 2013**



**CII**

**Excellent Energy Efficient unit  
Most Useful Presentation 2019**



**CII**

**– Excellent Energy Efficient Unit 2022**

# We committed in 23<sup>rd</sup> National Award for Excellence in Energy Management 2022



Energy efficient power transformer retrofit

👍 Completed



AHU conventional V belt replacement with polyurethane belt

👍 Completed



Solar based battery inbuilt LED streetlight

👍 Completed



T5 light fixtures replace with LED light fitting

👍 Completed




AHU – EC fan retrofit

🕒 PO issued - WIP




# Energy consumption trend – 2020 to 2022



Energy consumption trend in million kWh



Monthly energy consumption trend last 3 years in million kWh



# Cognizant's approach



# National benchmark comparison

Benchmark data - BEE for buildings where air-conditioned area is 50% more than carpet area bandwidth at buildings for 3 climate zones


EPI in kWh / m <sup>2</sup> / Year			
Star rating	Warm and humid	Composite	Hot and dry
1 Star	200 – 175	190 – 165	180 – 155
2 Star	175 – 150	165 – 140	155 – 130
3 Star	150 – 125	140 – 115	130 – 105
4 Star	125 – 100	115 – 90	105 – 80
5 Star	Below 100	Below 90	Below 80

Coimbatore facility EPI				
Description	2019	2020	2021	2022
EPI: kWh/m <sup>2</sup> /year	117	54	30	34




\* Solar energy excluded.

# Cognizant internal benchmark comparison




\* Solar energy included.

# Specific energy consumption (kWh/m<sup>2</sup>/Year) – 2018 to 2022



\* Solar energy excluded.


# Our journey



# Summary on ENCON projects – Investments

S.No	Title of project	Year	Total annual energy saving (kwh)	Total annual savings (₹ INR million)	Investment made (₹ INR million)	Payback (months)
1	LED Retrofit – workstation space – 2x36W CFL to 24W LED lights around – 2,610 numbers	2020	7,608	3.48	4.35	15.0
2	LED Retrofit – downlighter 18W CFL to 12W LED – 400 numbers (Raw and EL)	2020	10,800	0.08	0.34	53.0
3	300KVA UPS 1&2 workstation UPS Energy saver Eco mode enable	2020	2,30,256	0.11	0.00	0.0
4	Cooling tower fills replacement retrofit at SDB – 1 1000 TR CT 1 & 3 and 300 TR CT 1	2020	150	2.37	2.09	11.0
5	New condenser coil replacement at SDB – 1 chiller – 1 900TR	2020	87,060	0.00	4.49	0.0
6	LED retrofit – workstation space – 2x36W CFL to 24W LED lights around – 705 numbers	2021	15,216	1.21	1.17	12.0
7	LED retrofit – downlighter 18W CFL to 12W LED – 800 numbers (Raw and EL)	2021	5,530	0.21	0.69	39.0
8	LED retrofit for SDB – 2 Tower – 1 & 2 staircase lights (EL) from 2x18w CFL to 20W LED (surface mounted) fitting – 40 numbers	2021	1,53,504	0.08	0.09	14.0
9	Cooling tower FILS replacement retrofit at SDB – 1 1000 TR CT 3 and 300 TR CT 2	2021	1,45,152	2.14	1.05	6.0
10	STP Plant – one stream of 375KLD aerator system optimization	2021	8,460	2.02	0.00	0.0
11	LED retrofit – workstation space – 2x36W CFL to 24W LED lights around – 1,800 numbers	2022	2,30,124	3.45	3.45	13.0
12	LED retrofit – downlighter 18W CFL to 12W LED – 80 numbers (Raw and EL)	2022	1,728	0.03	0.03	11.0
13	Solar LED Retrofit – 35w LED St. Lights to 35w LED solar base inbuilt battery – 12 numbers	2022	7,200	0.11	0.11	49.0
14	Energy efficient power transformer retrofit at SDB – 1 substation – 1 number	2022	21,570	1.91	6.58	38.0
15	HVAC Retrofit – Hub room BVRF to IVRF ODU replacement at SDB – 1 – 4 numbers (2 X 22HP) & (2 X 12HP)	2022	98,280	1.14	1.14	20.0
16	HVAC Retrofit – LDPA unit to chilled water-based AHU unit installation – 2 numbers (22TR LDPA to 15TR AHU) at SDB – 1 GF UPS & Battery Room	2022	36,000	0.55	0.55	44.0
17	HVAC Retrofit – R22 to R32 energy efficient 5-star rated split unit upgradation	2022	2,49,885	0.25	2.08	7

# Energy saving projects implemented – 2020 to 2022



Year	Number of energy savings projects	Investments (₹ INR million)	Energy Save (Million kWh)	Cost Save (₹ INR million)	Impact on SEC (%)
2020	5	11.27	0.59	6.04	7.97%
2021	5	3.01	0.41	5.66	9.15%
2022	7	16.22	0.64	10.93	12.77%



# Innovative : 1 – Energy efficient power transformer retrofit



## Ideation

Energy efficient power transformer  
2500 kVA 22/0.433kV



## Challenges

- High voltage issue at during nighttime and weekend.
- Forced to run the DG system.
- High carbon emission.



## Target

- High voltage period is eliminated.
- DG running cost is eliminated.
- High efficiency & energy savings. Winding design is as per IS:1180 Level – 2.



## Growth

Cost avoidance } 19.5 Lakhs  
Energy savings } 21,570 kwh  
Co2 emission } 100 Metric Tons

## Before



## After



Efficiency	Exiting transformer 2500kVA, 22/11/0.433kV		New transformer 2500kVA, 22/0.433kV IS: 1180 Level – 2	
	U.P.F	0.8P.F	U.P.F	0.8P.F
100% load	98.78%	98.48%	99.27%	99.09%
75% load	99.00%	98.76%	99.40%	99.26%
50% load	99.18%	98.98%	99.51%	99.38%
25% load	99.19%	98.99%	99.50%	99.37%
<b>Load at which max efficiency occurs</b>	<b>Efficiency : 99.232% @ Load: 35.162%</b>		<b>Efficiency : 99.530% @ Load : 36.453%</b>	

# Innovative : 2 – HVAC Retrofit – DX to AHU installation at the UPS room



## Objective

Conversion of DX to chilled water-based AHU unit installation at the UPS room.



## Process

22TR LDPA to 15TR AHU  
DX to chilled water-based operation.



## Target

- Low O & M cost.
- CO<sub>2</sub> reduction on refrigerated avoidances.
- Higher Efficiency



## Growth

- Energy savings: 43,200 kWh
- Cost savings: INR 6,97,688



Energy savings calculation			
Sl. no	Description	UOM	Qty
1	LDPA unit operational average consumption	kWh/Day	130
2	AHU operational average consumption	kWh/Day	30
3	Energy savings per day	kWh/Day	100
4	Energy savings per month	kWh	3,600
5	Cost savings per month (Rs.15.25)	INR	45,750
6	<b>Cost savings per annum</b>	<b>INR</b>	<b>6,97,688</b>

# Innovative : 3 – R22 to R32 energy efficient 5 – star rated split unit retrofit



## Objective

Conversion of R22 to R32 energy efficient 5 star rated split unit.



## Process

R22 to R32 operated split unit.



## Target

- Eco-friendly maintenance
- High CFM level achieved – contributing energy saving
- Over energy savings achieved – 20%



## Growth

Energy savings: **2,49,885 kWh**  
 Cost savings: **INR 2,49,885**

## Energy savings calculation

Make		Capacity	Qty	Total tonnage	Operational hour/day	Old unit EER	New unit EER	Old system energy consumption in annum	EE 5star unit energy consumption in annum	Energy save, kWh in annum
Daikin	Cassette	2	2	4	12	2.1	3.5	80,091	48,055	32,037
Daikin	Cassette	4	2	8	12	2.1	3.5	1,60,183	96,110	64,073
Daikin	Split	1.5	4	6	12	2.1	3.5	1,20,137	72,082	48,055
Daikin	Split	1.8	4	7.2	12	2.1	3.5	1,44,165	86,499	57,666
Daikin	Split	3	2	6	12	2.1	3.5	1,20,137	72,082	48,055
<b>Total</b>		<b>12.3</b>	<b>14</b>	<b>31.2</b>	<b>12</b>	<b>2.1</b>	<b>3.5</b>	<b>624,713</b>	<b>3,74,828</b>	<b>2,49,885</b>

Food court 3<sup>rd</sup> floor UPS room

Indoor



Outdoor



Food court 3<sup>rd</sup> floor Hub room


Indoor



Outdoor



# Utilization of renewable energy sources



95% is through renewable energy

Year	EB	Wind (Offsite)	Solar (Onsite)	DG	Total	%of Renewable
2020	1,760,293	4,588,945	835,544	177,685	7,362,467	74%
2021	3,521	3,512,227	757,263	168,137	4,441,148	96%
2022	119,760	3,929,634	871,594	124,390	5,045,378	95%



Offsite wind wheeling



Onsite rooftop solar (750 kW<sub>p</sub>)

# Waste management



E – waste disposed through authorized recycler



Food waste processed through OWC and utilized as manure



Paper waste processed through ITC




STP plant recycle water utilized for WC flushing, gardening




Ban on single – use plastic as per TNPCB



Batteries disposed through authorized recycler




## Recycle Certificate



# GHG emission trend


## GHG emission



Sources	Refrigerant							Diesel	LPG	Electricity	Scope 1	Scope 2
	R22	R134a	R407C	R410A	R125	R32	R404A	Diesel (stationary & mobile)	LPG consumption	Grid unit		
UOM	kg	kg	kg	kg	kg	kg	kg	litre	kg	kWh	Ton of CO2	Ton of CO2
2019	16.4	930	7.5	92.6	0	0	0	1,01,140	32840	76,74,179	1,935.8	6,216.08
2020	9.22	434	30	155.5	0	0	0	65,680	235	17,60,293	1,193.2	1,425.84
2021	9.22	620	30	155.5	0	0	0	69,825	564	3521	1,471.4	2.85
2022	9.5	0	10.5	76.8	0	0	0	57,700	2612	1,19,760	359.6	97.01

# Environment test reports

E-mail : test@mettexlab.com Phone : 044-22323163, 22311034  
 Web : www.mettexlab.com 42179490, 42179491


**CHENNAI METTEX LAB PRIVATE LIMITED**  
 Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032.

**TEST REPORT** Page No 1 of 1

**ISSUED TO:** M/s. Cognizant Technology Solutions India Pvt Ltd.,  
 C3-CHIL Special Economic Zone,  
 Keeranatham Village, Saravanampatti Via,  
 Coimbatore - 641 035.

Customer Reference : Email Dated: 31.03.2023  
 Laboratory Reference No : 23103709  
 Sampling Plan & Procedure : CML/LAB/ENV/SOP/08  
 Date of Sampling : 30.03.2023  
 Date of Receipt : 31.03.2023  
 Sample Description : Indoor Air Quality Monitoring  
 Location of Sampling (as stated by customer) : CCC2SD05C01M466.

Test Certificate No : CML/23-24/2946  
 Test Certificate Date : 12.04.2023  
 Analysis Commenced On : 31.03.2023  
 Analysis Completed On : 10.04.2023

Sl. No.	TEST PARAMETERS	TEST METHOD	RESULTS	Unit	Permissible Limit	Reference
01	Oxygen (O <sub>2</sub> )	NIOSH Manual of Analytical Method (4 <sup>th</sup> Edition) - Method 6601.1994	20.9	%	19.5 to 23.5	OSHA
02	Carbon Monoxide as (CO)	NIOSH Manual of Analytical Method (5 <sup>th</sup> Edition) - Method 6604 - 2016	BDL(DL 1.0)	ppm	<9 ppm for max 8 hrs.	ASHRAE 62.1.2016
03	Carbon Dioxide (CO <sub>2</sub> )	ASTM D 6245 - 2018	571	ppm	< 1000	ASHRAE 62.1.2007
04	Respirable Suspended Particulate Matter (RSPM)	IS 5182 Part 23 (RA 2017):2006	8.6	µg/m <sup>3</sup>	50	ASHRAE 62.1.2016
05	Temperature	CML/IAQ/SOP/18	25.2	°C	23° - 26° C in summers and 20° C - 24° C in winters	ASHRAE 62.1.2016
06	Relative Humidity (RH)	CML/IAQ/SOP/18	58	%	30 - 60	ASHRAE 62.1.2016
07	Ventilation Rate	ASTM D 6245 - 2018	48.0	cfm	Min 17	ASHRAE 62.1.2016
08	Total Volatile Organic Compounds	USEPA Method 21-1995	0.007	ppm	3	ASHRAE 62.1.2016
09	Illumination	CML/ILL/SOP/23	345	Lux	200 - 400	NBC
Discipline - Biological						
10	Total Bacterial Count	APHA 5 <sup>th</sup> Edn. 2015 Ch. - 3	92	cfu/ m <sup>3</sup>	500	AIHA
11	Total Fungal Count	APHA 5 <sup>th</sup> Edn. 2015 Ch. - 3	31	cfu/ m <sup>3</sup>	500	AIHA
12	Legionella	APHA 5 <sup>th</sup> Edn. 2015 Ch. - 3	Absent/plate		Absent	AIHA


**Note:** OSHA - Occupational Safety and Health Administration. ASHRAE - American Society of Heating, Refrigerating, and Air-Conditioning Engineers. AIHA - American Industrial Hygiene Association, APHA - American Public Health Association, PPM - Parts Per Million, CFU - Colony Forming Unit. BDL - Below Detection Limit. DL - Detection Limit. NBC - National Building Code of India  
 Unit Conversion : CO<sub>2</sub> 1ppm = 1.8 mg/m<sup>3</sup>. Total Volatile Organic Compounds 1ppm = 1000 ppb, 1 ppb = 2 µg/m<sup>3</sup>

For Chennai MettEx Lab Private Limited  
 Reviewed & Authorized By  
**G.S. RADHA**  
 Technical Manager

For Chennai MettEx Lab Private Limited  
 Reviewed & Authorized By  
**V. SELVAKUMAR**  
 Senior Chemist

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirements, while permissible & environmental testing related residual samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai MettEx Lab's customer, and is provided in accordance with the agreement between Chennai MettEx Lab and its Customer.

E-mail : test@mettexlab.com Phone : 044-22323163, 22311034  
 Web : www.mettexlab.com 42179490, 42179491


**CHENNAI METTEX LAB PRIVATE LIMITED**  
 Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032.

**TEST REPORT** Page No 1 of 2

**ISSUED TO:** M/s Cognizant Technology Solutions India Pvt Ltd.,  
 C3-CHIL Special Economic Zone,  
 Keeranatham Village, Saravanampatti Via,  
 Coimbatore - 641 035.

Cust. Ref : Email Dated : 10.11.2022  
 Lab No : 2360072  
 Sample Description : Stack Emission : 1500 KVA DG - 3 (Phase - II), (as stated by customer)  
 Work Commenced on : 09.11.2022  
 Sampling Plan & Procedure : CML/LAB/ENV/SOP/09  
 Discipline / Group : Chemical / Atmospheric Pollution

T.C Date : 17.11.2022  
 T.C No : CML/22-23/54265  
 Date Of Receipt : 10.11.2022  
 Analysis Commenced On: 10.11.2022  
 Analysis Completed On : 14.11.2022

Sl. No.	Stack Details	
01.	Diameter	1.0 m
02.	Ambient Temperature	30 °C
03.	Stack Temperature	199 °C
04.	Velocity	7.6 m/sec
05.	Volume of Gas discharged	13,424 Nm <sup>3</sup> /hr


Sl. No.	TEST PARAMETERS	UNIT	TEST METHOD	RESULTS	CPCB NORMS
01.	Particulate Matter	mg/Nm <sup>3</sup>	IS 11255 Part 1-1985 (RA:2019)	24.6	75
02.	Sulphur-di-oxide (SO <sub>2</sub> )	mg/Nm <sup>3</sup>	USEPA Method - 6C - 1996	BDL (DL:3.0)	--
03.	Oxides of Nitrogen (NOx)	ppmv	USEPA Method - 7E - 1990	263	710
04.	Carbon Monoxide as CO	mg/Nm <sup>3</sup>		117	150
05.	Carbon dioxide as CO <sub>2</sub>	%	CML/STACK/SOP/05	5.5	--
06.	Oxygen as O <sub>2</sub>	%		13.2	--

**Note:** BDL : Below Detection Limit. DL : Detection Limit.

For Chennai MettEx Lab Private Limited  
 Reviewed & Authorized By  
**P. KAVITHA**  
 Technical Manager  
 Authorised Signatory

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirements, while permissible & environmental testing related residual samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai MettEx Lab's customer, and is provided in accordance with the agreement between Chennai MettEx Lab and its Customer.

E-mail : test@mettexlab.com Phone : 044-22323163, 22311034  
 Web : www.mettexlab.com 42179490, 42179491


**CHENNAI METTEX LAB PRIVATE LIMITED**  
 Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032.

**TEST REPORT** Page No 1 of 1

**ISSUED TO:** M/s Cognizant Technology Solutions India Pvt Ltd.,  
 C3-CHIL Special Economic Zone,  
 Keeranatham Village, Saravanampatti Via,  
 Coimbatore - 641 035.

Cust. Ref : Email Dated : 05.11.2022  
 Lab No : 2358932  
 Sample Description : Ambient Air Quality - Near Pump Room - Phase - I, (as stated by customer)  
 Work Commenced on : 03.11.2022 - 11.30 am to 04.11.2022 - 11.30 am  
 Ambient Temperature : Min. 22.9 °C & Max. 29.2 °C  
 Relative Humidity : Min 58 % & Max. 92 %  
 Sampling Plan & Procedure : CML/LAB/ENV/SOP/07  
 Discipline / Group : Chemical / Atmospheric Pollution

T.C Date : 17.11.2022  
 T.C No : CML/22-23/54254  
 Date Of Receipt : 05.11.2022  
 Analysis Commenced On: 05.11.2022  
 Analysis Completed On : 11.11.2022

Sl. No.	TEST PARAMETERS	UNIT	PROTOCOL	RESULTS	TNPCB STANDARDS
01	Sulphur dioxide as SO <sub>2</sub>	µg/m <sup>3</sup>	IS: 5182 Part 2- 2001 (Reaff 2017)	7.2	80 (24 Hours)
02	Nitrogen Dioxide as NO <sub>2</sub>	µg/m <sup>3</sup>	IS: 5182 Part 6-2006(Reaff 2017)	15.5	80 (24 Hours)
03	Particulate Matter (PM <sub>10</sub> ) (Size Less than 10 µm)	µg/m <sup>3</sup>	IS: 5182 Part 23-2006(Reaff 2017)	48.9	100 (24 Hours)
04	Particulate Matter (PM <sub>2.5</sub> ) (Size Less than 2.5 µm)	µg/m <sup>3</sup>	IS: 5182 Part 24-2019	25.2	60 (24 Hours)
05	Ozone as O <sub>3</sub>	µg/m <sup>3</sup>	IS: 5182 Part 9- 1974 (Reaff 2019)	BDL (DL:20)	100 (6 Hours)
06	Lead as Pb	µg/m <sup>3</sup>	USEPA Compendium Method IO-3.4.1999	BDL (DL:0.1)	1.0 (24 Hours)
07	Carbon Monoxide as CO	mg/m <sup>3</sup>	CML/IAIR/SOP/05	BDL (DL:0.1)	2.0 (6 Hours)
08	Ammonia as NH <sub>3</sub>	µg/m <sup>3</sup>	IS: 5182 Part 25- 1999 (Reaff 2019)	BDL (DL:20)	400 (24 Hours)
09	Benzene	µg/m <sup>3</sup>	IS: 5182 Part 11-2006 (Reaff 2017)	BDL (DL:1.0)	5.0 (Annual)
10	Benzo (a) Pyrene	ng/m <sup>3</sup>	IS: 5182 Part 12 -2004 (Reaff 2019)	BDL (DL:0.1)	1.0 (Annual)
11	Arsenic as As	ng/m <sup>3</sup>	USEPA Compendium Method IO-3.4.4.1999	BDL (DL:1.0)	6.0 (Annual)
12	Nickel as Ni	ng/m <sup>3</sup>	USEPA Compendium Method IO-3.4.1999	BDL (DL:1.0)	20 (Annual)

**Note:** BDL: Below Detection Limit. DL: Detection Limit  
 INSTRUMENT No. CML/ENV/FDS-042. RDS-029.

For Chennai MettEx Lab Private Limited  
 Reviewed & Authorized By  
**P. KAVITHA**  
 Technical Manager  
 Authorised Signatory

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirements, while permissible & environmental testing related residual samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai MettEx Lab's customer, and is provided in accordance with the agreement between Chennai MettEx Lab and its Customer.


# ENCON projects summary – GHG emission reduction

	SL NO	Project Title	Annual Savings	Cost Savings
2020	1	LED retrofit – workstation space – 2x36W CFL to 24W LED lights around – 2,610 numbers	33,83,40 kWh	INR 34.74 lakhs
	2	LED retrofit – downlighter 18W CFL to 12W LED – 400 numbers (Raw and EL)	7,608 kWh	INR 0.78 lakhs
	3	300KVA UPS 1 & 2 workstation UPS energy saver eco mode enable	10,800 kWh	INR 1.11 lakhs
	4	Cooling tower FILS replacement retrofit at SDB – 1 1000 TR CT 1&3 and 300 TR CT 1	2,30,256 kWh	INR 23.67 lakhs
	5	New condenser coil replacement at SDB – 1 chiller – 1 900TR	150 kWh	INR 0.02 lakhs
2021	1	LED retrofit – workstation space – 2x36W CFL to 24W LED lights around	87,060 kWh	INR 12.11 lakhs
	2	LED retrofit – downlighter 18W CFL to 12W LED – 800 numbers (Raw and EL)	15,216 kWh	INR 2.11 lakhs
	3	LED retrofit for SDB – 2 Tower – 1 & 2 staircase lights (EL) from 2x18w CFL to 20W LED (surface mounted) fitting – 40 numbers	5,530 kWh	INR 0.76 lakhs
	4	Cooling tower FILS replacement retrofit at SDB – 1 1000 TR CT 3 and 300 TR CT 2	1,53,504 kWh	INR 21.36 lakhs
	5	STP Plant – one stream of 375KLD aerator system optimization	1,45,152 kWh	–
2022	1	LED retrofit – workstation space – 2x36W CFL to 24W LED lights around – 1800 numbers	2,30,124 kWh	INR 34.52 lakhs
	2	LED retrofit – downlighter 18W CFL to 12W LED – 80 numbers (Raw and EL)	1,728 kWh	INR 0.26 lakhs
	3	Solar LED retrofit – 35w LED street-lights to 35w LED solar base inbuilt battery – 12 numbers	7,200 kWh	INR 1.08 lakhs
	4	Energy efficient power transformer retrofit at SDB – 1 substation – 1 number	21,570kWh	INR 32 lakhs
	5	HVAC retrofit – Hub room BVRF to IVRF ODU replacement at SDB1 – 4 numbers (2 X 22HP) & (2 X 12HP)	98,280 kWh	INR 11.44 lakhs
	6	HVAC retrofit – LDPA unit to chilled water-based AHU unit installation – 2 numbers (22TR LDPA to 15TR AHU) at SDB – 1 GF UPS & Battery Room	36,000 kWh	INR 5.49 lakhs
	7	HVAC retrofit – R22 to R32 energy efficient 5-star rated split unit upgradation	2,49,600 kWh	INR 38 lakhs




# Measuring, monitoring & training

Energy Report Monitoring & Review Flow Chart




Energy Report Monitoring & Review Flow Chart




# Best practices

## Digitalization



## Digitalization



## Digitalization



## Power Quality Improvement



- Live monitoring on critical systems
- Energy savings through automation

# IGBC – LEED Certificate



SDB-1



SDB-2

# Cognizant's commitment



**2040:** Reduce absolute emissions by 90%



**2030:** Reduce absolute emissions by 50%



**2026:** Source 100% renewable energy

NetZero to reduce our contribution to climate change we set a global, public goal of reaching net zero emissions compared to our 2019 emissions baseline. In order to achieve our Net Zero Goal, we will address emissions in our operations, including our offices and facilities, as well as from our supply chain and business travel. The commitment will shape our real estate management, energy sourcing, supply chain and travel philosophy in addition to the equipment and technologies we use in our offices and data centers.

### Key elements of our Net Zero Goal

- Focuses on absolute emissions reductions through operational efficiencies and renewable energy use, before the use of carbon offsets.
- Measures reductions from a recent, pre-COVID 19 emissions marking 2019 as a baseline.
- Includes a near-term renewable energy target.
- Includes often-hidden emissions, from travel to supply chain to associate commuting, in Scope 3
- Aligns with the need to keep global average temperature increases to 1.5 degrees Celsius

### Key elements of our Net Zero Goal governance

- Submitted for third-party validation with the Science Based Targets Initiative (SBTi)\*
- Periodically reviewed by the Board's Governance and Sustainability Committee
- Commissioned an external third-party to perform attestation procedures over our GHG emission
- According to the United States Environmental Protection Agency, Scope 3 emissions are the result of activities from assets not owned or controlled by the reporting organization, but that the organization indirectly impacts in its value chain.

# Way forward 2023 to 2024



SBR unit installation for cooling towers water treatment



Higher efficiency HVAC pump retrofit



Lift room across ventilation system to avoid running of DX unit - 👍



AHU – EC fan retrofit - ⌚



OCEMS system installation at STP Plant - 👍

## Investment towards energy saving projects in 2023

No of energy savings project in 2023	Investment (Rs in Million)
07	18

# Thank you

Kanipandi. G – Senior Associate

Jayaprakash. M – Chief Engineer