

# 24<sup>th</sup> National Award for Excellence in Energy Management

# **GMR Hyderabad International Airport Ltd.**

### **Presenting By:**

Mr. Vijay Rathod – Chief Project & Engineering Officer (Energy Auditor)

Mr. Bixam Bhukya – Specialist - Electrical



# **Company Profile**





"GMR Group will be an <u>institution in perpetuity</u> that will build entrepreneurial organizations <u>making a difference to society</u> through creation of value"

#### Model

 Based on the PPP model & structured on – BOOT; Project Completed in Record time of 31 Months

# **Operations Commenced**

• March 23, 2008

# **Design Capacity**


- Terminal: 12Mn PassengerPer Annum
- Cargo: 1.5 LakhMT /Annum

# Present Operation

- Terminal: 21+
   Million
   Passenger Per
   Annum (Pre COVID)
- Cargo: 1.5 Lakh
   MT /Annum
   respectively

# **Currently under Expansion**

• 40 MPPA & 2.5 Lakh MT/Annum





# **Building Specifications**







Natural lighting during day through Façade and Temple leaf structure in the roof.



Curved & Corrugated, structure around the Passenger Terminal provides resistance from sunlight.





Good thermal insulation properties @ Terminal glass Façade: U-value = 1.4 W/m<sup>2</sup>K, SC =0.47



# Specific Energy Consumption, Passenger Growth & Energy Usage Trend











# **Benchmark – Power & Emissions**











# **ECBC Norms**



# **Energy Intensity Level for different Building Types**



- Energy Performance Index for various types of Commercial Buildings is detailed in adjacent graph.
- The average EPI is observed to be ~200 kWh/M²/year.
- The EPI of HYD airport for FY23 is 145 kWh/M²/year.







Energy Use in Commercial Buildings - Key Findings from the National Benchmarking Study



# **ECBC Requirements**



- The existing Terminal Building is undergoing expansion on East & West wings/piers to increase operational capacity from 12 MPPA to 34 MPPA.
- Current Building area has already increased by ~25%, due to operationalization of phased expansion areas.
- Once Expansion is complete, revied Building footprint shall be +143% of existing Building area.



| S No | Description of Feature              | <b>Existing Terminal Building</b> | <b>Expansion Terminal Building</b>                |
|------|-------------------------------------|-----------------------------------|---|
| 1    | Micro-Climate                       | Composite                         | Composite   |
| 2    | Building Orientation                | North-South                       | North-South                                       |
| 3    | Shading Co-efficient of Glass       | 0.47                              | 0.278   |
| 4    | Visual Light Transmittance (VLT)    | 62%                               | 38.8%   |
| 5    | Energy Performance Index (EPI)      |                                   |   |
| А    | Project Base case EPI (kWh/M²/Year) | NA                                | 342.36  |
| В    | Project Existing EPI (kWh/M²/Year)  | 145.96                            | 268.86  |
| С    | ECBC Rating                         | NA                                | $\Rightarrow \Rightarrow \Rightarrow \Rightarrow$ |





# Roadmap for being Global Leader in Energy Efficiency



# FY 23

Introduction of Power BI Dashboard for utility monitoring & controlling

100% LED conversion

# FY 24

100% Green Airport

100% LED conversion

## FY 25

Digitization & Automation of maintenance processes

100% LED conversion

Replace vehicles with electric vehicles

# FY 26

Stabilization of engineering systems & scheduled operation of expanded Terminal

Phased upgradation of existing engineering equipment

# FY 27

Phased upgradation of existing engineering equipment in with energy efficient equipment




# **Global Leader in Energy Efficiency**





# **Utilization of Renewable Energy Sources**





| Technology | Type of<br>Energy | Location | FY      | Installed Capacity (MW) | Generation<br>(million kWh) | % of overall electrical energy |
|------------|-------------------|----------|---------|-------------------------|-----------------------------|--------------------------------|
| Colon DV   |                   |          | 2017-18 | 5 MW + 5 MW             | 7.02                        | 25%                            |
|            |                   |          | 2018-19 | 5 MW + 5 MW             | 5 MW + 5 MW 6.99            | 25.3%                          |
|            | Electrical        | Onsite   | 2019-20 | 5 MW + 5 MW             | 7.31                        | 27%                            |
| Solar PV   | Electrical        | Offsite  | 2020-21 | 5 MW + 5 MW             | 6.02                        | 24.3%                          |
|            |                   |          | 2021-22 | 10 MW*                  | 10.37                       | 34.3%                          |
|            |                   |          | 2022-23 | 10 MW                   | 12.97                       | 34.9%                          |

<sup>\*</sup> Commissioned in July 2021 after approval from relevant authorities



# **Key EnCon Projects in Past 3 Years**

| #  | Few Energy Saving Projects Implemented  | FY      | Investment Million<br>INR | Saving MU | Savings<br>Million INR |
|----|---|---------|---------------------------|-----------|------------------------|
| 1  | Power optimization by Scheduled Operation of AHU & Lights                     | 2020-21 | 0.0                       | 2.82      | 20.59                  |
| 2  | Operation of New Energy Efficient Sewage Treatment Plant                      | 2020-21 | 17.5                      | 0.11      | 0.78                   |
| 3  | Secondary Runway AGL Upgradation & LED Conversion                             | 2020-21 | 50.0                      | 0.09      | 0.69                   |
| 4  | Cooling Tower Efficiency enhanced by Upgradation (Phase-I)                    | 2020-21 | 2.45                      | 0.05      | 0.35                   |
| 5  | Main Runway CAT-I to CAT-II upgradation with LED Upgradation                  | 2021-22 | 50.00                     | 0.19      | 1.36                   |
| 6  | Cooling Tower Efficiency enhanced by Upgradation (Phase-II)                   | 2021-22 | 7.59                      | 0.48*     | 3.51*                  |
| 7  | Upgradation of Pumping System   | 2021-22 | 3.43                      | 0.23      | 1.68                   |
| 8  | Power Optimization by Scheduled Operation of AHU & Lights                     | 2021-22 | 0.0                       | 0.32      | 2.36                   |
| 9  | Low side HVAC Improvement works with the help of in-house team                | 2022-23 | 0.0                       | 0.23      | 2.08                   |
| 10 | Upgradation of Chillers with Energy Efficient unit for Expansion              | 2022-23 | 60.00                     | 0.54      | 4.83                   |
| 11 | Upgradation of Pumping system with Energy efficient Motors for Expansion Area | 2022-23 | 1.75                      | 0.42      | 3.74                   |
| 12 | Upgradation with LEDs at Expansion Area                                       | 2022-23 | 20.00                     | 0.13      | 1.17                   |
| 13 | WTP Pump House -Raw to Domestic water filtration pumps upgradation            | 2022-23 | 0.00                      | 0.05      | 0.48                   |

| Financial Year | Investment Million INR | Saving Million Unit | Savings Million INR | Payback<br>(Months) |
|----------------|------------------------|---------------------|---------------------|---------------------|
| 2020-21        | 73.2                   | 3.14                | 22.95               | 38                  |
| 2021-22        | 62.91                  | 1.49                | 11.04               | 68                  |
| 2022-23        | 86.69                  | 1.52                | 13.51               | 77                  |

<sup>\*</sup> Typo error Corrected



# **EnCon Projects Implemented in FY2022-23**



| S No | EnCon Project Description  | Energy Savings<br>(Million kWh) | % Contribution in Overall Savings |
|------|--|---------------------------------|-----------------------------------|
| 1    | Upgradation of Chillers with Energy Efficient unit (Expansion)                                 | 0.54                            | 35.72                             |
| 2    | Upgradation of Pumping system with Energy efficient Motors (Expansion)                         | 0.42                            | 27.70                             |
| 3    | Low-side HVAC Improvement works (in-house)   | 0.23                            | 15.37                             |
| 4    | Upgradation of LED lights in Airport Expansion Project   | 0.13                            | 8.65                              |
| 5    | Replacement of Conventional fittings to LED at various locations (Departure & Airport village) | 0.06                            | 4.20                              |
| 6    | Upgradation of Water Filtration Pumps at WTP   | 0.05                            | 3.56                              |
| 7    | Upgradation of Feed Pumps at STP   | 0.03                            | 1.71                              |
| 8    | LED Conversion at Check IN hall & Departures   | 0.02                            | 1.44                              |
| 9    | Energy & Domestic Water conservation at Township   | 0.02                            | 1.42                              |
| 10   | Drain line modification at Gate 106  | 0.01                            | 0.21                              |
|      | Total  | 1.52                            | 100.00                            |

**FY23 Projected Energy Consumption:** 272.22 Million kWh **FY23 Actual Energy Consumption:** 270.70 Million kWh



1

# **Upgradation of Chillers with Energy Efficient unit for Expansion**



### **Background:**

• There are 7 Chillers in existing Terminal Building. To cater to additional load of expansion areas, 6 new Chillers were required to be installed.



#### **Execution:**

• Coordinated with Design team during Project Inception to explore & install high Energy efficient Chillers for Expansion areas.



## Savings:

• Energy Savings: 0.54 MU/Annum

• Replication Potential: Yes

• Percentage of overall Savings- 35.72 %









# Upgradation of Pumping system with Energy efficient Motors – Expansion Area





#### **Background:**

• To cater to the enhanced operations of Expansion areas in Terminal, new pumping systems were required to be installed.



#### **Execution:**

- Coordinated with Design team at Project inception for installation of energy efficient pumping system.
- The Efficiency of new pumping system is 95.40%, compared to existing pumping systems' 83.3%.



#### **Savings:**

- Energy Savings: 0.42 MU/Annum
- Replication Potential: Yes
- Percentage of Overall Savings: 27.70%






# Low side HVAC Improvement works with the help of in-house team





#### **Background**

HVAC is one of the largest & important system which is the biggest power consumer at the airport terminal. To further optimize the HVAC system, we have carried out various refurbishment to the AHUs (Low-side).



#### **Project Executed**

- Refurbished the AHUs (attended Air & Water leakages, rectification of distorted Body parts
- Condition-based Monitoring to improve all relevant parameters (Low-side).



#### **Savings:**

- Energy Savings: of 0.23 MU/Annum
- Replication Potential Yes
- Percentage of overall Savings- 15.37 %



| Category | AHU (No's) | Remarks            |
|----------|------------|--------------------|
| Class A  | 61         |                    |
| Class B  | 34         | Taken up FY 23     |
| Class C  | 8          | Completed in FY 22 |
| Total    | 103        |                    |





# **Upgradation with LEDs at Expansion Area**





# **Towards 100% LED Conversion**

- Coordinated with Design team during Project Inception stage to Install LED lights in Expansion area, along with Light Dimming system through LMS (Lighting Management System),
- Around 461 Nos of 85W LED fixtures installed in place of 150W conventional type.



### **Savings**

- Energy Savings: 0.13 MU/Annum
- Replication Potential: With this project completion, all lights in expansion area are LED.
- % Percentage of overall Savings: 8.65%



**Before** 



**After** 





# LED Conversion at Airport Village, Departure Entries, Level E Arrivals, Check-In hall & Departures



(Conventional) with LED **Towards 100% LED Conversion** Qty Watt Qty Watt 150 **Airport** 11 600 Village 11 6 Dep 8 300 8 150 **Entries** Level E 200 56 200 40 **Arrival** Check-In hall & 100 200 150 100 Dep

**Existing** 

Replaced



- Energy Savings: 0.08 MU/Annum
- Replication Potential: Yes
- Percentage of overall Savings : 5.64%

Savings





<sup>\*</sup>There was no impact on Lux levels and Illumination





# WTP Pump House -Raw to Domestic water filtration pumps upgradation





**Background:** 

- The Domestic Water Filtration System in WTP, comprises of 2 conventional pumps.
- These pumps were delivering domestic water at 100 KL/Hr.





- To optimize the energy consumption at WTP, these Filtration Pumps were replaced with a single pump of similar flow rate/capacity.
- This single pump operation has sufficed the requirement of flow rate of 100KL/Hr.

Savings:



- Energy Savings:0.05 MU/Annum
- Replication Potential: Yes
- Percentage of Savings- 3.56%



**Before** 







# STP 1 & 2 Feed pumps replacement with energy efficient pumps





Ø

- In STP, conventional Feed pumps (5.5 kW) are installed.
- Due to continuous operation & general wear & tear, the pumps were not operating at design efficiency.
- These feed pumps were replaced with energy efficient of lower power rating (3.7kW).



Savings:

- Energy Savings: 0.03 MU/Annum
- Replication Potential: Yes
- Percentage of Overall Savings: 1.71%









# **Conservation of Energy & Domestic Water at Township**



#### **Background:**

- At GMR Township, domestic water is being supplied with pressurized pump station with 3.7 KW rated pumps for ~20 Hrs.
- Average consumption was 170 KL -180 KL/day.





- To Conserve Water & Energy , Installed total 29 no's of overhead tanks in all residential buildings with the capacity of 2 KL.~4 Hrs./day operation to serve the domestic water supply suffice the requirement.
- With pumping operations for ~4 Hrs./day, to serve the domestic water requirement.
- Provided 40 mm float valves in each overhead tank to control tank overflow.


#### **Savings:**



• Energy Savings: 0.02 MU/Annum

• Replication Potential: No

• Percentage of overall savings: 1.42%













#### **Problem:**

10



- Existing washroom drain was temporarily connected to a underground syntax chamber, where sewage sludge would need to be pumped to the existing sewage network.
- The manual pumping of sewage was causing foul smell & inconvenience to the Pax movement while using Gate 106.




#### **Solution:**

• Constructed new manhole chamber and modified the existing drain line network to accommodate new gravity-flow drain line for Gate 106 washroom without impacting operations with in-house team.



#### **Savings:**



• Replication Potential: No

• Percentage of overall Savings: 0.21%









# Replicated Project: 200KVA UPS Upgradation at PTB





 Upgraded 200KVA UPS (2 No's from conventional type(90% efficiency) to Modular type (95% efficiency).

• In FY22, 4 No's were upgraded.



Savings:

- Energy Savings: 4.2 Lakhs Unit/Annum
- Replication Potential: Yes









# **Waste Management**

#### **TSPCB Certified Vendors**








# Mistry Petrolium Products

Medak, Telangana, India





## **KAIZEN - Innovative Projects**



Enhancement of Airfield Light fixtures serviceability



To accommodate enhanced operations/substantially increased Air traffic additional Background: new taxiways and stands were operationalized & Entire AGL System was upgraded to 100% LED.



**Problem Faced:** 

We observed that few of the LED lights were failing, due to moisture inside the light fixtures.



Innovative Solution: The team came up with in indigenous solution to identify faulty fixtures. Subsequently, faulty fixtures were repaired & system availability improved.









**FAS SYSTEM** 



**FAS SYSTEM** 



#### Problem:

 Due to continuous operations and ageing of conventional equipment, various electronic equipment like PCB's are failing, Which are difficult to source in market.



#### Innovative solution:

• we explored various methods to indigenously repair these circuit boards in-house.



# **KAIZEN - Innovative Projects**





## Project Tittle:

• EV charging stations at Various locations



#### Background:

• GHIAL is promoting the benefits of EV vehicles to all its stakeholders & taking necessary initiatives for transitioning towards EV vehicle operations (like passenger coaches, baggage trolleys, staff movement vehicles etc.),





#### Execution:

- GHIAL installed EV Charging stations at various locations of the airport for its visitors, passengers & staff,
- Car Park 4 No's x 30 kW,
- Public Transport Complex 4 No's x 30 kW,
- Airside 4 No's x 240 kW,
- Site Office 6 No's x 7.5 kW,
- Some more EV charging stations are in development.
- Liaising with State Govt. officials to arrange EV bus operations to & from airport





# **Continuous Improvement**





#### Project:

City-side Check-In Facility (before entering Terminal Building)




#### **Project Brief:**

GHIAL introduced the Self-Baggage Drop facility at city side for remote check in near PTB Car park to enhance passenger experience & provide a service at par with other world class airports.



#### **Benefits:**

- It reduces the check-in time and queuing and
- It allows passengers to shop & dine at available facilities without the burden of carrying their luggage





# **GHG Emissions**











# **GHG Inventorisation & Energy Policy**



Certification

Bureau Veritas

#### GMR HYDERABAD INTERNATIONAL AIRPORT LIMITED

GMR Aero Tower, Rajiv Gandhi International Airport, Shamshabad, Hyderabad 500 108, Telangana, India.

Bureau Veritas Certification Holding SAS - UK Branch certifies that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the Management System Standard detailed below.

#### ISO 50001:2018

Scope of certification

Operation and Maintenance of Passenger Terminal Building Air Side & Land Side Facilities

Original cycle start date:

Recertification cycle start date: 11 August 2023 Subject to the continued satisfactory operation of the organisation's Management System. this certificate is valid until: 19 August 2026

Certificate No. IND.23.7595/EN/U

UKAS

Further classifications regarding the acope of this certificate and the applicability of the management system requirement may be obtained by consulting the organisation. To check this certificate validity please call # of 12 96274 2000.







This is to certify that Airport Carbon Accreditation, under the administration of WSP, confirms that the carbon management processes at

#### RAJIV GANDHI INTERNATIONAL AIRPORT



**GHG** 

implemented by GMR Hyderabad International Airport Ltd.

have earned the accreditation level of NEUTRALITY, in recognition of the airport's exceptional work in managing, reducing and compensating all of the CO2 emissions under its control, as part of the Global airport industry's response to the challenge of Climate Change.

ACTION C'ENTRE PROPERTY AND INCOME.

www.sinjorf002.org

Director General

Simon Clouston Director ACI Asia-Pacific WSP

**Certificate of Accredation** 



F.No. BRE/PAT/Boildings/Airport/2019-20/1947-

21d January, 2020

Ms. Rubins Ali. Joint Socretary, Ministry of Civil Aviation, Rajiv Gandhi Bhawan, Block B. Safdarjung Airport Area, New Delhi - 110003 Ph; 011-24628012.

Subject: Inclusion of Airport sector under PAT Scheme.

Dear Medem.

This is with reference to the meeting held in your office on 18th December, 2019 regarding implementation of PAT Scheme. As per the discussion, we are enclosing the Energy Performs for the Airport sector to capture all energy consumption data for the Airport.

This performs may be sent to all the Airports and they would be requested to fill the performs and submit to BEE office within 15 days. They may also be requested that the officials from BEE will contact them for their support in data collection and implementation of the Scheme

After receipt of requisite data Technical Committee Meeting may be held in your chairmanship.

This issues with the approval of DO, BEE.

Yours sincerely,





**BEE PAT Scheme** 



# **Net Zero Carbon Emission Airport**





#### ENVIRONMENTAL & SUSTAINABILITY POLICY

We, at GMR Hyderabad International Airport Limited (GHIAL), consider that environmental protection and sustainability are integral part of our business, and are committed to conducting the operations at Rajiv Gandhi International Airport (RGIA) in an environment-friendly and sustainable manner, in line with our Vision, Mission, Values & Beliefs and Corporate Policies. As part of this commitment we will strive to conserve the environment and achieve sustainability by:

- Managing environmental aspects of the airport through identification, impact evaluation and providing suitable control measures
- Ensuring compliance to applicable environmental statutory requirements
- Preventing pollution and maintain optimum levels of ambient noise and local air quality by adopting eco-friendly technology, infrastructure and practices in collaboration with the stakeholders
- Conserving natural resources by inculcating the culture of reduce, recycle & reuse. Promoting green economy through green supply chain , in particular, use of sustainable resources, and eco-friendly products by partnering with local communities.
- Formulating long term absolute greenhouse gas emissions reduction target for achieving net zero carbon emissions through sustainable airport operations - green buildings, energy conservation by efficient devices and practices, and opting for renewable energy & alternative fuels by partnering with the relevant stakeholders
- Maintaining clean and green airport eco-system through greenery, clean fuel, life cycle assessment of materials, efficient waste management practices, and stringent monitoring of environmental quality parameters
- Inculcating sustainable environment stewardship among the airport community and other stakeholders through trainings and awareness programmes
- Setting environmental objectives to achieve continual improvement in the airport's environmental performance and the overall environmental management system
- Reporting on our environmental performance and initiatives taken to achieve sustainable development

We will communicate this Policy to all persons working for and on behalf of the organization. The Policy will be reviewed periodically in line with the emerging requirements and practices.


2021 Chief Operating Office

Pradesp Parrilly Chief Executive Officer

## Date: 1" January, 2021 Chief Operating Officer Version - 4

## **GHIAL** aspires to achieve

Net Zero carbon emission through sustainable airport operations by opting for renewal energy & alternative fuels by partnering with stakeholders. GHIAL Achieved 100% Green Power in Jun'2023.







# **National Energy Conservation Day 2022**




You are cordially invited for the

# **Energy Conservation Reward & Recognition**

December 2022

**Venue:** Old Site Office – Auditorium, Opp. GMR Aero Towers, Hyderabad International Airport, Shamshabad

> Date: Friday, 16<sup>th</sup> December 2022 Timing: 10:30 AM – 12:00 noon













# Awareness Training on Energy Management System ISO 50001:2018

We have Conducted Energy Management System Awareness Training across the GHIAL Staff covering various departments & Stakeholders listed below:

- Engineering & Technical Services
- Procurement
- CFL-FMS Service Provider
- AOCC
- Projects Expansion
- Ground Transport Dept.
- Business Development (Non-Aero)
- Security
- External Stakeholder
  - Beumer (BHS)
  - AMA (AGL)
  - Faber Sindoori (MEP ALS & PTB)
  - ADB Safe Gate (AGL)









# **EnCon Team, Monitoring & Budget**





Management Reviews & Feedback



#### Top Management

- Define Energy Policy
- Organizational Goals


Quarterly Energy Reviews & Half yearly/Yearly Audits



# Derive Objectives & Targets

- Action plan
- Responsibility
- Resources & time lines







# **Daily Monitoring**




#### **Daily Energy Monitoring Report Chaired by EVP**

| , 0,                                     |             | <del>,</del>                                  |           |
|--|-------------|---|-----------|
| Rajiv Gandhi Inte                        | national A  | irport, Shamshabad, Hyderabad                 |           |
| Daily O&M Report                         |             |   |           |
| Report Date & Time: 0000 to 2359Hrs      | Thursday, 1 | 10 August, 2023                               |           |
| Day Shift :-                             | Sankar, Sur | neel & Ankit                                  |           |
| Night Shift :-                           | Gopi Kumar  | , Satish & Saravanan                          |           |
| HVAC                                     |             | Electrical                                    |           |
| Chiller Load (TR)                        | 33060.00    | Total Consumption KWh(220KV+Solar Generation) | 268296.00 |
| Decoupler Flow (M <sup>3</sup> /Hr.)     | 79.60       | Total Consumption KWh (220 KV SS)             | 228896.00 |
| Chilled Water dt (Deg C)                 | 3.69        | Solar Generation (MWh)                        | 39.40     |
| Condenser Water dt (Deg C)               | 6.43        | Solar Net Export (MWh)                        | 39.20     |
| Average Ambient temperature ( deg C)     | 27.79       | Gross Consumption PTB(kWh)                    | 169951.22 |
| Max. Ambient Temp (Deg C)                | 32.64       | Gross Consumption ALS (kWh)                   | 98344.78  |
| Water Consumption (Cooling Tower PTB) KL | 211.40      | Maximum Demand (MVA)                          | 11.76     |
| R.Humidity                               | 75.53%      | Commercial KVAH                               | 50100.00  |
| Serviceability Chiller (Number)          | 7/7'        | Commercial MD(MVA)                            | 3.257     |
| Serviceability AHU (Number)              | 103/103     | Industrial KVAH                               | 56440.00  |
| CPM (Chiller Plant Manager) Status       | OK          | Industrial MD(MVA)                            | 3.080     |
| IKW-PTB (Incl Secondary)                 | 0.69        | Power Consumed by NOB Chillers kWh            | 1892.12   |
| IIDT Chiller Load (TR)                   | 0.00        | Power Consumed by PSOB Chillers kWh           | 790.06    |
| IKW -IIDT                                | 0.00        | DG Yard - Status (Ok/Not Ok)                  | OK        |
| NOB Chiller Load (TR)                    | 2756.90     | Serviceability of BMS (Ok/Not Ok)             | OK        |
| IKW-NOB                                  | 0.69        | Pax Area Lighting Number -Fittings (W /NW )   | W         |
| PSOB Chiller Load (TR)                   | 1165.63     |   |           |
| IKW-PSOB                                 | 0.68        |   |           |
| B/D of equipment (hrs.)                  | 0.00        |   |           |
| Chiller Punning Hrs                      | 57.9        |   |           |

### **Dashboard for AMR Water Meters & IoT based Road Lighting System**

| HYDERABAD RAIN CANDIS HYDERABAD HTERNATIONAL AIRPORT  | -MR  |                             | G                | NR.                    |
|---|--|-----------------------------|------------------|------------------------|
|   | Sewage Inflow  |                             |                  |                        |
| STP   |  | Initial<br>Reading          | Final<br>Reading | Consumption<br>(KL)    |
| STP-1 Input   | M1   | 0                           | 0                |                        |
| STP 2 Input   | M2   | 0                           | 0                |                        |
| Total STP Inflow  | M1+M2  |                             | 0 0              |                        |
| Tr  | eated Water Outpu  | nt.                         |                  |                        |
| STP   | •  | Initial                     | Final<br>Reading | Consumption<br>(KL)    |
| STP-1 Output  | M3   | 0                           | 0                |                        |
| STP-2 Output  | M4   | 0                           | n                |                        |
| Total STP Output  | M3+M4  |                             | 8 8              |                        |
| Difference of Inlet-Outlet  | (M1+M2)-(M3+M4)  |                             |                  |                        |
|   | Elizabeth Indones Addresses  |                             |                  |                        |
| D.  | Flushing Water   |                             |                  | Consumption<br>(KL)    |
|   | - 1000   |                             |                  |                        |
| Total Treated Water Generation  | etails   |                             |                  | (KL)                   |
| Total Treated Water Generation<br>Gross Flushing Water Consumption<br>Bifference of Generation, Consumption   | M3+M4<br>M8+M9   |                             |                  | (KL)                   |
| Total Treated Water Generation<br>Gross Flushing Water Consumption<br>Difference of Generation-Consumption  | M3+M4<br>M8+M9   | -1                          |                  | (KL)                   |
| Total Treated Water Generation<br>Gross Flushing Water Consumption<br>Difference of Generation-Consumption<br>Flo   | M3+M4<br>M8+M9<br>(M3+M4)-(M8+M9)  | -1                          |                  | (KL)                   |
| Total Treated Water Generation Gross Plushing Water Consumption Difference of Generation Consumption Fit De Flushing Line 1 Consumption   | M3+M4<br>M8+M4<br>M8+M9<br>(M3+M4)-(M8+M9)<br>Ushing Water Line-<br>stalls             | INLET                       |                  | (KL)  Consumption (KL) |
| Total Treated Water Generation Gross Flushing Water Consumption Difference of Generation-Consumption Fit De Flushing Line 1 Consumption Total Sub-Consumption to Flushing Line  | M3+M4<br>M8+M4<br>M8+M9<br>(M3+M4)-(M8+M9)<br>Ushing Water Line-<br>stalls             | INLET                       |                  | (KL)  Consumption (KL) |
| Total Treated Water Generation Gross Flushing Water Consumption Difference of Generation-Consumption Fit De Flushing Line 1 Consumption Total Sub-Consumption to Flushing Line  | M3+M4<br>M8+M4<br>M8+M9<br>(M3+M4)-(M8+M9)<br>Ushing Water Line-<br>stalls             | INLET                       | TILE!            | (KL)  Consumption (KL) |
| Total Treated Water Seneration Gross Flushing Water Consumption Difference of Seneration Consumption Flushing Line 1 Consumption Total Sub Consumption to Flushing Line Difference of Line 1 to Sub-Consumption                             | M3+M4<br>M8+M4<br>M8+M9<br>(M3+M4)-(M8+M9)<br>Ushing Water Line-<br>stalls             | INLET<br>OUTLET<br>INLET-OU | TILET            | (KL)  Consumption (KL) |
| Total Treated Water Generation Gross Flushing Water Consumption Difference of Generation Consumption Flushing Line 1 Consumption Total Sub-Consumption to Flushing Line Difference of Line 1 to Sub-Consumption                             | M3+M4<br>M8+M9<br>(M2+M9-(M8+M9)<br>Ishing Water Line                                  | INLET<br>OUTLET<br>INLET-OU | ILEI             | (KL)  Consumption (KL) |
| Total Treated Water Generation Gross Flushing Water Consumption Difference of Generation Consumption Flushing Line 1 Consumption Total Sub-Consumption to Flushing Line Difference of Line 1 to Sub-Consumption Flushing Line 2 Consumption | M3+M4<br>M8:M9<br>M8:M9<br>(M3+M9-(M8+M9)<br>ishing Water Line-<br>stalls<br>Cluster 6 | INLET OUTLET-OU             | TILET            | Consumption (KL)       |
| Total Treated Water Generation Gross Flushing Water Consumption Officences of Generation Consumption Flushing Line 1 Consumption Total Sub-Consumption to Flushing Line Dillerences of Line 1 to Sub-Consumption                            | M3+M4<br>M8:M9<br>M8:M9<br>(M3+M9-(M8+M9)<br>ishing Water Line-<br>stalls<br>Cluster 6 | INLET<br>OUTLET<br>INLET OU | IILEI            | Consumption (KL)       |



#### **Chiller Plant Daily MIS Report**



### **Chiller Plant Manager**



### **Power Consumption Analysis with and Same day last year**


|  |       |       |       |       |       |       |       | Energ | v Cons | umptic | n Rep   | ort (Incl | udina ( | Concessionario                             | es)                          |                   |                   |         |         |        |                   |
|--|-------|-------|-------|-------|-------|-------|-------|-------|--------|--------|---------|-----------|---------|--|------------------------------|-------------------|-------------------|---------|---------|--------|-------------------|
|  |       |       |       |       |       |       |       |       | ,      |        | 9-Aug   |           | 3       |  |                              |                   |                   |         |         |        |                   |
| Consumption on date                              | TXF-1 | TXF-2 | TXF-3 | TXF-4 | TXF-5 | TXF-6 | TXF-7 | TXF-8 | TXF-9  | TXF-10 | TXF-11  | TXF-12    |         | Chiller& Asso.<br>equipment<br>Consumption | PTB Chiller<br>Running Hours | Max<br>Temp<br>°C | Min<br>Temp<br>°C | IIDT    | IDAT    | PAX    | KPI<br>(kWH/ PAX) |
| Consumption<br>on 08-08-2023                     | 11000 | 14298 | 8748  | 11864 | 7840  | 10004 | 6564  | 6616  | 9292   | 3571   | 0       | 1701      | 91498   | 27894                                      | 52:50:00                     | 31                | 23                | 2750    | 0       | 55,977 | 1.63              |
| Consumption<br>on 09-08-2023                     | 10400 | 17096 | 8772  | 12456 | 7948  | 10364 | 6876  | 6524  | 9496   | 3683   | 0       | 1480      | 95095   | 28167                                      | 60:10:00                     | 31                | 23                | 2719    | 0       | 61,950 | 1.54              |
| Difference<br>Comparison<br>with previous<br>day |       |       | 2,222 | 592   | 108   | 360   | 312   | (92)  | 204    |        | 112     | (221)     | 3,597   | 273  | 07:20:00                     | 0                 | 0                 | (31)    | -       | 5,973  | (0.10)            |
| Consumption<br>on 09-08-2022                     | 9406  | 5289  | 16942 | 11973 | 8476  | 10351 | 5032  | 6932  | 8620   | 118    | 6553    | 2811      | 92503   | 24180                                      | 55:30:00                     | 27                | 22                | 8132    | 1332    | 58054  | 1.59              |
| Difference<br>Comparison<br>with 2022 year       |       |       | 4,631 | 483   | (528) | 13    | 1,844 | (408) | 876    |        | (2,988) | (1,331)   | 2,592   | 3,987                                      | 4:40:00                      | 4                 | 1                 | (5,413) | (1,332) | 3,896  | (0.06)            |



# **Energy Monitoring –Best Practices**



# Thermography for Electric Panels (Replicated from AGL maintenance best practices)








## **Water - Net Consumption**



### **Key Water Conservation Initiatives:**

- Water Balancing Analysis & Pressure Control
- Recharge of Open Wells & Bore wells
- Topographical Study of Airport Land to create reservoirs for rainwater usage
- Cloud based Automatic Irrigation System
- Natural Coagulant Enhanced STP throughput by 30%
- Water efficient appliances & equipment
- Creating awareness among the Airport Community
- Wastewater reuse & recycling (STP 2\*925KLD+1\*1325KLD)
- Rainwater runoff use
- Push-type taps with aerators installed
- Less water consuming plantation in Landscape Area



Based on entire campus hydrological study, GHIAL has developed 4 storm water reservoirs at strategic locations capable to store 10 Lakh KL water, spread over 127 acres, for domestic use & ground water table recharge.





# **CII National Award for excellence in Energy Management**

At CII National Award Ceremony for 'Excellence in Energy Management", GHIAL has previously won

- National Energy Leader for the 4<sup>th</sup> consecutive time (2019, 2020, 2021 & 2022)
- Excellent Energy Efficient Unit for the 8<sup>th</sup> time (2014, 2015, 2017 2018, 2019, 2020, 2021 & 2022)











# **Telangana State Energy Conservation Awards (TSECA)**



At the Telangana State Energy Conservation Awards, GHIAL clinched

The "Gold Award" in 2020, The "Excellence Award" in 2021, The "Special Award" in 2022.





GMR-led Hyderabad International Airport Limited (GHIAL) clinched the prestigious "Certificate of Merit" at BEE's National Energy Conservation Awards (NECA) 2021.



# **CII Champions' Trophy Award**

# **GHIAL Bagged**

- 1 Super Challenger Award
- 2 Star Challenger Awards
- 2 Jury Challenger Awards
- Jury Champion Award









## **Awards & Accolades**





GHIAL has won the ACI Green Airports Gold Recognition 2023, in the 15-35 MPPA category in the Asia – Pacific region for its 'Single-Use Plastic Elimination' process. Starting from 2018, this is the 6th consecutive year that GHIAL has won this award.



GHIAL named as the "Best Regional Airport in India & South Asia" at the 2023 Skytrax World Airport Awards.

GHIAL wins the prestigious 'ACI Worlds - ASQ Best Airport Award 2022 for outstanding Pax Experience' in 15-25 Million Pax/Annum (MPPA) category.





#### **International Best Practice Competition, 2023**

GHIAL clinched the 6 star rating for "Eliminate unsafe incident during PBB wheel negative angle movement" 4 star rating for "Water depth measurement on RWY - GRF Tool"




### **Awards & Accolades**



GHIAL has won Third Position under the Category Infrastructure & Construction under 18th National Awards for Excellence in Cost Management-2022 announced by The Institute of Cost Accountants of India.





### It is Green all the Way for GMR Hyderabad Airport Now fully powered 100% by Green Energy

Taking a leap towards sustainability, GHIAL announced its transition to 100% sustainable green energy for its energy consumption at the airport and across its ecosystem. Hyderabad Airport, in partnership with Telangana State Southern Power Distribution Company Limited, TSSPDCL will revolutionalise its operation by harnessing the power of green energy through a combination of its own 10MWp solar power plant and green energy supplied by TSSPDCL.

The airport by integrating green energy into its operation and infrastructure will reduce its carbon footprint by approx. 9300 tons of carbon dioxide annually.



# **Awards, Accolades and Certifications**



### **GMR Group level Competition in 2022**

CIP Group award at Business Excellence event 1st prize award in "recurring cost saving.

CIP Group award at Business Excellence event 3rd prize award for Best "5S Zone" - Workplace management Project.


CIP Group award at Business Excellence event 2nd prize award in "Dare to try" category.













Rise high Awards 2023 finalist – GMR Township

### • GHG - ISO 14064: 2006

• EnMS – ISO 50001: 2018

#### • QMS - ISO 9001: 2015

#### • EMS - ISO 14001: 2015

#### • OHSAS – ISO 450001: 2018

#### • CRM - ISO 10002: 2018


#### • ISMS - ISO 27001: 2013

#### ITSM - ISO 20001: 2018

#### LEED Certification- "Silver Rating"

#### Airport Carbon Accreditation Level 3+ Neutrality

#### • British Safety Council-5 star



**Certifications** 



# ಕಂಪಾಬಾದ್ ವಿಮಾನ್ಫಾಕಯಾನಿತೆ ರಿಂದು ಜಾತಿಯ పುರನ್ಮಾರಾಲು

కంషాబాద్, మ్యాస్ట్ మడే: శంషా బాద్ రాజీవోగాంధీ అంతర్వాతీయ విమానాశయం సిగలో మరో రెండు పురస్కారాలు చేరాయని జీహెచ్ఐఏఎల్ రులు ఓ స్థకటనలో తెలిపారు. కాన్స్ ఆఫ్ ఇండియన్ ఇండస్ట్

బీజినెస్ సంస్థల ప్రతినిధులు సంయుక్తంగా విమానాశయాలు కర్సన ఉదారాల నివారణ కోసం అవ లంబిసును విధి విదానాలను



పురస్కారాలు అందుకున్న జీహెచ్ఐపెఎల్ అభికారులు

చారు. ఇటీవల నిర్వహించిన ఎనర్టీ ఎఫి షియెన్స్ సమ్మిబ్ 21వ ఎడిషన్లో శంషా బాద్ విమానాశ్రయం నేషనల్ ఎనర్జీ లీడర్, ఎక్స్ లెంట్ ఎనర్టీ ఎఫిషియెంట్ యూనిబ్ 2022 జాతీయ ఆవారులు గెలు చుకున్నట్లు మకటించారు. నాలుగోసారి వరించిన ఈ

ည်ာအဆုံ မဝင် లను జీహెచ్ఐఏఎల్ ఆధికారి విజయ్ రాథోడ్, ఎయిర్పోర్ట్ ఎల్మకికల్ విభాగం భూక్యా అందుకున్నారు.

# జీఎమ్మార్ ఎయిర్పార్నకు నేషనల్ ఎనల్టీ లీడర్ అవార్డు

సాక్షి, సిటీబ్యూలో: కాన్పెడరేషన్ ఆఫ్ ఇండియన్ ఇం డ్రనీ (సీఐఐ), గోదైజ్ గ్రీన్ బిజినెస్ సెంటర్ (జీబీసీ) నిర్వహించిన ఎక్పలెన్స్ ఇన్ ఎనర్జీ మేనేజ్ మెంట్ 23వ జాతీయ అవారులలో హైదరాబాద్

అంతర్వాతీయ విమాన్యాశయానికి నేషనల్ ఎసర్టీ లీడర్, ఎక్సలెంట్ ఎనరీ ఎఫీషియంట్ యూనిట్ అవార్తులు లభించాయి. జీఎమ్మార్ హైదరాబాద్ అంతరాతీయ విమానాశయం ఈ అవారులను

గౌలుచుకోవడం వరుసగా ఇది 4వ. 6వ సారి. చీప్ పాజెక్ అండ్ ఇంజనీరింగ్ ఆఫీసర్ విజయ్ రాథోడ్. ఏజీఎం భిక్రం భూక్వాలు అవార్శలను అందుకున్నారు.



# CII'S ENERGY EFFICIENY AWARD



GMR Hyderabad International Airport has won the National Energy Leader and Excellent Energy Efficient Unit awards at the 23rd National Award Ceremony for 'Excellence in Energy Management' organised by the Confederation of Indian Industry (CII) on Monday

# 'విద్యుత్తు'పై పీహెచ్డీ చేసిన కేసీఆర్

#### కేసీఆర్కు ఉన్న అవగాహన దేశంలో ఎవలకీ లేదు.. ఇంధన పాదుపు పురస్కారం ఇవ్వార్నింది కేసీఆర్

- 🔸 లైట్లు ఆయనే వేస్తారు.. పెక్టేప్పుడు ఆఫ్ చేస్తారు
- 🕠 పట్టణాలకంటే గ్రామాల్లోనే విద్యుత్తు వృథా ఎక్కువ
- త్వరలో స్కూళ్లలో పార్యాంశంగా ఇంధన పాదుపు
- » ఇంధన పాదుపు పురస్కారాల్లో మంత్రి జగబీశ్**రె**డ్డి

హైదరాబాద్. డిసెంబరు 20 (ఆంధ్రత్యోతి). విద్యుత్తు రంగంపై సీఎం కేసీఆర్కు ఉన్నంత అవగాహన, పట్టు దేశంలో మరెవరికీ లేదని, విద్యుత్తు రంగంలో కేసీఆర్ పీహెచ్డ్ చేశారని ఇందన రదినీ, దివ్వుత్వ రంగాలా మంది జనుంచి కోరాలు ఇం మంది జనుంది రెడ్డి బ్యాంలో అందన పోయన ప్రరస్సారం ఎవరమైన జన్యాలంలో ముందు కేసీఆరోకి జన్యాలరి జగునీకొండ్లి మంచి ఇందిన వురక్కున్నా అందుకుంటున్న జీఎంఆర్ స్థతివిధులు చెప్పారు. 22 ఏట్లగా ఆయనతో తనకు పరిచయం ఉందని, ఏ గది లోకి వెళ్ళినా లైట్లను ఆయనే ఆన్ చేసి, బయటికి వెళ్తతున్నప్పుడు ఆఫ్

లోం ఎక్కాల రెల్లమైన ఆయం ఇం ఎన్. పరుగుడి పరియున్నియు ఇం చేస్తుంలనరి, కానే హోదాలో ఉన్నానన్ విషయం వట్టిందుకోరని కేంటే ర్వారు. లైట్లు అనవసరంగా వేసి ఉంటే జగ్గహం వ్యక్తం చేస్తారు చేస్పారు. మంగణానల హైదరాబాదిలో తెలంగాల రెక్క వ్యవదర్ధరేయు ఇందన వనరుల ఆటివృద్ధి సంస్థ (జీఎస్రెనిమో) ఆధ్వర్యంలో మెది? సంవ త్వరానికి ఇంధన పరస్కారాల ప్రదానం జరిగింది. ముఖ్య అతిథిగా హాజ రైన మంత్రి మాట్లాడుతూ విద్యుత్తు విషయంలో కేసీఆర్ ఆలోచించినం తగా స్థరాని, దేశంలో ఏ ముఖ్యమంత్రి కూడా ఆలోచన చేయరన్నారు. నగరాలు, పట్టణాలకన్నా గ్రామాల్లోనే విద్యుత్తు వృధా జరుగుతోందన్నారు. అవసరం లేకున్నా విద్యుత్తు వాడే వారిని గుక్తించి, వారిలో చైతన్నం తెచ్చే బాధ్యతను రెడ్డికో తీసుకోవాలని సూచించారు. ఇంధన పొదుషను పాఠశా లల్లో పార్యాంకంగా బోధించాలని మంత్రి కోరారు. ఆధికారులు కరికుల మ్.మ రూపొందించి విద్యా శాఖకు అందించాలన్నారు.

#### ఒక యూనిట్ పొదుపు చేస్తే...

ఒక యూనిట్ విద్యుత్తును పొదుపు చేస్తే రెండు యూనిట్ల ఉత్పత్తి చేసినట్లేనని ట్రాన్స్ట్ కోజిన్ సీఎండీ దేవలపల్లి ప్రభాకర్రావు అన్నారు. డ్రుగతికి సూచిక ఆయిన తలసరి విద్యుత్తు వినియోగం దేశంలో 1255 యూనిట్లుగా ఉంటే తెలంగాణలో 2162 యూనిట్లుగా ఉందన్నారు. విద్యుత్స్తు రంగంలో 8 ఏళ్లలో రూ.85 వేల కోట్లు వెచ్చించామన్నారు. పంపిణీ, నరఫరా నషాలు దేశవ్వాప్తంగా 18 శాతంగా ఉంటే రాష్ట్రంలో 10



దక సామర్యం 7 వేల మెగావాట్లకు చేరనుందన్నారు. రాష్ట్రంలో ఈవీ (ఎల క్టిక్ వెహికల్) పాలనీ తెచ్చామని, దార్జింగ్ కేండ్రాలకు బల్క్ కరెంట్ అందించడానికి సిద్ధంగా ఉన్నామన్నారు. ఇంధన పొడుషు కోసం అందరూ ప్రత్యే చేయాలని రెడికో వైర్మన్ సతీష్ రెడ్డి కోరారు. ప్రభుత్వ పాఠశాలల్లో జెలికుడే పైరట్లు, ప్యాస్ట్లు మీస్స్లెమన్నారు. బందన శాఖ ప్రక్రేత ప్రదాన కార్యదర్శి సునీలికర్క దక్షిణ డిన్కమ్ సీఎండీ జి.రముమారెడ్డి, రెడికో వీసీ ఎండీ జానయ్య మీర్మాలగూడ ఎమ్మెల్యే బాస్కరరావు పాల్గొన్నారు.

నాలుగు ప్రధాన కేటగిరీల్లో అవార్యలు ఇందన పొదుపులో వరిశ్రమల కేటగిరీలో ఇటీసీ పేపర్ బోర్తుకు ప్రత్యేక ఆవార్డు దక్కింది. మై హోమ్ ఇండస్టీస్ కుంగారు, గ్రామ్మాల్స్ ఇండస్టీస్ కు వెండి ఫలకాలు లభిందాయి. విద్యా సంస్థల భవనాల కేటగిరీలో వర్దమాన్ ಇಂಜನಿರಿಂಗ್ ಕ್ ಶೆಜೆಕಿ ಐಂಗ್ ರು. ವಿಶ್ವರಿಯ್ ಮಮಾರಿಯಲ್ಲಿ ಪ್ರಕ್ಷುತ್ತು ಗುರು కుల పాఠశాలకు వెండి, ప్రభుత్వ భవనాల కేటగిరీలో సంచాలన్ భవన్కు బంగారు, లేఖా భవన్కు వెండి, వాణిజ్య భవనాల కేటగిరీలో జీఎంఆర్ హైదరాబాద్ అంతర్రాతీయ విమానాశ్రయానికి ప్రత్యేక ప్రరస్కారం, విప్రాపేకు బంగారు, రైల్వే స్టేషన్లలో కావిగూడకు బంగారు, నికిండ్రాబాద్కు వెండి, రవాణా రంగంలో ఆర్టీసీకి జనగామ డిపోకు బంగారు, ఫలక్సుమా డిపోకు వెండి, పరపాలక సంస్థల్లో నల్లగొండకు బంగారు, గైటర్ హైదరా

# <u>ಸ್ಲಿಟ್ ಟ</u>ಂಲ್ ಕಂಪಾಬಾದಿವಾ

### సమయపాలనలో హెదరాబాద్ ఎయిర్పోర్ టాప్

ప్రపంచ స్థాయిలో ఆర్టీఐఏకు అగ్రస్థానం . సమయానుసారంగా 90% విమానాల రాకపోకలు



నూ భేష్ అనిపించుకున్నది. ప్రయాణికు మరుగైన సేవలను అందిస్కూ ప్రపంచ (మ ఎయిర్పోర్బల్లో ఒకటిగా ఖ్యాతినార్హిం శంషాబాద్*లో*ని రాజీవ్**గాంధీ ఇంటర్నేష** చి విడుదలైన తాజా జాబితాలో అగ్రస్థా

#### 50 లక్షల విమానాలపై సమీక్ష..

ప్రపంచవ్యాప్తంగా మార్చి నెలలో 50 లక్షల విమానాల రాకపోకలను సమీక్షించి ్ ఎయిర్పోర్ట్ (ఆర్టీఐఏ).. సమయానికి ఈ నివేదికను సిద్దం చేసింది నీరియం సంస్థ. కపోకలు జరిగే ఎయిర్పోర్టులకు సంబం అయితే సమయపాలనలో ఎప్పుడూ ువి విడుదలైన తాజా జాబితాలో ఆగ్రస్థా లో నిలివింది. ప్రముఖ ఏపియేషన్, ట్రాపె గమించి తొలిసారి ఓ భారతీయ ఎయిర్ గ్ అధ్యయన సంస్థ సీరియం ఈ ఏడాది పోర్ట్ నిలిచింది. ఈ ఘనత హైదరాబాద్ ర్వికిగాను ఇచ్చిన నివేదికలో సమయపా ఎయిర్జేహిర్లుకు దక్కడం విశేషమనగా ఎయిర్పోర్జుకు దక్కడం విశేషమవగా.

#### - ప్రదీప్ పణికర్, జీఎమ్మా ర్ సైకియాలలో ఎయిరోపోర్ట్ సీతున్

వచ్చిన రిపోర్జులో హైదరాబాద్ ఎయిర్పోర్ట్ ఓటీపీ 88.44 శాతంగా ఉన్నది. అప్పుడు

దేశంలోని విమానాత్రయాల్లో హైదరా బాద్ ఇంటర్నేషనల్ ఎయిర్పోర్యకు మొద 

కియోస్స్ల్లు, ఈ-బోరింగ్, వీడియో అనలి టిక్స్ వంటి నయా టెక్నాలజీలు ఇక్కడి శంషా టిక్ని వెంట నియో బక్సాలతలు ఇక్కడ శండ్రా బాద్ ఎయిర్పోర్టు సొంతం. ఇవన్ని కూడా ఆన్టేటైమ్ పెర్కార్మెన్స్లోను (ఓటీపీ) ప్రభావితం చేసే అంశాలేనని ఎయిరోపోర్టు వర్గాలు పేర్కొ న్నాయి. ఇక ఈ జాబితాలో బింగళూరులోక ట్నుంచీ భ్రత్యేక గుర్తింపే ఉన్నది. ఆధునిక కెంపెగౌద అంతర్వాతీయ విమానాత్రయం కూడా ఉన్నది. 86.14 శాతం డిపార్చర్ ఓటీ పీతో రెండో స్థానం పొందింది. కాగా మార్చిలో దేశ. విదేశాల్లోని 77 చూట్లలో హైదరాబాద్ నుంచి 14.658 విమానాల

# ಕಂವಾಬಾದ್ ಎಯಿರ್ವಾರು ಅವಾರು

#### ದಿಕ ಕಂಪಾಬಾದ್:

జీఎంఆర్ హైదరాబాద్ ఇంటర్నేషనల్ ఎయిర్పోర్ట్ లిమిటెడ్ ఇంధన పొదుపులో చేసిన కృష్టికిగాను తెలంగాణ ప్రభుత్వం నుంచి 2021-22కు ప్రత్యేక అవారును అందుకుంది. హెదరాబాద్ విమా



అవార్డు అందజేస్తున్న మంత్రి జగదీశ్వర్ రెడ్డి

న్యాశయం 'కమర్షియల్ బిలింగ్' విభాగంలో ఈ అవారు వరించింది. డిసెంబర్ 20న ఖైరతాబాద్లోని ద ఇన్స్టేట్యూట్ ఆఫ్ ఇంజిసీర్స్ భవనంలో జరిగిన కార్యక్రమంలో మంత్రి జగదీశ్వర్ రెడి చేతుల మీదుగా ఎయిర్పోర్ సీనియర్ అధికారులు ఈ అవారును అందుకున్నారు.

# హెదరాబాద్ ఎయిర్పోర్ కు

# రెండు అవారులు

హైదరాబాద్, వెలుగు: కాన్ఫెడరేషన్ ఆఫ్ ఇండియన్ ఇందస్టీ (సీఐఐ), గోదైజ్ గ్రీన్ బిజినెస్ సెంటర్ (జీబీసీ) లు ప్రకటించిన 'ఎక్సలెస్, ఇస్ ఎనరీ మేనేజ్మెంట్' 23వ జాతీయ అవార్తులలో జీఎంఆర్ గ్రూప్ కు చెందిన హైదరాబాద్ అంతర్జాతీయ విమా న్నాశయం (జీహెచ్ఐఏఎల్) 'నేషనల్ ఎనరీ లీదర్', 'ఎక్రలెంట్ ఎనర్జీ ఎఫీషియంట్ యూనిట్' అవారులను గెల్పుకుంది. 'ఎనరీ ఎపీపియెనీ, సమీట్' 21వ ఎడిషన్ సంద ర్చంగా వీటిని ప్రకటించారు. హెదరాబాద్ ఎయిర్పోర్త్ 'నేషనల్ ఎనర్టీ బీడర్' అవారు ను గెలుచుకోవడం వరుసగా ఇది నాలుగవ సారి కాగా, 'ఎక్సలెంట్ ఎనర్రీ ఎఫీషియం ట్' యూనిట్ అవారును దక్కించుకోవడం వరసగా ఇది ఆరవసారి. గత మూడేళుగా ఎనరీని సమరవంతంగా వాడుకోవడానికి వివిధ చర్యలు చేపడుతున్నామని జీహెచ్ఐ ఏఎల్ ఓ సేట్మెంట్లో పేర్కొంది. ఇప్పటి

