


CII ENERGY AWARD 2023
STT GLOBAL DATA CENTRE
DELHI DC GK1 INDIA


Presented By: Bikram Thakur
Gaurav Gupta



STT GDC INDIA-OUR GROWTH STORY



Key Achievements



OUR UNIQUE FEATURES

Most Credible Colocation Provider with Least Risk




Financially stable
strong reputation
and brand



No tenancy risk
Land parcels, large
capacities on short notice



Proven delivery track record
always On
Time delivery



Closest to customers
multi-city presence in India
and overseas



Network rich & carrier neutral
all DC Campus are also
PoPs



Design Excellence
strategic locations, high voltage
tap, enterprise grade




Operations excellence
decades of experience, low
maintenance window


HOW IS STT GDC INDIA RIDING THE GROWTH WAVE ?

Operating since 2004 in India, 33% market share in India colocation market. 21 DCs in 9 cities, 220 MW IT load projected to double in 3 years.

21 DCs with 200 MW IT load



Upcoming DCs, total 2x of current IT load



Under construction: 42 MW
Planned in the next 3 to 5 Yrs: 200 MW

* included under construction facilities

RESILIENT AMIDST COVID-19

Overcoming Challenges with Strategy

5-PRONGED STRATEGY TO DEAL WITH COVID-19 AND LOCKDOWNS



DC Operations

- Coordinating with authorities
- Guaranteed customer support
- Ensuring safety and wellbeing and morale
- Facilitating OEM support
- Providing mobility and people availability



Employees

- Enablement with Collaboration
- Tools and Processes
- Remote Working for non-Ops Staff with timely advisories & engagement
- Health & Safety Initiatives - Advisories, Medical Tie-Ups and related Support



Customers

- Timely customer communication
- Proactive identification & address of churn/ downgrade prospects
- Focus on positively impacted sectors
- Proactive Customer Support
- Virtual A/c engagement



Projects

- Delivery acceleration for Top 10 customers
- Vendor engagement for prioritised supply resumption




Liquidity

- Adequate cash reserves maintained
- Completed FY closure on time despite remote working
- Managed to Waive DSCR Covenants
- Ensuring Collections - AR under was control



The Social
Cor
CII Gold A
Implement
Inter-Industry



Green Building
Cong
IGBC Perform
Green Building
Award



HR Orientation 2019

CEO of the Year 2016
For Excellence in IT



Iconic Brand 2020



Centre
the Year

rd 2019/2021


st in India

ons
18


DATA CENTRE EQUIPMENT AND INFRASTRUCTURE

Highly specialized facilities designed to support the operation of customers' critical systems, networking, storage and information technology requirements

Data Centre Equipment



Infrastructure for Operations



Energy Efficient Data Centres



Temperature as per
ASHRAE guidelines



Customised
Containment



Chiller based
cooling



Optimal power consumption by
computing resources



**Less wastage
= cost savings**

STT GDC India -Operational Excellence

- ❑ Launch of Mock drills Practice with Various Simulated Scenarios FY22 ~ 180 Mock drills completed
- ❑ LoL – Learning over Lunch – Specific to Site SOP's and Practicing FY22 ~ 86 LoL Completed
- ❑ Weekly Action Tracker – for the Site rounds and observations to action on proactive measures
| 9213 Observations , 586 WIP |
- ❑ Established formal waste management policies and procedures for hazardous and non-hazardous wastes, General Waste , Hazardous Waste and E waste Disposal completed Value INR 14.054 Cr Benefit till end of Feb 2023
- ❑ SOP's & RCA Standardization with the Quality Improvement , Simplified Block Diagrams , Site Walk thro Postures
- ❑ PMO – Key Projects drive and timely execution
- ❑ Dynamic Risk Register (DRR) Tracker and Monthly review , Operations Comprehensive Monthly dashboard and Publish
- ❑ Standardization of Energy measurements and Calculation formalized and practiced with the Uniformity Approach
- ❑ Various PoC Set ups and evaluation at our COE Centre (UPS –Li-ON Battery)
- ❑ Introduction of C10 Battery discharge Maintenance Program Across Sites , to check the health of Battery cells
- ❑ Automation Drive – Electrical Control and Mechanical Control Systems Implementation including the Complex VSB Sites





STT GDC INDIA ENVIRONMENTAL, SOCIAL, AND GOVERNANCE (ESG)

- **STT GDCI and Group has Committed to be Net Carbon-Neutral by 2030**
- **36% of our Electricity consumption is derived from Zero-Carbon Renewable Sources**
- **We are constantly updating our data Centre's with more efficient technologies and are implementing energy-saving initiatives to improve our PUE**
- **Women empowerment -Successful integration of women in mission critical operational roles**
- **Fostering a safe and diverse workplace**
- **0 TRIR across our operations 3 years in a row**

- **Rainwater harvesting pits provided at the Storm water drains .At Delhi DC GK1 we have 24KL capacity of under ground storage for Rainwater.56KL to discharge the rainwater in ground and 100KL STP plant.**
- **We have the underground storage tank capacity of 2Lakh KL.**
- **We reduce our water consumption by installing Water-recycling technologies and using recycled water for all NON-IDC purposes.**
- **Tech refresh with zero / low Ozone depletion potential refringent (Ex. R22 gas is getting phased out)**

A CLOSER LOOK

into our state-of-the-art, certified and highly reliable data centres in Delhi



DC 2- KEY FEATURES



Plot Area (In acres)

~127 acres



Floor Loading

1500kg/Sq.Mts



Floor Height

4.42 Meters Height
accommodate , up-to
48U racks.



Power Path

Dual power feed from
220 KV Substations
with Diverse
Route



DC Hall

6 DC Halls with
designed IT load of
6MW



DG Set

5nos of 2.5 MVA DG
Set with N+1
redundancy



Building

Purpose DC buildings, G + 5
Building



Floor Plate (in sq. ft.)

32,000 SFT approx



Security

5 Layers of Physical
Security



Fibre paths

3 Nos of Fibre path
with Multiple MMR
Rooms



IT Power Capacity

9 MW of IT Load



UPS resiliency

UPS with N+N (System +
System) redundant topology



Dedicated **33kV** onsite substation

Two express feeders- Masjid moth and Nehru place, tapping from 220kV main substation


Installed 2nos **HT 33kV** Distribution panel outgoing to 5Nos Transformers.

- HT-1 Outgoing - TRF1, TRF2, and TRF4
- HT-2 Outgoing - TRF3 and TRF5

Remotely operation of both HT-1 and HT-2 panel

SCADA Integrated with IBMS System for remote monitoring

2500kVA, 33/0.433kV **5nos** Transformer for Substation.



Design and installed for LT DG set of **2500kVA x4** (cummins) and **2500kVA x1** (sterling) DG feeding to MLTP 1 to MLTP 5

DG with N+1 redundancy & seamless power restoration when changeover from DG to EB.

Installed 5nos DG day tank for diesel flow with capacity **990 Liters**.

Installed **coil cooler** system for 2nos of DG and 3nos DG have cooling tower system

Integrated with **IBMS** to monitor critical DG parameters

CCTV installed around the DG area for 24x7 monitoring

STT Delhi

Battery Bank

- ❄️ Lithium-Ion battery 51.52V/64Ah - 10 no'sx6 battery banks for UPS 800kVA*8.

Battery backup for UPS rooms VESDA system installed for early fire detection

Rooms are protected by Novec 1230 Gas for Fire Suppression system
LMS battery health monitoring system (BHMS) configure with IBMS



Li-Ion BB

GK1 POWER SYSTEM



CRAC



CHILLER



CRAC/HVAC

- N+1 for each server hall
- Air cooled chiller system



Humidity Maintained - 35 to 70 %



Temperature


22 to 27 degree Celsius, customer specific to ASHRAE guidelines



Fire System

- Smoke detectors and VESDA for fire detection
- Inergen for fire suppression

Sustainable Initiatives @ STT Delhi GK1



UTILIZATION OF RENEWABLE ENERGY SOURCE

1. Renewable Energy

Meeting the present demand of our business require us to consume energy—primarily electricity—to power our data centres. Challenging climate change requires the world to changeover to a clean energy. That's why we have made it a top priority not only to become more energy efficient, but also to ensure the energy we purchase comes from clean sources, such as renewables.


STTelemedia GDC India is one of the largest user of renewable energy in India majorly from solar and wind and Hydro power producer. STTelemedia GDC India are using app. 36% of our Energy from renewable Energy sources .In Delhi GK1, 3 MW from Hydro plant through Open Access and 625kw onsite solar generation contributes app. 65% share of total consumption.

Site Building roof top alongwith forest area 625 KW Solar Plant Grid tied



625KW Solar installed onsite

3MW Hydro through OA



Green Supply Chain: STT GDCl is procuring Renewable Energy (Hydro, Wind & Solar Power) both from onsite & offsite sources (under Open Access route) and We will be increasing our Green Energy Percentage by 75% by next year

Delhi GK1: ~ 65 % of our Site Energy is from Renewable Sources

GHG EMISSION TREND and NET zero Emission

ENERGY DATA

| Parameters | | 2020-2021 | 2021-2022 | 2022-2023 |
|--|-------------|------------|-------------|-------------|
| Annual Electrical Energy Consumption, purchased from utilities | kWh | 17665063 | 12086472 | 24675198 |
| Annual Electricity Generation (in-situ), through Diesel Generating (DG)/Gas Generating (GG) Set(s) | kWh | 123481 | 161096 | 256279 |
| Total Annual Electricity Consumption, Utilities + DG/GG Sets | kWh | 17788544 | 12247568 | 24931477 |
| Annual Cost of Electricity Consumed from utilities | million INR | 21.5066593 | 17.3097613 | 32.6753355 |
| Annual Cost of Electricity generated through DG/GG Sets | million INR | 7.52863657 | 13.92352728 | 25.23066755 |
| Total Annual Electricity Cost, Utilities + DG/GG Sets | million INR | 29.04 | 31.23 | 57.91 |
| Total facility Energy | kWh | 34065628 | 35110426 | 38135300 |
| IT Equipment Energy | kWh | 18594000 | 21090533 | 22406315 |

| Year | CO2 Emission Reduced | | | | DG | Total | Green percentage |
|-------|----------------------|-------------|-------------|-------------|--------|-------------|------------------|
| | Solar | Hydro | Discom | Total Green | | | |
| 20-21 | 638182 | 15638902.15 | 17665062.68 | 16277084.15 | 123481 | 34065627.83 | 48% |
| 21-22 | 688484 | 22174374.65 | 12086472.4 | 22862858.65 | 161096 | 35110427.05 | 65% |
| 22-23 | 608043 | 12595780.61 | 24675198.29 | 13203823.61 | 256279 | 38135300.9 | 35% |

| CO2 Emission avoided |
|----------------------|
| 12907.72773 |
| 16232.62964 |
| 9374.714763 |
| 38515.07213 |

| CO2e year | Scope 01 | Emission factor CO2e / unit = 2.70 | Scope 02 | | | Total Emission, CO2 in tons |
|--------------|-------------------------|------------------------------------|------------------------------|-----------------------------|-----------------------------|-----------------------------|
| | Fuel consumed in liters | Total GHG emission in TCO2e | EB Energy consumption in kWh | Emission factor CO2e / unit | Total GHG emission in TCO2e | |
| FY 2020 - 21 | 1,23,481 | 334 | 17665063 | 0.793 | 14008 | 14342 |
| FY 2021 - 22 | 1,61,096 | 436 | 12086472 | 0.71 | 8581 | 9017 |
| FY 2022 - 23 | 2,56,279 | 693 | 24675198 | 0.71 | 17519 | 18213 |

EMISSIONS

| Year | Scope 1 Emission | Scope 2 Emission | Scope 3 Emission | Total kgCO2 / Ton of Final Product |
|---------|------------------|------------------|------------------|---------------------------------------|
| 2022-23 | 693 | 17519 | | 18213 |
| 2021-22 | 436 | 8581 | | 9017 |
| 2020-21 | 334 | 14008 | | 14342 |
| 2019-20 | | | | |

Target (short term/ long term) for CO2 emission reduction and action plan to be mentioned


Shifting the emphasis to renewable energy. ONGuard 4000 has been installed inside the DC halls




Innovative Projects@ STT Delhi GK1

2. Cooling Infrastructure efficiency

- ❑ Data centre ~ 33% Energy utilization by cooling infrastructure –Hence our focus is high on the cooling infra right thro Design , Equipment's selections, Operations to achieve the higher efficiency and energy conservation
- ❑ Air cooled chillers with CPM installed to use them efficiently.
- ❑ Selection of the Chillers and all associated equipment's are with high efficiency with highest Quality
- ❑ All secondary pumps and chillers are with VFD
- ❑ AHUs are equipped with VFD to save Electrical Power and Thermal Power.
- ❑ Automatic SCADA based Chiller Management Systems which improves the efficiency
- ❑ Periodic Energy audits to evaluate the Chiller efficiency & tracking
- ❑ Effective and periodic maintenance which includes validation of Quality of the water & insulation to ensure the UPTIME.



Ref. Screen Shot



| Battery room | | | | | | | |
|----------------|---------------|---------|----------|---------------|---|-----------|----------------|
| Without VFD | Phase Voltage | | | Current/phase | | Total KVA | Units Consumed |
| | R | Y | B | R | B | | |
| 242.49423 | 7 | 6.9 | 7 | | | 5.06 | 40747.7 |
| Apparent Power | 1697.46 | 1673.21 | 1697.46 | | | | |
| KVA/Phase | 1.69 | 1.67 | 1.6 | | | | |
| Battery Room | | | | | | | |
| With VFD | Phase Voltage | | | Current/phase | | Total KVA | Units Consumed |
| | R | Y | B | R | B | | |
| 242.49423 | 4.2 | 4.1 | 4 | | | 2.98 | 24207.7 |
| Apparent Power | 1018.4 | 994.2 | 969.9769 | | | | |
| KVA/Phase | 1.018 | 0.99 | 0.96 | | | | |


Sustainable Initiatives @ STT Delhi GK1

3. Water recycling

- We reduce our water consumption by installing water-recycling technologies and using recycled water for the
- Project initiated to reuse 100% of the wastewater of RO plant in the facility.
- Commissioned 100 KL STP plant to reuse 100% water for NON-IDC requirement. Saving more than 21023 KL.
- Rainwater harvesting installed, which connected to water treatment plant, reducing the external dependency on water.
- Coil Cooler have been installed in place of Water based cooling tower for DG.



Water is precious reuse and recycle



| STP RECYCLE DATA | | | |
|------------------|---------|---------|---------|
| Month | 2020-21 | 2021-22 | 2022-23 |
| April | 275 | 518 | 962 |
| May | 299 | 422 | 922 |
| June | 541 | 605 | 1056 |
| July | 482 | 460 | 844 |
| Aug | 404 | 420 | 798 |
| Sep | 407 | 417 | 789 |
| Oct | 532 | 537 | 717 |
| Nov | 480 | 564 | 722 |
| Dec | 627 | 586 | 513 |
| Jan | 541 | 437 | 771 |
| Feb | 436 | 417 | 658 |
| Mar | 479 | 654 | 731 |



Operational Projects@ STT Delhi GK1

4.Data Centre best practises

- ❑ Strictly adopted hot and Cold Aisle containment into the complete DC raised floor area's i.e. all 80Ksq. Ft of DC
- ❑ Tightly hide air gaps using pedestal-sized openings cut from cold-locked cables and a custom sealing method applied where it clearly proves that the hot zone is warmer and the cold zone is colder, and the combination of AIR cold and hot is almost irrelevant.
- ❑ Tested the CRAC units operating efficiency realised at 90 % and Delta T with higher temperature value
- ❑ Using empty panels in unused rack space - this is one of the more difficult tasks as the shelves/cabinets are owned by the customers, but our constant focus through customer training has given them the awareness to ensure that the empty panels are recovered after use work - we also have a daily floor walk to re-inspect and repair the cover panels-

CRAC ROOM



DC FLOOR GALLERY



PROPER CABELING
CAC ON ALL FLOOR



BLANKING PANEL



Operational Projects @ STT Delhi GK1

5.Aisle and Gaps Containment

- Strictly adopted hot and Cold Aisle containment into the complete DC raised floor area's i.e. all 80k sq. Ft of DC .
- All the opening of trays going inside the DC hall been closed to minimize cooling loss.
- Well-designed air flow management systems (cold and hot aisle system), we have minimized hot and cold air mixing leading to lesser energy consumption


Key highlights :

CRAC – Supply temperature setting was 18 Deg C (Without CAC)

Post Containment – CRAC Supply Temperature setting at 21 Deg C
CAC helps to eliminate the air leakages , Improves the Delta T

- Supply air measured in all CAC – 21 Deg C
- Return air measured in all CAC – 32 Deg C
- Delta T : 11 Deg C which is matching with the CRAC Design
- Humidification and dehumidification Cycle reduction
- Resulting high efficiency of the Cooling Infrastructure

Overall – Huge savings on energy and Water



Sustainable Initiatives @ STT Delhi GK1

6. Solar panels , Motion Sensor etc

- Motion Sensors installed on all floors.
- Energy efficient lighting fixtures - LED's
- 3.5MW Solar and Hydro power is directly connected to MLTP from where we are running the Gk1 exterior and interior lights




BMS Projects@ STT Delhi GK1

6. BMS Monitoring and parameters




ND-GK-1 Fire Alarm and VESDA System

| VESDA System | | | Fire Alarm System | |
|--------------|-----------------------------|--------------|--------------------------------|-------------|
| Floor | Room Name | Alarm Status | Room Name | Fire Status |
| 4th Floor | CRAC ROOM PANEL 1 (2 Panel) | ON | 4th Floor Fire Alarm System | ON |
| | CRAC ROOM PANEL 2 (2 Panel) | ON | 4th Floor Fire Alarm System | ON |
| | CRAC ROOM PANEL 3 (2 Panel) | ON | 4th Floor Fire Alarm System | ON |
| Ground Floor | CRAC ROOM PANEL 1 (2 Panel) | ON | Ground Floor Fire Alarm System | ON |
| | CRAC ROOM PANEL 2 (2 Panel) | ON | Ground Floor Fire Alarm System | ON |
| | CRAC ROOM PANEL 3 (2 Panel) | ON | Ground Floor Fire Alarm System | ON |
| | BATTERY ROOM | ON | | |
| | WIP-1 ROOM | ON | | |
| | WIP-2 ROOM | ON | | |



UPS DASHBOARD

| LOCATIONS | MP 01 | MP 02 | MP 03 | MP 04 | MP 05 | MP 06 | MP 07 | MP 08 | MP 09 | MP 10 |
|------------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
| DESIGN-3 4th FLOOR UPS | ON | ON | ON | ON | ON | ON | ON | ON | ON | ON |
| DESIGN-3 3rd FLOOR UPS | ON | ON | ON | ON | ON | ON | ON | ON | ON | ON |
| DESIGN-4 BASEMENT UPS | ON | ON | ON | ON | ON | ON | ON | ON | ON | ON |



Sustainable Initiatives @ STT Delhi GK1

Plantation & Rainwater harvesting

- ❑ Our intend and initiatives are in line with Green Campus
- ❑ Plantation on many occasions
- ❑ Rainwater harvesting .(78KL)
- ❑ Largest green area covered in India.
- ❑ Recycling of water by Sewage Treatment plant (STP) installed. Recycled water is used to non-potable purposes



8. Management of Hazardous Waste

- ❑ Batteries are recycled as per the Battery Management rules

Battery Cells disposal completion @ 175 Tonnage

- ❑ Hazardous waste (like used lube oil) is recycled through authorized recyclers

Waste lube oil disposal completion 8.53 Tonnage

- ❑ Strict enforcement of plastic management rules.



Form 1
Hazardous Waste Manifest
This form is used to track the movement of hazardous waste from the generator to the transporter and finally to the handler. It is a legal document and must be filled out for every consignment of hazardous waste.



Form 2
Receipt for Receipt of Hazardous Waste
This form is used to record the receipt of hazardous waste by the handler. It is a legal document and must be filled out for every consignment of hazardous waste.




Form 3
Receipt for Receipt of Hazardous Waste
This form is used to record the receipt of hazardous waste by the transporter. It is a legal document and must be filled out for every consignment of hazardous waste.



Form 4
Receipt for Receipt of Hazardous Waste
This form is used to record the receipt of hazardous waste by the generator. It is a legal document and must be filled out for every consignment of hazardous waste.





STT GDC India Operations – Approach



Projects completed in 22-23 @ STT Delhi GK1

| Sr No. | Title of Project | Annual Electrical Saving (kWh) | Annual Thermal Saving (Kcal) | Total Annual Saving in INR |
|--------|---|---------------------------------|-------------------------------|----------------------------|
| 1 | PAHU/PAC three side bottom gaps closing impact and analysis. | 35000 | 6655.3 | 428400 |
| 2 | Installation of VFD in all AHU | 32655.24 | 6109 | 399700 |
| 3 | Dismantling of existing CFL light fixtures & Supply and Installation led tube light with fixture with required cable along with Motion sensors. | 84273 | 7603.6 | 1021388 |
| 4 | EOL old analog compressor-based replacement with New digital compressor-based PAC | 120000 | 33276 | 1460000 |
| 5 | SITC of old 1x40KVA UPS at GK | 20000 | 5690 | 244000 |
| 6 | Chiller automation | 394200 | 11085 | 4777704 |
| 7 | Gap closing on DC floor | 20000 | 5690 | 242400 |
| 8 | PAHU setpoints increase | 70000 | 25689 | 848400 |
| | | | | |

| Year | Chiller | IT load | Chiller | IT load | Chiller | IT load |
|--------------------|------------|----------------|------------|----------------|------------|-------------|
| | 20-21 | 20-21 | 22-23 | 22-23 | 22-23 | 22-23 |
| April | 567 | 1150 | 584 | 1411 | 618 | 1742 |
| May | 618 | 1211 | 589 | 1460 | 675 | 1760 |
| June | 676 | 1150 | 662 | 1441 | 710 | 1770 |
| July | 671 | 1118 | 672 | 1480 | 728 | 1760 |
| Aug | 665 | 1276 | 686 | 1552 | 718 | 1820 |
| Sep | 665 | 1282 | 650 | 1521 | 700 | 1862 |
| Oct | 570 | 1252 | 606 | 1579 | 650 | 1880 |
| Nov | 571 | 1148 | 556 | 1546 | 600 | 1836 |
| Dec | 505 | 1127 | 505 | 1617 | 545 | 1838 |
| Jan | 474 | 1140 | 485 | 1625 | 510 | 1840 |
| Feb | 514 | 1182 | 524 | 1647 | 542 | 1870 |
| Mar | 534 | 1688 | 538 | 1731 | 562 | 1877 |
| Avg | 586 | 1282 | 588 | 1578 | 627 | 1880 |
| Chiller/Fac | | | | | | |
| Wly Load | | | | | | |
| | | 26% | | 23% | | 22% |
| | | Savings | 70 KWh | Savings | 45KWh | |
| | | KWH | 63300 | KWH | 394200 | |
| | | Savings in INR | 7431964 | Savings in INR | 4777704 | |



| Battery room | | | | | | |
|----------------|---------|---------|---------|---|-----------|----------------|
| Phase | Voltage | R | Y | B | Total KWh | Units Consumed |
| (242)4023 | 7 | 6.9 | 7 | | | |
| Apparent Power | 1697.66 | 1673.21 | 1697.66 | | 5.06 | 40247.7 |
| KVA/Phase | 1.69 | 1.67 | 1.6 | | | |

| Battery Room | | | | | | |
|----------------|---------|-------|-----------|---|-----------|----------------|
| Phase | Voltage | R | Y | B | Total KWh | Units Consumed |
| (242)4023 | 4.2 | 4.1 | 4 | | | |
| Apparent Power | 1038.4 | 994.2 | 1009.9769 | | 2.98 | 24207.7 |
| KVA/Phase | 1.038 | 0.99 | 0.96 | | | |

| Saving with Motion Sensors KWH | | | | |
|--------------------------------|---------|---------|---------|---------------|
| BEFORE | Q1 | 2021-22 | 28382.4 | |
| AFTER | 2022-23 | | 7000 | |
| BEFORE | Q2 | 2021-22 | 28382.4 | |
| AFTER | 2022-23 | | 6789 | |
| BEFORE | Q3 | 2021-22 | 56764.8 | |
| AFTER | 2022-23 | | 15467 | |
| Annually Consumption before | TOTAL | 2021-22 | 113530 | KWH Saving |
| Annually Consumption After | TOTAL | 2022-23 | 29256 | Saving in INR |
| | | | 84273.6 | 1021396.032 |

Data Center Competitors National & Global benchmark

| Global Benchmark | | | |
|-------------------------------------|--------------|------|--------|
| Description | Standard | Good | Better |
| PUE | 2 | 1.5 | 1.2 |
| Temperature as per ASHRAE guideline | 19- 27 deg C | | |
| Humidity as per ASHRAE Guideline | 40%-80% | | |

| Sr No | National/Global | PUE | Remarks |
|-------|-----------------|------|-----------------|
| 1 | National | 1.5 | Actual |
| 2 | Global | 1.11 | Source-Internet |

Steps towards to achieve it

Few of those initiatives are,


- Proper CFM analysis through external vendor.
- We are exploring Free cooling in winter to reduce the chiller usage.
- All Pahu and PAC three side bottom has been closed, directing all the air in the designated space only
- Liquid cooling proposed for STT GDC india sites.
- Replacement of old equipment with high efficient equipment even at lower operating load condition (part of H&H)
- Close monitoring of temperature in various parts of the facilities, balance and optimize.
- Initiative and continuous focused monitoring on leakages (CAC, HAC, False floor tiles) and arresting.
- Keeping the condenser approach as low as possible for the chillers.
- No deviation on the maintenance practices (filter cleaning, replacement, etc)
- Dedicated COE team formed to monitor and drive across PAN India.

PUE – Trend Last and savings.

Designed PUE of the Building is 1.70



| Month | 2020-21 | 2021-22 | 2022-23 |
|-------|---------|---------|---------|
| APR | 1.78 | 1.71 | 1.62 |
| MAY | 1.85 | 1.74 | 1.63 |
| JUNE | 1.90 | 1.75 | 1.66 |
| JULY | 1.81 | 1.73 | 1.67 |
| AUG | 1.80 | 1.66 | 1.58 |
| SEP | 1.74 | 1.66 | 1.58 |
| OCT | 1.73 | 1.60 | 1.59 |
| NOV | 1.73 | 1.62 | 1.52 |
| DEC | 1.66 | 1.59 | 1.54 |
| JAN | 1.64 | 1.60 | 1.52 |
| FEB | 1.62 | 1.61 | 1.50 |
| MAR | 1.62 | 1.58 | 1.53 |



| | | PUE | | KW | KWH | RS |
|--------------------|-------|------|---------|------|--------|------------|
| Avg FL-2020-21 | | 1.74 | Savings | 0.08 | 124.16 | 1087641.6 |
| Avg FL-2021-22 | 17.2% | 1.66 | | | | 12148956.7 |
| IT load % Increase | 21.6% | | | | | 772 TON |

| | | PUE | | KW | KWH | RS |
|--------------------|-------|------|---------|------|----------|-------------|
| Avg FL-2021-22 | | 1.66 | Savings | 0.08 | 142.3701 | 1247161.715 |
| Avg FL-2022-23 | 12.9% | 1.58 | | | | 13930796.4 |
| IT load % Increase | 17.8% | | | | | 785 |

Achievements and Proposed Projects

- ❑ **Green and Smarter Energy Transformation of our Data centres i.e. 36 % of Energy usage on renewable's – Wind, Solar Hydro etc & The usage of renewable energy is expected to grow up through our continual PPA approach**
- ❑ **Selection of High efficiency -next generation technology Equipment's such as UPS, Cooling etc to enhance our Energy conservations**
- ❑ **Smarter Water conservation – Rainwater harvesting and recycled i.e.21023 KL water . .**
- ❑ **Potential Energy savings opportunity Via our smart Energy usage and minimising the losses 0.5 mw Potential savings opportunities through energy efficient drive.**
- ❑ **Adiabatic Cooling Pad for Chillers.**
- ❑ **EOL PDU replacement with Smart PDU.**
- ❑ **Emissions: with our Renewable energy percentage and PUE savings, our onsite and offsite green energy ventures have resulted in 40,072 Ton of CO2 less emission.**
- ❑ **Proposed Gas based DG with negligible Exhaust hence the pollutants.**

THANK YOU

Bikram Thakur +917070995379 Bikram.Thakur@sttelemediagdc.in
Gaurav Gupta +919711549889 Gaurav.gupta@sttelemediagdc.in

 **STTelemedia**
Global Data Centres