

STT GDC India

Energy and Operational Efficiency Drive


August 22, 2023




PUE – Trend Last 4 Yrs.

FY	PUE Achieved	Energy KW	Cost Saving INR	Co2 Ton
2019-20	1.98 -> 1.94 =0.04	722.12	5.5 CR	5926.17
2020-21	1.725 -> 1.69 =0.035	575.98	4.21 CR	4745.064
2021-22	1.68 -> 1.66 = 0.02	889.79	6.25 CR	6691.40
2022-23	1.72 ->1.65= 0.069	986.5	Yet to be calculated	8126

3174.39 KW FY 19-Feb 23
Energy Savings Opportunity 

15.96 Cr FY19-Mar 22
Cost Savings 

25488.63 Tons CO2 avoidance
Carbon Emission reduction 



The PUE calculation includes all equipment KWH consumption including the losses.

The PUE improvement initiatives taken over the last 5 years is reflecting.

- Few of those initiatives are,
- Replacement of old equipment with high efficient equipment even at lower operating load condition (part of H&H)
 - Close monitoring of temperature in various parts of the facilities, balance and optimize.
 - Initiative and continuous focused monitoring on leakages (CAC, HAC, False floor tiles) and arresting.
 - Keeping the condenser approach as low as possible for the chillers.
 - No deviation on the maintenance practices (filter cleaning, replacement, etc)
 - Dedicated COE team formed to monitor and drive across PAN India.

STT GDC INDIA OPERATIONS – ENERGY EFFICIENCY AND ESG APPROACH

Datacenter Energy Efficiency improvement

ESG Measures DC Operations

- Water usage measurement
- Refrangent top up
- Hazardous waste Management
- E-Waste Management
- Fuel Consumption
- PUE Monitoring

Cooling Infrastructure Energy Efficiency Strategy

- Tech Refresh-Replacement:**
- Condenser + ODU
 - CRAC , Chillers , PAHU
 - Automation of Chillers with CPM
- Best Practices:**
- Air balancing through CFM Grill
 - Water Balancing through Chilled water Piping
 - Temp control @ PAHU room
 - Adequate Refrigerant level
 - Cable dressing and management

- Best Practice**
- Qualitative Air Balancing Assessment of datacenter facility.
 - Provides recommendation of best practices for efficient functioning
 - CAC /HAC Deployment + Air Tightening
 - Provided Blanking Panels in unused rack Space
 - Concealing of Air leakage
 - Replacement of Return Air Grills
 - Filters replacement, Installation VAHU's

Electrical Infrastructure Energy Efficiency Strategy

- High efficiency UPS Tech refresh +Consolidation
- Continual PF improvement
- Energy Measurement points and data recording
- PUE Template standardization
- Watch on losses : TRX , UPS , Chillers
- Replacement of Conventional lights with LED lights

STT GDC India -Operational Excellence

- ❑ Launch of Mock drills Practice with Various Simulated Scenarios FY22 ~ 180 Mock drills completed
- ❑ LoL – Learning over Lunch – Specific to Site SOP's and Practicing FY22 ~ 86 LoL Completed
- ❑ Weekly Action Tracker – for the Site rounds and observations to action on proactive measures | 9213 Observations , 586 WIP |
- ❑ Established formal waste management policies and procedures for hazardous and non-hazardous wastes, General Waste , Hazardous Waste and E waste Disposal completed Value INR 14.054 Cr Benefit till end of Feb 2023
- ❑ SOP's & RCA Standardization with the Quality Improvement , Simplified Block Diagrams , Site Walk thro Postures
- ❑ PMO – Key Projects drive and timely execution
- ❑ Dynamic Risk Register (DRR) Tracker and Monthly review , Operations Comprehensive Monthly dashboard and Publish
- ❑ Standardization of Energy measurements and Calculation formalized and practiced with the Uniformity Approach
- ❑ Various PoC Set ups and evaluation at our COE Centre (UPS –Li-ON Battery)
- ❑ Introduction of C10 Battery discharge Maintenance Program Across Sites , to check the health of Battery cells
- ❑ Automation Drive – Electrical Control and Mechanical Control Systems Implementation including the Complex VSB Sites

STT GDC India ENVIRONMENTAL, SOCIAL, AND GOVERNANCE (ESG)

- **STT GDCI and Group has Committed to be Net Carbon-Neutral by 2030**
- **36% of our Electricity consumption is derived from Zero-Carbon Renewable Sources**
- **We are constantly updating our data Centre's with more efficient technologies and are implementing energy-saving initiatives to improve our PUE**
- **Women empowerment -Successful integration of women in mission critical operational roles**
- **Fostering a safe and diverse workplace**
- **0 TRIR across our operations 3 years in a row**

- **STT GDC India Experience Centre @ Bangalore**
- **Specialized facilities designed with Simulation of DC Critical Infrastructure for the Skills developments of Students Via Practical Training**
- **2 Batches ~ 120 Students Trained and certified – Placement Completed at Various mission Critical Operations role**
- **3rd Batch 60 Students Program is on going**

- **Water Usage effectiveness (WUE) 0.55 across India**
- **Aiming towards zero Liquid discharge by Capturing Surface rainwater Example :160 kL roof rainwater collection sump and treatment for reuse @ Bangalore DC3**
- **Rainwater harvesting pits provided at the Storm water drains .Example at Bangalore DC3 42 kL Capacity**
- **We reduce our water consumption by installing Water-recycling technologies and using recycled water for the water-cooled chiller cooling tower purpose**
- **Tech refresh with zero / low Ozone depletion potential refrigent (Ex. R22 gas is getting phased out)**

OPERATIONAL EXCELLENCE

Consistent quality across our global portfolio



Strong global-local leadership

- Enabling market entry for our customers across our global platform
- Global strength matched by our local expertise, with accredited and qualified teams on the ground who know their home markets best



Built and operated to global standards of excellence

- Centre of Operational Excellence department to adopt best practices and communication across STT GDC platform



State-of-the-art, new data centres

- Purpose-built data centre designed to the highest technical specifications
- Modular approach providing customer expansion options in future



Reliability

- Robust systems and procedures in place to manage change control and incidents
- High power availability for customers' mission-critical data, providing peace of mind and reliability they need



Wide range of connectivity options

- Carrier-neutral
- Interconnection and peering fabrics
- Ready connectivity via both local and global network service providers
- Direct connectivity to Cloud Service Providers




Physical security


- Multi-layer security at all sites
- On-site security personnel
- Enhanced security measures *e.g. intrusion detection, physical access controls, 24x7 CCTV monitoring*

Operating since 2004 in India, 33% market share in India colocation market. 21 DCs live in 8 cities, 220 MW IT load projected to double in 3 years.

18 Existing DCs with 220 MW IT load



Upcoming DCs, total 2x of current IT load



STT GDC India - Pune DC1

Energy and Operational Efficiency Drive

Presented by -

Ramdas Manekar – Assistant General Manager DC Operations



STT GDC Datacenters Limited, Pune (MH).
Singapore | India | APAC

www.sttelemidiagdc.com

A COMPANY OF ST TELEMEDIA

Consistent quality across our Data centres



People

- Dedicated ops staff with desired qualification and critical infrastructure experience
- A dedicated EHS Manager for Campus
- Organization structure and staffing plan will meet all required competencies.
- Skill development through Various drills
- Knowledge Management through Trainings (Technical, Behavioural and Soft), Seminars & factory visits.



Process

- ITIL aligned operational processes.
- Well-defined site-specific SOP/EOPs.
- Risk management, RCA, BCP processes.
- ISO 45000 framework aligned EHS processes.
- Structured 52 weeks PPM process
- Operations Governance: Weekly, Monthly and Quarterly Operations Reviews.
- Material management process aligned to customer's implementation plan.
- Asset Lifecycle management program (Annual)



Physical security

- Separate ring-fencing to segregate the DC buildings within campus
- Enhanced security measures such as UVSS, Turnstiles, Boom Barrier shall be implemented
- Flood lights around the fencing with comprehensive patrolling.
- BGV Process .Both Internal as well as Complying to customer specific requirements



Tools

- DC setup will have dedicated fully integrated IBMS system,
- Fully automated and redundant CPM system.
- Fully automated and redundant EPMS systems.
- SNOW tool for Operations Management (Incident , Problem ,Change, Escalation Management)
- Capacity Management and PMMs portal



Partnership

- SLA governance. With underpinning contracts.
- Monthly and quarterly performance review Engagement
- Critical Spares and Inventory management.
- Robust Contractor Pre-qualification and Selection process that includes clear contractual language on EHS standards and expectations.



Quality Management

- Early engagement of operations team right from Concept design to IST and HOTO.
- Quality standards adherence and certifications.
- CoE lab for any simulations, testing, POC, etc.
- Simplified SLD , Block Diagrams
- NO/NC Indicators
- Weekly Site / Campuses Walk thro
- Waste Management

Information of Data Center Competitors National & Global benchmark

Global Benchmark			
Description	Standard	Good	Better
PUE	2	1.5	1.2
Temperature as per ASHRAE guideline	19- 27 deg C		
Humidity as per ASHRAE Guideline	40%-80%		

Sr No.	National /	Name of Competitor	PUE	Remarks
	Global			
1	National	Pune DC2	1.65	Actual
2	Global	Google Data Center US	1.11	Source: Internet

Pune Data Center

The image displays a satellite map of the Pune Data Center area. A yellow star icon marks the location of the STT Global Data Centres India Private Limited, labeled as 'Pune-DC-1'. Other nearby landmarks include Tata Communications Limited, VSNNL OLD COLONY, and the Bombay Sappers Army Pre-Primary School. A red arrow points to the data center location. An inset photograph in the top right shows the modern, multi-story glass and concrete building. A circular badge in the bottom right corner certifies the facility as 'ANSI/TIA-942:2017 DESIGN RATED 3 TIA-942 .ORG'. The map interface includes a 'Layers' button, a 'Live traffic' dropdown menu, and a color-coded speed scale.

Building Infrastructure



Operational – Capacity 10.17 MW , Area 2.0 Lakh Sq .ft
– STT GDC Pune has 3 Data Centre towers in Pune, DC01 (Jade Building), DC02 and DC03 which are suit to build data center for one of the hyper scaler customer.

TIA-942-Rated 3, Purpose built DC, Seismic zone 3

Clear height of **~4.3 m** (Slab to Slab) for accommodating Racks up to **48 U** (Flexibility to go vertical)

Load bearing Capacity of 1500kgs/white space & Technical areas

On-site HSD fuel storage of **48 hours** at full load.

Ramp less Design, Two Material lifts , One Passenger Lift ,One Scissor lift .

Cooling Infrastructure



Chillers N+N configuration with N+N diverse chilled water piping system

Water Cooled- 1150 TR x 3 Nos

Water Cooled- 1050 TR x 1 No

Air Cooled Chiller Net Capacity- 460 TR x 4 Nos

Primary Pumps 3200 x2 gpm 160kW & **Redundant**
Condenser Pumps 4800x2 gpm 110kW

Electrical Infrastructure



Modular design with N+N Redundancy at GIS 220kv Onsite Substation

Key systems equipped with **Dual Feed** from Two **independent paths**.

Rack Capacity : 2049 Rack

Designed for **up to 8 KW density** and **average rack density of 5 KW**

Floor Level Infrastructure Design with **Distributed Redundancy**.

Rack level power Design with **2N** mode. Each rack is fed from two independent UPS & PDU Sources

IBMS Infrastructure



Integrated with respect to Electrical, Cooling, Security & Safety Infrastructure

Fully **Automated Cooling** System

Tailor made **Dashboards** like BMS Network, Fire Safety, Security systems

Redundant BMS network path from Distribution Level onwards

Installed **Addressable** Safety Systems & **Advanced** Suppression systems suitable for Technical areas

Integrated ACS, CCTV

Certifications



ISO/IEC 20000-1:2018
ISO 14001 : 2015
ISO/ IEC 27001 : 2013
ISO/ OSHAS:45001
TL 9000-V R6.2/R5.7
PCI DSS 3.2.1

Datacenter Facility footprint



Utility Power

- 2 X 220 kV feeders with substation on site
- N+1 transformers Bank
- Campus scalable up to 10.19 MW of IT Load



UPS

- Distributed Redundant (N+N/2) for each server hall with up to 13 mins of battery backup as well as By pass UPS protection
- Concurrent maintainability no Single Point of Failure



Generator

- N+1 configuration and as well as 3*3MVA and 2.5MVA HT DG sets For Critical Chiller and Power Backup



Fuel Tanks

- 1.1 KL U/G HSD fuel tanks yard
- 48 hrs. backup on full load



Design Uptime

- 99.982% of power uptime in line with tier-3 specifications



Floor Loading – 1,500 kg/sq. meters



Heights

- Slab to Slab – 5 mts
- Raised Floor to False Ceiling height – 4.2m
- False Floor height - 0.8m



Loading Dock

- Dedicated Raised loading dock and staging area available for Customer



Elevators

- Passenger – 2 Nos
- Freight elevator – 2 Nos
- 2 x 3 Ton capacity,



CRAC/HVAC

- N+1 for each server hall
- N+N Water cooled and Air Cooler chiller system Cooling Protection



Humidity Maintained – 35 to 70 %



Temperature

22 to 27 degree Celsius, customer specific to ASHRAE guidelines



Fire System

- Smoke detectors and VESDA for fire detection
- Inergen for fire suppression

Data Center Facility Energy Data


Parameters	Units	FY20 – 2021	FY21- 2022	FY22- 2023
Annual Electrical Energy Consumption, purchased from utilities	kWh	620,316,79	296,381,04	921,722,1.43
Annual Electricity Generation (in-situ), through Diesel Generating	kWh	489,089	178,574	312,760
Annual Renewal Electricity (Solar + Open access)	Kwh	246,350,2	294,729,80	58053006
Total Annual Electricity Consumption, Utilities + DG/GG Sets + Renewal	kWh	649,842,70	592,896,58	675,829,87.07
Annual Cost of Electricity Consumed from utilities :	million INR	554.03	430.86	500.65
Annual Cost of Electricity generated through DG/GG Sets	million INR	45.24	16.51	30.44
Total Annual Electricity Cost, Utilities + DG/GG Sets	million INR	599.27	447.37	531.09
Built Up Area	Sq.Ft	112,000	112,000	112,000
No of floors in the building	Level	G+2	G+2	G+2

Facility consumption trend – Continuous PUE improvement

The facility has been in operation since 2009 and has a design PUE of 1.81, but our constant endeavor and approach to reduce the power usage effectiveness (PUE) continues year after year, thereby we are reducing our carbon footprint and achieve Our target PUE benchmark, basically PUE is a metric used to determine the energy efficiency of Data Center.

PUE Target Achievement Road Map

Design PUE 1.81



Yearly PUE Trend

Year	Target	Achieved
FY 19-20	1.81	1.71
FY 20-21	1.7	1.68
FY 21-22	1.65	1.63
FY 22-23	1.63	1.61

PUE


Lesser PUE

- DC Operators quote lesser PUE's in Technical round
- PUE used for power pay out is quoted separately in Commercial Section else there is administrative charges included
- Some operators giving very aggressive PUE's are on Water Cooled Chillers.

Water Usage Effectiveness

- The world's water usage rises by about 1% every year. which means a 28% increase by the year 2050. Water Scarcity is an impending global problem. Therefore, data centers that use water cooling solutions must work to reduce water usage.
- Water Usage Effectiveness (WUE) is a parameter in the data center that analyzes how efficiently water is being utilized. It has become the natural extension of PUE.

PUE Trend



DC-1 Pune Major Encon Projects FY 22-23

Sr. No	Investment	Invested Value in Million	Annual Electrical saving Million KWH	Annual Electrical cost savings millions
1	4 Nos of 500KVA UPS replaced with New 4*500KVA UPS under EOL Guidelines	Rs. 12	6526	53514.84
2	2 Nos of VFD installation done for water-cooled pumps (160kw)	Rs. 3		
3	2*55 Watt old tube light fittings replaced with new 2*36-watt LED fittings (600nos)	Rs. 1.5		
4	4 Nos of 1150TR water-cooled chiller descaling done	Rs. 0.7		
	Total	Rs.17.2		

Waste utilization and management

WASTE MANAGEMENT

S. No	Type of waste	Quantity	Disposal Method (with Supporting Documents)
1	Hazardous Waste(DG +Transformer Oil)	1.105MT /Year	Wastes are collected, segregated and stored at our inhouse Hazardous storage area. These wastes are disposed Govt approved vendor For Recycling .
2	Battery Waste	45 MT /Annual	Wastes are collected, segregated and stored at our inhouse battery storage area. These wastes are disposed approved vendor.



Form 10 (See rule 19 (1))
Manifest for Hazardous and other Waste

1 Occupier's Name & Mailing Address (including phone No.): STT Global Data Centres India, DC-1, Mowli Road, Pune 411015

2 Occupier's Registration No.: 01/01/2015/10000998

3 Transporter's Name & Address (including phone No.): PLUS LUBRICANTS, Gut No. 228(P1), S.No. 43, Satepada Road, Village Abilghar, Taluka - Wada, Dist. Palghar - 421303, Maharashtra

4 Transporter's Document No.: BO/MPCB/RO(HQ)/KN/CR/B-1901000998

5 Type of vehicle: (Truck/Tanker/Special Vehicle)

6 Vehicle registration No.: MH02ER9341

7 Receiver's name and mailing address (including Phone No. and e-mail): PLUS LUBRICANTS, Gut No. 228(P1), S.No. 43, Satepada Road, Village Abilghar, Taluka - Wada, Dist. Palghar - 421303, Maharashtra

8 Receiver's authorisation No.: MPCB/RO(HQ)/HSMO/Author/19/H&OW-26

9 Waste Description: DG Smear oil filter

10 Facility's Phone: 09820200720 / 022 26665151 Email: pluslubricants@pluslubricants.in

11 Total Quantity: 1.105 MT m³ or MT

12 No. of Containers: 27 nos filter

13 Physical Form: (Solid/Semi-Solid/Sludge/Oily/Tarry/Slurry/Liquid)

14 Special handling instructions and additional information: handle with care.

15 Sender's Certificate: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are categorized, packed, marked, and labelled, and are in all respects in proper conditions for transport by road according to applicable national government regulations.

Signature: Anshu Bhandari, Date: 21/03/2025

Signature: [Signature], Date: 21/03/2025

Signature: [Signature], Date: 21/03/2025

FORM 10
MANIFEST FOR HAZARDOUS AND OTHER WASTE

1 Sender's name and mailing address (including Phone No. and e-mail): STT Global Data Centres India, DC-1, Mowli Road, Pune 411015

2 Sender's authorization No.: 01/01/2015/10000998

3 Manifest Document No.: 138

4 Transporter's name and address (including Phone No. and e-mail): PLUS LUBRICANTS, Gut No. 228(P1), S.No. 43, Satepada Road, Village Abilghar, Taluka - Wada, Dist. Palghar - 421303, Maharashtra

5 Type of vehicle: (Truck/Tanker/Special Vehicle)

6 Transporter's registration No.: BO/MPCB/RO(HQ)/KN/CR/B-1901000998

7 Vehicle registration No.: MH02ER9341

8 Receiver's name and mailing address (including Phone No. and e-mail): PLUS LUBRICANTS, Gut No. 228(P1), S.No. 43, Satepada Road, Village Abilghar, Taluka - Wada, Dist. Palghar - 421303, Maharashtra

9 Receiver's authorisation No.: MPCB/RO(HQ)/HSMO/Author/19/H&OW-26

10 Waste Description: DG Smear oil filter

11 Facility's Phone: 09820200720 / 022 26665151 Email: pluslubricants@pluslubricants.in

12 Total Quantity: 1.105 MT m³ or MT

13 No. of Containers: 27 nos filter

14 Physical Form: (Solid/Semi-Solid/Sludge/Oily/Tarry/Slurry/Liquid)

15 Special handling instructions and additional information: handle with care.

16 Sender's Certificate: I hereby declare that the contents of the consignment are fully and accurately described above by proper shipping name and are categorized, packed, marked, and labelled, and are in all respects in proper conditions for transport by road according to applicable national government regulations.

Signature: Anshu Bhandari, Date: 21/03/2025

Signature: [Signature], Date: 21/03/2025

Signature: [Signature], Date: 21/03/2025

We believe in "waste to wealth" and we adapted the system of segregation and recycling since beginning.


UTILIZATION OF RENEWABLE ENERGY SOURCE

UTILIZATION OF RENEWABLE ENERGY SOURCE and EMISSION Reduction

Year	Total Open Access Renewable Energy Consumption, kWh/Year	Total solar Renewable Energy Consumption, kWh/Year	Total Energy Renewable Energy Consumption(Open Access+Solar), kWh/ Year	CO2 emission avoided, tons of CO2/year
FY20-2021	-	24,63,502	24,63,502	2,020.07
FY21-2022	2,77,19,098	17,53,882	2,94,72,980	24,167.84
FY22-2023	5,51,13,051	29,39,955	5,80,53,006	47,603.46
Total 73791 Ton Carbon Per Year Emission have been Reduced through Renewal Energy				73,791.38



**Co2 Reduction
73791 Tons
/Year**



- 1.Meeting the present demand of our business require us to consume energy—primarily electricity—to power our data centres. Challenging climate change requires the world to changeover to a clean energy. That’s why we have made it a top priority not only to become more energy efficient, but also to ensure the energy we purchase comes from clean sources, such as renewables.
- ST Telemedia GDC India is one of the largest user of renewable energy in India majorly from solar power producer.To date,we’ve contracted to purchase 58053006 ofKWH Per renewable energy for our STT Pune DC-1 facility and objective to reach more than the present usage of renewable energy.
- Through we are looking beyond our business to drive wide-scale adoption of renewable energy. We’re supporting new energy purchasing models such as our pioneering commitment to long-term contracts to buy renewable energy directly from developers (power purchase agreements, or PPAs) and our support of renewable energy purchasing programs with utilities.
- **Green Supply Chain:** STT GDCl is procuring Renewable Energy (Wind & Solar Power) both from onsite & offsite sources (under Open Access route) and year on year has rapidly increased its green power portfolio.
- Presently we are meeting our green power through RE entered with reputed green Power Suppliers.



Off-site Renewal wind energy



GHG EMISSION TREND

GHG EMISSION TREND

CO2e year	Scope 01	Emission factor CO2e / unit = 2.70	Scope 02			Total Emission, CO2 in tons
	Fuel consumed in liters	Total GHG Emission in TCO2e	EB Energy Consumption in kWh	Emission Factor CO2e / unit	Total GHG Emission in TCO2e	
FY 20-2021	1,74,907	473	64872640	0.793	51444	51917
FY 21-2022	1,04,279	282	36530744	0.71	25937	26219
FY 22-2023	1,56,965	425	9402971	0.71	6676	7101



241171 Tons of CO₂

GHG Road Map

DG set operation


Renewal Energy purchase

Optimization in DG set daily test

- ✓ A check frequency test reduced from 2 in Week to once in weekly .
- ✓ Annually 2.16 kL of Diesel consumption reduced.
- ✓ Approx. 5.72Tons of CO₂ emission reduction per Year

RE purchase – Solar and Open access

- ✓ We Purchase Extra 90 % open access Power in 2023
- ✓ 60% energy consumption drawn from Renewal Energy Purchase and on site 2.7 MW Solar power Planform Carbon foot print Reeducation
- ✓ 241171Tons of CO₂ off-set Generation



Sustainable Initiatives for Water Management

Water Saving Details

Description	Units	live	Stand By
CoC Without Nalco		3	3
Avg COC		7.8	7.7
Recirculation Rate	m3/hr	1090	1090
Temp. Diff.	Deg C	4	4
Hours of Operation	Hour	24	24
Evaporation	m3/day	161	161
Total Blowdown With Nalco	m3/day	23.7	24.1
Total Blowdown Without Nalco Nalco	m3/day	80.6	80.6
Total Saving in Blowdown	m3/ day	57	57
Water charges	Rs / m3	28	28
Total cost for Makeup water	Rs/ day	1592	1583
Total Cost for make up water	Rs / month	47,775	47,478
Total annual cost of Make up water	Rs/ year	5,73,299	5,69,734
Saving On Makeup water cost	Rs / year		11,43,033

- Our Data Center facility utilize the common STP commissioned in the Separate zone and The Wastewater are treated in STP and reused back for gardening purpose
- Our Data Center facility is Zero Liquid Discharge
- Our intend and initiatives are inline with Green Campus



STT Global Data Centres India Pvt. Ltd.

Alandi Road, VSNL Old Colony, Digi, Pune, Maharashtra



- Ckt-1 Water Cooled Chiller-1
- Ckt-1 Water Cooled Chiller-2
- Ckt-2 Water Cooled Chiller-1
- Ckt-2 Water Cooled Chiller-2



- Ckt-1 Air Cooled Chiller-1
- Ckt-1 Air Cooled Chiller-2
- Ckt-2 Air Cooled Chiller-1
- Ckt-2 Air Cooled Chiller-2




- Condenser Water System
- Chilled Water System



Home Mimic Water Cooled Chiller Air Cooled Chiller CND System CHW System Water Distribution BTU Meter PLC System

CIRCUIT-1 WATER COOLED CHILLER-2





EVAPORATOR FLOW
ON/OFF COMMAND: ON

EVAPORATOR FLOW
SET POINT: 00.0


Ckt-1 WC Chiller-1 Ckt-2 WC Chiller-1


Ckt-1 WC Chiller-2 Ckt-2 WC Chiller-2

CHILLER STATUS		Chiller Water Setpoint	OTHER COMPRESSOR	
Local Setpoint Control: Local	Remote: Auto	 75 Drive O/P Power 20	High side Oil Pressure	
Run Status: On	Alarm: Inactive		Low side Oil Pressure	
Alarm Reset Command: Inactive	Emergency Stop: Auto		Diff. Refrigerant Pressure	
Compressor Status: Running	Capacity Limited: Not Limited		Oil Diff. Pressure	
Actual Run Capacity: 25%	Actual Current Limit SP: 100%			
Run Time (Hours): 12 Hr				


VOLTAGE		CURRENT	
Phase Voltage R-Y: 415 Volt	Phase Voltage Y-B: 415 Volt	Motor Current-U: 00.0 Amp	Motor Current-V: 00.0 Amp
Phase Voltage B-R: 415 Volt		Motor Current-W: 00.0 Amp	

EVAPORATOR FLOW		CONDENSER SYSTEM	
EVAPORATOR-1 WATER FLOW: 0.0	EVAPORATOR-1 WATER FLOW: 0.0	CONDENSER-1 WATER FLOW: 0.0	CONDENSER-1 WATER FLOW: 0.0
HEADER SUPPLY TEMP: 00.0°C	HEADER RETURN TEMP: 00.0°C	HEADER INLET TEMP: 00.0°C	HEADER OUTLET TEMP: 00.0°C


00.0°C


00.0°C

- ❖ Data Center 33% Energy Utilization By Cooling Infrastructure - Hence our Focus is High on the cooling infra thro Design ,Equipment's selections ,Operation to Achieve Higher Efficiency and Energy Conservation
- ❖ Water Cooled System With Economizer highly Efficient Water-Cooled Chiller offers 0.53 TR for 1KW IT Load
- ❖ Selection of the chiller and all associated Equipment's are with High Efficiency With High Quality
- ❖ Automatic Chiller Building Management System Which Improve The Efficiency and Reduced Manual intervene for Operation sustainability
- ❖ Periodic Energy Audit to Evaluate the Chiller Efficiency and Tracking as well as It's Performance
- ❖ Effective and Periodic Maintenance which Includes Validation of quality of the water and to ensure no water wastages and to ensure the Data Center UPTIME




Sustainable Initiatives of Chiller Plant Descaling Activity @ Pune DC-1

Chiller No	Average Approach Before descaling	Average Approach After cleaning	Difference in AT
	Degree C	Degree C	Degree C
LIVE 2	6.3	2.1	4.2
LIVE 3	6.3	1.7	4.6
SB1	4.1	1.2	2.9
SB2	3.5	1.1	2.4

Energy Performance Saving

Parameter	Units	SB Chiller 1	SB Chiller 2	LIVE Chiller 2	LIVE Chiller 3
Total Chiller Capacity	Tons	1,200	1,200	1,200	1,200
Load	%	82%	90%	91%	88%
Operating Chiller Capacity	TR	984	1,080	1,092	1,056
KW/TR- Design	INR/KW-HR	0.68	0.68	0.68	0.68
Total Kw	KWH	669	734	743	718
No OF Hr.	hrs/day	12	12	12	12
Total KW Per Day	KWH	8,029	8,813	8,911	8,617
No of Day Operation per year	days/year	360	360	360	360
Total Energy Consumption		28,90,598	31,72,608	32,07,859	31,02,106
Increased Approach Without Nalco	Degree C	2.9	2.4	4.2	4.6
1 Degree Increase impacts Cost 3%		9%	7%	13%	14%
KW/TR Due to Increased Approach	Kw/TR	0.74	0.73	0.77	0.77
Total Energy Consumption	INR/year	31,42,080	34,01,036	36,12,049	35,30,196
Excess Energy Consumption	INR/year	2,51,482	2,28,428	4,04,190	4,28,091
Unit Cost/ kW	Rs	8	8	8	8
Grand Total Potential Energy Saving	INR/year	20,11,856	18,27,422	32,33,522	34,24,725
					1,04,97,525



Chilled water 160 KW Pump Technical Evaluation		
Nameplate Parameters (Designed)		
1	Voltage	415
2	Ampere	264
3	PF	0.89
4	Flow (m3/Hr)	726.8
5	Head Mtr	51.8
6	Rated Power KW	160
7	Motor Efficiency	93

Existing Pump Motor Power Consumption

1	Rated Power	Name Plate	160.00	KW
2	Motor Efficiency	Rated	93.00	%
3	Power Drawn	Rated Power/Efficiency	172.04	KW

High Efficiency IE3 Pump Motor Power Consumption

4	Rated Power	Name Plate	132.00	KW
5	Motor Efficiency	Rated	95.00	%
6	Power Drawn	Rated Power/Efficiency	138.95	KW
7	Power Saving	(172 - 138.95)	33.10	KW/Hr
		(33.10 X 8760 x 2 Pumps)	579835.65	KW/Year
8	Electricity Price		8.20	Rs/Kwh
9	Saving	579836 X 8.2	4754652.36	
			47.54	Lac/Year
10	Investment	2 CHW Pump with VFD	130.00	Lac
11	Pay Back Period	Investment/Saving	2.73	Years

Sustainable Initiative for Green and energy saving Equipment Procumbent

- ❑ **Energy efficient LED lights, motion sensor**
- ❑ **Cold Aisle containment for all Server Room to avoid Hot and Cold Air**
- ❑ **Energy efficient transformer, UPS and PAHU**
- ❑ **Common share point is being used at site by team to maintain documents thereby minimizing the usage of hardcopies**
- ❑ **STP treated water using for flushing and garden.**
- ❑ **Best Industrial Safety Awareness Trainings for environmental for best practices**

Server Room Led Light




Server Room Cold Aisle containment



Energy efficient transformer, UPS Server Room



Best Safety Awareness Good Practices



Data Center Equipment's and Environment Air Quality Monitoring Details

- Energy Efficiency best management practices at every level/ through Datacenter life cycle.
- DG Noise and Stack Testing as per CPCB
- Using STP treated water for gardening
- Indoor Environmental Air quality
- Utilization of waste
- Plantation
- Encourage employees to use public/pooled transport

Indoor Environmental Air quality

GREEN ENVIROSAFE Engineers & Consultant Pvt Ltd. A-7/20-11, Capital City, Salade - Chakan Road, Chakan MIDC, P.H.V. Village Nighoj, Tal. Khed, Dist. Pune-410501. Mo: 9540084603, 8421365421. CIN No. U74900P020312P1C140966

Recognized by Ministry of Environment and Forests (MoEF) / Central Pollution Control Board Govt. of India (CPCB) and ISO/IEC 17025:2017 (NABL), ISO 9001:2015, ISO 14001:2015 Certified Company.

TEST REPORT					
Test Report No.:	GESEC/PRO/2023-24/04/265	Date:	24/04/2023	Sample Code:	GESEC/PRO/2023-24/04/265
Name & Address of the Client:	Client Name: M/s. STT GLOBAL DATA CENTRES INDIA PRIVATE LIMITED Address: TATA Communications, Jade, Alandi Road, Dighi, Pune 411015				
INDOOR AIR SAMPLE DETAILS					
Type	Location <th colspan="3">Sampling done by</th>		Sampling done by		
Indoor Air Quality	Ground Floor - Sitting Area		Perfect Pollution Services, Thane		
Date of Sampling	Sample Receipt Date	Analysis Start Date	Analysis End Date		
17/04/2023	19/04/2023	20/04/2023	24/04/2023		
Sample Test Details					
Sr. No	Parameters	Method	Unit	Permissible Limits of Exposures (LLV)	Result
1.	Sulphur Dioxide (SO ₂)	IS 5182 (part-2)-2001 (IS: 2012)	ppm	<5ppm*	BDL
2.	Sulphur Trioxide (SO ₃)	NIOSH-1988	ppm	<5ppm*	BDL
3.	Oxides of Nitrogen (NO _x)	NIOSH-6014-issue-2 Feb1998	ppm	<5ppm*	0.61
4.	Ozone (O ₃)	IS 5182 (part 10)-1974 (IA: 2014)	ppm	0.1ppm*	BDL
5.	Ammonia (NH ₃)	NIOSH 6015-issue-1 Aug1994	ppm	<50ppm*	BDL
6.	Oxygen (O ₂)	NIOSH-6601-issue-Aug 1994	% (v/v)	19.5 to 23.0%	20.8
7.	Temperature	ASTME-337	°C	20°C to 26.0°C	25.5
8.	Relative Humidity	ASTME-337	%	30 to 65%	50
9.	Hydrogen Fluoride (HF)	OSHA-1989	ppm	<3 ppm*	BDL
10.	Chlorine as (Cl ₂)	OSHA 3144-06R2003	ppm	<1 ppm*	BDL
11.	Hydrogen Sulphide (H ₂ S)	NIOSH-1983	ppm	<10 ppm*	BDL

Remark: BDL - Below Detectable Limit.
a-NIOSH- National Institute of Occupational Safety & Health

Mr. Vinod Hande (Technical Manager) Reviewed & Authorized By

Outdoor Environmental Air quality

GREEN ENVIROSAFE Engineers & Consultant Pvt Ltd. A-7/20-11, Capital City, Salade - Chakan Road, Chakan MIDC, P.H.V. Village Nighoj, Tal. Khed, Dist. Pune-410501. Mo: 9540084603, 8421365421. CIN No. U74900P020312P1C140966

Recognized by Ministry of Environment and Forests (MoEF) / Central Pollution Control Board Govt. of India (CPCB) and ISO/IEC 17025:2017 (NABL), ISO 9001:2015, ISO 14001:2015 Certified Company.

TEST REPORT					
Test Report No.:	GESEC/PRO/2023-24/04/255	Date:	24/04/2023	Sample Code:	GESEC/PRO/2023-24/04/255
Name & Address of the Client:	Client Name: M/s. STT GLOBAL DATA CENTRES INDIA PRIVATE LIMITED Address: TATA Communications, Jade, Alandi Road, Dighi, Pune 411015				
AAQM SAMPLE DETAILS					
Type	Location <th colspan="3">Sampling done by</th>		Sampling done by		
Ambient	Near DG Set (Sterling)		M/s. Perfect Pollution Services, Thane		
Start Time	Stop Time <th colspan="3">Total Hrs.</th>		Total Hrs.		
10:30 AM	10:30 AM		24		
Ambient Temperature °C	35.0	Wet Bulb Temperature °C	26.0		
Dry Bulb Temperature °C	35.0	Relative Humidity % RH	47		
Date of Sampling	19/04/2023	Sample Receipt Date	19/04/2023	Analysis Start Date	24/04/2023
Name of Instrument	PFS04114.214.3		Date of Calibration	31-05-2022	
Calibration Certificate No.	TECH/CAL/202205/C/10,11,12		Due Date of Calibration	30-05-2023	
Sample Test Details					
S. No	Parameters	Method	Unit	NAAQ Standards	Result
1.	Sulphur Dioxide (SO ₂)	IS 5182 (PART 2) 2017	µg/m ³	≤ 80	40.5
2.	Oxides of Nitrogen (NO _x)	IS 5182 (PART 6) 2018	µg/m ³	≤ 80	40.2
3.	Particulate Matter PM ₁₀	IS 5182 (PART 4) 2019	µg/m ³	≤ 100	61.0
4.	Particulate Matter PM _{2.5}	IS 5182 (PART 24) 2019	µg/m ³	≤ 60	44.5
5.	Ozone (O ₃) For 1 Hrs.	Method 411, Air Sampling and Analysis 3 rd Edition, 2013	µg/m ³	≤ 180	BDL
6.	Ammonia (NH ₃) For 24 Hrs.	Method 401, Air Sampling and Analysis 3 rd Edition, 2013	µg/m ³	≤ 400	BDL
7.	Carbon Monoxide (CO)	IS 5182 (PART 10) 2019	mg/m ³	≤ 04	0.54
8.	Benzene (C ₆ H ₆)	IS 5182 (PART 11) 2019	µg/m ³	≤ 05	BDL
9.	Benzene(a)P:rene (BaP)	IS 5182 (PART 12) 2019	ng/m ³	≤ 01	BDL
10.	Arsenic (As)	IS 5182 (PART 22) 2019	µg/m ³	≤ 06	BDL
11.	Nickel (Ni)	IS 5182 (PART 20) 2019	µg/m ³	≤ 20	BDL
12.	Lead (Pb)	IS 5182 (PART 22) 2019	µg/m ³	≤ 10	BDL

Remark: > NAAQS-National Ambient Air Quality Standards
> BDL - Below Detectable Limit.

Mr. Vinod Hande (Technical Manager) Reviewed & Authorized By

DG Set Stack Monitoring

GREEN ENVIROSAFE Engineers & Consultant Pvt Ltd. A-7/20-11, Capital City, Salade - Chakan Road, Chakan MIDC, P.H.V. Village Nighoj, Tal. Khed, Dist. Pune-410501. Mo: 9540084603, 8421365421. CIN No. U74900P020312P1C140966

Recognized by Ministry of Environment and Forests (MoEF) / Central Pollution Control Board Govt. of India (CPCB) and ISO/IEC 17025:2017 (NABL), ISO 9001:2015, ISO 14001:2015 Certified Company.

TEST REPORT					
Test Report No.:	GESEC/PRO/2023-24/04/265	Date:	24/04/2023	Sample Code:	GESEC/PRO/2023-24/04/265
Name & Address of the Client:	Client Name: M/s. STT GLOBAL DATA CENTRES INDIA PRIVATE LIMITED Address: TATA Communications, Jade, Alandi Road, Dighi, Pune 411015				
Stack Sample Details					
Stack No.	Location <th colspan="3">Sampling done by</th>		Sampling done by		
12 NEW DG - 1 (220 KVA)	At Stack		Perfect Pollution Services, Thane		
Sample collection Date	Sample Receipt Date <th>Analysis start Date</th> <th>Analysis completed Date</th> <td colspan="2"></td>	Analysis start Date	Analysis completed Date		
20/04/2023	20/04/2023	20/04/2023	24/04/2023		
Name of Instrument	Date of Calibration <th colspan="3">Due Date of Calibration</th>		Due Date of Calibration		
TECH/2023/SNK/06/01	11-01-2024		11-01-2024		
Stack Diameter / Dimensions (m)	Flow Rate (m ³ /hr) <th colspan="3">Gas Velocity (m/hr)</th>		Gas Velocity (m/hr)		
0.3	10.2		10.24		
Temperature (°C)	Sample Test Details				
Sr. No.	Parameters	Method	Unit	Limit	Result
1	Total Particulate Matter (TPM)	IS 5182 (PART 13) 2019	mg/NM ³	≤ 30	30.2
2	Sulphur Dioxide (SO ₂)	IS 1125 (Part 2) 2019	mg/NM ³	≤ 4.0	0.24
3	Carbon Monoxide (CO)	SOP, IS 1125 (Part 2) 2019	mg/NM ³	≤ 4.0	0.60
4	Total Hydrocarbon	IS 5182 (PART 17) 1979 (IA: 2019)	mg/NM ³	≤ 4.0	0.82

Remark: All above results are well within CPCB Limit. (N) Not Specified

12 SET NOISE REPORT					
Sr. No.	Location	Result dB(A)	Result dB(A)	Insertion Loss Result dB(A)	
1.	Open Door	At East	80.3	At East	62.1
	At West	87.8	At West	63.4	
	At North	88.8	At North	60.8	
	At South	89.1	At South	62.8	
Average		87.8	Average	64.6	38.3

Remark: As per CPCB Std Insertion Loss is approx = 25dB

Mr. Vinod Hande (Technical Manager) Reviewed & Authorized By

Synopsis:- Quarterly once indoor air quality measured through third party vendors Ambient air quality monitoring station installation was completed on April'23

Status	CO2 (ppm)
Excellent	0-775
Good	776-865
Satisfactory	866- 955
Moderate	956-1100
Poor	1101-1500
Very Poor	1500-3000

- Green and Smarter Energy Transformation of our Data centers i.e., 55 % of Energy usage on renewable's – Wind, Solar etc & The usage of renewable energy is expected to grow up through our continual PPA approach
- The DG no load test frequency has been reduced, earlier we used to take no load test 2 times a week, after analysis we reduced this and implemented the load trail only once a week, which gives us an estimated 4.3 KL manages to save fuel and have reduce CO2 emissions in environment
- Cooling monitoring of server room through CFD software and proper analysis of cooling requirement in server room, to increase the availability of network and we reduce the incident
- Server room air quality monitoring was done through Corrosion Coupon Test Kit, from which we can know what is the condition of temperature, humidity, silver and copper limit of our server room and whose analysis we can prevent failure of our critical equipment
- Selection a of High efficiency -next generation technology Equipment's such as PDU , CRAC, UPS, Chillers , Led Lights etc to enhance our Energy conservations
- Energy efficient lighting fixtures –LED's Installation Activity
- Strictly adopted hot and Cold Aisle containment into the complete DC raised floor area's i.e., all 1 Lsq. Ft of DC
- Tight concealing of Air GAPS using Stand size of cable cut out openings with cold locks & customized closure method which is implemented at the site where it's clearly witnessing the hot zone is hotter and Cold zone is colder & mix of AIR cold /hot is almost negligible
- Use of Blanking panels on the unused rack space – This is one of the most challenging task due to the racks /Cabinet's ownership with the customers however our constant focus Via Customer education created awareness to them to ensure the blanking panels refix post their work -also we do have daily floor walk thro to get this recheck and fix the blanking panels
- Monthly Cooling Monitoring and analysis Air Requirement in Server Room through CFD simulation and Reduced the unwanted CRAC Unit operation
- Migration of Low Efficiency 2*200KVA UPS In High Efficiency 600kva those are already Working at Low Load After This Migration we Save 10% Power Loss and saving approximate 200 kw Yearly
- Replacement of old Low Efficiency Chiller Pump Motor to High Efficiency IE3 Pump Motor and Saving approximate 579835.65 KWH/Year and 47.54 Lack Per Year
- Potential Energy savings opportunity Via our smart Energy usage and minimising the losses
0.3 mw Potential savings opportunities through energy efficient drive
- Huge reduction on Carbon <CO2> footprint reduction
- Emission During the financial year ended 31 March 2023, our onsite and offsite green energy


Data Center Energy monitoring system

Operation Team Training

- ❖ • We Have Online Real Time energy Monitoring recording and consumption Software SCADA & “Azbil BMS system
- ❖ Daily every morning Email Energy Reports To Energy Manager , Regional Head and DC Manger For Review and Suggestion for Further Implement
- ❖ Additionally manual recording by MST Every Shift in a day
- ❖ Weekly/monthly review meeting of Energy and on going Project for Energy Management and Data Center 100% Uptime by Regional Manager , DC Manger , Energy manger, SMS and Operation Team
- ❖ Periodical review by Higher Management
- ❖ Monthly Operation Team training/familiarization with New learning and Technology on Different topic For Energy saving and 100% Up time management
- ❖ periodic visit by advisor/consultants and advice to technical Recommendation for Energy saving and Reeducation of Carbon Emission
- ❖ The campus has a dedicated Energy Manager.
- ❖ Annual Energy conservation budgets are available for projects that meet the internally laid out NPC criteria.
- ❖ Trainings: Inhouse & external trainings are provided to employees on a regular basis.



Certifications



Vice President - Datacentre Operations
DC Facilities and Energy Team
3rd party Operations

Energy Manager Responsibility

- ✓ • develop and implement an energy policy;
- ✓ • generate management information on energy consumption;
- ✓ • communicate effectively with energy users; • educate staff in energy awareness;
- ✓ • develop housekeeping practices for staff;
- ✓ • identify training needs for energy related matters where necessary;
- ✓ • spot cost-effective opportunities for increasing energy efficiency;
- ✓ • formulate an investment program for reducing energy consumption;
- ✓ • review procedures for establishing the value for money of energy; management activities to senior management.

Energy Manager's Golden Rules


1. Gain control. The first thing is to gain control over energy consumption.
2. Measure how well you are doing. Constantly monitor and record achievements.
3. Report in a simple, clear and relevant way. Provide simple clear reports that match the information managers are used to
4. Share the glory. Ensure that people get praise and credit for their energy savings.
5. Promote your achievements with your senior managers. Publicis your success in order to maintain funding.

BEE Certified Energy Manager – Mr. Nitin Mittal
BEE Certification No-EA – 15647



Function	Responsible Person				
	Director	Mgr A	Mgr B	Asst. C	Asst. D
Measure consumption	▲		■		●
Identify energy cost centres			▲	*	■
Track performance					
Set targets for energy usage					
Develop conservation programme	▲	■		●	
Inspect equipment					
Select projects for improvement					
Allocate budget and resources					
Prepare documentation					
Provide training					
Review new projects for energy efficiency					
Carry out energy management audits					

Key: ▲ Approval Authority ■ Responsible for Work ● Perform Work * Provide Technical Support



Our Certification For Sustainable and Green Data Center Initiatives



DATA CENTRE STANDARDS
ANSI/TIA-942-B:2017
Rated 3 Certified
2017



OPERATIONAL EXCELLENCE
ISO 14001: 2015



OPERATIONAL EXCELLENCE
TL 9000-V R6.2/R5.6



OPERATIONAL EXCELLENCE
ISO 45001 : 2018

CERTAC
Certification & Accreditation
Certificate of Conformance Constructed Facilities
This is to certify that the constructed data center facilities of
STT Global Data Centres India Private Limited
located at

PNQ DCL, Pune-Alandi Road, Dighi
Pune - 411 015, Maharashtra
India

has been independently assessed and found to conform to the requirements of:

ANSI/TIA-942-B:2017
Rated-3

for the following scope:



CERTIFICATE NUMBER: 9120202012270040
Certificate validity: 27-Dec-20 until 26-Dec-23

Surveillance audits due by:

Karin Kok
Certification Manager

Audited by:



This certificate can be verified at www.tia-942.org.
Lack of fulfillment of certification terms and conditions may render this certificate invalid.
This certificate remains the property of Certac Pvt Ltd, to whom it must be returned upon request.
Version 1.0

bsi.
Certificate of Registration
ENVIRONMENTAL MANAGEMENT SYSTEM - ISO 14001:2015

This is to certify that: **STT Global Data Centres India Pvt. Ltd.**
Mumbai - (BKC)
Plot C-21 & C-36, 'G' Block
Bandra Kurla Complex,
Mumbai 400 098
Maharashtra
India

Holds Certificate No: **EMS 737631**
and operates an Environmental Management System which complies with the requirements of ISO 14001:2015 for the following scope:

Providing Data Centre Services.

For and on behalf of BSI:

Theuns Kotze
Theuns Kotze, Managing Director Assurance - IMETA

Original Registration Date: 2017-03-30
Latest Revision Date: 2023-03-27

Effective Date: 2023-03-30
Expiry Date: 2026-03-29

Page: 1 of 4



...making excellence a habit.™

This certificate was issued electronically and remains the property of BSI and is bound by the conditions of contract.
An electronic certificate can be authenticated online.
Printed copies can be obtained at www.bsigroup.com/certification or by telephone +44 (0) 1202 954500.
Further clarifications regarding the scope of this certificate and the applicability of ISO 14001:2015 requirements may be obtained by consulting the organization.
This certificate is valid only if printed original copies are in compliance etc.
Information and Contact: BSI, Knockholt Road, Knockholt, Kent, DA20 3AY, UK. Tel: +44 (0) 1202 954500
BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A Member of the BSI Group of Companies.

CERTIFICATE

This is to certify that

STT Global Data Centres India Private Limited
Plot No. C 21 & C 36, G Block
Bandra Kurla Complex, Vidyanagar P.O.
Mumbai - 400 098
Maharashtra
INDIA

with the organizational units/sites as listed in the annex.

has implemented and maintains a **Quality Management System**.

Scope:
Provision of Data Centre Services across 15 Locations in India.

Product Categories:
e-Business and Content Hosting; 9.6

TL 9000-V R6.2/R5.7 **ISO 9001 : 2015**

TL Id number: 7104
Certificate registration no.: 50251816 TL
Date of original certification: 2016-03-29
Date of certification: 2021-09-14
Valid until: 2024-09-13

DQS Inc.

Brad McGuire
Brad McGuire
Managing Director

Accredited Body: DQS Inc., 1500 McConnor Parkway, Suite 400, Schaumburg, IL 60173 USA
Administrative Office: Deutsch Quality Systems (DQS) Pvt. Ltd., 5th Floor, Avenue Techno Park,
147, HAL Airport Road, Kothrud, Bangalore - 560 017 - India

ISO 45001 Certification



- ISO45001 Internal Auditors Training
- 16 Certified Internal Auditors
- EHS Gap Assessment
- ISO45001 Internal Audits for DC Operations
- ISO45001 Stage 1 Audit
- ISO45001 Stage 2 Audit
- Achieved ISO45001 Certificate

ENVIRONMENT, HEALTH & SAFETY MANAGEMENT SYSTEM (EHS MS) - STT GDC India

Our Certification For Sustainable and Green Data Center Initiatives



OPERATIONAL EXCELLENCE



OPERATIONAL EXCELLENCE



DATA SECURITY

bsi.  

Certificate of Registration

INFORMATION SECURITY MANAGEMENT SYSTEM - ISO/IEC 27001:2013

This is to certify that:

STT Global Data Centres India Pvt. Ltd.
Mumbai - (BKC)
Plot C-21 & C-36, 'G' Block
Bandra Kurla Complex,
Mumbai 400 098
Maharashtra
India

Holds Certificate No: **IS 737629**

and operates an Information Security Management System which complies with the requirements of ISO/IEC 27001:2013 for the following scope:

Information Security Management System for Service Delivery and Support Operations of the Following Data Centre Services.

- Colocation Services
- Remote Hands Services in accordance with the latest Statement of Applicability

For and on behalf of BSI: 
Theuns Kotze, Managing Director Assurance - IMETA

Original Registration Date: 2008-03-27
Latest Revision Date: 2023-03-31

Effective Date: 2023-03-27
Expiry Date: 2025-10-31

Page: 1 of 4

...making excellence a habit.™

This certificate was issued electronically and remains the property of BSI and is bound by the conditions of contract. An electronic certificate can be authenticated [here](https://www.bsi.com/ClientDirectory). Printed copies can be validated at www.bsi.com/ClientDirectory or telephone +91 11 2692 9000. Further clarifications regarding the scope of this certificate and the applicability of ISO/IEC 27001:2013 requirements may be obtained by consulting the organization. This certificate is valid only if provided original copies are in complete set.

Information and Contact: BSI, Kilnburn Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, UK. Tel: +44 345 080 9000
BSI Assurance UK Limited, registered in England under number 7805322 at 389 Chiswick High Road, London W4 4AL, UK.
A Member of the BSI Group of Companies.

bsi.  

Certificate of Registration

IT SERVICE MANAGEMENT SYSTEM - ISO/IEC 20000-1:2018

This is to certify that:

STT Global Data Centres India Pvt. Ltd.
Mumbai - (BKC)
Plot C-21 & C-36, 'G' Block
Bandra Kurla Complex,
Mumbai 400 098
Maharashtra
India

Holds Certificate No: **ITMS 737630**

and operates an IT Service Management System which complies with the requirements of ISO/IEC 20000-1:2018 for the following scope:

The IT Service management system supporting the provision of the following data centre services in accordance with service catalogue

- Colocation services
- Remote Hands Services.

This is in accordance with the latest Service Catalogue.

For and on behalf of BSI: 
Theuns Kotze, Managing Director Assurance - IMETA

Original Registration Date: 2008-03-27
Latest Revision Date: 2023-03-31

Effective Date: 2023-03-27
Expiry Date: 2026-03-26

Page: 1 of 4

...making excellence a habit.™

This certificate was issued electronically and remains the property of BSI and is bound by the conditions of contract. An electronic certificate can be authenticated [here](https://www.bsi.com/ClientDirectory). Printed copies can be validated at www.bsi.com/ClientDirectory or telephone +91 11 2692 9000. Further clarifications regarding the scope of this certificate and the applicability of ISO/IEC 20000-1:2018 requirements may be obtained by consulting the organization. This certificate is valid only if provided original copies are in complete set.

Information and Contact: BSI, Kilnburn Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, UK. Tel: +44 345 080 9000
BSI Assurance UK Limited, registered in England under number 7805322 at 389 Chiswick High Road, London W4 4AL, UK.
A Member of the BSI Group of Companies.

A PCI QSA Firm

NETWORK INTELLIGENCE
Global cybersecurity provider

THIS CERTIFICATE OF COMPLIANCE IS PRESENTED TO

STT Global Data Centres India Pvt. Ltd.

This is to certify that STT Global Data Centres India Pvt. Ltd. has been assessed by Network Intelligence Pvt. Ltd. & was found to be compliant with the PCI DSS version 3.2.1

Nature of the business:
Service Provider

Scope of Work:
Co-Location Services

Locations:
Mumbai-BKC; Plot C-21 & C-36, 'G' Block, Bandra Kurla Complex, Mumbai 400 098, Maharashtra, India
Mumbai-VSB; Lokmanya Vishakh Sanchar Bhavan, Kasturba Shrii Mandi, Opp. Kirti College, Poochardev, Mumbai - 400 028, Maharashtra, India.
Pune-Dighi DCI Pune-Alandi Road, Dighi, Pune 411 015, Maharashtra, India
Delhi-GF DCI & Q-C2; Bhambhania Tower (DCI) & Nertigen Tower (DCI), Opp. Saurthi Cinema Flyover, Greater Kailash - 1, New Delhi 110 048, India.
Chennai-DCI Ambattur 206, Thiruvattar Satellite Earth Station, Road HSK Road, Kalugumam Ambattur, Chennai 600 053, Tamil Nadu, India.
Chennai-DCI VSB; Vishakh Sanchar Bhavan, No. 5, Sivani Sivarama Sathi, Chennai - 600 003, Tamil Nadu, India.
Hyderabad-VSB; Vishakh Sanchar Bhavan, CPC-1, Software Units Layout, Madhapur, Hyderabad 500 081, Telangana, India.
Gurgaon-DCI Building No. 48, Data Centre Building, Gyan Mandi, GFT City, Gurgaon Sector 28-25C, Gurgaon, India.
Kolkata-VSB; Vishakh Sanchar Bhavan, 1/8, C.I.T Scheme VIII-M, Saltlake, Kolkata 700 054, West Bengal, India.
Bangalore-DCI (KIADB); #142, 143, 144 & 145-D, EPID Industrial Area, Sy. No. 307, Hosli Village, KR Puram Hobli, Whitefield, Bangalore - 560 066, Karnataka, India.
Bangalore-DCI (KIADB); #18, 19 & 20, EPID Layout, KIADB, Whitefield, Bangalore - 560 066, Karnataka, India

Date of Assessment: 13th October 2022 Valid till: 12th October 2023

Certification Number: STTG355131022


Vishal Gurule
PCI QSA

NETWORK INTELLIGENCE
The Digital Security Co.

Disclaimer: Network Intelligence Pvt. Ltd. certifies that the above mentioned company has met the requirements of PCI DSS version 3.2.1 as per the scope of the assessment. This certificate is valid only if provided original copies are in complete set. This certificate is not a guarantee of security. The certificate holder is responsible for maintaining the security of their systems and data. Network Intelligence Pvt. Ltd. is not responsible for any data loss or security breach. For more information, please contact us at info@networkintelligence.com or [+91 11 2692 9000](tel:+911126929000).



 **STTelemedia**
Global Data Centres