

Oral Care



Skin Care



Hair Care



Home Care



24th
National Award for
Excellence in Energy Management **2023**
13 - 15 September 2023 || HICC, Hyderabad

Galaxy Surfactants Limited, Taloja

V/23 Industrial Area, Taloja, Navi Mumbai, Maharashtra, 410208

Presented By -

Amit kakkar	General Manager	Amit.kakkar@galaxysurfactants.com
Kunal Waghmare	Manager	Kunal.Waghmare@galaxysurfactants.com
Pragati Kumbhar	Officer	Pragati.Kumbhar@galaxysurfactants.com



GALAXY AT A GLANCE



Leading
Indian manufacturer
of ingredient for
Home & Personal
Care (HPC)
industry

7
Manufacturing
Units Around
the World


Manufactures
210+
Products

Caters to
1400+
Customers

Presence in
80+
Countries

79
Patents
Granted Since
2000

1600+
Employees
across all
our facilities



Transformers: 2 x 2.5 MVA
1 X 1.6 MVA



Coal Boiler : 5 TPH
(Natural Gas Boiler Installation FY 23-24)
Boiler Efficiency – 83 %



Utility Chillers : 1 x 250 TR , 1 x 210 TR

Air Compressor : 2 x 293 CFM with VFD

Thermic Fluid Heater : 1 million Kcal
Max Sanctioned Demand : 3.5 MVA
Load factor : 65-70 %
Power factor : >0.995
(APFC + Harmonic Filters)





Overall Specific Energy Consumption (MWh/MT)



■ Increase ■ Decrease ■ Total


Target is based on 2 Sigma Approach

43.6 % reduction

(last 3-year reduction) 3.3 %

(Target 23-24) 5.3 %

X



- Major Projects:**
- Pump pressure optimization,
 - Temp. setting optimization
 - CT pump reduced flow through VFD Energy efficient pump in V23 WTP (P65A)
 - Optimum flow of 52k3 Ventilex conveyer blower through reduction in motor rpm
 - 10 KWp solar power in V23 admin
 - Project Ushma- Waste Heat recovery

- Major Projects:**
- LED
 - 2 Turbo Blower
 - Canteen Air blower RPM reduced through VFD
 - Stoppage of York chiller
 - GOLD Rotary valve Run time reduction theme
 - Waste heat recovery

- Reason for increase:**
- Replacement of turbo blower
 - Addition of equipment to enhance quality and safety parameter (Project Sure)

- Reason for Decrease:**
- VFD in 12K1
 - ATCS to improve the condenser approach of all Chiller
 - Centralized air compressor
 - BCT reduction in ethoxylation
 - Removal of unwanted equipment
 - Design Modifications.

- Potential:**
- ~0.2 millions KWh**
- Installation of screw blower by replacing root blower (1.12 millions KWh)
 - Separate chiller installation by analyzing load pattern and temperature requirement (0.25 Millions KWh)
 - Energy efficient AHU installation (0.0193 Millions KWh)
 - Online deaeration for formulation (0.174 Millions KWh)
 - Power reduction in Mixer by design modification (0.29 Millions KWh)


0.53 X

2011-12 2012-13 2013-14 2014-15 2015-16 2016-17 2017-18 2018-19 2019-20 2020-21 2021-22 2022-23

2023-24

Electrical Energy (KWh /MT)

Target reduction FY 23-24 – **5.8 %**




- Capacity optimization through proactive Safety concerns
- Addition of equipment to maintain Optimal conditions for reliability, safety and quality

- Increased output with the same energy input.
- Implementation of the EnCON themes

Thermal Energy (Kg/MT)

Target reduction FY 23-24 – **2.3 %**




- Increase output with the same energy input (especially in the Ethoxylates)
- Additional measurement devices
- Implementation of the EnCON themes

Internal benchmarking is among all the sulfation Plant



Location	Year of Commissioning	Specific Energy Consumption
Taloja (L1)	1997	X
Taloja (L2)	2004	0.85 X
Taloja (L3)	2010	0.94 X
Egypt	2011	*0.78 X
Jhagadia (Gujarat)	2018	0.75 X

System Standardization



Energy Management Software

Shift wise Power Consumption - Dashboard

Equipment Status

OFF (Red circle) ON (Green circle) NO Load (Blue circle)

Daily Energy Report (Planned Vs Actual)

Item	Planned	Actual
...
...
...

Limits & Alarm Generation

- Revised Budgeted value
- To Identify En-CON Themes
- Automation
- Provided Interlocks
- Amended SOP's
- Specialized Audits

Power Quality Software

User-friendly Dashboard

Voltage & Current Harmonics


Event Measurement (Alert)

Event ID	Description	Value	Status
1	High alarm	2.50V	Warning
2	SCE Event	Additional Value	Warning
3	SCE Event	Additional Value	Warning


Flickering and Fluctuations

PARAMETERS	STANDARD	ACTUAL VALUE
VOLATGE HARMONICS	5 % THD	2 %
CURRENT HARMONICS	8 % THD	4 %
POWER FACTOR	1	0.999

- System Harmonic level validated
- Breakdown Root cause analysis



User friendly deviation identification



DATA

- Maintenance log and alert
- Hourly & Daily report with recommended actions for Below Average/Critical recommended parameters

Property	Excellent	Below Average/Critical	Recommended actions for Below Average, Critical
Evaporator Flow m3/hr	>127	<114	Chilled water flow rate less than 114 m3/hr. Check the chilled water pump. Make sure the valves are fully open. Check pump amperes. Check pump outlet pressure. Check the chiller performance graphs.

INFO





Chiller Performance index

ACTION



Sigma Air Manager - Compressor

Cloud based Monitoring System- Chiller



■ Furnace Oil ■ Electricity
■ Coal ■ Diesel

**Steam-
50 %**

- Condensate heat recovery
- Boiler efficiency monitoring and control
- Waste heat recovery boiler



**Motor & Pumps-
40.4 %**

- IE3 Motors while procuring new motors
- HPS System based on pressure
- Temperature interlocks with CT fan (PID)
- VFD installation to the variable load
- Dedicated audit for Pumps by Grundfos



**HVAC-
5.7 %**

- KW/TR= 0.55 to 0.65
- Automatic Tube Cleaning System for all chillers
- Separate chiller for low and high temperature equipment
- Continuous monitoring of critical parameters




**Lighting-
1.7 %**

- 100 % LED Installation
- Lighting Energy Saver for lighting system





**Compressed Air-
1.3 %**

- KW/CFM – 0.16
- Centrifugal Compressor Centralize System with VFD
- Air leak detection software
- IOT Software for CBMS



**Process Heating-
0.9 %**




Monitoring Instruments	Nos
Multi Function meters (Equipment level Monitoring)	144
Steam flow Meter (Section Level Monitoring)	12
Compressed Air flow meter (Generation & plant level)	5
Nitrogen (Storage & plant level)	3

Significant Energy Users should comply the EnMS Standard requirements...!!

Target Setting – Plants Level
(2 sigma Approach)




EnCON Project Implemented



Year	No. of Energy saving projects	Investments (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Savings (INR Million)
FY 2020-21	4	0.2	0.093	85	2.8
FY 2021-22	18	11	0.88	2188	20
FY 2022-23	5	3	0.088	1941	7

Project Name - Implementation of Innovative logic for Batch cycle time reduction in the batch mixing vessel by using plate for splashing material.



Thought Process


- Why-1: Why higher vacuum application time is required for removing moisture from RM?**
 Because there is no surface area generation to remove moisture
- Why-2: Why there is not enough surface area generated?**
 Because there is no splashing of Raw material in reactor
- Why-3: Why there is no splashing of material in reactor?**
 Because circulation line in reactor is a dip line.



Benefits-

- ✓ Batch time reduction - **10** min/batch
- ✓ No of batch increased - **330** batches/ Annum
- ✓ Decreased specific energy consumption by **7 %**
- ✓ Annual KWH Savings - **23,100** KWH
- ✓ Production increased by **3000** MT/annum
- ✓ Total savings Rs **1.6** Cr/annum





Heat Pump

1

To save 150 - 200 kW of heat load of boiler by using heat pump

Order has been placed



Screw Blower installation

2

Replacement of lobe blower with screw blower to achieve 35 % reduction

Order has been placed



Energy Efficient AHU

3

PM Motor and efficient Fan for Warehouse AHU

Detailed Engineering Completed



Steam trap monitoring

4

Online monitoring of steam traps

Detailed Engineering Completed

~0.2
millions KWh



Renewable Energy (Taloja Plant)

- ❑ Open Access – **5.64** MWp
- ❑ Inhouse Solar -**314** KWp

TOTAL : ~ 6 MWp
(38 % of Total Ele. Energy)


Renewable Energy Resources –



Rooftop Solar



Solar Water Heater





Sustainability



Scope 1

- Refrigerant Refilling, Coal, Diesel/ Petrol, Fire Extinguisher, FO, HSD, LDO, LPG, Natural Gas, Scrubber Emission

Scope 2



- Purchased Electricity

Scope 3

- Capital Goods & Services
- Upstream transportation & distribution
- Business Travel, Employee Commuting,
- Downstream transportation
- Emission due to waste transportation

Online monitoring Software of GHG

Co2 emission (Ton Co2 / MT)



Sustainability Report 2021-2



- ✓ Climate Change- B-
- ✓ Water Security- B
- ✓ Forest- C



ISO 14064

12041 021



SUSTAINABILITY GOALS 2023-24

sustainability is the way of life



01

Climate Change

- Science Based Target Reducing Scope 1+2 Emissions to 46584 tCO₂e
- Tree plantation Plantation of 10,000 Trees
- Renewable Energy Utilization 25% of Renewable energy in operations



02

Circular Economy

- Waste Mapping Achieving 50% product wise waste mapping.
- Waste Circularity Achieving 15% waste circularity.
- Zero Waste to incineration Ensuring 35% Disposed waste doesn't go to incineration.



03

Water Stewardship

- Water Management System Implementation of Water Management System at all sites by 2030
- Water withdrawal Reduction in Water withdrawal intensity by 7%



- Natural Gas Boiler moving forward towards elimination of coal and furnace oil by 2023-24
- Energy Management horizontal deployment of ISO 50001 :2018



Net Zero Pathway



Science Based Target

X

42 % reduction

0.58X

- 100 % Renewable Energy
- For boilers fuel, shifting from coal to natural gas and bio-mass briquettes
- Energy Efficient equipment seg screw blowers, Heat pumps
- Comprehensive and customized energy audits for more insights

* We are committed to the Science Based Target Initiative in alignment with the Paris Agreement goal to limit the global temperature rise to 1.5 degrees Celsius. Currently, **we are in the target validation process.**

2022-23 2023-24 2024-25 2025-26 2026-27 2027-28 2028-29 2029-30




- Bags Reused - **5** Times
- Instead of **bags** for solid RM, **Tankers** are used for transportation of liquid RM.



RM1

The number of **25 kg** paper bags for RM saved are **13,058**



RM2

By switching from RM 39% to RM 62%, we have avoided **49 IBCs** and **2718 kg of waste**

➤ Projects Planned –


1. Shifting RM 2000PPM entirely to liquid at Taloja.
 2. Transferring RM from HDPE Drums to tankers.
- Maxima IBC : 20IBCs in 20feet container, resulting in 9% reduction in plastic content of IBC inner Bottle




Zero Liquid Discharge Unit since May 2017

- Condensate recovery (>50 %) as condensate sent to boiler.
- MEE has been installed and commissioned in Feb 2020.
- 1.9 tons of waste at sulfation plant was reduced by changing design
- WHRB Capacity = 2* 1 TPH.


Waste Fuel used (MJ)




Waste heat recovery is **26 %**



Type of Hazardous Wastes Generated & Their Methods Of Disposal



Energy Management Cell



- 1 MIS – Status of Energy Saving Project
- 2 Energy performance review- included in MIS and DPR's
- 3 Plant Monthly meeting
- 4 Sustainability Cell Meeting
- 5 Annual Performance Report, Sustainability Report & BRR
- 6 Corporate -Management Review & Quarterly meeting



Strategy Adopted for Awareness creation and Employee Involvement

- Team of 22 Internal auditors available
- 2 BEE Certified Manager
- E-Module on energy conservation and requirements of Energy Management System ISO 50001 : 2018
- Celebration of Energy week
- WESAP – Training
- 16 Major loss- Training
- Energy Policy & Requirements Energy Management System ISO 50001:2018 Video
- Reward and Recognition





Strategy Adopted for Awareness creation and Employee Involvement

The screenshot shows a web-based LMS interface. At the top, there is a search bar and navigation icons. The main content area displays a list of modules under the heading "Showing Modules available to enrol, under All Courses". A sidebar on the left contains filter options for courses and module types. Three modules are visible in the main grid:

- Masterclass - Intellectual Horsepower**: A recording of a masterclass by Sudeep Chhabra. It includes a "Merit Points extra" badge and a rating of 4.39/5.
- Empowerment and Accountability: How Much Rope Should You Give...**: A module with a "Managerial Effectiveness" tag and a rating of 4.46/5.
- Energy Management System- ISO 50001 : 2018**: A module with an "Energy Management System- ISO..." tag and a rating of 4.46/5. This module is highlighted with a green border.

E-Learning on EnMS (LMS)

The screenshot shows a video player interface. The video content displays the "Energy Policy" of Galaxy Surfactants Ltd. The text on the screen reads:

We in Galaxy Surfactants Ltd are committed to establish and implement an effective Energy management system (EnMS) aimed to continual improvement in energy performance, reduce energy consumption and preservation of the environment through the reduction of greenhouse gas emissions through the following policies:

- Create the availability of information and of necessary resources to achieve objectives and targets.
- Comply with applicable legal requirements and other requirements, regulate energy use, conservation and efficiency.
- Provide a framework for setting and reviewing energy objectives and targets.
- Support the purchase of energy efficient products and services, and design for energy performance improvement.
- Ensure continual improvement in our energy performance.
- Consider energy performance improvements in design and modification of our facilities, equipment, systems and processes.
- Commit to invest in people training and development to convey their role in EnMS and positively impact their behaviour contributing to energy objectives and targets.

At the bottom of the video frame, there is a control bar with a play button and a volume icon.

Video on Energy Policy




TPM Based Organization

Captures **16** types of losses



- Equipment Failure (Breakdown) Loss
- Set up & Adjustment Loss
- Cutting Tool/ Blade Change Loss
- Start-up Loss
- **Energy Loss**
- Minor Stoppage & Idling Loss
- Speed Loss
- Defects and Rework Loss
- Shutdown loss (Planned Maintenance Loss)
- Operation Loss
- Operating Stir Loss
- Line Organization Loss
- Distribution/ Logistic Loss
- Measurement & Adjustment Loss
- Consumable Loss
- Yield Loss


WESAP Performance



Successfully Completed **9** Years



Every participation counts...



Involvement of Factory Manager



Appreciation from Vice President



Involvement of all Contractors, Staff & Operators



Implementation of ISO 50001/ Green Co/ IGBC rating



SILVER
2020 - 2023

Energy Management System

Galaxy has adopted structured way of energy monitoring and control through EnMS 50001:2018. The certification was awarded to Taloja plant, India after successful audit conducted by BSI, a certification body.

CII Green Co

Galaxy has adopted the GreenCo rating system at its Taloja plant, India to assess its operations' environmental performance adopting a procedure-based approach. The plant thus became only the 2nd Surfactant unit in the country to achieve this feat.






Award & Achievements



7th Edition of CII National Energy Efficiency Circle Competition

Certificate No. EC23/A77





Save Today for Tomorrow Survival

Thank You !!

Amit kakkar- General Manager

Mob : 9867963066

Email : amit.kakkar@galaxysurfactants.com