

Grasim Industries Ltd. Chemical Division, Rehla

WELCOMES

**National Award for Excellence
In Energy Management-2023**



Presented By:-

- ❖ Mr. Deepak Sharma
General Manager
- ❖ Mr. Suraj Pandey
Sr. Manager- CPP
- ❖ Mr. Bijendra Kumar
Manager- CAP

Unit at a Glance - Introduction

Manufacturing Process

Energy Consumption in Last Three Years

Information on Competitors

Energy Saving Projects Implemented in last Three Years

Innovative Projects Implemented

Utilization of Renewable Energy /RPO obligation

GHG Inventorisation and Green Supply Management

EMS and Other Informations


Unit at a Glance-Brief Introduction



Business	“CHLOR ALKALI”
Unit	GRASIM INDUSTRIES LTD Chemical Division
Location	Ghanshyam Kunj, Rehla, Distt. Palamau, Jharkhand – 822124
Product	Caustic Soda (NaOH), Liquid Chlorine (Cl₂), Hydrochloric Acid (HCl), Sodium Hypochlorite (NaOCl), Compressed Hydrogen Gas, Aluminium Chloride Anhydrous, Stable Bleaching Powder (SBP), Caustic Soda Flakes, Dilute Suphuric Acid.
Capacity	(300 TPD -UDHE -1984) + (250 TPD -AKCC 2021)
Power Source	Captive Power Plant: (Thermal Coal Based) <ul style="list-style-type: none"> • TPP-1 : 1x30 MW Commissioned in 2000 • TPP-2 : 1x30 MW Commissioned in 2014
Certifications	<u>ISO-9001, ISO-14001, ISO 45001, SA-8000, ISO 50001, ISO 27001</u>

City	Distance by Road (KM)
Ranchi	203
Patna	254
Kolkatta	632
Varanasi	230

Manufacturing Process



Technologies, Equipments and Facilities:

Caustic Soda Plant :

Environmentally friendly and State of Art Membrane Cell Technology for manufacturing of Caustic Soda.


Sea salt (NaCl) after purification in solution form is electrolyzed by using Direct Current to produce Caustic Soda, Chlorine and Hydrogen.

Power Plant configuration:

- 1x135TPH CFBC Boiler (Thyssen Krupp)+1x30MW Steam Turbo-Generator (BHEL)
- 1x150TPH CFBC Boiler (ISGEC) + 1x30MW Co-gen Steam Turbo- Generator (BHEL)

Value Added Products :

- **Aluminium Chloride:** A value added product of Chlorine in powder and granule form used in Pharmaceuticals, Pesticides, and Dyes & Pigments industries.
- **Stable Bleaching Powder:** This product has competitive edge over the market in the segment of pulp and paper, Textiles, Carpet , Water Treatment, Sanitation etc




- ❖ **2008** : The company became subsidiary of M/s Hindalco Industries Limited.
- ❖ **2009**: Name of the Company was changed from Bihar Caustic & Chemicals Limited, to Aditya Birla Chemicals (India) Limited, Rehla
- ❖ **2016**: ABCIL merged into Grasim Industries limited as Chemical Division.

Product Portfolios

Products	Unit	1984 - 85	2006-07	2008-09	2010- 11	2016-17	2019-22
Caustic Soda	TPD	100	225	300	300	300	550
Chlorine	TPD	40	100	160	160	190	488
HCl (100%)	TPD	50	100	100	100	70	180
Aluminum Chloride	TPD	-	-	32	41	41	65
Stable Bleaching Powder (SBP)	TPD	-	-	48	48	62	80
Caustic Soda Flake	TPD	-	-	-	-	100	200


Energy Consumption (Overall)

CAUSTIC PRODUCTION VS ENERGY CONSUMPTION




Specific Energy Consumption

CAUSTIC PRODUCTION VS ENERGY CONSUMPTION




Energy Consumption (Source wise)

CAUSTIC PRODUCTION VS THERMAL ENER. CONS.



CAUSTIC PRODUCTION VS ELECTRICAL ENER. CONS.



Cell Power : Is defined as the total power utilized directly in process of electrolysis.

Factors Effecting Cell Power :-

- Aging of Membrane – 15 kWh/ton of Caustic, Remembraning in a duration of 4Years
- Coating Depletion for Anode and Cathode Pans, Recoating in a duration of 8 Years.
- Higher Current Density Operations.
- Generation of Electrolysers
 - Gen IV – 2180 KWh/ton @ 4.75 CD
 - Gen V – 2030 KWH/ton @ 4.75 CD
 - Gen VI – 2005KWh/ton @ 5.00 CD

Aux Power : Is defined as the additional power required for associated equipment's.

Factors Effecting Aux Power :-

- HCL and Liquid Chlorine production percentage.
- Power associated with utility, Cooling Water and Chilled Water.
- Media for Liq. Chlorine pumping.

Units	FY22		FY 23	
	Target (Kwh/Mt)	Actual (Kwh/Mt)	Target (Kwh/Mt)	Actual (Kwh/Mt)
Nagda	2188	2227	2187	2218
Rehla	2101	2083	2083	2081
Renukoot	2113	2127	2106	2081
Vilayat	2174	2187	2132	2149
Karwar	2104	2117	2234	2242
Ganjam	2189	2113	2135	2083

ENERGY SAVING PROJECTS IMPLEMENTED IN LAST THREE YEARS

Sr. No	Year	No of Energy Saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal Savings (Million Kcal)	Total Savings (INR Million)	Payback period (in months)
1	2020-21	6	15.08	1.76	432	22.02	8.22
2	2021-22	6	19.71	3.34	0	14.13	16.74
3	2022-23	9	24.76	1.61	32298.82	71.29	4.17
	Total	21	59.55	6.71	32730.82	107.44	

ENERGY SAVING PROJECTS IMPLEMENTED IN FY-2020-21

Sr. No	Name of Energy saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)	Payback period (in months)
1	Conventional Light to LED light Replacement	1	0.02	0	0.132	0
2	Unit #01 –CPP- Heat Rate Reduction (Heat Exchanger Leakage Rectification and Condenser Cleaning)	1	0	432	5.326	2.40
3	Unit #01 ASD work on Airpower Optimization (ID Fan impeller replacement & APH tubes replacement)	1.4	0.1012	0	2.904	6
4	Remembraning of one 6th generation Electrolyzer F	11.68	0.098311	0	4.56	33
5	PLF optimization-CPP 02 One MCW Pump stopping on part load	0	0.7359	0	4.356	0
6	PLF optimization- CPP 02 One ID Fan stopped on part load	0	0.8028	0	4.75	0

ENERGY SAVING PROJECTS IMPLEMENTED IN FY-2021-22

Sr. No	Name of Energy saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)	Payback period (in months)
1	CAP- Remembraining of Electrolyzer A- Energy saving project	12.41	1.13	0	4.2	36
2	Conventional Light to LED Replacement	0.3	0.03	0	0.15	0
3	Unit-1 ACW PUMP stopped by provision of interconnection	0	0.30	0	1.37	0
4	Unit-1 BFP-1 operation made with DP, Unit-1 BFP-1 pressure Control closed loop taken in Auto with assured DP>7kg/cm2	0	0.22	0	1.00	0
5	Instrument Air compressor stop by provision of interconnection with Unit-1	0	0.41	0	1.85	0
6	Unit-2, BFP-1 Replaced with energy efficient Pump.	7	1.23	0	5.53	16.79

ENERGY SAVING PROJECTS IMPLEMENTED IN FY-2022-23

Sr. No	Name of Energy saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)	Payback period (in months)
1	Cl2 Compressor @ 80 TPD as standby for MC1 for combination run	3.7	528000	0	4.166	9
2	Chilled water pump Motor rating changed from 90 KWH to 55 KWH	2.1	231000	0	1.823	24
3	VFD Installed in Buffer pump B	3.7	396000	0	3.124	12
4	CPP-2, CT cells-1&3 Fins replaced,- heat rate has been reduced by improvement of vacuum	1	0	3207.6	5.817	2.40
5	Unit #01 HP Heater partition plate leakage arresting work done in first week of Apr-22	2	0	4752	8.617	3
6	TG-2 Condenser tube cleaning done in ASD	1	0	712.8	1.293	12

ENERGY SAVING PROJECTS IMPLEMENTED IN FY-2022-23

Sr. No	Name of Energy saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)	Payback period (in months)
7	CPP-2 BFP-2 Replaced with energy efficient pump	3	231000	0	1.823	36
8	Boiler-2 APH tube replaced during annual shutdown in Jun-22	3	231000	0	1.823	36
9	CPP-2 Turbine Major Overhauling carried out in Jun-22	5.26	0	23626.42	42.84	1.42

LIST OF MAJOR ENCON PROJECTS PLANNED FOR FY-2023-24

Sr. No	Year	Title of Project	Annual Electrical Saving	Annual Thermal Saving	Investment	Current Status
			(Million kWh)	(Million Kcal)	(Rs in Million)	
1	2023-24	CPP-1 Boiler feed pump Replaced with energy efficient pump	0.726	0	7	<u>Implemented</u>
2	2023-24	CPP-1 All condenser tube replaced (7500)	0	9166.3	24.74	<u>Implemented</u>
3	2023-24	Boiler-1 APH tube replaced during annual shutdown	1.606	0	3.11	<u>Implemented</u>
		TOTAL	2.332	9166.3	34.85	

Major Energy Saving Projects planned

Sr. No	Year	Name of Energy saving Projects	Investment (INR Million)	Electrical savings (Million kWh)	Total Savings (INR Million)	Payback period (in Year)
1	FY24	Electrolyser "C" Remembering Generation IV	15	0.96	4.8	3.12
2	FY25	Conversion of Electrolyser "C" from IV to latest VI Generation	240	6.51	39.1	6.14
3		Electrolyser "D" Remembering, Generation VI	15	0.96	4.8	3.12
4		Electrolyser "E" Remembering, Generation V	15	0.96	4.8	3.12
5	FY26	Electrolyser "A" (UHDE) Remembering and Recoating, Generation VI	95	4.62	23.1	4.11
6		Electrolyser " F " (UHDE) Remembering and Recoating, Generation VI	95	4.62	23.1	4.11
7		Electrolyser " A " (AKCC) Remembering, Generation VI	19	1.05	5.3	3.62
8		Electrolyser " B " (AKCC) Remembering, Generation VI	19	1.05	5.3	3.62
9		Electrolyser " C " (AKCC) Remembering, Generation VI	19	1.05	5.3	3.62

Project-1- Boiler drum level maintaining through feed pump BIAS Logic

❑ Theme:-

- Boiler Feed pump operation through BIAS logic

❑ Problem Statement:-

- Higher power consumption of BFP
- BFP contributes about 25-30% of the total


❑ Solution:-

- Made a BIAS logic for close loop operation of BFP
- Feed control valve kept full open & reduced DP

❑ Out Come

- Power Saving:- 2.23 Lacs Kwh /annum.
- Cost Saving- :- 13.39 Lacs/annum.

Project-1- Boiler drum level maintaining through feed pump BIAS Logic



Project-2- Replacement of VAM machine with electric chiller

❑ Theme:-

- Replacement of VAM machine with electric chiller

❑ Problem Statement:-

- Higher steam consumption
- More expensive

❑ Solution:-

- Replaced VAM machine with electric chiller

❑ Out Come

- Cost Saving- :- 119 Lacs/annum.

Project-2- Replacement of VAM machine with electric chiller

Previously used VAM to generate Chilled Water in CSP Plant which was high steam consuming and now Replacement of VAM Machine with Electrical Chiller.

VAM Unit

Before

After

Electrical Chiller



COMPARISON

BENEFIT




	VAM	Chiller
Steam Consumption	36 MT/Day	Nil
Power Consumption	Nil	5200KWH/Day
Total Operating cost(RS/Day)	72000/-	39000/-
Saving(Lakh)	0.33L/- Per day & Annual Saving-119 L/Year	

SL NO.	BENEFITS OF ELECTRIC CHILLER
1	Easy Operation and more efficient
2	Low maintenance Cost
3	Chemical consumption zero
4	Pollution level is less as compared to VAM
5	Low initial set-up cost
6	No crystallization problem

Project-3- Industry 4.0 Implementation- Automation & Digitization

A new dimension to Process Optimization through Process Score Card.

Central Manufacturing Cockpit, Grasim Chemical Division													
RHL Process Score Card Report V2													
Unit-01		Date		11-09-2023									
		Unit Load	MW	26.68	28.33	28.13							
		Running Hours	Hours	8.00	8.00	8.00							
		PLF	%	88.92	94.43	93.77							
		Shift		A	B	C							
#	Process Parameter	UOM	Baseline	tolerance Lim	eight	actual paramete	Score	actual paramete	Score	actual paramete	Score		
1	MS Inlet Temp-boiler	°C	485	480 to 490	5	488.42	5	486.83	5	484.89	5		
2	MS Pressure-boiler	kg/cm'	66	64 to 67	5	66.01	5	65.62	5	65.47	5		
3	SPM in flue gas	mg/Nm'	<100	20 to 100	5	40.20	5	40.61	5	40.64	5		
4	Condenser vacuum	kg/cm'	-0.900	-0.890 to -0.915	5	-0.891	5	-0.879	0	-0.88	0		
5	Steam to CAP temp.	°C	195	185 to 210	5	190.79	5	191.50	5	192.34	5		
6	Steam to CAP press.	kg/cm'	12	8 to 16	5	11.38	5	11.71	5	12.10	5		
7	Economiser Feed water Inlet Temp.	°C	180	165 to 182	5	176.72	5	179.02	5	178.76	5		
8	Bed temperature	°C	890	850 to 910	5	883.77	5	883.85	5	882.34	5		
9	Furnace pressure	mmwC	-30	-40 to -15	5	-24.30	5	-24.95	5	-24.95	5		
10	Generator Winding Temp. #	°C	95	90 to 105	5	90.03	5	95.925	5	95.008	5		
11	Specific steam consumption	ton/MW	4.1	3.5 to 4.25	5	4.13	5	4.15	5	4.16	5		
12	Primary air temp after APH	°C	255	240 to 270	5	236.33	0	241.49	5	242.63	5		
13	Secondary air temp after APH	°C	260	240 to 275	5	247.78	5	250.26	5	250.04	5		
14	Oxygen level in flue gas	%	3.5	2.5 to 4.5	5	3.37	5	3.00	5	3.30	5		
15	C/W I/L temp	°C	33	20 to 36	2	34.13	2	35.30	2	35.02	2		
16	C/W outlet temp	°C	42.4	22 to 44	2	42.84	2	44.43	0	44.16	0		
17	Flue gas exit temp	°C	145	120 to 145	2	139.59	2	142.82	2	141.98	2		
18	Unburnt in bottom ash. #	%	4	0 to 6	2	0.29	2	0.181	2	0.18	2		
19	Unburnt in fly ash #	%	1.6	0 to 2.5	2	3.17	0	3.30	0	3.30	0		
20	Sp. Power Consumption(CHP)	kWh/ton	2	0 to 2.5	4	0.10	4	1.74	4	-1222.82	0		
21	Sp. Power Consumption(Boiler)	kWh/ton	16	0 to 17	4	12.80	4	12.45	4	6.04	4		
#	Sp. Power Consumption(Turbine)	kWh/MW	23	0 to 25	4	23.18	4	20.77	4	10.08	4		
#	Sp. Power Consumption(ESP)	kWh/MW	1.8	0 to 2	4	0.94	4	0.84	4	0.41	4		
#	Sp. Power Consumption(Compressors)	kWh/MW	5.2	0 to 8	4	8.09	0	7.24	4	3.11	4		
						Grand Total	100	Process Score	83	Process Score	81	Process Score	87



Objectivity

- Process Optimization

Scope

- SIPOC, Process criticality, Parameters criticality, Benchmarking, Shift Score Card
- Shift wise monitoring and control to maintain Shift Score

Area of Benefits


- Optimization of Plant heat rate (**PHR**) of Power plant
 - by maintaining parameters affecting Boiler efficiency (Flue Gas temp, UBC, O2 etc)
 - Steam Turbine Hear Rate (MSP, MST, SSC, FWT, Vacuum etc)
- Optimization Auxiliary power consumption (**APC**) of power plant
 - ESP (700 kwh/day)
 - Coal Handling Plant (400 kwh/day)
 - Unit & Equipment Combination, Fans & Pumps (900 kwh/day)
 - Compressors (200 kwh/day)

BFP Replaced in FY-April 21

- **Description**-High Power consumption & low efficiency of Old BFP.
- **Goal**-To Reduction of Specific Power consumption of Boiler feed Pump.
The Feed water flow is controlled only through Feed Control Station. The old BFP design head is 1720 m against the requirement of 110 kg/cm² in Boiler Drum.
- **Solution**-Replacement of old BFP with High energy efficient BFP having low head
- **Benefit**- Auxiliary power consumption directly reduced.
- The design data of BFP is shown below.

DATA	OLD BFP	NEW BFP
FLOW	196 M3/HR	170 M3/HR
HEAD	1720 (MTR)	1500 MTR
KW	970	833
DESIGN EFFICIENCY	68%	76%
	Before implementation	After Implementation
	Energy Consumed=24858 kwh/day	Energy Consumed=21281 kwh/day
Full LOAD SAVING IN RS.	=(24858-21281)*335day&4rs/kwh= 47.93 Lac Rs/Annum	


- ✓ Plant is located in Jharkhand state
- ✓ Availability of indigenous coal mines
- ✓ Study for Solar Plant done-10 Mw.
- ✓ Capex Proposed for Solar Plant
- ✓ 100 % Compliance of RPO
- ✓ 100 % PAT Compliance
- ✓ Best performed in PAT-2 Cycle
- ✓ Get 9978 Escort Certificates



GHG Inventorisation

Reduction of GHG emission 26.08% from FY20-21

Year	Total Kg CO2/Ton of Final Product
20-21	4617.971 Kg CO2/T
21-22	3734.692 Kg CO2/T
22-23	3333.230 Kg CO2/T




Competitors Carbon Intensity:-


- 1) GRCD-RENUKOOT – 3.3 (t GHG/MT)
- 2) GRCD-VERAVAL – 3.3 (t GHG/MT)*

The less you burn, the more you earn

Green Supply Chain Management Carbon footprint Reduction



- Well Established Energy management cell.
- EMS is available for Energy Monitoring .
- Daily monitoring of Plant KPIS and comparing with benchmarks Nos
- Benefits analysis after project implementation
- Analysis of equipment performance for deviation
- Identification of energy conservation project/work
- Theme base suggestions/Kaizens scheme under
- Feasibility study of suggestions & proposal submission



Grasim Industries Limited-Rehla

National Energy Conservation Day Celebration- 14 Dec-2022



Energy & Carbon Team GRCD-Rehla

Grasim Industries Limited-Rehla

National Energy Conservation Day Celebration- 14 Dec-2022



Distribution of Pamphlets and Badges

Grasim Industries Limited-Rehla

National Energy Conservation Day Celebration- 14 Dec-2022



Training and Awareness Session Glimpses- Total 110 Employees Participated

Approach / Deployment

Operational Excellence

- Focus on to Improve Basic Condition through Gemba Walk
- Development of Ownership Culture
- Enhancement of people participation

IMS - Multi-site Certification of ISO 9001 /14001 /45001 / 50001/ 27001 & SA 8000)

- Unit have ISO 9001 / 14001 / 45001 /50001/27001 & SA 8000 Certification
- Documented Information Management i.e. Procedures, Work Instructions, SOPs, SMPs continue review and new update in view of Energy Management System (ISO 50001)

ISO -Certifications

Certificate ISO 9001

Certificate ISO 14001

Certificate ISO 45001

Certificate ISO 50001

CERTIFICATE

Management system as per
ISO 9001 : 2015

The Certificate Body TÜV NORD CERT Grant hereby certifies as a result of the audit, assessment and verification activities according to ISO 9001:2015, that the organization:

GRASIM INDUSTRIES LIMITED
Corporate Office
Birla Aaram Tower, 10th floor, Near Century Square,
Dr. Ambedkar Road, Worli Mumbai - 400 030,
Maharashtra,
India

operates a management system in accordance with the requirements of ISO 9001: 2015 at the location:

GRASIM INDUSTRIES LIMITED,
Chemical Division, Raha
Gurham Road, P. O. Raha - 822 124,
District: Palamu Jharkhand,
India

will be assessed for conformity within the 3 year term of validity of the certificate.

Manufacture and Dispatch of Caustic Soda Lye and Flakes, Liquid Chlorine, Sulphuric Acid, Hydrochloric Acid, Compressed Hydrogen Gas, Stable Bleaching Powder, Sodium Hypochlorite and Aluminium Chloride, Captive Power Generation

Certificate Registration No. 44 014 2239449-002 Valid from 28.06.2023
Audit Report No. 2.6-198692021 Valid until 28.06.2026
Initial certification 07.03.2020

Certificate Body at TÜV NORD CERT GmbH, Munich, 88 48 2023

This certificate is valid in conjunction with the main certificate.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



CERTIFICATE

Management system as per
ISO 14001 : 2015

The Certificate Body TÜV NORD CERT Grant hereby certifies as a result of the audit, assessment and verification activities according to ISO 14001:2015, that the organization:

GRASIM INDUSTRIES LIMITED
Corporate Office
Birla Aaram Tower, 10th floor, Near Century Square,
Dr. Ambedkar Road, Worli Mumbai - 400 030,
Maharashtra,
India

operates a management system in accordance with the requirements of ISO 14001 : 2015 at the location:

GRASIM INDUSTRIES LIMITED,
Chemical Division, Raha
Gurham Road, P. O. Raha - 822 124,
District: Palamu Jharkhand,
India

will be assessed for conformity within the 3 year term of validity of the certificate.

Manufacture and Dispatch of Caustic Soda Lye and Flakes, Liquid Chlorine, Sulphuric Acid, Hydrochloric Acid, Compressed Hydrogen Gas, Stable Bleaching Powder, Sodium Hypochlorite and Aluminium Chloride, Captive Power Generation

Certificate Registration No. 44 104 2239449-002 Valid from 28.06.2023
Audit Report No. 2.6-198692021 Valid until 28.06.2026
Initial certification 16.11.2012

Certificate Body at TÜV NORD CERT GmbH, Munich, 88 48 2023

This certificate is valid in conjunction with the main certificate.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



CERTIFICATE

Management system as per
ISO 45001 : 2018

The Certificate Body TÜV NORD CERT Grant hereby certifies as a result of the audit, assessment and verification activities according to ISO 45001:2018, that the organization:

GRASIM INDUSTRIES LIMITED
Corporate Office
Birla Aaram Tower, 10th floor, Near Century Square,
Dr. Ambedkar Road, Worli Mumbai - 400 030,
Maharashtra,
India

operates a management system in accordance with the requirements of ISO 45001 : 2018 at the location:

GRASIM INDUSTRIES LIMITED,
Chemical Division, Raha
Gurham Road, P. O. Raha - 822 124,
District: Palamu Jharkhand,
India

will be assessed for conformity within the 3 year term of validity of the certificate.

Manufacture and Dispatch of Caustic Soda Lye and Flakes, Liquid Chlorine, Sulphuric Acid, Hydrochloric Acid, Compressed Hydrogen Gas, Stable Bleaching Powder, Sodium Hypochlorite and Aluminium Chloride, Captive Power Generation

Certificate Registration No. 44 104 2239449-002 Valid from 28.06.2023
Audit Report No. 2.6-198692021 Valid until 28.06.2026
Initial certification 06.08.2019 (ISO 45001:2018)

Certificate Body at TÜV NORD CERT GmbH, Munich, 88 48 2023

This certificate is valid in conjunction with the main certificate.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



CERTIFICATE

Management system as per
ISO 50001 : 2018

The Certificate Body TÜV NORD CERT Grant hereby certifies as a result of the audit, assessment and verification activities according to ISO 50001:2018, that the organization:

GRASIM INDUSTRIES LIMITED
Corporate Office
Birla Aaram Tower, 10th floor, Near Century Square,
Dr. Ambedkar Road, Worli Mumbai - 400 030,
Maharashtra,
India

operates a management system in accordance with the requirements of ISO 50001 : 2018 at the location:

GRASIM INDUSTRIES LIMITED,
Chemical Division, Raha
Gurham Road, P. O. Raha - 822 124,
District: Palamu Jharkhand,
India

will be assessed for conformity within the 3 year term of validity of the certificate.

Manufacture and Dispatch of Caustic Soda Lye and Flakes, Liquid Chlorine, Sulphuric Acid, Hydrochloric Acid, Compressed Hydrogen Gas, Stable Bleaching Powder, Sodium Hypochlorite and Aluminium Chloride, Captive Power Generation

Certificate Registration No. 44 104 2239449-002 Valid from 28.06.2023
Audit Report No. 2.6-198692021 Valid until 28.06.2026
Initial certification 07.03.2020

Certificate Body at TÜV NORD CERT GmbH, Munich, 88 48 2023

This certificate is valid in conjunction with the main certificate.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



Certificate SA 8000

Certificate ISO 27001

CERTIFICATE

Management system as per
ISO/IEC 27001 : 2013

The Certificate Body TÜV NORD CERT Grant hereby certifies as a result of the audit, assessment and verification activities according to ISO/IEC 27001:2013, that the organization:

GRASIM INDUSTRIES LIMITED
Corporate Office
Birla Aaram Tower, 10th floor, Near Century Square,
Dr. Ambedkar Road, Worli Mumbai - 400 030,
Maharashtra,
India

operates a management system in accordance with the requirements of ISO/IEC 27001 : 2013 at the location:

GRASIM INDUSTRIES LIMITED,
Chemical Division, Raha
Gurham Road, P. O. Raha - 822 124,
District: Palamu Jharkhand,
India

will be assessed for conformity within the 3 year term of validity of the certificate.

Information Security Management System (ISMS) Applies to Manufacturing and Dispatch of Chlorinated Products (COP), Value Added Products (VAP) and Various Polymer Fibre (VPF) Supported by Packaging and Shipping Services Involving: Storage, Distribution, Physical Security, Access and

Certificate Registration No. 44 104 2239449-006 Valid from 28.06.2023
Audit Report No. 2.6-198692021 Valid until 28.06.2026
Initial certification 08.08.2023

Certificate Body at TÜV NORD CERT GmbH, Munich, 88 48 2023

This certificate is valid in conjunction with the main certificate.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



CERTIFICATE

Management system as per
SA 8000 : 2014

In accordance with TÜV NORD CERT procedures, it is hereby certified that:

GRASIM INDUSTRIES LIMITED
Chemical Division, Raha
Gurham Road, P.O.Raha,
Dist. Palamu - 822 124, Jharkhand,
India

operates a management system in line with the above standard for the following scope:

Manufacture and Dispatch of Caustic Soda Lye and Flakes, Liquid Chlorine, Sulphuric Acid, Hydrochloric Acid, Compressed Hydrogen Gas, Stable Bleaching Powder, Sodium Hypochlorite and Aluminium Chloride, Captive Power Generation
Primary Processes include Salt Pile/Leach, Salt Drying, Salt Sublimation, Brine Purification, Brine Clarification, Electrolysis, Chlorine Gas Purification, Chlorine Lye, Chlorine Concentration, Chlorine Flaking, Chlorine Drying, Chlorine Aqueous Salt Brine, Standard, Raha

Certificate Registration No. 44 114 2239449-003 Valid from 16.01.2023
Audit Report No. 2.6-198692021 Valid until 16.01.2026
Initial certification 10.06.2020

Certificate Body at TÜV NORD CERT GmbH, Munich, 14877-2023

This certificate is valid in conjunction with the main certificate and is subject to TÜV NORD CERT audit procedures and to regular surveillance audits.

TÜV NORD CERT GmbH, Am TÜV 1 4007 Essen, www.tuvnordcert.com
TÜV India Pvt. Ltd., Bengaluru - 1, L.S.B. Marg, Chokkikulam (2), Mumbai - 400 086, India, www.tuvnordcert.com



Year	Awards & Accolades
2023	NABL Certification for Finished products (Caustic Lye, Flakes, Hydrochloric Acid, Sodium Hypochlorite & Stable Bleaching powder)
2023	Unit got Various Awards among ABG-DCA business in Performance excellence league – May-2023
2023	Award for Top Performer in PAT Cycle -2 by BEE – New Delhi
2019	Energy Efficient Unit Award By – CII-Hyderabad
2019	National Energy Conservation Award 2019 by Bureau of Energy Efficiency, Ministry of Power (Government of India)
2017	Eminent Award-2017 -in Platinum Category for “Economic & Social Development” by “EK Kaam Desh Ke Naam”, New Delhi for the year 16-17.
2017	Award for Top Performer in PAT Cycle -1 by BEE – New Delhi
2013	12th Annual Green Tech Safety awards by Green Tech Foundation, New Delhi

Year	Awards & Accolades
2012	Agro Tech Award by Birsa Agriculture University for Watershed Development in Jharkhand
2012	Greentech Gold award in Environment Excellence by Green Tech Foundation, New Delhi
2012	Industry 2.0 Manufacturing Leadership Award in Energy efficient in Manufacturing
2012	ICC Award for Excellence in Social Responsibility by Indian Chemical Council, Mumbai
2011	Chairman's WCM Gold Awards by the Chairman among ABG group of Company
2010	Best Prax Benchmarking Compass Trophy 2010 by Global Bench Marking Network, Mumbai
2008	IMC Ram Krishna Bajaj National Quality Award Trophy by IMC, Mumbai
2009	Green tech Environmental Excellence Gold Award by Green Tech Foundation, New Delhi
2007	Green Tech Safety Excellence Gold Award by Green Tech Foundation, New Delhi



THANKS !!!...