



सदैव श्रेष्ठतम
मथुरा रिफाइनरी

Indian Oil Corporation Limited Mathura Refinery

Presenting Members :
Ms. Srishti Singh, Assistant Manager (Process)

Making a Mark Among
Top Global Corporates in



500

listing since 1995

IndianOil ranked

94TH

Globally Acclaimed Proudly Indian




In an impressive leap, IndianOil has ascended 48 places to secure the 94th rank in the prestigious Fortune 500 list for 2023. With this surge, IndianOil becomes one of only two Indian corporations and the only PSU to have been listed in the top 100 ranking. It is remarkable that IndianOil has consistently featured in the list since 1995. This is a validation of the company's unbroken record of excellence for over two decades.

The Fortune Global 500 list ranks corporations globally based on their total revenues for their respective fiscal years.



Values at our Core, Guiding us Forever More

IndianOil Values :
The North Star guiding our Thoughts
and Actions



Mathura Refinery

1982



MATHURA REFINERY
8 MMTPA

2016



Merged in
2009

1998



**BONGAIGAO
N REFINERY**
2.35 MMTPA

Merged in



1981

**PANIPAT
REFINERY** 15
MMTPA

1975



**DIGBOI
REFINERY** 0.65
MMTPA

1965



**HALDIA
REFINERY** 7.5
MMTPA

196



**GUJARAT
REFINERY** 13.7
MMTPA

196



**BARAUNI
REFINERY** 6
MMTPA

0.8
MMTPA

1962

80.7 MMTPA
(Including
subsidiaries CPCL:
11.5 MMTPA)

**GUWAHATI
REFINERY** 1 MMTPA



Late Prime Minister Smt. Indira Gandhi, laid the foundation stone of Mathura Refinery on 2nd October, 1973.

Mathura Refinery is a Public Sector Refinery, built in collaboration with erstwhile USSR

Mathura Refinery




CRUDE SUPPLY



CRUDE FROM SALAYA PORT



MATHURA REFINERY



TRANSPORTATION

- Liquefied Petroleum Gas
- Propylene
- Naphtha
- Motor Spirit
- EBMS
- Aviation
- Turbine Fuel
- Kerosene
- Diesel Fuel (HSD)
- Furnace Oil, Bitumen
- Sulfur



1st refinery in the world to be accredited with **ISO-18001 (Occupational Health & Safety Management System)** certification in Nov'98, **ISO-14001 (Environment Management System)** certification in July'96.



1st industry in India for which **Scientific Environmental Impact Assessment (EIA)** was study carried out before commissioning due to its location sensitive Taj Trapezium Zone (TTZ).



Set up a Hospital (**Swarn Jayanti Samudaik Hospital**) outside township for community welfare in April'99.




First Indian refinery to produce Ethanol blended Motor Spirit at refinery location




First refinery in India to produce XP 100 – step towards Atma Nirbhar Bharat

MATHURA REFINERY – A UNIQUE REFINERY



Specific Energy Consumption in last 3 years

MBN




63.12 in (2020-21)

7 %

60.49 in (2022-23)

Energy Intensity Index




88.76 in (2020-21)

9 %

80.84 in (2022-23)

Fuel & Loss %




7.34% in (2020-21)

9 %


6.84% in (2022-23)

Specific Power



- Stoppage of HGU-1,
- BBU operation on Single reactor and producing bitumen from VDU

Net Specific Thermal energy



- Running of additional SRU,
- Running of additional STG during GT-3 crises

Awards & Accolades/Certifications



CII Energy Efficient Unit Award 2022 for 3rd time in a row



Uttar Pradesh State Energy Conservation Award-2022



Refinery of the year FIPI Award 2022



Award of Excellence in Consistent TPM Commitment in 2019





ISO 5001:2018 Certification



ISO 16064 recertification




- Worldwide Average Refinery EII reduction : 1 EII/ year
- 28.0 EII Reduction in 12 years (2.3 EII/Year reduction)
- One quartile reduction in EII from Q3 to Q2 in Solomon study of 2020.
- MR performance has further improved its performance in Solomon study 2022 . EII further reduced from 87 to 83



IOCL's Emission Reduction Plan – Refinery Operations

Emissions in MMTCO_{2e} per annum

Overall reduction of 7.57 MMTCO_{2e}



* For existing Refinery, excluding projects.

20.53 MMTCO_{2e} for 2021 is Scope 1 & Scope 2 for IOCL Refineries & PNC excluding CPCL (23.77 MMTCO_{2e} incl. CPCL)

Projects approved/under implementation
(~100,000 SRFT ⇔ 3 MBN ⇔ 225 MTPA CO2 eq)

FCCU WGC steam turbine replacement with motor
(10,500 SRFT)

Conversion of steam tracing with electrical tracing
(VGO, VR, Vac. Slop, IFO & Bitumen lines) – 4000 SRFT

Stoppage of 2 out of 3 GT post grid power import
(65,500 SRFT)

Converting TPS STG from condensing cum
backpressure to fully backpressure type(4000 SRFT)

Replacement of steam turbine with motor in NPRU
HPC (12,000 SRFT)

First ever
implement of
high speed
motor in
India

Projects under conceptualization
(~30,000SRFT ⇔ 1 MBN ⇔ 121 MTPA CO2 eq)

Replacement of HP steam exchanger with electric
heater (6000 SRFT)

Hot Water belt in the FCCU (6000 SRFT)

Conversion of steam tracing with electrical tracing in
14 no of Bitumen Tk (3000 SRFT)

Replacement of steam turbine with motor in MAB &
Installation of PRT across orifice chamber in FCCU
(15000 SRFT)

Major ENCON projects planned in FY 2023-24

Sr No.	Scheme	Category (Inhouse/PCRA/EIL/CH T/RPIP etc)	Savings (SRFT/Yr)	Savings (Million Kcal/Yr)	Savings Millions	Completion Date (MMM-YY)	Investment in Millions
1	Perlite Insulation on HP Steam Header (2 nd Phase-8.8 KM)	In-house	1905	19050	65	FY 2023-24	72.2
2	Installation of additional CPH module in HRSG 2	In-house	1300	13000	76	Completed	50.9
3	High emissivity furnace coating in the AVU furnaces	In-house	920	9200	54	Completed	17
4	DHDT complete off gas routing to PSA-140 (Stab offgas, stripper offgas)	In-house	350	3500	20	FY 2023-24	0.5
5	Reduction in LP steam consumption in HGU-1 Deareator 06-V-004.	In-house	1200	12000	70	Completed	0
6	Modification in IGV modulation to increase Cogen efficiency of GT/HRSG-2	In-house	200	2000	12	Completed	0
7	Cleaning of the AVU preheat exchangers through online chemical cleaning to reduce downtime	In-house	2300	23000	135	FY 2023-24	
8	Implementation of coracoat coating in the cooling water pumps	In-house	1200	12000	70	FY 2023-24	7

Major ENCON projects planned in FY 2023-24

Sr No.	Scheme	Category (Inhouse/PCRA/EIL/ CHT/RPIP etc)	Savings (SRFT/Yr)	Savings (Million Kcal/Yr)	Savings Millions	Completion Date (MMM-YY)	Investment in Millions
9	Application of Electrical tracing in offsite piping and tank farm in place of stream tracing (MP steam cons in Bitumen tank Farm: 15 TPH; Power requirement: 2.5 MW).	In-house	3000	30000	176	FY 2023-24	80
10	Provision of HP rich amine flash vessel in OHCU to recover fuel gas	In-house	800	8000	47	FY 2023-24	70
11	Replacing WGC condensing turbine drive with motor in FCCU	In-house	4900	49000	287	FY 2023-24	800
12	Replacing MAB Condensing Turbine Drive with Motor Drive in FCCU	In-house	5000	50000	293	FY 2023-24	800
13	Conversion of existing STG (partial condensing type) to back pressure turbine	In-house	4000	40000	234	FY 2023-24	140
14	Converting turbine to motor in Heat pump compressor in NPRU	In-house	5500	55000	322	FY 2023-24	900




Installation of additional CPH module
in HRSG 2.
Stack temperature reduced by $> 30^{\circ}\text{C}$

High emissivity coating in
the AVU, VBU & DHDT
furnaces.

Total 7 number of furnaces,
3% of fuel saving





Stoppage of MP steam in TPS
deaerator (3500 SRFT)

Repair /replacement of faulty
steam traps (3446 SRFT)

Stopping 1 BFP in TPS by
increasing reliability of auto
start logic
Overhauling & water washing
GT-1 (2565 SRFT)


Attending step less controller in
OHCU(1200 SRFT)

Overhauling & vaccum
improvement of STG1 (1915
SRFT)


Routing of propylene analyzer
purge to HPC suction KOD
(1570 SRFT)

Net saving:
(14610
SRFT ↔
1.4 MBN)

Replacement of thermal
insulation in TPS
Overhauling of pumps in AVU,
OMS (144 SRFT)



Name of Project	Description	Trigger for implementing	Year of implementation	Annual savings	Investment
Hydrogen recovery from LP off gases through PSA 140 Revamp	PSA 140 was revamped to incorporate LP off gases from other units which were originally routed to FG header. After revamp hydrogen was recovered from LP gases and routed to Hydrogen header, there by reducing load on HGU.	Hydrogen savings and reduction in HGU plant load which is a huge energy consumer.	2022-23	4574	140
Energy Management System	Online monitoring tool of refinery, which provides updates on hourly basis on all energy key performance indicators.	Stringent monitoring	2022-23	4000	140
BFW injection for improving AVU pre heat	improvement in PHT-3 of 3 °C, was observed after BFW injection. This activity is carried out on quarterly basis or when ever pre heat drops significantly.	Online exchange cleaning and pre heat improvement	2022-23	854	5



Hydrogen recovery from LP off gases through, PSA-140 revamp (new PSA bed)

Energy Management System

EMS - Mathura Refinery - Home

Total Throughput Processed : 29.6 TMT/day TPS Power : 67.59 MWh TPS Steam : 326.58 TPH TPS HPS Exp : 135.45 TPH TPS MPS Exp : 156.69 TPH
Last Updated Timestamp : 02-09-2022 09:00:00

Specific Energy Cost (INR/MTCrude) Deviation : 3.05% Actual Optimized : 4187.25 4063.44	Total Energy Consumed (Gcal/hr) 679.34 Flare Loss(kg/hr): 256.06 REF : 760 +80.66	Energy Intensity Index 77.95 REF : 85.5 +7.55	MBN (MMBTU/Mbarrel/NRGF) 54.91 NRGF : 5.44 REF : 60.7 +5.79	GHG Emission (tCO2e) (Ton/hr) 201.57 REF : 218 +16.43	% Fuel & Loss (%) 5.79 % Fuel : 5.59 % Loss : 0.2 REF : 7 +1.21	Total Fuel Consumed 87.90 % Solid 64.29 % Liquid 12.09 % Gas
--	---	--	---	--	--	--

Area-wise SEC Distribution

Deviation % SEC: 0-15% (Green), 15-30% (Yellow), 30-100% (Red), Offline (Grey)

FCCU	AVU	HGU1	HGU2
DHDS	DHDT	OHCU	CCRU
VBU	SRU	BBU	NPRU
PrimeG	MSQU	Octamax	ARU
SWS	TGTU		

Trend: Total Energy Consumed (Gcal/hr) | 02-09-2022 00:00 | 02-09-2022 23:59

Primary Axis Trends: Line | Secondary Axis Trends: Bar

TOTAL ENERGY CONSUMED_GCAL_HR (Left Axis, 0-700)
TMT/Day (Right Axis, 0-35)

BFW injection in Pre Heat train-3 for improving AVU pre heat


On Site generation

	Technology	Installed capacity (MW)	Consumption (Million kWh)	Share
2022-23	Solar	0.89	0.912205	0.16
2021-22	Solar	0.89	0.96972	0.17
2020-21	Solar	0.89	0.708281	0.13

Off Site generation

	Solar	Installed capacity (MW)	Consumption (Million kWh)	Share
2022-23	Solar	0.35	0.461960	0.08
2021-22	Solar	0.35	0.442281	0.08
2020-21	Solar	0.35	0.264576	0.05

Total Solar Energy generation



GHG emissions:

Year	Scope 1	Scope 2
	kg CO ₂ /MT of product	kg CO ₂ /MT of product
2022-23	181.92	0.20
2021-22	211.59	0.20
2020-21	216.78	0.18

tCO₂e/ MT Of Crude →

0.213


0.201

0.207


0.211

0.210

Absolute emission in TMT of CO₂ e




GHG emissions




PAT CYCLE II to VI : IOCL-MR Performance

PAT Cycle-II : FY 2016-2019



PAT Cycle-VI : FY 2020 -23



14 MBN Reduction against

5.2 MBN Target


No of Escerts issued:

71718 Escerts


Target for Year **2022-23 : 60.7 MBN**

Achieved in the Year **2022-23: 60.5 MBN (⇔ 1669 Escerts)**

With focused approach, IOCL- MR has not only achieved but surpassed the target in both PAT II, VI.




EMS dashboard



Steam Leak Reporting Portal



Flare dashboard



AVU PHT Monitoring dashboard

Challenge I – transportation due to Ethanol being polar in nature.

Overcame by : Addition of Coupler at refinery location



Challenge II – costlier w.r.t MS due to high ethanol cost.

Overcame by – addition of low cost Naptha stream with high Octane Ethanol in MS pool to maintain overall Octane and low cost



Thus Mathura Refinery was able to maintain

1. overall margin in EBMS production
2. reduce the associated carbon footprint of MS
3. helped local farmers/agriculture industries to grow





IndianOil



CLEAR BLUE

Diesel Exhaust Fluid is the necessity to comply with the NOx emission norms of BS-VI fuel and it is a remarkable sustainable effort of IOCL towards producing vehicle additives for making the engine exhaust cleaner

DIESEL EXHAUST FLUID



