

# ● THE RAMCO CEMENTS LIMITED, JAYANTHIPURAM



## Team Members:

SVRK Murthy Rao – SVP (Works)  
P. Raghuram – (SDGM – E&I)  
G. Hanumath Prasad (Manager – Process)

**24<sup>th</sup> CII - National Energy Award for  
Excellence in Energy Management -  
2023**

# THE RAMCO CEMENTS LIMITED

**FOUNDER**



**Sri P.A.C. RAMASAMY RAJA**

**FORMER CMD**



**Sri P.R. RAMASUBRAHMANEYA RAJHA**

**MANAGING DIRECTOR**



**Sri.P.R. VENKETRAMA RAJA**

“Do Not look at Productivity as a game in numbers. Try to learn from others and never compromise on quality and always stay ahead in terms of technology. In the long run, they will pay off “

- Shri P.A.C Ramasamy Raja, Founder Ramco Group

The Ramco cements limited is a flag ship company of Ramco Group with interests in:

- 1) Cement
- 2) Cotton Yarn
- 3) Software System
- 4) Fiber Cement Products and
- 5) Wind Energy

# 1.THE RAMCO CEMENTS LTD

- The Ramco Cements limited is the 5<sup>th</sup> largest and one of the fastest growing cement companies in India, with a production capacity of 21 million tonnes per Annum.
- The Company operates 6 Integrated Cement plants and 7 Cement grinding Units across the country.
- The Ramco Cements limited is known for introducing many new technologies first time in the Indian cement industry.

# 1.THE RAMCO CEMENTS LTD , Jayanthipuram Works

➤ Jayanthipuram Cement Works, located in the NTR District of Andhra Pradesh, Commissioned in the year 1986.

➤ Presently the plant is operating with a production capacity of

Clinker – 4.685 MTPA

Cement – 3.65 MTPA

➤ With support of

Coal based Captive Power plant – 42 MW (2\*18 + 1\*6 MW)

Waste Heat recovery System – 27 MW (3 \* 9 MW)

The manufacturing Products are OPC,PPC and RSC


## Plant Capacity at a Glance

Year	Milestone	Cumulative Clinker Capacity	Cumulative Cement Capacity
		Million TPA	Million TPA
1986	Line-1 commissioned	0.75	0.75
1995	Line-1 Up-gradation	1.10	1.10
1999	Slag Cement	1.10	1.60
2008	Line-2 commissioned	2.80	2.60
2010	Expansion (Installation of VRPM )	2.80	3.65
2016	Line-1 Upgradation	3.185	3.65
2020	Phase-1 WHRS in Line-2 Commissioned	9 MW	
2021	Phase-2 WHRS in Line-1 Commissioned	9 MW	
2021	Line-3 Commissioned	4.685	3.65
2021	Phase-3 WHRS in Line-3 Commissioned	9 MW	

# 2 . Energy Consumption Details


## Overall Energy Consumption - 2023

Thermal Consumption in MTOE	313465
Electrical Consumption in MTOE	95586
Total Consumption in MTOE	409051




Power Source in (%)	2020-21	2021-22	2022-23
TPP	85	60	42
WHR	15	40	58
Total	100	100	100

## Power Consumption (%)



# 2. Thermal Energy Consumption


Specific Heat Consumption (Kcal/kg clinker)



Specific Heat Consumption reduced by 1.5%

## 2. Electrical Energy Consumption – Up to Clinker


kWh/ T Clinker



Specific Power consumption reduced by 5.44%




## 2. Electrical Energy Consumption – Overall Cement




Specific Power consumption reduced by 4.7%.

## 2. Electrical Energy Consumption – Cement Product



SEC reduced by 6.44%



SEC reduced by 6.81%

### 3.Information on National and Global benchmark


<b>International Benchmark</b>	<ul style="list-style-type: none"><li>• SHC-665 Kcal/Kg Clk</li><li>• SEC-65 Kwh/T Cem</li></ul>
<b>National Benchmark</b>	<ul style="list-style-type: none"><li>• SHC-690 Kcal/Kg Clk</li><li>• SEC-65 Kwh/T Cem</li></ul>
<b>TRCL Jayanthipuram</b>	<ul style="list-style-type: none"><li>• SHC-733 Kcal/Kg Clk</li><li>• SEC- 79.5 Kwh/T Cem</li></ul>

Reference:


National Benchmark: Energy Bench Marking For Cement Industry Version 5

International Benchmark : Indian cement and construction industries-global competitiveness-NCB-CMA special publication presented in 8th NCB International Seminar

### 3.Roadmap to achieve national/Global benchmark-Thermal Energy



### 3.Roadmap to achieve national/Global benchmark-Electrical Energy



## 4. Energy Conservation Projects Implemented in the years 2020-21, 2021-22 & 2022-23

No of Projects – 32



Projects with Nil investment - 07



Total Amount Invested – 165.8 Crores



Cost savings achieved – 105.50 crores



Electrical Energy Saved – 1783.40 Lakh kWh



Thermal Energy Saved – 41000 MT of coal



# Major ENCON Projects during years 2020-21,22 and 23


Sno.	Team / Section	Project details	Annual savings (INR Lakh)	Investment (INR Lakh)
1	Phase-1 WHR	Installation Waste heat recovery system in kiln-2 (9 MW)	245	8500
2	Phase-2 WHR	Installation Waste heat recovery system in kiln -1 (9 MW)	7	8200
3	Phase-3 WHR	Installation Waste heat recovery system in kiln -3 (9 MW)	7	8200
4	Mines Auto, LOCO & DGPP	Plant water pump replaced with high discharge pump (400Cubic M/Hr water discharge instead of 285Cubic M/Hr discharge @ 175kw power.	12.4	6
5	TPP	Replacing Encon blades with Parag blades in ACC fans for STG -6	17.24	30.5
6	WHRS	Installing VFD for Condensate Extraction pump in WHRB steam Turbine	3.46	10
7	L.S.Crusher	Optimization of power consumption through idle running of B Conveyor,Secondary screen, Spillage BC-1 & 2 conveyors,A conveyor,C conveyor,CBA BC-1, Stacker feed belt, Stacker Boom conveyor by eliminating frequent overload tripping of B1 Conveyor by replacing existing 3.7kw motor & drive units with 7.5kw capacity.	0.625774	0.16
8	Coal mill-1 & Coal Handling	Optimization of Coal Mill-1 output material transport (grinding circuit) screw pumps operation for saving energy.	5.2416	Nil

# Major ENCON Projects during years 2020-21,22 and 23


Sno.	Team / Section	Project details	Annual savings (INR Lakh)	Investment (INR Lakh)
9	TPP	Elgi Service air compressor New VFD installation.	7	6.5
10	Mines	Power reduction in North Band Mines dewatering system by replacing the under efficiency old pumps with high efficiency pumps.	38	22.57
11	Kiln-2	Optimization of Line -2 ID Fan Specific Power (operation in SPRS mode) -by installing ID Fan SPRS to recover the power loss in slip Power	11	4.12
12	Kiln-1	Interconnected the pipe lines between these three blowers area and stopped the KF1AB07 blower as standby for remaining blowers.	1	Nil
13	TPP	STG-3 CEP-2 Spare VFD was installed, pump discharge pressures were reduced depend up on the Deareator pressure. Auxiliary power consumption reduced.	0	Nil
14	TPP	While 30MW power generation, operating one 260 KW (18MW) plus one 132 KW (6MW) Main cooling water pumps instead of two 260 KW pumps. Auxiliary power consumption reduced.	2	Nil
15	Kiln-2	Optimization of Kiln-2 ID fan & Bag house fan after WHR	10	Nil
16	Kiln-1	Optimization of Kiln-1 ID fan for New tower Pre heater after WHR	4	Nil



# Waste Heat Recovery System In Line-2 (9 MW)



**PH-2 Boiler**



**AQC-2 Boiler**

Phase -1 WHRS in Line-2 was commissioned on 13/09/2020

Units Generated in

2020-21 : 27,114,350 kWh

2021-22 : 46,931,618 kWh

2022-23 : 53,024,170 kWh

# Waste Heat Recovery System In Line-1(9 MW)



**AQC-1**



**PH-1B**



**PH-1A**

Phase -2 WHRS in Line-1 was commissioned on 25/02/2021


Units Generated in

2020-21 : 43,38,520 kWh


2021-22 : 45,742,539 kWh

2022-23 : 50,740,900 kWh

# Waste Heat Recovery System In Line-3 (9 MW)



**PH-3 Boiler**



**AQC-3 Boiler**

Phase -3 WHRS in Line-3 was commissioned on 13/11/2021

Units Generated in

2020-21 : Nil

2021-22 : 13,877,100 kWh

2022-23 : 59,278,031 kWh



## LRS Speed Reduction in Coal Mill-2&3

- After commissioning WHR in all preheaters ,the mill inlet temperature got reduced from 250 to 150 due to this fine coal moisture increased.
- When fine coal moisture increases, it affects the fine coal conveying systems and also increased the heat for evaporation of excess fine coal moisture
- We decided to reduced the water spray in coal mill which is used for grinding bed stabilization.
- Without affecting mill grinding process we reduced the water spray by running the table with lower speed
- Reduction of mill table speed has achieved by LRRS.
- By doing so, the mill outlet temperature has increased from 45 deg C to 60 deg C and the fine coal moisture got reduced from 3.5% to 0.7%

**Heat Savings: 1.5 Kcal/kg clinker**



# TPP ENERGY SAVING PROJECTS

- Installed VFD to 1 no ACW Pumps with 90 Kw motor and saved 328 kwh/day. Total cost Savings Rs. 4.98 lakhs ( $328 \text{ kwh} * 365 * 4.16$ ).
- Installed VFD to 3 no's of Cooling Tower Fans, each with 75 kw motor and saved 327 kwh/day. Total cost Savings Rs. 4.97 lakhs ( $327 \text{ kwh} * 365 * 4.16$ ).
- Installed VFD to BFP Pump each with 425 kw motor and saved 730 kwh/day. Total cost Savings Rs. 10.93 lakhs ( $730 \text{ kwh} * 365 * 4.16$ ).
- Installed VFD to 3 nos CEP Pumps each with 55 kw motor and saved 990 kwh/day. Total cost Savings Rs. 11.12 lakhs ( $990 \text{ kwh} * 270 * 4.16$ ).

**Total savings-32 lakhs**

# WHRS - Encon Blades for STG -6



- Energy Saving and Payback calculation in ACC Fans after Changing Parag Blades to Encon Blades (STG-6 unit). These are light weight blades with better aero foil section.

Parameter	Uom	Before	After
TG Load	MW	>8.5	>8.5
Average Power Consumed (4 Fans)	Kwh/Day	3259.45	1578.5
Average Power Consumed /Fan	kwh	33.95	16.44
Net power saving(4 Fans)	Kwh/Day	1681	
Power Savings (4 Fans)	Kwh/hr	70	
Run hours (250 Days)	Hours	6000	
Power saving	Kwh/Annum	420200	
Power cost	Rs/Kwh	3.74	
Cost saving/STG Unit	Rs /Annum	15,71,735	
Investment cost/Unit	Rs	30,25,480	
ROI	Months	23 months	
Angle for Fans	Deg	16-17	4-5

**Total savings-15.72 lakhs**

# 5. Innovative Project-1

## Cooler DPC Tail end return spillage collection conveyor

### Issue:

Heavy return spillage at clinker cooler discharge DPC tail end area.

### Modification done

Conveyor installed at the DPC tail end to collect & carry back the spillage material into the same DPC.

### Advantages of modification

- ✓ Spillage at dpc tail end area avoided.
- ✓ Housekeeping improved.

## 5. Cooler DPC Tail end return spillage collection conveyor (Before)





## 5. Cooler DPC Tail end return spillage collection conveyor (After)



## INNOVATIVE PROJECT-2

# Hot air Duct tapping from TPP to Coal mill-2

- Coal Mill-2 is required to run during Line-2 shutdown also to avoid the production loss in Line-1.
- During Line-2 shutdown, we have taken the trial of Coal Mill-2 running without hot air. But, due to insufficient air and temperature the mill was not able to run even with the reduced feed and reduced table speed.
- Hence, to run the Mill during Line-2 shutdown, it is proposed to tap the hot air from TPP to Coal Mill Hot ESP Fan inlet. The temperature at the TPP ID Fan outlet is maintaining around 150°C and 85000 m<sup>3</sup>/hr gas flow, which can be utilized for the Coal grinding.

Hot gas duct from TPP



Hot gas duct joining coal mill-2 inlet duct



# 6.Utilization of Renewable Energy sources

Type of Res	2020-21	2021-22	2022-23
	Energy	Energy	Energy
	Generated	Generated	Generated
	(kWh)	(kWh)	(kWh)
Solar	10724	10764	10736
WHRS	31452870	106551257	163043101
<b>% RE Utilization</b>	<b>15</b>	<b>40</b>	<b>58</b>

Technolgy (Electrical)	Type of Energy	Onsite/Off site	Installed Capacity (MW)	Generation (lakh kWh)	Year	Capacity addition & Investment made	Share Considered for plant
Renewable	Wind	Off site	166	327.06	2020-21	Nil	Nil
Renewable	Wind	Off site	166	333.65	2021-22	Nil	Nil
Renewable	Wind	Off site	166	331.27	2022-23	Nil	Nil

## 6.Utilization of Renewable Energy sources – Solar Energy



# 200 Kg/day Capacity Bio-gas plant




Type of Res	2020-21	2021-22	2022-23
	Energy	Energy	Energy
	Generated	Generated	Generated
	(kcal)	(kcal)	(kcal)
Bio Gass Plant	77000	102070	90500

# 7. Waste utilization and management – AFR Usage

S.No	Year	Name of Aletrnate raw material used	Name of Material gets replaced	Quantity Used (MT/Year)
1	2020-21	Slag	IR Laterite	15002
2	2021-22	Slag	IR Laterite	78481
3	2022-23	Slag	IR Laterite	115699

FUEL TYPE	UOM	QUANTITY
ALTERNATE FUEL - BLACK GRAM HUSK	MT	77.96
ALTERNATE FUEL - BRIQUETTE	MT	468.75
ALTERNATE FUEL - BURNT MAIZE STICK	MT	573.07
ALTERNATE FUEL - CHILLI SPENT	MT	174.38
ALTERNATE FUEL - COAL DUST	MT	0.00
ALTERNATE FUEL - COC FEED	MT	12.32
ALTERNATE FUEL - CORN WASTE	MT	28.52
ALTERNATE FUEL - GREEN MAIZE STICK	MT	2.85
ALTERNATE FUEL - MAIZE OIL EXTRACTED STICKS	MT	202.39
<b>ALTERNATE FUEL - ORGANIC WASTE LIQUID</b>	MT	9,855.35
ALTERNATE FUEL - PALM FIBRE	MT	12.22
ALTERNATE FUEL - PALM NUT SHELL	MT	23.49
ALTERNATE FUEL - PP WASTE	MT	4.58
<b>ALTERNATE FUEL - PRODUCTION ASH WASTE - SPENT CARBON</b>	MT	10,901.64
ALTERNATE FUEL - TYRE FIBRE	MT	8.04
ALTERNATE FUEL - WOOD BARK	MT	459.27
ALTERNATE FUEL - WOOD CHIPS (SRSM)	MT	12.70
ALTERNATE FUEL - WOOD SHIVES	MT	535.65
ALTERNATE FUEL BENGAL GRAM DUST	MT	172.85
ALTERNATE FUEL CARBON BLACK	MT	35.84
ALTERNATE FUEL GROUND NUT DUST	MT	300.44
ALTERNATE FUEL RICE HUSK .	MT	2,830.87
ALTERNATE FUEL SAW DUST .	MT	12.86
ALTERNATE FUEL WOODCHIPS .	MT	3,283.80


# 7. Waste utilization and management – TSR





## 8.GHG Inventorisation

Year	Total CO <sub>2</sub> e (MT)/T Cement
2020-21	683
2021-22	648
2022-23	617



Scope 1 emissions	Calcination, Fuel for kiln & CBPP, owned vehicle, Refrigeration & AC
Scope 2 emissions	Power consumption
Scope 3 emissions	Raw Material Supply & Product delivery

# 9.EMS System and other requirements – ISO 50001

**bsi.**  

## Certificate of Registration

ENERGY MANAGEMENT SYSTEM - ISO 50001:2018

This is to certify that: **The Ramco Cements Limited**  
Kumarasamy Raja Nagar,  
Jaggayyapet Mandal,  
Krishna District,  
Andhra Pradesh 521 457  
Andhra Pradesh  
India

Holds Certificate No: **ENMS 616875**

and operates an Energy Management System which complies with the requirements of ISO 50001:2018 for the following scope:

The Manufacture of clinker and cement, Generation & utilization of thermal/ DG/ WHRB captive power; bio-gas and sale of power; Utilization of fuel for material handling/ industrial canteen within the premises.

For and on behalf of BSI:   
Chris Cheung, Head of Compliance & Risk - Asia Pacific

Original Registration Date: 2014-10-30  
Latest Revision Date: 2020-10-29

Effective Date: 2020-10-16  
Expiry Date: 2023-10-15

Page: 1 of 1

...making excellence a habit.™


This certificate was issued electronically and remains the property of BSI and is bound by the conditions of contract.  
An electronic certificate can be substantiated [online](https://www.bsi.com/online).  
Printed copies can be validated at [www.bsi.com/ClientDirectory](https://www.bsi.com/ClientDirectory) or telephone +91 11 2002 2000.

# 9.EMS System and other requirements – Green Supply chain management & Energy Policy


- ▶ We are communicating the message of “Energy Efficiency” & “Technical specifications for Energy Efficiency on purchase equipment to supplier
- ▶ Awareness on green purchase policy for suppliers to evaluate.
- ▶ Going to environment friendly evaluation during product evaluation.
- ▶ Reverse logistics from Kakinada & Vizag port for Coal & Gypsum ,Same rake transferring clinker to Vizag grinding unit

## Projects :

- ▶ All lights are replaced by LED fittings entire plant
- ▶ Procuring high efficient motors & fans for Line-3 project
- ▶ Air cooled condenser instead of Water cooled condenser for WHRS



# Core Committee Team – Energy Cell





## 9.EMS System and other requirements – Learning From CII Award

- ▶ Great Platform to explore our company art of technology used and results achieved
- ▶ We have analyzed the plant performance of ours with respect to other competitors
- ▶ Innovative ideas for actions to reduce Energy
- ▶ Specific Electrical & Thermal consumption in Global level

# 10. NET ZERO Commitment

A Way Forward to :

- 1) Installation of 2\*4 MW On Site Solar Power Plant
- 2) Increase in AFR Utilization
- 3) Logistics & Reverse Logistics through Rail
- 4) Green Belt Development



# Green Belt Development



Year	No of Saplings Planted	Area covered (acres)
2020-21	18496	12.33
2021-22	22354	17.55
2022-23	25670	19.85
% of Green belt area (1986- March 2023)		48.11 %



# Environmental Projects- Green Development

Colony Ground



Main Gate Entrance



Plant top view



Consumer stores

# Environmental Projects- Green Development

Health center



Guest house



Park

# Environmental Projects- Green Development

Mines area



Reclaimer Area



TPP Area



Colony Bird View

# CII – 21<sup>st</sup> National Award for Excellence in Management - 2020



# Environmental Excellence Award in WHRS Category (Southern region) at cemWHR – 2023 by Mission Energy Foundation, New Delhi



**Save  
energy  
Save planet**





# Thank You

[raghuramp@ramcocements.co.in](mailto:raghuramp@ramcocements.co.in)

[hpg@ramcocements.co.in](mailto:hpg@ramcocements.co.in)

## Coal Mill-2 requirement during Line-2 Shutdown

Parameters	Additional Fuel required	Coal Mill-2 Productivity	Coal Mill to be run for Line-1
	MT	TPH	hrs
Petcoke	113	15	8
Coal	152	19	8
Petcoke & Coal (50:50)	127	17	7

The adequacy of existing Hot ESP Fan was checked and found that the fan can run with the available hot air from TPP.

**The new duct (of diameter 1.60 m) has been laid for connecting the TPP ID Fan outlet to Coal Mill-2 Hot ESP Fan inlet.**

**Benefit :- Kiln-1 running with normal feed at 295 TPH.**

**Production loss Avoided – 35 TPH of kiln feed (21 MT clinker / hour)**