




NAVA LIMITED

DHENKANAL, ODISHA-759121



N SK S Kameswara Rao
EnMS Lead Auditor

Rajat Sahoo
Manager (Electrical -FAP)



India: Andhra Pradesh, Telangana & Odisha

Ferro Alloy Plant

Product	HcFeCr & SiMn
Furnace	2 X 22.5 MVA SAC
Cooling Tower	Counter flow Induced Draft
Dryer	Double Drum Rotary (LPG)
Compressors	Reciprocating type
Power	From CPP



90 MW Coal Based CPP

Boilers	AFBC (2 X 65 & 2 X 125 TPH)
Turbine	Condensing Extraction
Cooling Tower	Counter flow Induced Draft
Ash Handling	Pneumatic dry ash conveying
Compressors	Reciprocating type
Fuel	Domestic Coal from MCL



ISO 9001


ISO 14001

ISO 18001


ISO 50001

Production Details :

S.no	Parameter	UOM	2020-21	2021-22	2022-23
1	FeCr Production	MT	57512.80	67592.68	35909.60
2	SiMn Production	MT	0.00	0.00	11826.48
3	Normalized Final Product	MT	57512.8	67592.68	51254.49
4	CPP Generation	MWH	343771	495937	433976
5	CPP Plant Load Factor (PLF)	%	43.60	62.90	55.05
6	Average GCV of Coal	Kcal/Kg	3351.70	3275.37	3234.80



**Plant Heat Rate
(kcal / kWh)**



**Auxiliary Consumption
(%)**




**Sp. Electrical Energy Cons.
(kWh/ MT)**




**Sp. Thermal Energy Cons.
(Million Kcal/MT)**

Note: The Sp. Electrical Energy Consumption of FAP, slightly increased due to number of furnace start/stops & Product change




**PAT - GtG Energy Consumption
(Mtoe / MT)**



CPP - Gross Heat Rate

One of the Top EE Industry



FAP Sp. Electrical Energy Consumption

PAT Target

Player-1

Player-2

National Best

NAVA – DKL Best

- **Providing Variable Frequency Drives**
 - for Clarifier Pump
 - for FD Fan-1 & 2 in CPP-1
 - for AHU motor in ESP control room
- **Migration of conventional lamps to LED**
- **Major Overhauling of TG-2**
- **Installation of Aerodynamic Energy Efficient FRP Blades**



Anticipated
Electrical Savings
0.811 MU

Anticipated
Thermal Savings
9 Million Kcal

EnCon Projects:

Year	No of Measures	Investment (Rs. Million)	Electrical Savings (Million kWh)	Thermal Savings (Million Kcal)	Total Savings (Rs. Million)	Pay back period (Months)
2020-21	10	25.54	0.12	20926	19.23	16
2021-22	11	4.13	0.42	735	1.54	33
2022-23	10	6.14	0.21	345692	5.21	14

Resource Suggestion Scheme:

Year	No of Suggestions		Total Savings (Million kWh)	Total Savings (Rs. Million)
	Received	Executed		
2020-21	7	7	0.11	0.55
2021-22	9	9	0.24	0.27
2022-23	8	7	0.21	1.61

Replaced eroded APH tubes in module-1 of Boiler-1 & provided diversion plate in CPP-2



Implemented in : 2022-23
 Coal Savings : 460 MT
 Cost Savings : 1.29 Rs. Million

Optimizing moisture content of ore by storing more quantity in chrome ore shed & covering the ore with tarpaulin



Implemented in : 2021-23
 LPG Savings : 28.65 MT
 Cost Savings : 1.12 Rs. Million

Replaced eroded APH tubes of both Boilers in CPP-1



Implemented in : 2021-23
 Coal Savings : 605 MT
 Cost Savings : 1.69 Rs. Million

Separated HPH & LPH drains by providing dedicated flash tanks



Implemented in : 2020-21
 Coal Savings : 540 MT
 Cost Savings : 1.40 Rs. Million

Replaced damaged LP & HP Heaters in CPP-2



Implemented in : 2020-21
 Coal Savings : 6060 MT
 Cost Savings : 15.76 Rs. Million

Energy Savings: 24149 Million Kcal

Benefits

Cost Savings : 21.26 Rs. Million

Replaced the blades of 1 CT Fan in CPP-2 with energy efficient aerodynamic FRP MOC blades (Make-Encon)



Implemented in : 2022-23
 Energy Savings : 0.076 MU
 Cost Savings : 0.25 Rs. Million

Replaced Motor pulley of AHU at ESP control room in CPP-2



Implemented in : 2021-22
 Energy Savings : 0.0023 MU
 Cost Savings : 0.007 Rs. Million

Improving the pumping efficiency of RWPH by Installation & commissioning of 75kW, 450 m3 Energy efficient pump (IE3)



Implemented in : 2021-22
 Energy Savings : 0.177 MU
 Cost Savings : 0.58 Rs. Million

Installed MOV at slurry pump suction & provided interlock with Zig operation at MRP in FAP



Implemented in : 2021-22
 Energy Savings : 0.0005 MU
 Cost Savings : 0.003 Rs. Million

Replaced Furnace-1 direct granulation pump with new pump by changing the design & MOC of impeller



Implemented in : 2020-21
 Energy Savings : 0.0055 MU
 Cost Savings : 0.03 Rs. Million

Energy Savings: 0.26 Million kWh

Benefits

Cost Savings : 0.87 Rs. Million

Replaced Cooling Tower drift eliminators & Optimized the blade angle in CPP-2




Implemented in : 2022-23
 Energy Savings : 0.0067 MU
 Cost Savings : 0.022 Rs. Million

Installed Variable Frequency Drive for green Briquette screen in FAP



Implemented in : 2022-23
 Energy Savings : 0.0123 MU
 Cost Savings : 0.04 Rs. Million

Reducing the idle running of conveyors by optimizing the operation of CHP in CPP-2



Implemented in : 2020-21
 Energy Savings : 0.007 MU
 Cost Savings : 0.023 Rs. Million

Replacing conventional HPSV lights & CFL with LED in FAP



Implemented in : 2021-23
 Energy Savings : 0.2512 MU
 Cost Savings : 0.46 Rs. Million

Replacing conventional HPSV lights & CFL with LED in CPP



Implemented in : 2021-23
 Energy Savings : 0.158 MU
 Cost Savings : 0.521 Rs. Million

Energy Savings: 0.17 Million kWh

Benefits

Cost Savings : 1.07 Rs. Million

Before


2 no of LPG fired Double Drum Rotary Dryers of capacity of 20 TPH are used to dry the ore from moisture of 8 % to 2 %. But at optimum valves closing condition the O/P moisture was found 1.5 %. As a result dryer consuming more LPG

After

Arranged a bypass chute from inlet to outlet conveyor for partial blending of high moisture ore, over dried output moisture of 2% is obtained

Result / Benefit Achieved:

- Improved Efficiency
- Reduced Molasses consumption
- Reduced LPG consumption (75 Kg / day)
- Reduced Electrical consumption (261 kWh/ day)



Deviation

Significant power consumption of CCSY & High diesel consumption of unloading equipment

Root cause

Idle running of Crushed Coal Stacking System equipment & Improper location of BF-2 (**design (OEM) constraints**)

Action Taken

- **Dismantling of concrete wall** at back side of the Truck tippler ground hoppers
- **Enlarging GH-1 & 2 grizzly openings** from 200 x 200 mm to 400x400 mm
- **Enlarging all transfer point chutes** to accommodate the lump coals size up to 400 mm
- **Relocation of BF-2** (From Transfer house-2 to CPP-2 Ground hoppers)

Result / Benefit Achieved

- **Reduced Power Consumption (0.162 kWh /MT of coal feed)**
- **Reduced Running hrs of Dozer & Unloading equipment**



Before

Concrete Wall




After




Before

GH Grizzly Opening



After



Before

Belt Feeder-2



After

- ❖ Installed **solar water heaters** at guest house & Bachelor hostel
- ❖ Utilizing **passive sun lighting** at applicable areas in the plant
- ❖ Installed **NoriKool double glazed** transparent sheet
- ❖ Construction of office & club building with **Eco Friendly lighting**
- ❖ Installed **Solar Street Lights & Turbo ventilators**

RPO Compliance:

Solar - 1210 & Non Solar – 6773 for the FY 22-23





High Efficiency roof top solar power plant at Silicon House



40 kW Solar Power Unit at Nava Bharat Schools, Paloncha



Solar water heaters at Dhenkanal & Paloncha



Solar Street Lights at Dhenkanal & Paloncha




Turbo Ventilators at Dhenkanal & Samalkot



CSTR Bio-Digester to recover biogas & to use as fuel to distillery boiler



Waste Heat recovery system from furnace flue gas at Paloncha



Using Passive day lighting at Dhenkanal & Paloncha

Adopted Emission based calculation approach for calculating the CO₂e

Scope-1


- Fuel used in Power Generation
- Start-up oil consumption
- Fuel used in Dryer



Scope-1 Emissions Intensity (CO₂e / MT)

Scope-2

- Import power from Grid



Scope-2 Emissions Intensity (CO₂e / MT)

Environmental management programs During last five years:

- ❖ Installed **MK-IV controller, Ammonia & Lime dosing system**
- ❖ Installed **Online Mercury Analyzer, HDIP camera & Ammonia monitoring systems**
- ❖ Installed **dust extraction system, Wheel Washing System**
- ❖ Provided **Water Spray & Atomizing water spray nozzles**
- ❖ Installed **Oil traps, Aerators & Neutralization Pit**
- ❖ Construction of **Silt catch Pits** at applicable areas



- ❖ Utilizing **Vapor Absorption Machine**
- ❖ Using **Battery operated vehicles** with in plant premises
- ❖ Reusing of waste oil generated during maintenance in **mud gun mass preparation** in FAP
- ❖ **Mechanical waste convertor** to convert organic waste to compost
- ❖ Installed **Ash product plant**
- ❖ **100 % Fly ash utilization**
- ❖ **Zero Liquid discharge through**
 - **STP (Bio-digester & Phytorid Technology)**
 - **Reusing CT Blow Down & Clarifier sludge Water**
 - **Recycling Boiler Blow down & Filter back wash water**



Identifying the Legal & Other Requirements
Conducting energy Review / Audit (Internal / External)
Identifying & prioritizing the Opportunities for Improvement
Establishing the Baseline, Identifying the EnPI
Establishing the Objectives & Targets
Establishing the Action Plans



Ensuring the Competency of People & creating awareness
Establishing & Communicating the Operational Criteria for effective & efficient plant operation
Procurement of Energy Efficient Products
Maintaining The required Documents



Ongoing Energy Review by functional chiefs
EnMS Review by management representative
Taking decisions for Energy performance improvement
Continual Improvement




Monitoring the Key characteristics
Evaluation of Legal Compliances
Conducting regular Internal Audits
Identifying potential non conformities & taking C-CAPA

- Installed Energy Meters for **Significant Energy Uses**
- Periodical **Ongoing Energy Review**
- Record of **Energy Deviations & Management Action Plan (REDMAP)**
- Monitoring **Variables & Controls**
- **Conditioning Monitoring & performance evaluation** of Critical equipment



- Installation of VFD for **condensate extraction pump**
- Switching off the **hopper heaters of ESP 1st field** during normal operation
- Providing **AIRTRON** energy saving device to conserve Split AC Power consumption
- Installation of **NoriKool double glazed transparent sheet**



Description of the Project	Suggested By	Year
Reducing the running hours of Boiler blow down pit & Filter back wash pit pumps in CPP-1 by Float switches	DM Plant Chemist	2020-21
Reducing the running hours of clarifier sludge pit pump in CPP-2 by providing Float switch	DM Plant Chemist	2020-21
Reducing the running hours of slurry pump at MRP in FAP by providing Float switch	FAP Electrician	2021-22
Replacing the old inefficient sieving machine with new energy efficient sieving machine	Silo Operator	2021-22
Replacing 7.5 kW, 20 m3 Neutralization pit pump-2 with 11 kW, 40 m3 energy efficient pump (IE2) in Unit-1	Supervisor	2021-22
Replacing 8 No's of conventional 400 W HPSV lights with 120 W LED lights at boundary & CCSY area	PP Electrician	2022-23
Replacement of 112 numbers of Conventional lights with Energy Efficient LED lights in plant	FAP Electrician	2022-23





- ❖ Observing **Energy Conservation week**
- ❖ Improving awareness through **internal training**
- ❖ Showing the **external presentations** to core team
- ❖ Providing Training on **SEU & its Variables**
- ❖ Deputing the staff to **External Seminars**
- ❖ Display of **awareness posters**
- ❖ Utilizing the **whatsApp** for sharing the Tips
- ❖ Resource Suggestion Scheme





Creating awareness among the Future generation & Employees by conducting Drawing, Quiz and Essay Competition



Creating awareness among the Employees and Contract workmen by Oath taking and Awareness Classes

Resources Management



- ❖ CII - **National Award for Excellence in Energy Management (8 Times)**
- ❖ CII(ER) - **4 Star Rating in Energy Management (2 Times)**
- ❖ CII - **National Award for Excellence in Water Management (2 Times)**
- ❖ EIC-SDA (O) – **State Energy Conservation Award (1 Time)**

Environmental Management



- ❖ SPCB (O) - **Pollution Control Excellence Award (3 Times)**
- ❖ MOEF (O) - **Prakruthi Mithra award (1 Time)**

Safety



- ❖ DFB (O) - **Best Performance in Safety & Environment (4 Times)**
- ❖ DFB (O) - **State Safety Awards (5 Times)**
- ❖ DFB (O) - **State Safety Awards in different categories (5 Times)**
- ❖ EIC – DOE (O) - **State Electrical Safety Award (1 Time)**

NAVA Limited taken a initiative towards plantation & development of green belt in & around the Plant area , Peripheral villages & development of social forestry.

❖ **No. of trees planted so far : 69089**

❖ **Survival percentage : 89 %**







Thank You for your Attention

N SK S Kameswara Rao
skskrao.n@navalimited.com
7381097368
