

# 24<sup>th</sup> CII National Award for Excellence in Energy Management-2023 (Thermal Power Stations)



---

**GMR WARORA ENERGY LTD**

---

**2x300 MW**



# 24<sup>th</sup> CII National Award for Excellence in Energy Management-2023 (Thermal Power Stations)



## Presentation Flow :

1. GWEL - At a Glance; Journey Towards Excellence; Auditable System
2. Energy Consumption Over-view
3. Specific Energy Consumption
4. Benchmarking of Energy Consumption
5. Summary of Energy Saving projects implemented in FY 21, FY 22 & FY 23
6. Innovative Project implemented in FY 23
7. Use of Renewable Energy
8. Environment Management - Ash Utilization; Emission & Water
9. Best Practices in Plant
10. Team work, Employee Involvement & Monitoring
11. Implementation of EMS/ISO Certifications & AFR
12. Learnings from CII/Other Award Program
13. Awards & Accolades



# 1. GWEL At a Glance - Group's Vision, Values & Mission



## Vision


**“GMR Group will be an institution in perpetuity that will build entrepreneurial organization making a difference to society through creation of value.”**

## Mission

**GMR Energy wants to be the most profitable and one of the leading Integrated Energy Companies in India and derive value by**

- Diversifying strategically across Energy value chain
- Being a preferred employer
- Being socially responsible”

Humility | Entrepreneurship | Teamwork and Relationships | Deliver the Promise | Learning and Inner



**In line with Group's Vision & Mission, GWEL strives to create a difference to society through creation of Value by Institution Building**



# 1. Institution Building through System Approach- The GWEL Journey Towards Excellence

Various Management Systems implemented towards Quality, Environment, Health & Safety and Governance Management



# 1. Auditable System for Energy Management

## ENERGY MANAGEMENT POLICY ISO 50001

GMR Warora Energy Limited (GWEL) is committed to be the most Energy Efficient and Integrated energy utility in the world. Our Vision is to make use of all forms of energy resources most efficiently, minimize the impact of our operations on environment and conserve the scarce natural resources.


In order to achieve, we will

Adopt appropriate energy efficient and clean technologies in process design, procurement, and implementation and continually upgrade operating performance.

- \* Manage and make efficient use of all forms of energy by adopting industry wide best practices.
- \* Continual improvements in energy performance against the best in the world and improve competitiveness by training and knowledge sharing.
- \* Create awareness on efficient use of energy and various conservation methods amongst all stakeholders.
- \* Establishment of effective framework for setting & reviewing the energy Objective & Targets.
- \* Carry out regular energy audits to identify areas for improvement.
- \* Comply with all relevant Legal & other requirements on Energy Management.

This Policy statement is displayed at prominent places, and will be made available to interested external parties.

01<sup>st</sup> Jan 2020  
Revision: 02

  
Dhananjay Deshpande  
COO

GMR Warora Energy Limited

- Setting of Energy Objective & Targets
- Efficient Manage and usage of Energy
- Adoption of Best practices & continual upgradation
- Training & Knowledge sharing to raise awareness
- Internal & External Energy Audits & Improvement Initiatives
- Compliance with all legal requirements

## 2. Energy Consumption Overview FY: 2022-23


### Energy Consumption Overview for FY: 2022-23



Generation Mu's



Plant Availability %



PLF %

### Key Performance Indicators

**Gross Station Heat Rate** - 2306 kCal/kWh

**Turbine Heat Rate** - 2011 kCal/kWh

**Boiler Efficiency** - 87.21 %

**APC** - 7.61%

**SOC** - 0.11 ml/Kwh

**DM Make Up** - 0.16 %


**Raw Water** - 2.39 m3/MWh




# 3. Specific Energy Consumption




Gross Heat Rate Kcal/Kwh




Auxiliary Power Consumption %



Plant Availability %



Plant Loading Factor %



KPI	% Improvement	Comments
Heat Rate	(+) 0.17 % ●	<p><b>Constraints</b></p> <ol style="list-style-type: none"> <li>1. Partial Loading on account of Customer curtailment, coal shortage, market constraints.</li> <li>2. Further Heat rate could have been reduced by 7 kcal/kWh, however could not be achieved due to increase in the moisture in coal.</li> </ol>
APC	(+) 7.32 % ●	
Plant Availability	(+) 13.02 % ●	
Plant Load Factor	(+) 24.12 % ●	

1. Station achieved Heat rate of 2306 Kcal/kWh which is best among peer companies for FY 22-23. Heat Rate improved from previous year by 4 KCal/kWh. Station Heat rate before overhauling (COH) is 2313 Kcal/kWh which reduced to 2300 Kcal/kWh. Improvement projects like CT fills replacement, turbine flow path correction etc. has improved station heat rate & APC.
2. Reduced auxiliary power consumption from 8.4% to 7.3 % by embracing best operational practices and implementing various ENCON projects in overhauling, despite severe cash flow constraints. APC improved from previous year by 0.6% out of which 0.2% impact observed due to increase in PLF.
3. Station has recorded availability of 89.4% for FY-22-23. U-1 and U-2 achieved consecutive run of units for 239 & 155 days respectively and also Station achieved 155 days of continuous running in FY.

# 4. Benchmarking of Energy Consumption

## 4.1 Benchmarking Strategies: Roadmap to achieve National / Global Benchmark : Approach

GWEL uses Benchmarking tool to discover best performance being achieved

WITHIN



Internal Benchmarking

### Internal Benchmarking

- ❑ Design Performance- Monthly performance against design
- ❑ Performance Guarantee- Quarterly PG test, Audit and deviation analysis
- ❑ Interdepartmental Benchmarking - Reliability and efficiency KPI's department wise benchmarking study
- ❑ Performance after modification- Change Management & Sustenance
- ❑ Past Best Achieved - Performance analysis against past best performance

External Benchmarking

### External Benchmarking

- ❑ Same Sector Benchmarking with Thermal Power Stations of Similar Capacity & Technology
- ❑ International benchmarking with strategic Investor - Tenaga
- ❑ Site Visits to Similar capacity plants like Dhariwal Power Station
- ❑ Sharing of Best practices & incorporating the learnings through Participation in Paper presentations, Awards, Workshops etc.,
- ❑ Cross-Sector benchmarking like with our Airport Businesses - Best Maintenance Practices for HVAC, Compressors

WITH COMPETITOR

WITH DIFFERENT INDUSTRY

the P




# 4. Benchmarking of Energy Consumption




## 4.2 Internal Benchmarking


### Plant Availability %




### APC %




### SOC ml/Kwh




### PLF %



### SHR Kcal/kwh



### DM Make up %



- GWEL has achieved Plant Load Factor (PLF) of 82.2 % and best (Lowest) ever APC of 7.61% in FY 22-23, since commissioning.
- GWEL has best ever station performance in FY: 2022-23.


Actuals Target

# 4. Benchmarking of Energy Consumption




## 4.3 External Benchmarking


### Plant Availability %




### APC %




### SOC ml/kwh




### PLF %



### SHR Kcal/kwh



### DM Make up %




KPI	National Benchmark	International Benchmark
APC %	7.73	7.71
SHR kCal/kwh	2248	2242

- GWEL Best Achieved - Heat rate of 2275 Kcal/kwh & APC of 7.23% at 100% PLF
- GWEL achieved Best Heat rate & APC among its' peer companies.

● GWEL ★ Best Achieved ● Peers

# 4. Benchmarking of Energy Consumption

## 4.4 Road Map to achieve National & Global Benchmark



**Data Analytics for Efficiency & Reliability**

- Use of IoT, Machine Learning & Data Science for Energy Efficiency Enhancement
- Using AI Tool



# 4. Benchmarking of Energy Consumption



## 4.5 Future Plans towards Energy Conservation - FY:2023-24

S. No.	Title of Project	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Million Kcal)	Investment Planned in 2023-24 (INR in Million)
1	Upgradation of Energy Management system under Digitalization and Monitoring the Energy Management	3.40		5.00
2	Boiler Feed pump Performance Improvement through cartridge replacement & rectification of RC valve	0.36		5.26
3	Condenser Performance Improvement through jet cleaning, helium Leak test & hydro test		13437.15	0.62
4	Installation of vibrating feeder in second stream conveyor - BCN 2B		179.25	2.50
5	Cooling Tower Performance Improvement Program (Existing Cooling Tower Drift Eliminator, Nozzle & Fill Replacement, CW line modification etc.)		13437.15	3.00
6	Cooling tower fan motor to gearbox metallic shaft replacement with carbon fiber shaft	0.53		4.80
7	Installation of 30 MW Solar Plant	36.00		1350.00
8	Three coal mill operation instead of four coal mill operation during partial load operation.	1.96		-
9	Boiler Efficiency Improvement through replacement/ refurbishment of Coal mill rollers along with bull ring segments.		9288.00	1.46
10	Installation of Sonic Soot Blower in APH		5.94	2.10
11	APH Sector- plate servicing & replacement.	0.53	7.70	1.17
12	Implementation of CAVT recommendation in second pass for unit-1	0.40		0.30
13	Unit 1 HPHs partition plate inspection & replacement.		1652.40	0.30
14	Boiler Refractory Inspection and replacement	0.67	1261.97	1.00
15	Flue gas duct & primary air duct ceramic tiles inspection & replacement, duct leakage arrestation	0.53		1.68
16	Coal Mill Aero foil Replacement	0.27		1.68
17	Phase II project on optimal operation of LED along with reduction in LED wattage.	2.40		1.17
18	AHU retrofit- High efficient EC Fan	0.34		4.50
19	Governing Valve Overhauling and replacement		5832.00	1.00
<b>Total</b>		<b>43.98</b>	<b>45101.55</b>	<b>1382.54</b>


# 5. Summary of Energy Saving Projects




## Summary of Energy Saving Projects in Last 3 years

FY	No. of Energy Saving Projects	Investments	Electrical Savings	Thermal Savings	Savings
	Nos.	INR Million	(Million kWh)	(Million Kcal)	(INR Million)
FY 2020-21	21	27.5	21.3	181377	230.9
FY 2021-22	25	67.6	26.5	164427	251.0
FY 2022-23	17	120.1	18.0	259451	329.4
	63	215.2	65.8	605255	811.4


Investment made (Lakh INR/year)



Energy Savings (Lakh kWh/year)



Coal Savings (MT/year)



# 6. Innovative Project implemented in FY 2022-23



## 6.1: Reliability & Efficiency Improvement through Predictive Analysis using artificial intelligence & Machine learning.

Replicability : YES

### Project Trigger:

- A Typical TPP consumes Considerable amount of Energy which generates as APC.
- Difficulty in identifying **cause/ Solutions** on real time for High Specific Energy consumption by auxiliaries.
- DCS/EMS, Uses threshold based alarms to detect the operational issues after causing energy losses.
- DCS/EMS- Failure in detection of performance degradation & Equipment reliability issues beforehand.
- Unable to identify problems at early stages leading to disruptions leading to efficiency loss, Equipment failures leads to high Cost of generation & also poses a safety risk to workers.

### Problem Description:

- GWEL adopts industry best O&M practices such as EMS (ISO:50001)/AMS(ISO:55001) etc., but which are not always effective in identifying & addressing potential issues of High Sp. Energy consumption on real time basis.
- Due to aging of experienced personnel, leading non-availability of repository of knowledge base is impacting operational performance & also Non-Availability of guidance to operator on historical/ design performance.
- To optimize APC of Plant & also to achieve Operational/ Energy efficiencies it is imperative to embrace Digital solution which can enhance Asset Efficiency through Predictive Performance solution models.

### Solution:

- “AI Expert” utilizes, AI/ ML technology to optimize operational Parameters while analyzing **System Failure Modes** along with Providing **Recommendations** to Operator to maximize the **Asset Efficiency and Reliability**.
- AI Expert’s Artificial intelligence engine uses unsupervised deep learning on historical data to learn **correlations** between operating parameters. Given high order of system models, correlations are more precise compared to traditional statistics & multi-variate regression models.
- AI Expert capable of Early detection of issues requires detecting subtle changes in the operating parameters, As a result “AI Expert” is more accurate in giving early warning of the impending issues in the equipment and systems.
- Further, “AI Expert” model continuously updates itself to learn new behavior of equipment with very little manual effort. AI Expert Artificial intelligence models can detect the following kinds of issues without requiring the creation of four separate models.

1. Performance anomalies
2. Process anomalies
3. Equipment reliability anomalies


### Functions:

<b>Multi-equipment System Models</b> Generates a single alert for a system level issue & able to diagnose Equip./ Process/ Perf.	<b>Instrumentation Health &amp; Data Quality</b> Root Cause analysis, accuracy in MSA & Minimizing false alert	<b>Anomaly Detection</b> Equipment reliability, process & performance anomalies	<b>Failure Diagnosis</b> “Fingerprints” translate anomalies & interpret them as specific set of failure modes & Recommended actions.	<b>Advance Analysis Module</b> Process Heat map, Deviation in start & stops, correlating several parameters & computing signal statistics	<b>Alert Management</b> Grouping of similar alerts, duplicate alert suppression, auto-escalation of repeated alerts	<b>Performance Dashboards</b> Plant level & system level dashboards to get relevant information in a single page.
---	---	--	---	--	--	--

### Difference in Traditional Monitoring & AI Expert

#### Traditional Monitoring

- Monitors All Signals Separately
- Manually adjust thresholds



#### AI Expert-Early Detection & Fix

- Monitors All Signals Together
- Gives advance notification
- Understands Correlations
- No Manual rules

### Anomaly Detection with Failure Mode Analysis

TITLE Anomaly alert for FD FAN B	Created On Feb 3, 2023, 2:50 PM	SYSTEM FD FAN B	SOURCE Anomaly Detection	STATE Returned to Normal
Unit Unit 2	Severity Low	Owner Prudhvi Diksha	Status Rejected	Validity False Positive

Alert View Collaboration

FAN MECH RELIA

Failure Modes

1. High Bearing Temperature (0.07)

Approve Rejected

Reason: Very minor temperature variation is observed.

Feb 3, 2023 - Feb 3, 2023

Recommendations



# 6. Innovative Project implemented in FY 2022-23




## 6.1: Reliability & Efficiency Improvement through Predictive Analysis using artificial intelligence & Machine learning.

Replicability : YES

### Advantages with "AI Expert":

- Digitize "knowledge and work processes" to achieve plant consistency.
- Understand system & Equipment interrelations to identify root cause of an issue.
- Guides O& M teams by providing meaningful diagnosis & actionable recommendations using built-in cause-effect analysis
- Identify Data quality & sensor re calibration requirement.
- Seamlessly integrates with current operational Technology (OT) stack including maintenance systems like SAP-PM to assess issues holistically & identify root causes and Integrated Maintenance information for better context during analysis
- Plant wide coverage including all critical systems
- SAP & PI connectors for work history details and live data streaming



Plant & system dashboards

Defined with 3000+ DCS Tags of Critical Parameters of Critical Asset/ System Models


Configured with 1000+ failure modes and recommendations with predefined signature of deviations

90+ Assets are being covered under Phase-1 Implementation & 800+ Critical Alerts generated for corrections to operators

Anomaly score of latest alert region & identify contributing tags that opens up when clicked on the anomaly score.



Each Alert when generated will also show possible failure modes and recommended actions to rectify the failure

By default top 5 contributing tags will launch upon a click on anomaly score. The other tags in the model can also be opened if user wants to find any between the deviations.



Anomaly Detection/ Failure Diagnosis

Multi variable regression, ANOVA & Correlation of Critical Parameters



Tag	Temperature	Pressure	Flow	Level	Position	Speed	Power	Quality	Efficiency
TEMP001	70.0	10.0	100.0	50.0	10.0	1000.0	100.0	90.0	85.0
TEMP002	65.0	12.0	110.0	45.0	11.0	1100.0	110.0	88.0	82.0
TEMP003	75.0	9.0	90.0	55.0	9.0	900.0	90.0	85.0	80.0
TEMP004	60.0	15.0	120.0	40.0	12.0	1200.0	120.0	90.0	85.0
TEMP005	80.0	8.0	80.0	60.0	8.0	800.0	80.0	80.0	75.0

Failure Mode Effect Analysis

Impact : Annual Energy Saving - 12,60,000 kWh

# 7. Use of Renewable Energy



## 7.1 : Savings achieved through Onsite Renewable Energy Projects

	2020-21	2021-22	2022-23
No. of Project Implemented	3	2	2
Total Capacity - MW	1		
Total Power Savings Lakh KWh	87.18		
% Share	0.25		
Cumulative Savings (Rs Lakh)	267.38	268.01	270.08
RPO Obligation	Not Applicable		

Particulars	2020-21	2021-22	2022-23
Performance Ratio (%)	100	100	100
Capacity Utilization Factor (CUF)	100	100	100
Energy Injected into the grid	Nil	Nil	Nil
O&M Cost (Rs./MWp)	0.0067	0.0067	0.0067


Onsite Generation	Technology	Type of Energy	Installed Capacity (MW)	Usage (million kWh)	% of overall electrical energy consumption
FY 2020-21	Wind	Electrical	0.97	8.46	0.22
FY 2021-22	Wind	Electrical	0.97	8.46	0.24
FY 2022-23	Wind	Electrical	0.97	8.46	0.20

Onsite Generation	Technology (Thermal)	Installed Capacity (MW)	Usage (million kWh)	% of overall electrical energy consumption
FY 2020-21	Solar	Thermal	0.52	0.013
FY 2021-22	Solar	Thermal	0.52	0.014
FY 2022-23	Solar	Thermal	0.52	0.012


## 7.2 : Renewable Energy Projects Implemented



Solar Water Heater for Township : Solar Water Heater in Permanent Township installed for 150 Families



Solar Water Heater for Associates : Solar water heater of capacity 1000 LPD installed at Associate employee township.




Wind operated Cooling Fans (150 nos.) on TG Building, Ware House, CW Pump House, AHP Compressor House by replacing motor operated fans.



Rainwater Harvesting : Deep Aquifer & reservoir Recharge by Rainwater Harvesting in Plant & Colony



Pipe-Lighting Pipe light in Stores & Warehouse.



Translucent Cladding Sheet Translucent sheet cladding in CHP belt conveyors, Compressor House, RO-DM to reduce lighting load





Roof Top Rainwater Harvesting Roof Top Rain Water Harvesting from all buildings.

## 7.3 : Renewable Energy Projects under Implementation

Installation of 30 MW Ground Mount Solar & 5 MW Floating Solar Plant




- ✓ Third Party feasibility study done for setting up Solar PV at available land area, reservoir space & roof top for plant & township building by M/s TERI
- ✓ Study included Solar PV potential at locations of plant, analysis of the energy yield from system and proposed recommendations by performing feasibility capacity through Desktop Research, Site Visit, Solar PV Simulations
- ✓ Feasibility Study Output:-
  - ✓ Ground Mount Solar - 3 Potential Sites identified - Near Main Gate, Near Switchyard Area, Near Ash Pond
  - ✓ Floating Solar - 2 Nos. Reservoir
  - ✓ Roof Top Solar - 7 Potential Sites identified



# 8. Environment Management-Ash Utilization



## 8.1 : Utilization of Ash Generated



### Distribution of Areas of Ash Utilization

Sr No.	Particulars	UoM	2020-21	2021-22	2022-23
1	Ash Utilized in manufacturing of cement/ concrete others similar products	%	28%	20%	26%
2	Ash Utilized in Fly Ash Bricks	%	25%	22%	25%
3	Ash Utilized in Mine Filling	%	20%	0%	13%
4	Ash Utilized for Road Pavements	%	24%	49%	23%
5	Ash Utilized in Brick Manufacturing (From Bottom Ash)	%	2%	9%	7%
6	Ash Utilized in Bottom Ash Mine Filling	%	0%	0%	3%
7	Ash Utilized Bottom Ash for Road Pavements	%	0%	0%	3%
8	Expenditure on Ash Utilization (Annual)	INR (Lakhs)	1181	1180	2094.744



1<sup>st</sup> in Central India

Utilization of Ash at GWEL

- Continuous reduction in Legacy Ash YoY
- In FY: 2022-23, 82357 MT of ash was disposed of through 22 no's of rakes by rail.

**Ash Utilization at GWEL is 100% for Consecutive 6 Years**




# 8. Environment Management-Emission



## 8.2 GHG Inventorisation

### GMR Sustainability Report

➤ Every year GMR group publishes its sustainability report for public. It is available on the following link: Scope-1 Emission  
<https://www.gmrgroup.in/energy/>



◇ Mercury Emission - Nil

### Best Practices for Maintaining Emission Level within Norm

#### Current Control:

- GWEL is having Low Nox Burner installed since design stage with Nox value within norms limit
- GWEL is having 100% Ash Utilization
- Coal Blending through Automated Software to minimize emission& maximize efficiency.
- PM within norms limit
- Real time Ash & GCV Monitoring system installed
- Transportation of ash through jumbo bags by train mode
- Biomass Co-firing for reducing emissions
- ISO 14064- Green house Gas reduction

#### Future Control:

- FGD Implementation by Dec-2026- Contract finalization In progress, Project Execution will start from 2024
- 70 KW Solar Installation- Contract finalization under progress, Project Execution start by- Oct-2023.
- 30 MW Floating Solar Installation- Contract finalization under progress, Project Execution by- Mar-2024
- AAC (Aerated Autoclave Concrete ) block manufacturing unit installation

## 8.3 PAT Cycle-II Compliance

### PAT Cycle-II - Energy Consumption Target & Actual - Registration No.-TPP0149MH

Target NHR for Assessment Year 2018-19	Actual NHR Achieved for Assessment Year 2018-19	NHR Target Overachieved for PAT Cycle-II by
2555	2524	30.4

## 8.4 PAT Cycle-VII Compliance

### PAT Cycle-VII - Energy Consumption Target & Actual - Registration No.-TPP0149MH






Target NHR for Assessment Year 2024-25	Actual NHR Achieved for 2022-23	Difference	Remarks
2520	2496	24	Mandatory Energy Audit Completed in Dec-21

Operating Station NHR achieved with Normalization in FY 2018-19 : 2524.24 kCal/kWh  
 Number of EScerts to Sell : 9957      Total Price of EScerts to sell : Rs. 1.83 Crores

# 8. Environment Management - Emission



## 8.5 : ISO 14064:2019 Quantification, Monitoring & Reporting of GHG Emission and reduction



- GWEL successfully completed the GHG emissions verification audit as per guidelines laid with ISO-14064:2019. (Carbon Emission disclosure)
- Fuel sources & Activities includes Energy consumed, Travel, Transportation, Direct & Indirect emissions and many more.
- In Scope- 3 following categories are being considered -
  - Coal Transportation- Rail/ Road
  - Ash Transportation
  - Business Travel- Flight/ Road
  - CO2 Transportation
  - Chlorine Transportation
  - H2SO4 Transportation
  - HCL Transportation
  - LDO Transportation
  - Contractual Vehicle
  - Food Waste - Plant/ Township

# 8. Environment Management - Water




## 8.6 Our Value of Social Responsibility by Conservation of Natural Resource


To achieve above objective , we have adopted **Auditable System Driven Approach** by implementing comprehensive “**Water Efficiency Management System**” (WEMS, ISO 46001:2019)

- ✓ Implementation of **Water Efficiency Management System (ISO 46001)** for conservation of natural resource
- ✓ Implementation of **Water SCADA**- Dedicated water consumption monitoring and accounting
- ✓ **Zero Liquid Discharge Plant**
- ✓ **Water Management Policy & Objectives**
- ✓ **Identify Business activity indicators**
- ✓ **Evaluate the Water Use Review Report**
- ✓ **Significant Water Use Equipment's/Process**
- ✓ **Baseline Water Efficiency Indicators targets & action plan**
- ✓ **Benchmarking with Industry Leaders & capturing Best Practices**

Plant Raw water Specific Consumption m3/kwh



DM Make up - %



### 1<sup>st</sup> IPP to Implement WEMS, ISO 46001:2019

#### Water SCADA

##### Implementation


- 36 Flow Meters Installed.
- Additional 8 Flowmeters in Phase II.
- Area wise consumption accounting.
- Identification of Water Wastage
- Automated Reports
- Real Time Dashboard & Trend
- Alarm for increase in Water Consumption above base value
- **Water Saving-53.41 Lakh m3**



#### Water Audit

##### Implementation

- External Water Audit by CII Triveni Water Institute.
- Implemented recommendations from Audit
- Internal Audit:- Through CIPs - Continual Improvement Plan
- **Water Saving of 9.26 Lac m3 has been achieved through CIPs**



#### Rain Water Harvesting

##### Deep Aquifer Recharge:


- Plant-wide storm water drains connected to Rain water harvesting pond.
- Annual Rain Water Harvesting of 8.6 Lac m3.

##### Rooftop Rain Water Harvesting:

- Rain water harvesting from building roof tops & used as cooling tower makeup .
- Fresh Water Saving-10580 m3/Annum

##### Reservoir Recharge:

- Fresh Water Saving-54000 m3/Annum



#### Water- Beyond the Fence

- Awareness on Scientific Watershed Management for improving water condition in draught areas
- **RO Water ATM** installed in **17 Villages** for providing **Safe drinking water in fluoride zone**
- **Check Dams** construction
- Pond deepening at nearby villages
- **2 Nos. KT Weir** restored
- More than **285 acre land** brought under **irrigation**



# 9. Best Practices in the Plant



## 9.1 Best Practices - Non Energy Efficiency

### Flexibilization

- Sale of 10 MW of Power saved through APC in Market.
- 

### Maintenance & reliability

- Vibration Analysis, LOA, WDA, NAS, TAN, Infrared, Thermography, Dissolved Gas Analysis, Motor Signature Analysis
- Six Sigma based approach for addressing chronic issues.
- Adopted 5S methodology for boosting productivity, workplace management and safe & efficient

### Digitization

- Project SARATHI -Digital Log book, Near Miss, Incidents, HIRA, IMS Internal Audits, Waste Management, Vehicle/Agency Gate Pass
- Knowledge Management Portal, RFID based coal supply chain management.

### Asset Management

- Implementation of ISO 55001, AMS implementation by Asset System Manual & procedures Work Instructions and Manuals.
- Identification of Significant Assets by Asset Risk register.

### Biodiversity

- Friendly Habitat for Floras & Faunas
- Various varieties of fruit bearing & forest species plants like Danima, Eucalyptus, Golichowli, Conocorophous, Jamun, Amla etc.,

### Afforestation

- 42% of the total Plant area is covered under Green Belt against norm of 33%
- Total 205550 No. of Plants has been planted in plant area.
- Plantation has been done in nearby villages under CSR activity.

### Research

- Data Analysis Tool to generate innovative solutions to Cope with dynamic & regulated scenario for correct decision making for profitability improvement

### New Initiatives

- Implementation of ISO 26001, Social Accountability, Infrastructure support to Govt. Schools, Kid Smart Centres & Transportation Facility Health Clinics & Camps/ Individual Sanitary Lavatory, Vocational Training Centre & Libraries.
- Implementation of Business Continuity Management System, Information Security Management System.



# 10. Team work, Employee Involvement & Monitoring



## 10.1 Involvement of Employees in Energy Conservation

### Formation of Water & Energy Management Cell under ISO-50001 & ISO-46001

#### Objectives of EMC :

- Monitoring of Specific Energy & Water Consumption
- Water & Energy Audit (Internal & External) & Recommendation implementation status review
- Discussion on Water & Energy Conservation Projects
- Identification of New Water & Energy Conservation Initiatives
- Daily/weekly/Monthly/Yearly EnCON projects review by EMC.

#### Members of EMC :


- COO- Thermal(Chairperson), O&M Head, Head of WEMC, WEMC members (Energy Managers & Auditors)

#### Total Energy Managers- 21 Energy Auditors- 18


#### Appointment of Water & Energy Leaders

- Appointed throughout the plant & township
- Monitoring of Water & Energy consumption in their area
- Reporting of Energy (Electrical, Thermal, Air, Water wastage)
- Identification of Water & Energy saving opportunities.
- Monthly Localized Water & Energy Audits through Checklist
- Quarterly Area-wise Detailed Water & Energy Audit by Team of Energy Auditors & Managers
- Total 23 Water & Energy leaders appointed and all are BEE Certified EA/EM.

Summary				
S.No	Test Description	Test Conditions	UoM	Test Results
2.0	Boiler performance tests			
2.1	Boiler Efficiency	SWVO with 0% Make up	%	Un Corrected: 86.254 Corrected: 87.375
2.2	Air Pre-Heater X Ratio	SWVO with 0% Make up		APH-A: 0.65 APH-B: 0.66
2.3	Air Pre-Heater gas efficiency	SWVO with 0% Make up	%	APH-A: 56.79 APH-B: 57.43
2.4	Mill Fine-ness Result	SWVO with 0% Make up	%	MII-E -74.89; MII-C - 87.57 MII-D -73.54; MII-E - 80.22
3.0	Turbine performance tests			
3.1	Turbine Heat rate	SWVO with 0% Make up	Kcal/Kwh	Un Corrected: 1911.5 Corrected: 1958.6
3.2	Turbine Efficiency	SWVO with 0% Make up	%	HPT: 85.13 ; IPT: 93.55 ; LPT: 90.71
3.3	HF Heater Performance			
3.3.1	HFH-6 Heater: TTD	SWVO with 0% Make up	Deg C	2.5
3.3.2	HFH-6 Heater: DCA	SWVO with 0% Make up	Deg C	9.7
3.3.3	HFH-7 Heater: TTD	SWVO with 0% Make up	Deg C	6.5
3.3.4	HFH-7 Heater: DCA	SWVO with 0% Make up	Deg C	5.4
3.3.5	HFH-6 Heater: TTD	SWVO with 0% Make up	Deg C	4.8
3.3.6	HFH-6 Heater: DCA	SWVO with 0% Make up	Deg C	13.6
3.4	Condenser Performance			
3.4.1	TTD	SWVO with 0% Make up	Deg C	4.30
3.4.2	Temperature Rise	SWVO with 0% Make up	Deg C	13.54
3.4.3	Air Suction Temp Depression	SWVO with 0% Make up	Deg C	4.77
3.5	Cooling Tower Performance			
3.5.1	Approach	SWVO with 0% Make up	Deg C	9.33
3.5.2	Range	SWVO with 0% Make up	Deg C	13.11
3.5.3	Efficiency	SWVO with 0% Make up	%	0.58
3.6	Unit Heat rate	SWVO with 0% Make up	Kcal/Kwh	Un Corrected: 2228.7 Corrected: 2241.59
3.7	Auxiliary Power consumption	SWVO with 0% Make up	%	7.35



WEMC Organogram



WEMC MOM

Performance Test Report	Test No	Test Date	Test Time	Test Location	Test Operator	Test Result	Test Status	Test Remarks
Majority Performance Test-BO	1	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	86.254	Pass	
Majority Performance Test-BO	2	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	87.375	Pass	
Majority Performance Test-BO	3	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	86.254	Pass	
Majority Performance Test-BO	4	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	87.375	Pass	
Majority Performance Test-BO	5	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	86.254	Pass	
Majority Performance Test-BO	6	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	87.375	Pass	
Majority Performance Test-BO	7	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	86.254	Pass	
Majority Performance Test-BO	8	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	87.375	Pass	
Majority Performance Test-BO	9	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	86.254	Pass	
Majority Performance Test-BO	10	10/10/2023	10:00 AM	Boiler Area	Energy Auditor	87.375	Pass	

Performance Test Schedule

### Performance Test Reports


Internal Water & Energy Audit under Water & Energy Management Cell

# 10. Team work, Employee Involvement & Monitoring




## 10.2 Energy Efficiency Capability Building

Number of Trainings-All




Capability Building-% Employees Expertise




Program Name & details

Internal
Heaters Performance Improvement through Level Optimization
Boiler Performance Monitoring & Improvement
Best Practices for Energy Consumption Reduction in AHP
Training on Energy Management System (ISO 50001) & Energy Conservation awareness for all stakeholders
External
Workshop on Opportunities for APC Reduction in Thermal Power Plant by M/s Steag
Compressed Air System Energy Consumption reduction Best Practices by M/s Godrej
Six Sigma Training for Structured Methodology of Energy Efficiency Optimization by M/s KPMG-Batch-3

Training-Energy Efficiency-Man-hour



Nos. of Energy Conservation Ideas Identified Through Trainings - 18 Nos.



GWEL rated ESCO Grade-4 by Bureau of Energy Efficiency





# 10. Team work, Employee Involvement & Monitoring



## 10.3 Projects implemented through Kaizen ( Workers and Supervisor level)

At Supervisor Level
❑ Standby seal air fan auto pick up logic modified.
❑ Pressure Transmitter installed in economizer ash evacuation line.
❑ Stopping of Ferric Chloride dosing pump by providing Ferric Chloride Tank By-pass discharge line for gravity dosing.
❑ Replacement of Conventional exhaust fans with energy efficient exhaust fans at washrooms.
At Workmen level
❑ Energy Conservation through Installation of Wind Driven Exhaust fan in RO-DM building Roof Top
❑ Installation of Touchless Water Taps
❑ Auto Operation of Lamps in CW pump house by Day-Night Sensor
❑ Reduction in Auxiliary Power Consumption in Compressor House by identifying and attending air leakages

## 10.5 GWEL - Celebration of Energy Conservation Week

- Display of Energy Conservation Posters.
- EC Training for GWEL Employees and Associate employees.
- EC Program for Children of nearby village schools.
- Competitions for EC for Employees, Associates, Family Members.
- EC Program for family members.
- Felicitation of Winners.




## 10.4 GWEL - Web based Portals for Creating Awareness

**Knowledge Management Portal in Intranet**

**EnMS (ISO 50001) Web Portal in GMR intranet**

Item	Date (MM/YY)	Priority	Reference Document	Network	ISO Public	Network	ISO9001	Other Info Links
Site Process Manual for TBM - 02	07/12/2018	0.00	00					Process Portal
Energy Audit	07/12/2018	0.00	00					Process Portal
Energy Conservation Plan	07/12/2018	0.00	00					Process Portal
Energy Conservation Map	07/12/2018	0.00	00					Process Portal
Energy Conservation Form	07/12/2018	0.00	00					Process Portal
Energy Management Plan	07/12/2018	0.00	00					Process Portal
Energy Meter Calibration Certificate	07/12/2018	0.00	00					Process Portal
Energy Performance Indicators	07/12/2018	0.00	00					Process Portal
Energy Policy	07/12/2018	0.00	00					Process Portal


## 10.6 Expenditure towards EnCon Projects



# 10. Team work, Employee Involvement & Monitoring



## 10.7 Monitoring of Energy Consumption



### Centralized Energy Management System

- ✓ Real Time Comparison of HT & LT Equipment's Auxiliary Power consumption in EMS system for BTG, BOP, AHP & CHP
- ✓ Equipment SEC performance monitoring through Artificial intelligence.
- ✓ Auto Reports Generation for Energy Consumption on Daily/ Monthly and FY basis.
- ✓ Trending for better Analysis of Energy Consumption
- ✓ Availability of Plant-wide Equipment's with Rating >75KW
- ✓ Availability of Alarm, Auto SMS & Auto Mail Facility
- ✓ System Upgraded for Integration with DCS for Monitoring of Energy variation w.r.t interlinked variables
- ✓ Upgradation of Online Plant Performance Monitoring System - 18 Modules - Turbine, Boiler, Heaters, APH, Mills, Pumps, Fans, Compressors etc.,

## 10.8 Daily MIS Reports for Monitoring of Energy Consumption & Real time Monitoring System



Daily APC & Energy Deviation Report

Turbine Performance Monitoring

Sustenance Monitoring Reporting

Boiler Performance Monitoring



# 10. Team work, Employee Involvement & Monitoring



## 10.9 Major Area of Concern in Energy Efficiency & Reliability

### Flexible Operation

**Impact due to Low load and high Ramp Rate** - Escalated O&M costs, deteriorated Heat Rate & APC, high startup & shutdown cost, High Emission, Machine reliability compromised and PPA availability loss

### Coal Shortage

Plant PLF is getting affected due to **Coal Quality & Quantity Constraint** & same is affecting station Performance

### Machine Aging

Impact of **Machine aging** on Plant Performance

### Increase in APC due to FGD

**FGD** installation will result in **increase in plant Auxiliary Power Consumption**

### Increase in Renewable Energy Portfolio

Increase in worldwide **Renewable Energy portfolio** is necessity for tackling Climate change issues but same **may affect Plant PLF** which will effect performance


# 11. Implementation of EMS



## 11.1 Implementation of ISO 50001- Upgraded to ISO 50001:2018


- ✓ Energy Objectives & Targets
- ✓ Separate budget for Energy Conservation
- ✓ Participation in Various Forums & Awards
- ✓ Training & Knowledge Sharing

- ✓ Adoption of New Technologies
- ✓ Renewable Energy Projects
- ✓ EC Plans Implementation
- ✓ Green Supply Chain Management




- ✓ Best O&M Practices
- ✓ Energy Conservation projects for Stakeholders & CSR
- ✓ Sustenance Monitoring

- ✓ Evaluation of Energy Performance
- ✓ Internal & External Energy Audits
- ✓ Evaluation of Vendors / Suppliers
- ✓ Benchmarking of Performances



GAR Warran Energy Limited- 2X300 MW Daily Energy Deviation Report											
Sl No	Description	Capacity	Energy Performance Indicator (EPI)					Operation Control Limit (OCL)	Maintenance Control Limit (MCL)	Duration	Date
			UoM	Load (MW)	Average Value (AV)	Max. Value (MV)	Min. Value (MV)				
1.4: STG Assemblies											
1.11	BP-1R	300 MW	100% Duty/ TPI of FW	255.0	404.0	400.0	400.0	400.0	400.0	11-09-2022	24.00
				292.0	355.0	350.0	348.0	350.0	None DC	20-05-2022	24.00
				240.0	400.0	400.0	400.0	400.0		04-09-2022	24.00

### PDCA Approach- ISO 50001 Implementation



### ISO 50001 Implementation Plan

### Process of Continual Improvement

#### 1. Identification

- Identification through Internal/ External Audits, RCA for Energy deviations. Approval of Plant Head

#### 2. Implementation

- EC Plan Implementation Plan is Approved by Steering committee headed by Plant Head

#### 3. Completion

- Post Completion of EC Plan, Completion along with Benefits will be certified by Steering committee

#### 4. Effectiveness & Sustenance

- Actual savings achieved to be furnished against expected after 1 month of project completion & certified by Energy Manager

### Monitoring through Daily Energy Deviation Report & Deviation Closure by CAPA Closure Mechanism

### GWEL - Management of Energy Conservation Program- SIP Digitalization-Complete Cycle in SAP



Total 223 Energy Conservation SIP's implemented in last 8 FY's

% Investment on Turnover in FY 2022-23 : 0.51%


# 11. Implementation of ISO 55001/ Other ISO Certifications & AFR



## 11.2 Implementation of ISO 55001 and other ISO Certifications



SA- ISO 26000:2010



ENMS- ISO 50001:2018



ISMS- ISO 27001:2013



ISO 9001;14001;45001



AMS- ISO 55001:2014

## 11.3 Alternate Fuel Utilization

20 MT of Biomass is blended with 1300 MT of Coal at different blending ratios (1.3 - 1.8%)

Practices followed to maximize the AF utilization

1. Identification of designated location for storage of Biomass pellets.
2. Installation of fire fighting equipment around storage yard to prevent fire.
3. Deployment of specific team for biomass storage yard management.
4. Formulation of bunkering & blending methodology of pellets.
5. Interlock & Protection system incorporation for coal mill according to suitability of biomass fuel firing in both units.
6. Ensured the healthiness of Mill inerting steam system availability and trials for the same in regular intervals.


Challenges Faced

1. Increase in Exit flue gas temperature.
2. Fluctuation in Flame Intensity.
3. Shortage in Availability of Bio-mass at plant location.
4. Non robust, M/s Shanghai Electric Company make Chinese machine not suitable for bio-mass co-firing.
5. Fire & Explosion hazard for people working in mill & bunker area.



**Mahabal Enviro Engineers Pvt. Ltd.**  
 Test Report  
 Report No. ME/2024/02/2024-17-QM-APR-2024  
 Date: 04.07.2024  
 Location: GMR Warora Energy Limited, Warora, Dist. Warora, Madhya Pradesh, India  
 Client: GMR Warora Energy Limited, Warora, Dist. Warora, Madhya Pradesh, India  
 Test Item: Proximate Analysis of Coal (Biomass Blend)  
 Test Results:  

Sl. No.	Parameter	Unit	Result	Method Reference
1	Total Moisture	%	11.25	IS: 2335 (Part 1) - 2009, Part 11.01
2	Moisture in Ash	%	6.41	IS: 2335 (Part 1) - 2009, Part 11.02
3	Vol	%	12.23	IS: 2335 (Part 1) - 2009, Part 11.03
4	Fixed Carbon	%	64.51	IS: 2335 (Part 1) - 2009, Part 11.04
5	Total Ash	%	11.93	IS: 2335 (Part 1) - 2009, Part 11.05
6	Grain Carbon Value	mm/kg	3086	IS: 2335 (Part 1) - 2009






# 12. Learnings from CII/Other Award Program



## 12.1 Learning from CII/Other Award Program





# 13. Awards & Accolades



BEE-National Energy Conservation Award 2020-Consecutive 2 Times



CII Excellent Energy Efficient Unit Award (Consecutive Five Times) & National Energy Leader Award (Consecutive Thrice) & Most Useful Presentation - 2022



NSC-Sarvashreshtha Suraksha Puraskar-3 Times



Sword of Honor 2019



BSC 5 Star 2019



CII Innovative Environmental Project & Water Management Excellence 2021



IMC Ramakrishna Bajaj National Quality Award 2017



National Safety Council - Safety Shield



Maharashtra CSR Award \_WASH



Global Performance Excellence Award 2018-World Class



*There is a Name for those Who Conserve Energy...*

**... SMART**

Thank You