



Confederation of Indian Industry

Presented by


Shri. Kumar Ivaturi

Shri. Hemant Chouhan

Shri. Varaprasad


JSW Energy Ltd., Vijayanagar

JSW Energy – Broad Structure



A BRIEF INTRODUCTION OF THE COMPANY

JSW Energy is one of the most efficient power generation companies in India. With a capacity of 6.56 GW spread across several locations, with generation facilities at Vijayanagar, Ratnagiri, Barmer and Sholtu.



Unit	Fuel
SBU1	Imported coal & Steel Byproduct (BF Gas)
SBU2	Imported coal & Steel Byproduct (BF Gas)
CPP3&4	Imported coal & Steel Byproduct (BF Gas)
CPP1	Steel Byproduct (Corex & BF Gas)
CPP2	Steel Byproduct (BF Gas)
Solar	Natural Sunlight



SBU – Strategic Business Unit

CPP – Captive power plant

BF – Blast Furnace

GROWTH PATH...

JSW ENERGY, VIJAYANAGAR



ENERGY CONSUMPTION OVERVIEW



3854 MU

Annual
Generation



51.1%

Plant Load Factor



98.7%

Availability



2370
Kcal/kWh

Heat Rate



0.20
ml/kWh

Specific Oil
Consumption



7.88%

Auxiliary Power
Consumption





2225
M³/MU

Specific Raw
Water
Consumption

SPECIFIC. ENERGY CONSUMPTION




Last 3 Years (FY 2020-23)




PLF has increased, GHR and APC have reduced


AVAILABILITY TREND

Last 3 years (FY 2020-23)





Heat Rate is competitive with plants running at much higher PLF



APC is lower in spite of very low PLF

ENERGY CONSERVATION PROJECTS

Upcoming Projects in FY 23-24)

UNIT	PROJECT TITLE	Savings Electrical KWH (M)	Savings Thermal KCAL (M)	Investment Million (INR)
SBU2	APH baskets replacement in SBU2 U1 300 MW unit	8.87	-	32.8
SBU2	CW Pumps servicing to improve condenser vacuum	-	180600	10
SBU2	Turbine overhaul to improve efficiency	-	72240	30
SBU1	CW Pumps servicing to improve condenser vacuum	-	180600	10
SBU1	Turbine overhaul to improve efficiency	-	72240	30
SBU1	HVAC Chiller replacement to reduce specific power consumption	0.328	-	3.3
SBU1	Install VFD in SBU1 Both units CEP	1.764	-	21

ENERGY CONSERVATION PROJECTS

Implemented Projects in Last 3 years

FY	PROJECT TITLE	Investment Million (INR)	Savings Electrical KWH (M)	Savings Million (INR)
2022-23	BFP 1B de staging in SBU2 U1	25.34	7.46	56.01
2022-23	Cooling towers blade replacement with energy Efficient blades in SBU1(6Nos)	43.3	0.21	1.57
2022-23	Stopping of Ash handling Compressor up to max 12 hrs, based on the load condition in turn reduces Power Consumption	0	0.72	5.40
2022-23	Reducing secondary air Flow & reducing PA flow by two mill operation	0	3.26	24.48
2022-23	Rectification of blade pitch mechanism malfunction, Secondary Air Flow reduced to 480 to 440 tph	0	0.65	4.90
2022-23	PA fan reduced header pressure Up to 5.5 Kpa & 3 mill operation reduced header pressure up to 7 .0 Kpa	0	9.41	70.54
2022-23	Two mill Operation at low <120 MWh & coal flow < 58 TPH	0	2.37	17.78
2022-23	Low load operation CEP VFD locking speed reduced from 700 to 600 to avoid throttling losses	0	0.66	4.94
2022-23	To reduce slip losses in turn to reduce BFP Power Consumption by keeping both Working oil coolers in service	0	7.92	59.42

ENERGY CONSERVATION PROJECTS

Implemented Projects in Last 3 years

FY	PROJECT TITLE	Investment Million (INR)	Savings Electrical KWH (M)	Savings Million (INR)
2022-23	SBU1 One BFP stopping at low load	0	8.68	65.10
2022-23	SBU1 U2 PA fan auto pressure set point based on coal flow has given a saving 15 kwh	0	0.13	0.98
2022-23	SBU1 U2 BFP recirculation valve logic modification has given a saving of 311 kwh at 90 MW	0	5.12	38.40
2021-22	SBU2 BFP 1A RC Passing identification & rectification	0	1.54	14.34
2021-22	SBU2 U1 CEP Bypass MOV open to reduce throttling losses across deaerator level CV	0	0.21	1.85
2021-22	Turning gear & JOP Stopped in reserve unit	0	0.25	2.24
2021-22	SBU2 U1 8 CT cell fills replaced with trickle grid	28	1.40	8.36
2020-21	CEP VFD Deaerator level logic implementation to reduce throttling losses of Deaerator control valve	0	0.53	1.74
2020-21	SBU2 U1 4 CT cell fills replaced with trickle grid	14	0.70	4.18

ENERGY CONSERVATION PROJECTS

Implemented Projects in Last 3 years

FY	PROJECT TITLE	Investment Million (INR)	Savings Electrical KWH (M)	Savings Million (INR)
2021-22	Instrument Air Compressor Power Consumption Optimization by attending system leaks	0	0.543	4.89
2021-22	PAF 1A IGV throttling losses rectification by replacing hydro coupling scoop	0.3	0.442	3.98
2021-22	SBU1 Compressor -A Power Consumption Optimization by changing from base mode to suction throttling mode	0	0.314	2.83
2020-21	SBU2 U1 Reduction in Net Unit Heatrate by improving the vacuum at 140MW by Keeping 2 CWP in service	0	1.3500	7.57
2020-21	SBU2 U1 Clear water pump sump Level Auto control by varying VFD speed	0	0.1253	0.41
2020-21	SBU2 U1 Condenser cleaning 8-March-2021	0.265	0.3433	1.99

Flexibilization:

Enhancing the ability of thermal power plants to operate more flexibly and adapt to changes in demand and supply. To accommodate the integration of high renewable generation into the power system effectively.


Shift from High PLF to Low PLF Capability:

- Era change: The energy industry has transitioned from prioritizing high Plant Load Factors (PLFs) to focusing on improving the capability of units to operate at low PLFs.
- Reason: This shift is driven by the increasing integration of renewable energy generation into the power system.


Solar Power Integration:

- Installation: JSW Energy Vijayanagar has installed a 225 MW solar power plant connected to the power system.
- Daytime operation: Successfully running 300 MW units at a 75 MW load (25% PLF) during daylight hours, taking advantage of peak solar generation.

INNOVATION- FLEXIBILIZATION




- Home
- Asset groups
- Device groups
- Dashboard groups
- Documentation
- Device Configuration
- Asset Configuration



PROJECT: REDUCTION OF APC AT PART LOAD

- We at JSW Energy, Vijayanagar have installed a 225 MW solar power plant.
- During Solar injection i.e., daytime, we run our 300 MW units to 75 MW.




PROJECT: REDUCTION OF APC AT PART LOAD

- APC at such a low load was a great challenge, but we have achieved a low APC of 7.2 %.
- Several innovative measures were adopted to bring down the APC.

- **Measures implemented-**

- Ash handling compressors stopped at part load – power savings 17 kWh
- Only 2 Mills out of six mills kept in service- power savings 450 kwh
- Only 1 set of ID an FD Fans kept running- power savings 48 kwh
- Only 1 BFP kept in service, and its one impeller stage out of six stages trimming done - power savings 284 kwh
- CEP speed reduction from 1270 rpm to 600 rpm by VFD, and the Deaerator level control valve and its bypass moved fully open to reduce losses- 30 kwh
- FD fan blade pitch setting done at part load – power savings 24 kwh
- ESP fields made OFF depending upon SPM – power savings 12 kwh
- Six CT fans out of twelve stopped - power savings 90 kwh
- BFP De-staging




ENVIRONMENT MANAGEMENT- ASH UTILIZATION

Particulars	UOM	2020-21	2021-22	2022-23
Ash Stock in Plant (yard + pond)	Tons	113620.4	254517	212957
Ash Generated	Tons	113620.4	254517	212957
Ash Utilization	%	100	100	100
Ash Utilized in manufacturing of cement/concrete – other similar products	%	70	47	55
Ash Utilized in Fly Ash Bricks	%	12	15	15
Ash Utilized in Mine filling	%	18	38	30
Ash Utilized for Roads pavements	%	0	0	0
Ash Utilization in Other Areas – Please mention below	%	0	0	0


Ash Handling done through various methods		
Ash Handled (Wet Method)	%	0
Ash Handled (Dry Method)	%	55
Ash Handled (semi wet)	%	45

FY 22-23




■ Cement ■ Bricks ■ Mine

FY 21-22







■ Cement ■ Bricks ■ Mine

FY 20-21



■ Cement ■ Bricks ■ Mine 18



Whether Plant is Zero Liquid Discharge - YES


Operational Measures

- Low Specific Water consumption (2.2 cum/MWh) , below the CEA guidelines (4.0 Cum/MWh).
- Use of imported low Ash, low Sulphur coal.
- Use of steel plant waste gas.
- 100 % Fly ash utilization.


Environment Management Initiatives

- Reed bed based STP over conventional or domestic effluent treatment and use for plantation
- RO based effluent recycling plant to maximize recycling and balance effluent for ore beneficiation at steel plant.
- Rain water harvesting for water utilization
- Use of low NOx burners to minimize formation of NOx at source.

Sp. Raw water consumption



Sp. DM water consumption



BEST PRACTICES ADOPTED FOR SUSTAINABILITY



Use of low ash (<15%) and low sulphur (< 0.6%) imported coal to mitigate pollution




Usage of Electro chlorination in place of gas chlorination for micro biological control in Cooling towers



Closed conveyors / enclosed galleries in coal handling plant with bag filters / dust extraction and dust suppression systems at strategic points




Low-NOx burners with OFD to minimize NOx formation



The Existing IFM gas Igniter (LPG has primary fuel) has been replaced with HEA IGNITOR which helped to eliminate safety hazard and consumption of natural resource.



JSW group is Committed towards Net Zero Coal by 2050.



Action Plan- By 2030, we are planning 20 GW with 81% renewable energy. We are majorly focusing on renewable energy like Hydro, Solar, Wind, PSP.



JSW Neo Energy Ltd

The Green Energy Platform of JSW Energy

5.9 GW of installed capacity by CY 24

Current Generation Capacity (3,509 MW)



Under Construction Generation Capacity (2,403 MW)



Energy Products and Services



UTILIZATION OF RENEWABLE ENERGY SOURCES

Source	Year	Installed capacity (in MW)	Generation (in Million kWh)	Consumption (in Million kWh)	Share %
SOLAR	2022-23	225	392.4	392.4	100



225 MW Solar plant
commissioned on 6th
April 2022



610 MW Wind
projects under
installation

Existing energy monitoring system / IOT system

- OSI PI based Monitoring system with Realtime and historic dashboards for Heat rate, APC, Excursions, Turbovisory,


ISO 50001 certification

- We are an ISO 50001 Certified company

Learnings from CII energy award or any other award program

- CII and other Energy Awards give us awareness of what best and innovative practices are going around the world. It gives us the opportunity to showcase and share our best practices with the industry.

IT INITIATIVES





Procurement

1. Coal ViU
2. Coal Inventory
3. Coal Logistics Tracking



Reliability

1. IOT based vibration sensors
2. Excursion management system
3. SAP customized RCM tools.



Efficiency

1. AI/ML models for Heat Rate optimization
2. APC Benchmarking & Real time Monitoring
3. Mobile Application



Human Resource

1. CWMS
2. GPS Tracking
3. Drone Inspection
4. Darwin box

Elements of Employee Engagement

LONG SERVICE AWARD

SHRINIVAS SVOGA DISTRICT

Holi Celebration



UGADI Celebrations



Oliko Sense® Enterprise

HOME FINANCE PLANT PERFORMANCE BOARD MIS COAL INTELLIGENCE HR APC PERFORMANCE SNAPSHOT MARKET INTELLIGENCE MAINTENANCE PROCUREMENT AIRRA COMMERCIAL WIP

Power Monitoring Expert

0 500 0 1,881,432

ABT Monitoring System

JSW Energy Limited, Vijaynagar, Torangallu

Home

Home

Real Time

Dashboard

Communication

Single Line

KPI Reports

<<<<
ALL Lines
>>>>

CONSUMERWISE SG
PRICE VECTOR

	Block-1	Block-2	Block-3	Block-4	Block-5	Block-6	Block-7	Block-8
	00:00-00:15	00:15-00:30	00:30-00:45	00:45-01:00	01:00-01:15	01:15-01:30	01:30-01:45	01:45-02:00
Avg Freq (Hz)	49.99	49.99	49.98	49.98	49.98	50.02	50.04	50.03
Availability(MW)	245.00	245.00	245.00	245.00	245.00	245.00	245.00	245.00
Sch.Exp.(MW)	244.95	244.95	244.95	244.95	20.63	20.63	20.63	20.63
Act.Exp.(MW)	265.64	219.60	181.96	190.57	65.23	16.52	-0.80	30.48
UI(MWH)	5.17	-6.34	-15.75	-13.59	11.15	-1.03	-5.36	2.46

	Block-9	Block-10	Block-11	Block-12	Block-13	Block-14	Block-15	Block-16
	02:00-02:15	02:15-02:30	02:30-02:45	02:45-03:00	03:00-03:15	03:15-03:30	03:30-03:45	03:45-04:00
Avg Freq (Hz)	50.04	50.05	50.04	50.04	50.02	50.04	50.05	50.07
Availability(MW)	245.00	245.00	245.00	245.00	245.00	245.00	245.00	245.00
Sch.Exp.(MW)	20.63	20.63	20.63	20.63	20.63	20.63	20.63	20.63
Act.Exp.(MW)	40.10	10.89	16.75	28.36	27.51	11.24	28.01	-6.51
UI(MWH)	4.87	-2.44	-0.97	1.93	1.72	-2.35	1.85	-6.78

ABT Monitoring System - Developed By Schneider Electric

ISO CERTIFICATION

Bureau Veritas Certification

JSW ENERGY LIMITED

POST BOX NO. 09, TORANAGALLU, BALLARI DISTRICT - 583 123,
KARNATAKA, INDIA.

Bureau Veritas (India) Pvt. Ltd. (Certification Business) certify that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the Management System Standards detailed below

Standards

**ISO 9001:2015, ISO 14001:2015,
ISO 45001:2018 & ISO 50001:2018**

Scope of certification

**GENERATION OF 2X130MW & 2X300MW ELECTRICITY
FROM THERMAL POWER PLANT**

Original cycle start date ISO 9001 & ISO 14001: 08 December 2007
Original cycle start date ISO 45001: 29 January 2021
Original cycle start date ISO 50001: 08 May 2014
Expiry date of previous cycle for ISO 50001: 20 November 2022
Recertification Audit date for ISO 50001: 01 October 2022
Recertification cycle start date: 07 December 2022

Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: 07 December 2026


Certificate No. IND.22.8904/IM/N Version: 1 Issue date: 07 December 2022

Certification Authority
Jagdish N. MANIAN
Director - CERTIFICATION, South Asia
Commodities, Industry & Facilities Division

Local office: Bureau Veritas (India) Private Limited (Certification Business)
77 Business Park, Marol Industrial Area, MIDC Cross Road 1C,
Andheri (East), Mumbai - 400 092, India.

Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization. To check the certificate validity please call + 91 20 624 2006.





Five Star Occupational Health and Safety Audit Report

JSW Energy Ltd. - Vijayanagar

Post Box #9, Sandur-Taluk Village & Post
Toranagallu
Bellary District - 583123
Vijayanagar
Karnataka
India

Audit by: Alok Agrwal
Date of audit: 9 to 12 May 2023
Reference number: IND-FSA/236535

Version 1.0



Five Star Occupational Health and Safety Audit – Five Stars –

Valid until 11th May 2024



This is to certify that

JSW Energy Limited, Vijayanagar

after an extensive evaluation by a British Safety Council auditor, has been awarded a rating of Five Stars.



Mike Robinson
Chair of the Board of Trustees
Chief Executive

Certificate number
IND-FSA/236535

Issue Date
12/05/2023



Because Experience Counts

British Safety Council (Company Limited by Guarantee) Registered in England and Wales No. 44570. Registered Charity No. 109727 and CGO No. 90037696

AWARDS & ACCOLADES



Best Energy Efficient Unit in IPP below 250 MW SBU1 U1
Organized by the Council of Enviro Excellence



Green Crest Energy Conservation Award 2022
by Green Maple Foundation



"National Efficiency Award - 2023" for Best Thermal Power Performer-
by Mission Energy Foundation.



National Power Plant Award 2023 in the category of CPP above 135 MW
by Council of Enviro excellence



Best Energy Efficient Plant - Coal
Organized by Mission Energy



Jury awards for Innovation and Renewable initiatives Organized by the Indian Chamber of Commerce



National Award for Excellence in Energy Management 2022"
Organized by Confederation of Indian Industries



"National Energy Management Award 2021 organised by Society for Energy Engineers and Managers

“See every day as an opportunity to **Better Everyday**”

Thank You

kumar.ivaturi@jsw.in, 9449879370

hemant.chouhan@jsw.in, 9449879368

varaprasad.sriramoju@jsw.in, 9449879435

BETTER EVERYDAY