



25th National Award for Excellence in Energy Management 2024

CCC, Coimbatore

September 2024

Agenda

| | | | |
|--|----|---|----|
| • Cognizant overview | 3 | • Innovation project | 17 |
| • Facility overview | 4 | • Utilization of renewable energy sources | 21 |
| • Architectural design of the building | 6 | • Waste management | 23 |
| • Awards and recognitions | 7 | • GHG emission and indoor air quality | 24 |
| • We committed | 8 | • Measuring, monitoring and training | 25 |
| • Energy consumption overview | 9 | • IGBC – LEED certificate | 27 |
| • Benchmarking and energy conservation approach | 10 | • Net zero goal | 28 |
| • Energy saving projects implemented in last three years | 14 | • Way forward | 29 |

Cognizant overview

Cognizant is one of the world's leading professional services companies with a vision to become the preeminent technology services partner to the Global 2000 C-Suite.

Snapshot

In January 2024, we celebrated **30 years** of serving our clients.

approximately **3,47,700** employees. **1,33,600** women employees.

Operations in nearly **50** countries.

Three strategic pillars

- Accelerate growth
- Become an employer of choice
- Simplify our operations

Four business segments

- Financial services
- Health services
- Products and resources
- Communications, media and technology



Facility overview

CCC (Cognizant Coimbatore Campus) is an owned facility.

Commencement of operation from:

- SDB1 – 2009
- SDB2 – 2014 (Tower – 2)
– 2016 (Tower – 1)

Campus area :


- SDB1 – 6.56 Lakhs ft² with G+7 floors
- SDB2 – 6.50 Lakhs ft² with G+7 floors(Tower – 1&2)
- Green belt spread across 4.0 Lakhs ft²

Seat capacity : 14,040

- SDB1 – 5,770 seats
- SDB2 – 8,270 seats

1st Facility in Cognizant to attain “LEED India Gold Certification”.

ISO 45001:2018 Certified Facility






Software Development Block-1



Software Development Block-2

Utilities overview

| Description | | Specification | |
|-------------------------|---|---|--|
| Substation |  | <ul style="list-style-type: none"> EB Demand : 4,600 kVA Transformers Capacity : 2,500 kVA x 6 Nos (Oil cooled transformers) | |
| Roof Top Solar |  | <ul style="list-style-type: none"> Total Capacity : 750 kW_p (2 x 375 kW_p) | |
| Diesel Generators |  | <ul style="list-style-type: none"> Total Capacity : 15,000 kVA | <ul style="list-style-type: none"> Capacity Break up : 10 Nos x 1,500 kVA |
| UPS |  | <ul style="list-style-type: none"> Total Capacity : 2,860 kVA (Workstation – 2,300 kVA) | |
| Chillers |  | <ul style="list-style-type: none"> Total Capacity : 6090 TR Type - Water Cooled : 3 Nos x 950TR 3 Nos. X 900TR 2 Nos. x 270TR | |
| Sewage Treatment Plant |  | <ul style="list-style-type: none"> Capacity : 2 Nos x 375 kL per day | |
| High Speed Diesel (HSD) |  | <ul style="list-style-type: none"> Capacity : 60 kL | |
| Rainwater Sump |  | <ul style="list-style-type: none"> Capacity : 70 kL | |

Architectural design of the building



Façade glass (SHGC – 0.36 W/m2)



Roof top solar (750 kWp)



100% - EC fan at AHU in SDB-1



**100% - Water cooled chillers
(kW – 0.65 kW/TR)**



**100% - Modular UPS
(Efficiency - 99%)**



100% LED lights @ workstation

Awards and recognitions



Cognizant

Best Energy Saving Facility
2011 & 2012



CII
Excellent Energy Efficient
Unit 2013



CII
Excellent Energy Efficient
unit
Most Useful Presentation
2019



CII
– Excellent Energy
Efficient Unit 2022



CII
– Energy Efficient Unit
2023

We committed in 24rd National Award for Excellence in Energy Management 2023



SBR unit installation for cooling towers water treatment

👍 Completed



Lift room across ventilation system to avoid running of DX unit

👍 Completed



AHU – EC fan retrofit at SDB-1

👍 Completed




OCEMS system installation at STP Plant


👍 Completed

Energy consumption trend – 2021, 2022 & 2023



Energy consumption trend in million kWh



Monthly energy consumption trend last 3 years in million kWh



Cognizant's approach



****Current EPI : 0.52 with occupancy of 60%.**

National benchmark comparison

Benchmark data - BEE for buildings where air-conditioned area is 50% more than carpet area bandwidth at buildings for 3 climate zones


| EPI in kWh / m ² / Year | | | |
|------------------------------------|----------------|-----------|-------------|
| Star rating | Warm and humid | Composite | Hot and dry |
| 1 Star | 200 – 175 | 190 – 165 | 180 – 155 |
| 2 Star | 175 – 150 | 165 – 140 | 155 – 130 |
| 3 Star | 150 – 125 | 140 – 115 | 130 – 105 |
| 4 Star | 125 – 100 | 115 – 90 | 105 – 80 |
| 5 Star | Below 100 | Below 90 | Below 80 |

| Coimbatore facility EPI | | | | | |
|-------------------------------|------|------|------|------|------|
| Description | 2019 | 2020 | 2021 | 2022 | 2023 |
| EPI: kWh/m ² /year | 117 | 54 | 30 | 34 | 54 |





* Solar energy excluded.

Cognizant internal benchmark comparison




Specific energy consumption (kWh/m²/Year) – 2019 to 2023

Baseline : 2019 Consumption with Full occupancy
SEC (Estimate) : (Baseline Actual kWh – Cumulative Energy savings in the previous & current year kWh) / Sqm / Year



* Solar energy excluded.

Our journey on ECM




** ECM–Energy conservation measures

Summary on ENCON projects – Investments

| S. No. | Title of project | Year | Total annual energy saving (kWh) | Total annual savings | Investment made | Payback |
|--------|--|------|----------------------------------|----------------------|------------------|----------|
| | | | | (INR in million) | (INR in million) | (Months) |
| 1 | New condenser coil replacement at SDB-1 chiller- 1 900TR | 2020 | 87,060 | 0 | 4.49 | 0 |
| 2 | LED retrofit- Workstation space - 2x36W CFL to 24W LED lights around -705 numbers | 2021 | 15,216 | 1.21 | 1.17 | 12 |
| 3 | LED retrofit - Downlighter 18W CFL to 12W LED – 800 numbers (Raw and EL) | 2021 | 5,530 | 0.21 | 0.69 | 39 |
| 4 | LED retrofit for SDB-2 Tower- 1 and 2 staircase lights (EL) from 2x18w CFL to 20W LED (surface mounted) fitting – 40 numbers | 2021 | 1,53,504 | 0.08 | 0.09 | 14 |
| 5 | Cooling tower fills replacement retrofit at SDB-1 1000 TR CT 3 and 300 TR CT 2 | 2021 | 1,45,152 | 2.14 | 1.05 | 6 |
| 6 | STP plant - one stream of 375KLD aerator system optimization | 2021 | 8,460 | 2.02 | 0 | 0 |
| 7 | LED retrofit- Workstation space - 2x36W CFL to 24W LED lights around – 1,800 numbers | 2022 | 2,30,124 | 3.45 | 3.45 | 13 |
| 8 | LED retrofit - Downlighter 18W CFL to 12W LED – 80 numbers (Raw and EL) | 2022 | 1,728 | 0.03 | 0.03 | 11 |
| 9 | Solar LED retrofit - 35w LED streetlights to 35w LED solar base inbuilt battery – 12 numbers | 2022 | 7,200 | 0.11 | 0.11 | 49 |
| 10 | Energy efficient power transformer retrofit at SDB-1 substation – 1 number | 2022 | 3,015 | 1.91 | 1.91 | 38 |
| 11 | HVAC retrofit- Hub room BVRF to IVRF ODU replacement at SDB-1 – 4 numbers (2 X 22HP) and (2 X 12HP) | 2022 | 98,280 | 1.14 | 1.14 | 20 |
| 12 | HVAC retrofit - LDPA unit to chilled water-based AHU unit installation- 2 numbers (22TR LDPA to 15TR AHU) at SDB-1 GF UPS and battery room | 2022 | 36,000 | 0.55 | 0.55 | 44 |
| 13 | SDB-1 and café block EC fan retrofit activities - 58 numbers | 2023 | 3,96,000 | 5.94 | 5.94 | 22 |
| 14 | HVAC retrofit - Lift room across ventilation system and eliminated complete split -2TR x 2 numbers - 1 number of lift room | 2023 | 1,27,02 | 0.15 | 0.29 | 23.46 |
| 15 | LED retrofit - Downlighter 18W CFL to 12W LED - 500 numbers (Raw and EL) | 2023 | 14,400 | 0.216 | 0.216 | 8 |
| 16 | Solar LED retrofit - 35w LED streetlights to 35w LED solar base inbuilt battery - 10 numbers | 2023 | 6,000 | 0.09 | 0.09 | 20 |
| 17 | HVAC retrofit- Additional VAV control on uncontrolled direct throw at SDB-1 7F reception area | 2023 | 1,500 | 0.0225 | 0.0225 | 91 |

Energy saving projects implemented – 2020 to 2023



| Year | Number of energy savings projects | Investments (₹ INR million) | Energy Save (Million kWh) | Cost Save (₹ INR million) | Impact on SEC (%) |
|------|-----------------------------------|-----------------------------|---------------------------|---------------------------|-------------------|
| 2021 | 5 | 3.01 | 0.41 | 5.66 | 9.15% |
| 2022 | 7 | 16.22 | 0.64 | 10.93 | 12.77% |
| 2023 | 7 | 15.65 | 0.43 | 6.65 | 6.49% |

Innovative Project : Lift room cross ventilation system



Challenges

- Lift room temperature maintained by Split unit (2TR)
- Operational cost is high
- Frequent breakdowns
- R22 Refrigerant




Innovation


- Lift room temperature to be maintained by Passive Cross ventilation
- Instead of Split units, Exhaust fans are used

| | |
|-------------------------|----------------------------------|
| Split Units | 2 TR – 8 No's Total - 16 TR |
| Operational Hour | 12 |
| Split AC consumption | = 3.4 * 16 * 12 = 119,136 kWh |
| Exhaust Fan consumption | 17,520 kWh |
| Savings/Annum | 101,616 kWh |
| Cost Saving / Annum | 1.5 Million INR |
| Investment | 1.5 Million INR |

Overall layout



Lift room Cross ventilation system



Major Project: EC Fan Retrofit at workstation AHU's



| | |
|--------------------------|------------------------------|
| AHU Locations | SDB1 & Food Court |
| Retrofit Quantity | 58 |
| Investment | 19 Million INR |
| Savings/Month | 33,000 kWh |
| Savings/Annum | 396000 kWh |
| Saving/Annum | 5.9 Million INR |

Major Project: HVAC Retrofit - BVRF to IVRF Energy efficient Replacement



Objective

Conversion of BVRF to IVRF
Energy efficient ODU replacement



Process

4 nos of
2 X 22 HP
&
2 X 12 HP



Target

- Avoid of breakdown
- Highly efficient inverter compressors with 0.8 iKW/TR
- CO₂ reduction on refrigerated avoidances.



Growth

- Energy savings: **98,280 kWh**
- Cost savings: **11.59 Lakhs**

Before



22 HP BVRF unit

After



22HP IVRF unit

BVRF to IVRF - Energy savings

| SI No | Old BVRF | New IVRF Capacity HP | Power consumption (Before) | Power consumption (After) | Total Power Savings |
|-------|--------------------------------|-------------------------|----------------------------------|---------------------------------|------------------------|
| | Capacity HP | | | | kWh |
| 1 | 2 X 21 | 2 X 22 | 240 | 95 | 145 |
| 2 | 2 X 12 | 2 X 12 | 220 | 92 | 128 |
| 3 | Power Savings/Day | | | | 273 |
| 4 | Achieved Power Savings/Annum | | | | 99,645 |
| 5 | Cost per month (Rs.11.64/unit) | | | | 1,159,868 |
| 6 | Total Cost of replacement | | | | 1,807,128 |
| 7 | ROI in years | | | | 1.56 |

Major Project:



LED retrofit - Replacement of CFL into LED lamps to reduce energy conservation

Objective:

Energy consumption reduction by converting CFL into LED lamps.

Benefits:

- Reduced carbon footprints
- Reduction in E-waste generation for next 5 years.
- Lower energy costs & improved efficiency

Over all savings:

Approximate Avg. energy saving per year– **1.44 Lakhs kWh**

PO Screen Snap

C2846-V4-R80 31-Mar-23




LINE ITEM DETAILS (2 LINE ITEMS)

| NO. | DESCRIPTION | PART NUMBER | QTY | NO. | DESCRIPTION | PART NUMBER | QTY |
|-----|--|-------------|----------|-----|--|-------------|----------|
| 1 | SUPPLY OF 13WLED CIRCULAR RECESSED CEILING DOWN LIGHT, CCT-3000/4000/5700/6500 K | Part no 20 | 200 each | 2 | INSTALLATION OF 13W LED CIRCULAR SHAPE RECESSED CEILING DOWN LIGHT | Part no 53 | 200 each |



| Sl.no | Energy savings activities description | Qty | savings per Month in kWh | savings per Annum in kWh | cost per unit | Cost savings per year (Rs in Million) | Investment (Rs in INR) |
|-------|---|---------|--------------------------|--------------------------|---------------|---------------------------------------|------------------------|
| 1 | LED Retrofit - Downlighter 18 W CFL to 12W LED - 500Nos (Raw and EL) | 500 nos | 1200 | 14400 | 15 | 216,000 | 243,200 |

Utilization of renewable energy sources




90% is through renewable energy

■ EB ■ Wind ■ Solar ■ DG

| Year | EB | Wind (Offsite) | Solar (Onsite) | DG | Total | % of Renewable |
|------|----------|----------------|----------------|----------|-----------|----------------|
| 2021 | 3,521 | 35,12,227 | 7,57,263 | 1,68,137 | 44,41,148 | 96% |
| 2022 | 1,19,760 | 39,29,634 | 8,71,594 | 1,24,390 | 50,45,378 | 95% |
| 2023 | 5,04,470 | 58,42,429 | 1,40,430 | 1,52,480 | 66,39,809 | 90% |



Offsite wind wheeling



Onsite rooftop solar (750 kW_p)

Utilization of renewable energy sources – 2021, 2023 & 2023

Onsite renewable energy sources

| Year | Source | Installed capacity (in MW) | Capacity addition (MW) after FY 2021 | Total Generation (million kWh) | Share % w.r.t to Overall energy consumption |
|------|--------|----------------------------|--------------------------------------|--------------------------------|---|
| 2021 | Solar | 0.75 | 0 | 0.76 | 17% |
| 2022 | Solar | 0.75 | 0 | 0.87 | 17% |
| 2023 | Solar | 0.75 | 0 | 0.14 | 2% |

Offsite renewable energy sources

| Year | Source (Solar, wind, etc.,) | Total offsite installed capacity (MW) | Consumption by the company (million kWh) | Share % w.r.t to overall energy consumption |
|------|-----------------------------|---------------------------------------|--|---|
| 2021 | Wind | 256.85 | 3.51 | 10% |
| 2022 | Wind | 256.85 | 3.92 | 12% |
| 2023 | Wind | 256.85 | 5.84 | 14% |

- Solar Bill to operate model, installed capacity of **750 kWp**
- Third-party purchase under group captive agreement.
- Installed capacity: **256.85 MW**.
- Total wind energy contracted quantum: **525 lakhs kWh**.

Waste management



E-waste disposed through authorized recycler.



Food waste processed through OWC and utilized as manure.



Paper waste processed through ITC.



STP plant recycled water utilized for WC flushing, gardening.




Ban on single-use plastic as per TNPCB.




Batteries disposed through authorized recycler.

Recycle Certificate



GHG emission trend



GHG emission:

- Cognizant will source 100% renewable energy by 2026.
- Absolute emissions reduction by 50% in 2030.
- Absolute emissions reduction by 90% in 2040.


| Sources | Refrigerant | | | | | | | Diesel | LPG | Electricity | Scope 1 | Scope 2 |
|---------|-------------|-------|-------|-------|------|-----|-------|--------|-----------------|-------------|------------|------------|
| | R22 | R134a | R407C | R410A | R125 | R32 | R404A | Diesel | LPG consumption | Grid unit | | |
| UOM | kg | kg | kg | kg | kg | kg | kg | liter | kg | kWh | Ton of CO2 | Ton of CO2 |
| 2021 | 9.22 | 620 | 30 | 155.5 | 0 | 0 | 0 | 69,825 | 564 | 3521 | 1,471.4 | 2.85 |
| 2022 | 9.5 | 0 | 10.5 | 76.8 | 0 | 0 | 0 | 57,700 | 2,612 | 1,19,760 | 359.6 | 97.01 |
| 2023 | 5 | 0 | 0 | 104 | 0 | 0.8 | 0 | 53,681 | 9,738 | 5,04,470 | 380.8 | 415.18 |

Indoor air quality


| Type of system installed | Investment (INR in millions) | Year of installation | Benefits achieved | Parameters monitoring (O2, CO2, PM 2.5, PM 10, etc.,) | Type of system installed |
|--------------------------------------|------------------------------|----------------------------|---|---|--------------------------------------|
| CO2 monitoring for our premises | 0.245 | Through third-party vendor | Good indoor air quality maintained to ensure EHS in office premises | Temperature, CO2, CO, O2, RPM, TVOC and RH | CO2 monitoring for our premises |
| Indoor air quality monitoring system | 0.277 | Through third-party vendor | Good indoor air quality maintained to ensure EHS in office premises | Temperature, CO2, CO, O2, RPM, TVOC and RH | Indoor air quality monitoring system |

Measuring, monitoring and training


Energy report monitoring and review flow chart




Energy report monitoring and review flow chart



Best practices



Digitalization



Digitalization



Digitalization



Power quality improvement

- Live monitoring on critical systems.
- Energy savings through automation.

IGBC – LEED Certificate




◀ SDB - 1



SDB - 2 ▶





















Net Zero Goal and action plan



- In 2021, we announced our **Net Zero Goal**, a science-based approach to eliminate or offset our GHG emissions in line with the Paris Agreement.
- Net Zero Goal (compared to our 2019 emissions baseline).
 - 2030 – Reduce absolute emissions by 50% in our global operations and supply chain, offsetting the rest.
 - 2040 – Reduce absolute emissions by 90% in our global operations and supply chain, offsetting the remaining, unavoidable emissions.
- In April 2022, we announced our objective to source 100% of our energy needs for our offices and facilities from renewable sources, solar and wind, by the end of 2026.
- We plan to achieve our Net Zero Goal through six main levers: Renewable energy, green buildings, travel reduction, green IT and data centers, supply chain engagement and carbon offsets.

Way forward 2024 to 2025

-  SBR unit – Cooling tower water treatment - 
-  HVAC Retrofit - BVRF to IVRF ODU replacement - 
-  HVAC Retrofit – Lift room cross ventilation - 
-  Hybrid Solar based battery inbuilt LED streetlight - 
-  AHU – EC Fan Retrofit at SDB-2 - 
-  Higher efficiency HVAC pump retrofit - 
-  Emission control device - 
-  Electrical vehicle charging station - 
-  Solar Net feed-in upgradation - 

| Investment towards energy saving projects in 2024 | |
|---|----------------------------|
| No of energy savings project in 2024 | Investment (Rs in Million) |
| 7 | 31 |

Thank you

S. Sudhakar – Senior Manager

Jayaprakash. M – Chief Engineer