



# 25<sup>th</sup> National Award for Excellence in Energy Management 2024

MEPZ - Chennai

September 2024

# Contents

1. Cognizant overview
2. Facility overview
3. Passive design features
4. Energy consumption overview (2021-2023)
5. EPI in last three years (2021-2023)
6. Information on internal and national benchmark
7. Energy saving projects implemented in last three years
8. List of major Encon projects planned in 2024
9. Innovative projects implemented
10. Utilization of renewable energy sources (2021-2023)
11. GHG emission
12. Measuring and monitoring device and tool
13. Awards and certifications
14. Waste management
15. Net Zero action plan

# Cognizant overview

Cognizant is one of the world's leading professional services companies with a vision to become the preeminent technology services partner to the Global 2000 C-Suite.

## Snapshot

In January 2024, we celebrated **30 years** of serving our clients.

approximately **3,47,700** employees. **1,33,600** women employees.

Operations in nearly **50** countries.

## Three strategic pillars

- Accelerate growth
- Become an employer of choice
- Simplify our operations


## Four business segments

- Financial services
- Health services
- Products and resources
- Communications, media and technology



# Facility Overview

- Owned facility is at MEPZ. The operations commenced from 2008.
- Campus area: 14.45 acres.
- Total built-up area: 1,87,890.14 square meters.
- Ground coverage in square meters: 21,750.89
- Soft green area in square meters: 7,432
- Area of the terrace in square meters: 1,383.51
- Five blocks (SDB1, SDB 2, SDB 3, SDB 4 MLCP and cafeteria).
- Exclusive medical center with ambulance service.
- Seating capacity: 13,207.
- BAU head count: 11,558 associates.
- Present head count: 10,800 (As of Aug 2024).
- Certified for ISO 45001 and ISO 14001.





# Passive design features

## SDB-1 & Cafeteria



## SDB 2



## SDB 3



## SDB 4



- ❑ IGBC - LEED India for New Construction - Gold
- ❑ Building orientation: North - South
- ❑ Solar heat gain coefficient (SHGC) of glass: 0.25
- ❑ Visual light transmittance (VLT): 31
- ❑ Super insulated envelopes


- ❑ Healthy Indoor Air Quality Environment
- ❑ Heat reflection tiles installed in the roof of building
- ❑ 3M Sun Film glasses sheet placed in the window
- ❑ Day lighting strategies incorporated
- ❑ Natural ventilation for fresh air supply to AHU

# Utility overview


Description	Specification / capacity	Break up
<b>Substation</b>	EB demand: 14,200 kVA	Phase I : 8,400 kVA   Phase II : 5,800 kVA
Incomer supply: 33kV / 433 V.	Transformers capacity: 18,250 kVA	2,500 kVA x 1 No's  2,000 kVA x 4 No's  1,750 kVA x 4 No's  750 kVA x 1 No
Diesel generators	Total capacity: 14,625 kVA	1,500 kVA x 8 No's  2,000 kVA x 1 No's  625 kVA x 1 No's
UPS	Total capacity: 4,510 kVA	500 kVA x 2 No's   200 kVA 2 No's   300 kVA – 1No's  250 kVA – 1No's 150 kVA – 16 Nos   80 kVA – 2 Nos
Chillers	Total capacity: 4910 TR	Water cooled chiller: 420 TR x 5 No's
		Air cooled chiller: 375 TR x 4 No's  200 TR x 1 No's  155 TR x 2 No's  110 TR x 2 No's  90 TR x 2 No's  70 TR x 2 No's  65 TR x 4 No's
Sewage treatment plant (STP)	Capacity: 535 KLD	535 KL x 1 No
Water treatment plant (WTP)	Capacity: 480 KLD	20 KL per Hour x 15 Hour / Day operation currently
High speed diesel (HSD)	Capacity: 70 KL	35 KL x 2 No's
Raw water sump	Capacity: 672 KL	Phase I – 422 KL   Phase II – 250 KL
Rainwater sump	Capacity: 400 KL	200 KL x 2 No's
Rooftop Solar PV plant	Capacity : 10 kW	10 kW x 1 No

# Energy consumption overview - 2021 to 2023

Energy consumption comparison (kWh)





Source wise Energy utilization (%) - 2023



**Remark:**

- Energy share contribution by wind energy is 78.41%, EB units is 20.51%, DG units is 1.04% and solar units is 0.04%.
- Energy consumption in 2019: 20.15 MU | 2020: 10.42 MU | 2021: 7.50 MU | 2022 : 7.69 MU | 2023: 10.70 MU.
- Energy consumption in 2023 has been increased due to increased headcount at office. Percentage of HC for the seating capacity | Base year **2019 HC: 90%** | **2021 HC: 4%** | **2022 HC: 7%** | **2023 HC: 35%**. | **2024 HC: 83%**.

# Specific Energy Consumption (SEC) Overview - 2021 to 2023



**Remark:**

- Energy consumption in 2019: 20.15 MU | 2020: 10.42 MU | 2021: 7.50 MU | 2022 : 7.69 MU | 2023: 10.70 MU.
- Energy consumption in 2023 has been increased due to increased headcount at office. Percentage of HC for the seating capacity | Base year **2019 HC: 90%** | **2021 HC: 4%** | **2022 HC: 7%** | **2023 HC: 35%**. | **2024 HC: 83%**.



# National & Internal Benchmark

## National Benchmark - BEE

EPI in kWh/Sq. m./ year			
Star rating	Warm and humid	Composite	Hot and dry
1 star	200-175	190-165	180-155
2 star	175-150	165-140	155-130
3 star	150-125	140-115	130-105
4 star	125-100	115-90	105-80
5 star	Below 100	Below 90	Below 80

## Internal Benchmark - CODE 001

CO - Complaints	D - Downtime	E - Efficiency
Complaints relating to comfort : Zero	Downtime of equipment : Zero	Efficiency – 1 unit per square foot per month

## Climatic Zone - ECBC

City	Climatic zone
Chennai	Warm and humid
Coimbatore	Warm and humid
Bangalore	Moderate

### Inference:


- SEC estimate for our campus is 85.38 kWh/sq.mtr. Which is 15% lesser than the 5 Star rated benchmark of 100 kWh/sq.mtr.

## Internal benchmark for Owned campus - 2023

Owned campus	EPI (kWh / Sq. m./ Annum)
CBE - CHIL – SEZ	49.1
CHN - Siruseri	54.4
CHN - MEPZ - SEZ	68.9

# Energy saving projects vs SEC impact analysis

2021	Implemented No. of ECM project : 1 Investment Cost : ₹ 0.7 Million Energy Savings : 0.02 Million kWh Cost Savings : ₹ 0.16 Million
2022	Implemented No. of ECM project : 4 Investment Cost : ₹ 7.56 Million Energy Savings : 0.57 Million kWh Cost Savings : ₹ 5.37 Million
2023	Implemented No. of ECM project : 4 Investment Cost : ₹ 138.18 Million Energy Savings : 6.32 Million kWh Cost Savings : ₹ 60.05 Million



## Summary of Savings



# Major project 1: Replacement of old air-cooled chiller with energy efficient Water-cooled chiller and Air-cooled chiller

## Key highlights

	<b>Energy savings</b> 61,40,844 kWh/ annum
	<b>Investment</b> INR 12,98,57,630
	<b>Cost savings</b> INR 5,83,38,018
	<b>Payback period</b> 2.3 Years
	<b>Emission reduction</b> 4,974 MT

### Problem statement

- Existing air-cooled chiller kW was 1.45 kW/ TR and energy consumption was high.

### Goal/ success measure

- We have upgraded the centralized conventional Air-Cooled chiller system of 4235 TR capacity to the Hybrid chilled water system of 3600 TR (Water-Cooled Chiller – 2100 TR and Air-Cooled Chiller – 1500 TR).

### Benefits

- The designed chiller plant efficiency between 0.61 kW/TR to 0.66 kW/TR has been achieved based on our monitoring of the project over the last six months.

### Other key benefits

- The upgraded system adjusts more efficiently to maintain set temperatures, catering to varying weather conditions and occupancy levels. Consequently, this translates to greater energy conservation, improved comfort for occupants, an enhanced environment for productivity, and a smaller environmental footprint.

# Chiller retrofit before and after implementation

Existing System: Air cooled chiller



Air cooled chiller:  
 11 x 385 TR  
 (11 x 539 kW)

Implemented System: Hybrid Water cooled & Air-cooled chiller



Water cooled chiller:  
 5 x 420 TR  
 (5 x 253.3 kW)



Air cooled chiller:  
 4 x 375 TR  
 (4 x 474.9 kW)








**CL Reduction: 635 TR ( 2,288 kW)**



# Major Project 2 : EC fan retrofit for eight FCUs in SDB- 2 and 3

## Key highlights

	<b>Energy savings</b> 1,38,408 kWh / annum
	<b>Investment</b> INR 8,51,371
	<b>Cost savings</b> INR 13,14,876
	<b>Payback period</b> 8 months
	<b>Emission reduction</b> 114 MT

### Problem statement

- Existing belt driven fans were inefficient and resulted in losses due to the belt driven operation.

### Goal/success measure

- Eight conventional belt driven fans in the air handling unit have been replaced with energy efficient EC fan in SDB- 2 and 3.
- Four existing 3.7 kW fans and four 5.5 kW fans replaced with 3.5 kW in SDB- 2 and 3.

### Benefits

- Minimum power consumption, better efficiency and high air performance.
- Easy speed control and integration with BMS.

### Other key benefits

- Energy saving achieved and equivalent CO<sub>2</sub> emission is avoided.

# Major project 3: Providing hot water through heat pumps for dishwasher machine instead of using electric heater in cafeteria

## Key highlights



### Energy savings

1,38,000 kWh/ annum  
78.03 Mn kCal/ annum



### Investment

INR 9,43,276



### Cost savings

INR 13,11,000



### Payback period

9 months



### Emission reduction

114 MT

### Problem statement

- The existing dishwasher machine with electric heater consumes higher energy. The plan is to provide hot water through heat pumps for the dishwasher machine instead of using electric heater in the cafeteria.

### Goal/ success measure

- To reduce the energy consumption by adopting heat pump system for hot water requirement instead of electric heater.
- Existing 3 x 31 kW heaters were replaced with 2 x 12 kW heat pumps in cafeteria.

### Benefits

- Heat Transfer efficiency improvement.
- Environment friendly and cost effective.

### Other key benefits

- Energy saving achieved and equivalent CO<sub>2</sub> emission is avoided.

# Innovative project : Consolidate of primary and secondary pump with variable primary flow pump with VFD

## Key highlights




### Energy savings

13,01,089 kWh/ annum



### Investment

INR 1,23,81,920



### Cost savings

INR 1,23,60,348



### Payback period

1 Year



### Emission reduction

1,071 MT

## Problem statement

- Existing primary and secondary pump setup was very old, and energy consumption were high.

## Goal/ success measure

- We have upgraded the pumping system of 645 kW capacity (Primary Pump – 195 kW & Secondary Pump – 450 kW) to the Variable primary pump of 550 kW.

## Benefits

- Direct Pump load reduction of 95 kW.
- Pump efficiency improvement with VFD modulation.

## Other key benefits

- Energy saving is achieved.
- Equivalent CO<sub>2</sub> emission is avoided.

# Pump retrofit before and after implementation

Existing System: Primary and secondary pump system



Primary pump:  
13 x 15 kW

Secondary pump:  
6 x 40 kW  
7 x 30 kW

Implemented System: Variable primary flow pump system



Variable primary  
flow pump:  
10 x 55 kW  
(with VFD)




CL Reduction: 95 kW



# Utilization of renewable energy sources


Source	2021	2022	2023
EB (kWh)	42,212	10,29,678	21,94,661
DG (kWh)	82,940	90,257	1,10,846
Solar (kWh)	6,762	5,606	4,235
Wind (kWh)	73,67,630	65,61,514	83,88,571
<b>Total</b>	<b>74,99,545</b>	<b>76,87,055</b>	<b>1,06,98,313</b>



Group Captive – Offsite Power Purchase				
Year	Source (Solar, wind, etc.,)	Total offsite installed capacity (MW)	Consumption by the company (million kWh)	Share % w.r.t to overall energy consumption
2021	Wind	256.85	13.74	41%
2022	Wind	256.85	10.96	31%
2023	Wind	256.85	12.49	28%

Wind energy utilization reduced in 2023 compared to 2021 and 2022 due to less wind generation and allocation.

# GHG emission inventORIZATION



**Remarks:**


- Total CO<sub>2</sub> emission has been reduced by 87% compared with the baseline of 2019: 22,610 MT.
- Wind energy utilization reduced in 2023 compared to 2021 and 2022 due to less wind generation and supplies.
- Allocated wind energy in 2021: 41%, 2022: 31% and in 2023: 28%.

**Indoor air quality**


Type of system installed	Monitoring Method	Monitoring Period	Parameters monitoring	Benefits achieved
Ambient Air Quality monitor system	Online & External vendor	Realtime (IBMS) / Monthly (External)	Temperature, CO <sub>2</sub> , CO, O <sub>2</sub> , RPM, TVOC and RH	Good indoor air quality maintained to ensure EHS in office premises
Indoor air quality monitoring system	Online & External vendor	Realtime (IBMS) / Monthly (External)	Temperature, CO <sub>2</sub> , CO, O <sub>2</sub> , RPM, TVOC and RH	Good indoor air quality maintained to ensure EHS in office premises

# Water Management

## Sources of Water & Usages



## Water Percapita (LPD per Employee)



# Waste Management

## Waste management process (waste stream mapping and disposal / recycling process)



### Paper waste recycle, Reduce & Reuse

- Limitation of printer access
- E Fit tool implemented, and manual check list optimized
- Paper cups usages eliminated 100%



### Plastic waste Recycle

- Segregated and stored separately
- Disposed only through authorized recyclers
- Single use and throw away plastics are banned inside the campus



### Solid (garbage) waste Incineration

- All solid wastes generated are disposed within the SLA through the authorized vendors.



### Hazardous / E-waste/ battery waste Recycle

- Battery waste extension of battery warranty (3 to 3.5 years)
- E Waste CFL to LED retrofit to enhance the lifetime & reduce the waste generation.

### Organic waste converter



- Capacity : 130 Kg / Hour
- Input : Food / Vegetable waste and saw dust
- Output : Organic manure
- Recycle : Approximately 390 kg per day
- Utilization : Campus landscape and Weekly distribution to employees



# Inhouse Team Initiatives

Dining Door floor spring modification (90° to 0°)



Timer Controller for Peripheral Lighting




Heat Pump for Dishwasher machine hot water demand



MHL 70W with Solar LED 20W peripheral location




Lighting Operation control Via BMS



Motion Sensor for Restroom Lighting Control



Process & Comfort Chiller HVAC raiser interconnection



World Earth Hour Celebration



# Standardization of Best Practices

## Air-Conditioning



- Workplace temperature policy standardized 24°C to 26°C
- Maintaining UPS/ Battery room temperature b/n 25°C to 26°C
- Hub room temperature-maintained b/n 24°C to 26°C
- Standard operation temperature for all freezer equipment

## Kitchen / Pantry



- Elimination of electrical hot plate
- Mandatory use of BEE star rated equipment's
- Scheduled operation of ventilation system
- Weekly deep cleaning for all type of freezer

## Employee engagement



- QR code-based feedback system
- Common mailer on Go Green initiatives
- Awareness creation to associates on ECM
- Energy conservation day celebration

# Measuring and monitoring devices and tools

Monthly Report

Report >> Energy Management

Report: Energy Management | City - Facility: CHN - MEPZ - SEZ | Month - Year: 2023-6 | Consumption Target (in KWH): 1485080.64

Power | Diesel

Consumption Details

Total EB Units (in KWH)*	14278	Total DG Units (in KWH)*	5881	Bio Gas Units (if any) (in KWH)	0
Solar Power Units (if any) (in KWH)	588	Wind Power Units (if any) (in KWH)	1423802	Total Energy Consumption (in KWH)	1444549
FPI	0.00	PER Canita	207.64		

Daily Report

Facility: CHN - MEPZ - S... | Report Date: 08/07/2023

Power | Water | Diesel | Refrigerant | E & M Status

Description	Actuals	Target
EB Power Consumption (KWH)*	53640	0
Power Factor *	0.984	0
Solar Power Consumption *	43	0
DG Power Consumption (KWH) *	0	0

Save

cognizant

IND-CHN-MEPZ

DATE & TIME : 06/17/2024 10:11:36 AM

AHU Units | CSU Units | Switch Room Temperature | AHU RAT Summary | UPS System | RAW Water Management

Water Flow Meter | Fire Fighting System | Fire Alarm System status | Energy Meter | BMS INFO

Map of India showing locations: HR, UP, WB, MH, TS, KA, AP, KL, TN.


## Daily module

- Consumption details and breakup
- Hourly breakup-transformer/ DG/ chiller
- Diesel consumption
- Water report
- Refrigerant status
- Equipment status

## Monthly module

- Monthly module
- Facility details
- Consumption details
- Billing details
- Diesel consumption

# Measuring and monitoring devices - IBMS



## SDB1\_AHU\_SUMMARY

Location	AHU SCHEDULE	On/Off Cmd	AHU Set Point	Run Sts	Filter Sts	A/M	Trip Sts	RAT	Valve Cmd	Valve FB	VFD Cmd	CO2
SDB1_01F_CR3_AHU01	false	Off	24	Off	Clean	Auto	Normal	25.2 °C	100.0 %	83.2 %	78.9 %	704.5 ppm
SDB1_01F_CR1_AHU01	true	On	24	On	Clean	Auto	Normal	23.1 °C	94.0 %	80.6 %	5.6 %	604.0 ppm
SDB1_01F_CR2_AHU01	true	On	24	On	Clean	Auto	Normal	23.6 °C	68.1 %	68.0 %	43.9 %	661.7 ppm
SDB1_01F_CR4_AHU01	false	Off	24	Off	Clean	Auto	Normal	24.8 °C	100.0 %	0.0 %	80.0 %	612.5 ppm

cognizant

Current User: 478090  
Nagara Version: 4.11.0.142  
23-Aug-24 7:23 PM IST

### IND-MEPZ EXHAUST FAN SUMMARY

23-Aug-24 7:23 PM IST

Logoff

SDB2 EXHAUST FAN SUMMARY						
Location	Status	ON/OFF CMD	RUN STATUS	A/M STATUS	TRIP STATUS	
EX_FAN01	●	Off	Off	Manual	NA	
B_WING_TOILET_EX_FAN02	●	On	On	Auto	NA	
ELECTRICAL_ROOM_EX_FAN03	●	Off	Off	Auto	NA	
C_WING_TOILET_EX_FAN04	●	On	On	Auto	NA	

# Award and certification

## LEED India for New Construction - Gold



## Energy Efficient Unit Award in 2019





# Net Zero Goal and action plan

## Our Net Zero Goal

2026

Source

**100%**

renewable energy, or derivatives thereof, for all our global offices and facilities



2030

Reduce absolute emissions by

**50%**

in our global operations and supply chain, offsetting the rest



2040

Reduce absolute emissions by


**90%**

in our global operations and supply chain, offsetting the remaining, unavoidable emissions




- In 2021, we announced our **Net Zero Goal**, a science-based approach to eliminate or offset our GHG emissions in line with the Paris Agreement.
- Net Zero Goal (compared to our 2019 emissions baseline).
  - 2030 – Reduce absolute emissions by 50% in our global operations and supply chain, offsetting the rest.
  - 2040 – Reduce absolute emissions by 90% in our global operations and supply chain, offsetting the remaining, unavoidable emissions.
- In April 2022, we announced our objective to source 100% of our energy needs for our offices and facilities from renewable sources, solar and wind, by the end of 2026.
- We plan to achieve our Net Zero Goal through six main levers: Renewable energy, green buildings, travel reduction, green IT and data centers, supply chain engagement and carbon offsets.


# Way forward for 2024



# Learnings from CII Energy Awards



The Energy Awards highlight the latest innovations and technological advancements in the energy sector



The latest technology implemented by other competitors.



Benchmarking our organization performance with other peer companies



The Energy Awards highlight the latest innovations and technological advancements in the energy sector



The event emphasizes the importance of adopting sustainable practices and technologies to combat climate change and protect natural resources



The Energy Awards event fosters collaboration and knowledge sharing among industry professionals

# Thank you