

### FORTIS HOSPITAL MOHALI, A MULTY SPECILITY HOSPITAL

For

Cll 25th National Award for Excellence in Energy Management-2024 Presented By: - Mr Neeraj Tandon Chief Engineer



Email id: <u>neeraj.tandon@fortishealthcare.com</u> Mob.: 9872305900

# **BUILDING DETAILS**



Fortis Hospital Mohali Establishes in 2001, Approx
 2000 sqf/cardiac ICU bed instead of the normal 800 900 sqf/in Indian healthcare

➢Hospital set on sprawling 8.22 acres, with built up area of 50336 square meters.

>FHM is a 493 bedded (Census+Non-Census), JCI and NABH certified multi specialty tertiary care hospital,


Fortis Hospital, Mohali has won several awards, including; Best Design Award from American Institute of Architects, 1999.

	Total Plot Area	8.22acre				
	Built-up area	50336sqm				
1	No of Beds	493				
	<b>Operation Theatres</b>	17				
	Incoming Electrical	2 Sources 11KVA				
	Generators	1250KVA *3nos				
	Transformer	2000KVA*2nos				
	Chiller Plant	433TR*3nos				
		200KVA *3nos(UPS are in				
	UPS	parallel load with ATS),				
		120KVA *3Nos.				
	Fuel	PNG from AGL, HSD				

### Number of Buildings: 4

- IPD Block (A block)
- OPD Block (B block)
- Rehabilitation Centre
- Fortis Cancer Institute

## **NATURAL ENERGY USAGE FOR LIGHTING**




# **Energy Efficiency Summary**

Description	2019-20	2020-21	2021-22	2022-23	2023-24	% Change 2019-20 vs 2023-24
Specific Electrical Energy Consumption (kWh/Sqm)	111	102	107	107	110	-0.90%
kWh/Occupied Bed/Year	14141	13219	12876	12310	12278	-13.17%
Energy Consumption kWh in Lakhs	55.72	51.56	53.69	54.04	55.13	-1.05%

### What changed during 2019-20 to 2023-24?

In spite of increased patient Occupancy/Foot fall/ Equipment load by approx. 13.96 %, Specific Energy consumption (SEC) saved 0.90% and kWh/Bed Saved is 13.17% from FY 2019-20

<sup>4</sup>The nearest Competitor SEC (Specific Energy Consumption) of Hospital buildings stands at 124 Kwh / Sqm




13.17% kWh/Occupied bed reduction compared to 2019-20

Specific Energy consumption of Fortis Mohali stands at 110 kwh/m2 which is 45 % below the global bench mark and 46.34% below the National Benchmark

## **BENCH MARKING (KWH/SQM)**


## NATIONAL BENCH MARKING (KWH/SQM)



Reference A report on Energy efficient hospitals survey by *Cll*, **BEE National benchmark is defined for Hospitals is 200 kWh/m2** 


## International Benchmarking

### Specific Energy Consumption -kWh/Sq.Mtrs./year



Comparison of building energy benchmarks in Serbia, UK and Germany (CIBSE TM 46), (EnEv)----- KWH/M2 Fortis


# Roadmap for being Global Leader in Energy Efficiency....



## **BENCHMARKING – ENERGY USAGE- OUR CHALLENGES**

2022-23

- Current Consumption patterns ,Perpetual growth in facilities, diagnostic equipment's, additional beds thus increased Energy.
- Consumption patterns aren't fixed, they vary depending on the number of occupied beds, the footfalls & the local weather conditions. Increasing energy & Maintenance costs.
- Hospital are energy guzzlers. They not only adds to the operational costs but also to emissions that contribute to the anthropogenic green house gases



1% 3% 3% 2% 6% 9% 31% 8%

Lighting

Boilers

Medical Gases

DG Sets (Diesel generator)

- HVAC
- Medical Equipment
- Water Systems
- Laundry

STP (sewage treatment plant)

Equipment	Avg. Consumption 2023-24	Avg. Consumption 2022-23
HVAC (heating, ventilation, & air conditioning)	38%	39%
Lighting	8%	8%
Medical Equipment	32%	31%
Boilers	9%	9%
Water Systems	6%	6%
DG Sets (Diesel generator)	1%	1%
Laundry	3%	3%
Medical Gases	2%	3%
STP (sewage treatment plant)	2%	2%

# **Our Encon Journey**

### 2021-23

2022-23

**EPI 107** 

**Cooling Towers Approach** based Automated operations

2.Condenser Pumps with VFD

**3.Synchronized Elevators Operations** 

**4.RO Reject Water Reuse** 

**5.VFD operated Energy Efficient** OT AHU's

6.Conversion of old CPU's with Laptops and thin power saving CPU

2019-20

**EPI 110** 

### 2022-23

2. AHU with VFD

**1. VSD Chiller** 

3. BMS Operations

4. HVAC Primary Pump Stopage

**5. Energy efficient gearless** elevators

6. LED Lights

7. Disconnection of 2x80 KVA & 2X20 kVa UPS & given supply through main central UPS

8. Emergency lights on UPS to remain switched off , only to be on during power outage

> **BEE** National Benchmark 200

cood

2020-22

2019-20

**EPI 111** 

1999

**Best Design** Award from American Institute of Architects

**11.** Energy efficient gearless elevators 2. 5 no's VFD Operated AHU's

**3.** Solar PV Panels for Parking (2nd Phase)


4. Ahu replaced with EC fans

5. LED for new areas as well


2021-22 2020-21 **EPI 102 EPI 107** 


## SUMMARY OF PROJECT IMPLEMENTED IN LAST THREE YEARS

Year	No of Energy Saving Projects	Investments (INR Lacs)	Savings (INR Lacs)
2021-22	10	173.5	45.83
2022-23	7	167	44.44
2023-24	8	266	51.60



- Each year dedicated budget gets allocated towards
   Energy Conservation Projects
- Apart from technology up gradation, special focus is also given to operational optimization, to reduce energy wastage.
- Dedicated Energy Management cell looks after all Energy conservation projects and keep track of all regular energy saving activities.





### What changed during the last year?

4.64% kWh/Occupied bed reduction compared to 2020-21

Specific Energy consumption of Fortis Mohali is 110 kwh/m2 which is 45 % below the global bench marking and 46.34%

below the National Benchmark

# **Going Forward Targets**

## **ENCON PROJECTS PLANNED IN FY 2024-26**

Year	Description	
2024-25	Hydromx-Heat trnsfer Nano Fluid	
2024-25	Geothermal for chilled ground water	
2024-25	Open Access power Source	
2024-25	VFD for all the AHU's	
2024-25	VFD Operated Cooling Towers	
2024-25	Secondry Pumps with inbuilt VFD	
2024-25	Cooling towers fan replacement with FRP fans	
2025-26	OT AHU's replacement	
2025-26	VSD Chiller	
2025-26	Enhancing Renewable Energy	
2025-26	PNG for DG sets instead of HSD	
2025-26	Energy efficient elevators/cooling towers (2nd Phase)	
2025-26	Heat Pump for Hot Water	
2025-26	Power Optimizer for Chiller Machines	

Benchmarks 17762kWh/bed (By Bureau of Energy Efficiency, Govt. of India ECO-IIPProject)

## Innovative Project (1)

### Disconnection of 2x80 KVA & 2X20 KVA UPS & given supply through main central UPS

**Statement:** The design in FCI block was with two source of power with a facility to changeover to alternate source of power through ATS i.e. Automatic Transfer switch in case of power outage to all ICU's and OT's in new block. Thus power was fed through 2x80 kVA & LIGHTING WITH 2X20kVA UPS. Since main hospital building taking care of entire OT's set ups with central parallel operated 2x200 kVA UPS , Hence decided to put the 2X80kVA & 2X20kVA UPS load on central UPS thereby sparing 2x80 kVA & 2X20 kVA UPS from the system resulted in huge energy savings. This was indeed innovative.

**Trigger for implementing the project** Energy conservation is paramount not because to save money but to save wasteful energy and reduce the loss by innovating through kaizens and experience. Running of inductive motors besides whole lot of UPS in big tertiary care hospital consumes a lot of energy besides giving losses in the system both on load as well as on no load hence optimum utilization is the need of the hour. Thus triggered to save on energy triggered to do this innovative project for good.

**why innovative:** With Disconnection of 2x80 KVA & 2X20 KVA UPS & given supply through main central UPS ------ Few UPS were in use for ICU supply through ATS IN NEW BLOCK , Since load on these UPS were only 20% , HENCE DECIDED TO SHUT THEM BY SHIFTING THE LOAD ON Central UPS making it an innovative project.

### **Cost Benefit Analysis**

Energy Savings	132250kWh
Cost Savings	INR 10.91Lakhs
Investment	Nil
Payback	Immediately

### **Power Consumption Analysis**





### **Primary pumps stoppage**

**Statement:** Primary pump was delivering extra flow because it runs in series with Secondary pumps and Bypass line is fully closed. The design of HVAC pumping system was such that both Primary and Secondary pumps were put in use while Chillers were in use. But it was observed that when One Chiller remained in operation the required GPM were available even without running Primary pumps that is Secondary pumps were sufficient to make up the pressure. Hence stopped the Primary pump operation when Single chiller was in use. Whenever all 5 secondary pumps run they extract higher water through the system as they are fixed in line pumps.

**Trigger for implementing the project** This Innovation came up while evaluating the efficiency of chiller functioning during that time the Energy team made this observation and immediately the trigger was put across to OEM for confirmation and stopped the [Primary Pump of 7.5 Kw motor which resulted in huge Energy savings.

Why innovative: HVAC primary pump stoppage :Wasteful operation of primary pump stopped making it innovative . It was observed that Primary pump is delivering extra flow because it is running in series with the secondary pumps return line. Whenever all 5 secondary pumps run they extract higher water through the system as they are fixed inline pumps. and hence the required pressure was attained without running the primary pump required to feed chiller requirement.



#### Power Consumption Analysis Cost Renefit Analysis

Energy Savings	62500kWh						
Cost Savings	INR 5.50Lakhs						
Investment	Nil						
Payback	Immediately						




**Replication Potential :- Yes** 

## **Energy Savings Project Implemented in 2023-24**









**BMS** Operations

LED Lights



HVAC Primary Pump Stoppage



Energy efficient gearless elevators



Disconnection of 2x80KVA & 2X20 KVA UPS's

All Projects have Replication Potential

 Image: Contractor
 Image: Contractor

 Image: Contractor

Emergency lights on UPS to remain switched off , only to be on during power outage



AHU with VFD

### Savings of 5.82LkWh Power Units & 415MT CO2e

16

## **LIST OF ENERGY CONSERVATION PROJECTS IN 2023-24**

Projects	Annual Electrical Saving (KWH)	Electrical Savings (kW)	Annual Electrical Cost Saving (Rs million)	Total Annual Savings (Rs million)	Made		CO2e Reduction (MT)
VSD Chiller	98725	25	0.9	0.9	14	186.67	80.95
AHU with VFD	92500	16	0.82	0.82	5	73.17	75.85
BMS Operations	42500	18	0.38	0.38	0	0	34.85
LED Lights	65840	20	0.58	0.58	0.6	12.41	53.99
HVAC Primary Pump Stoppage	62500	50	0.55	0.55	0	0	51.25
Emergency lights on UPS to remain switched off , only to be on during power outage	20000	10	0.18	0.18	0	0	16.40
Disconnection of 2x80 KVA & 2X20 KVA UPS & given supply through main central UPS	132250	40	1.16	1.16	0	0	108.45
Energy efficient gearless elevators	67880	6	0.59	0.59	7	142.37	55.66
	582195	185	5.16	5.16	26.6	414.62	477.40
These projects have been replicated in other units							

These projects have been replicated in other units


0

## LIST OF ENERGY CONSERVATION PROJECTS IN 2021-2023


Sr. No	Title of Project	Year	Investment Made (Rs million)	Annual Savings (Rs million)	Payback (Months)	CO2e Reduction (MT)
1	Cooling Towers Approach based Automated operations	2022-23	1.025	0.624	17.20	62
2	Condenser Pumps with VFD	2022-23	1.05	0.25	88.80	25
3	Synchronized Elevators Operations	2022-23	7.25	1.153	75.26	112
4	RO Reject Water Reusage	2022-23	0	1.254	0.00	15
5	VFD operated Energy Efficient OT AHU's	2022-23	2.00	0.916	26.23	91
6	Conversion of old CPU's with Laptops and thin power saving CPU	2022-23	3.5	0.161	260.87	16
7	Timers for water coolers	2022-23	0.05	0.086	6.98	8
8	Energy efficient gearless elevators	2021-22	6.5	0.56	145	56
9	Disconnection of 2x80 KVA & 2X20 Kva UPS & given supply through main	2021-22	0	1.09	0	
9	central UPS					108
10	Trauma & Vascular OTs chilled water supplies routed through main pump	2021-22	0.15	0.33	11	33
11	Harnessed fresh air usage in winters for ICU, OT's and Patient rooms	2021-22	0.1	0.99	1	
<b>L</b> T	thereby chiller running was reduced					99
12	5 no's VFD Operated AHU's	2021-22	3	0.45	55	44
13	Solar PV Panels for Parking (2nd Phase)	2021-22	5	0.74	81	74
14	Ahu replaced with EC fans 1 no's for power savings	2021-22	1.5	0.16	44	16
15	Optimized electrical supply by switching off alternate lights /emergency	2021-22	0.1	0.08	15	
15	lights, motion sensors in office areas, washrooms					8
16	LED for new areas as well	2021-22	0.3	0.17	3	17
<b>17</b> 1	Mercury free hospital	2021-22	0.7	0 🏠	Forde	Care
Th	ese projects have been replicated in other units			п	101113	or good.

### **UTILISATION OF RENEWABLE ENERGY SOURCES**

Technology (Electrical)	Type of Energy	Onsite Solar PV Panels Installed Capacity (Kw)	Generation (I kWh)	Offsite Energy (RE) Purchased	Total Renewal Energy (LkWh)	% of Overall electrical Energy	Technology (Electrical)
2021-22	<b>Renewal Energy</b>	/ 480kW	5.99	0	5.99	11.04%	2021-22
2022-23	<b>Renewal Energy</b>	/ 480kW	5.92	27.26	33.18	61.40%	2022-23
2023-24	<b>Renewal Energy</b>	/ 480kW	5.18	49.37	54.55	98.95%	2023-24
Technology	(Thermal)	Type of Energy	On	site/Offsite	Installed Capa (kCal)	Usage (LCal)	% of Hot Water Usage
2021-	22 So	olar Water Heater		Onsite	8000	22.18	75%
2022-	23 So	olar Water Heater	•	Onsite		22.76	76%
2020-	21 So	olar Water Heater	· Onsite		8000 22.21		75%
	2023-24 Units Consumption (kWh) 2023-24					) 2023-24	



### Units Consumption (kWh) 2023-24



Onsite RE OffSite RE DG Units


19

## **Water Management**

- > Apply fresh water use reduction measures at FHM
- Improve water use performance
- Implement/manage water efficient landscaping systems
- Improve cooling tower water management performance
- Implement innovative water technologies for water efficiency improvement.



Water use reduction by efficient 550KLD Sewage treatment fixtures plant



### Water Consumption KLD/DAY



System level Water Metering facility



Rain Water Harvesting Pits

# **GHG Inventorisation**

Fortis Mohali is committed to GHG reduction not only by reduction of its own facilities but also creating Benchmarks for Indian Buildings as Smart Building.

Fortis Mohali Every year allocates Budget for Energy Efficiency program as a corporate initiative and allocate the budget based on Global competition, any project below 5years of pay back qualifies for it, This year Fortis Mohall has allocated approx. 26.6 Million INR for this program Globally.

2023-24 Project was part of the same corporate budgeting program.

### Reduction of 2214tCO2e tons from 2019 till 2024.

		FHM - 1B	
	FORTIS HOSPIT/	Page No: 1 of 2	
1 Fortis	POLICY ON GREEN PUR	Reviewed on: 1/7/22	
TUNIS	HOSPIT	Valid till: 30/6/25	
PREPARED BY Head Engineering	APPROVED BY Director		

#### 1.0 Purpose

To mitigate ill effects of environment (GREEN) on patients and staff and even hasten the recovery process through infection free ambience (CLEAN).

#### 2.0 Scope

The entire hospital building (structural Requirement), processes followed and outcome measured.

#### 3.0 Procedure

- 3.1 The process shall cover the
- a) Environment Management Requirement
- b) Structural Requirement
- c) Process Requirement
- d) Outcome Requirement

#### 4.0 Responsibility

Various departments across FHM FOLLOWING DIFFERENT LAWS AND REGULATIONS APPLICABLE AS PER STATE, NATIONAL LAWS AND FOLLOWS JCI/NABH/AHPI GUIDELINES.

#### 5.0 Outcome:-

- Hospital has established monitoring, review & verification of Procedures
- b. Reports (Third Party Validation)
- Reports (mild Party validation
   Purchasing green products

5.0 Reference:

## **Sources of Emission at FHM**

## Direct Emission Scope 1

- Fuel emission from BoilersFuel emission from DG set
- •Fuel emission from Fire drill
- •Emission from Fire extinguishers
- •Emission from Air conditioners & refrigerators

**Energy Indirect Emission** 

Scope 2

•Emission from Electricity usage

•Emission from RE (as per ACI guideline)

## Other Indirect Emission Scope 3

•Fuel emission from Patients and their attendants vehicles.

•Emission from employee daily commute

•Emission from employee business travel

•Electricity emission by concessionaires


# Green Supply Chain

a. Information on Projects implemented- Our Housekeeping cleaning Agents & Card Board and Wooden Packing Boxes are purchased from identified vendor who manufactures with Recycled material.
 b. Information on Evaluation done- Different vendors were evaluated and manufacturing processes and materials used were certified by FHM as per FHM standard before giving clearance for the Boxes.

c. Information on Benefits achieved- 50% reduction in cost and contribution to green initiative by the company.

Use of 100% LED lights in entire complex






Minimize exposure of building occupants and cleaning personnel to potentially hazardous chemical, biological and particulate contaminants Our Green chillers provide air conditioning comfort with lowest electrical energy





Segregation of dry and wet garbage at kitchen Wet garbage 100% recycling through AGA for piggery Forms

# **Carbon Footprint Reduction**



Base 2019-20 2020-21 2021-22 2022-23 2023-24

### **Reduction of CO2 Emission in Tons**

### What changed in 3 years ?

Year

Reduction of 13.16% CO2e/bed from 2019-20

Reduction of 2214 tCO2e from 2019-20

Reference IFHE : International Federation of Hospital Engineering 2013 CO2e Calculation for EB units from Central Electricity Authority of India (0.82kg/unit) CO2e Calculation for PNG from www.epa.Gov/energy/greenhouses (1.95mtCO2/SCM) CO2e Calculation for HSD from ecoscore.be (2.64kg/litre)

# **Towards Carbon Positive Hospital**

Renewable Energy Harnessing	<ul> <li>Solar Energy</li> <li>Solar Water Heater</li> <li>Rain Water Harvesting</li> <li>STP water for Gardening</li> </ul>	
Awareness and Training	<ul> <li>Energy Cell</li> <li>Daily monitoring</li> <li>Trainings</li> <li>Energy Audits</li> <li>Suggestions and implementations</li> </ul>	
Technical Intervention	<ul> <li>Efficient Water Cooler Chillers</li> <li>Energy efficient Pump and Motors</li> <li>LED Lightings</li> </ul>	2031144 BRHAUDR SUPPORT
Efficiency Improvement	<ul> <li>Benchmarking</li> <li>Auditing</li> <li>Monitoring</li> <li>Analyzing</li> <li>Improving</li> </ul>	GOAL

od

# **Environmental Monitoring**

# FHM strives to maintain healthy indoor air Quality.

- **3**<sup>rd</sup> **party air quality check** is done at regular intervals.
- Co2 sensors installed in return ducts of all AHUs & automatic fresh air intake when value crosses set parameters.
- Portable Co2 meters used to check Co2 level in all offices & crowdy areas multiple times in a day
- In FY2023-24, UV lamps being installed in all AHUs to upgrade the quality of indoor air.


Sr. no.	Parameters	Results	Standard	Test Method
1	Suspended Particulate Meter(PM)	6.8µg/m³		IS:5182(P-23):2006 Reaff. 2017
,	Respirable Suspended Particular Meter (PM10)	71.2	100.0µg/m³	IS:5182(P-23):2006 Reaff. 2017
3	Sulphur Dioxide (SO2)	6.3	80.0µg/m³	IS:5182(P-2):1999 Reaff. 2001
4	Nitrogen dioxide (NO2)	20.4	80.0µg/m³	IS:5182(P-6):2006 Reaff. 2017
5	Fine Particulate matter (PM2.5)	37.3	60.0µg/m³	SOP (ETL/SOP/02-Section- 4):2015
6	со	ND	2.0µg/m³	IS:5182 (P-10)
7	Lead (pb)	ND	1.0µg/m³	Lab. SOP (BY AAS)
8	Ozone (O3)	ND	100.0µg/m³	CPCB Guideline





### **<u>Rich landscape of Greenery</u>** is

maintained, which further upgrades the air quality & gives a feel-good attitude to all stakeholder




# **Waste Utilization and Management**

- We believe in "waste to wealth" and we adapted the system of segregation and recycling since beginning.
- Paper & Carton boxes, Oils & Food/canteen waste is handled by FHM Facility Management Services and sold to scrap dealers.
- Horticulture waste is composted by us onsite.
- Electronic waste, Metal waste & some paper waste is sell to the authorized vendors.
- > Old PCs, UPS, Converters, chairs, etc are given to desirous employees/sell to the PPCB authorized vendors.
- FHM is Zero Discharge Building. Storm water goes to RWH.
- Waste water is treated using MBR technology and 100% of the treated water is used for irrigation, flushing and AC cooling tower top-up.
  Waste Generated (kg/Occupied bed)



# Education imparted to Patients, Attendants, vendors & associates segregation of waste to minimize land pollution



## Why is ESG relevant for healthcare?



If the health sector were a country, it would be the fifth-largest emitter on the planet!

- Healthcare's climate footprint is equivalent to 4.4% of global net emissions (2 gigatons of carbon dioxide equivalent).
- Fossil fuel consumption is at the heart of healthcare's emissions. Emissions emanating directly from health care facilities & owned vehicles (Scope 1) make up 17% of the sector's worldwide footprint. Indirect emissions from purchased energy sources (Scope 2) comprise another 12%.




### **ENERGY MANAGEMENT**

- Hospitals are highly energy-intensive, using 2.5 times more energy per square foot than an office building.
- A 30% cut in health care electricity's carbon pollution by 2030 would reduce Green house gas emissions preventing an estimated 4,130 premature deaths, 85,000 asthma attacks, 4 million respiratory symptom events, 3,750 hospital visit incidents

### WASTE AND BIO-HAZARDOUS WASTE MANAGEMENT

• Globally, hospitals produce an average of 13.6 kg of waste per patient per day.

# Energy excellence frame work-FHM



# Energy Measurement, Monitoring & Reporting

- Dedicated energy Meters for all the panels
- Separate energy meters for lighting, HVAC
- All the Tenants have separate energy meter.
- ✤ All the energy meters are linked to BMS for energy monitoring.
- Record of daily energy meter recording
- Annual calibration of all energy meters.
- Carry out variance analysis of energy.











# ENCON – O&M BEST PRACTICES



- > Set point of chillers are manually controlled based on ambient condition.
- Automatic Scheduling for AHUs and Ventilation fans.
- > De-scaling of Water Cooled condenser tube and cleaning of Air Cooled condensers.
- Chemical Treatment for make up water
- Cleaning of Air Filters in AHUs and FCUs.
- Timers & Motion sensors for external & Corridors Lighting
- Reporting of carbon emission to CDP
- Mapping & reduction of carbon emission as per ACA
- Use of automated building Management System
- Use of renewal energy for day to day operations



## Kaizen Initiatives by in-house Technicians & Supervisors Team

Timer Controller for peripheral lighting




Motion Sensor for corridors



Limit Switch for Air curtains and Fire shaft Door



Damaged pedestal fan converted into wall mounted fan in engineering Area



Battery Operated Emergency lights in Corridors/stairs



Auto Operation of DG Fresh Air/Exhaust fans



Conventional lights replacement with LED




Modification in ducts for Two OT's ran with one AHU



cood.

# **Learning from CII Energy Award programs**



# **Implementation of ISO 50001**

**ISO 50001 Implementation WIP** 

0.05% investment of energy saving projects on total turnover of the company

## **COMMUNITY & NEIGHBORHOOD BENEFIT PROGRAMS**





- School Buddies Program (Trainings for fire safety & Electrical safety)
- Taken park adjacent to hospital and maintaining with STP treated water
- Safety Trainings to staff on protocols with creation of negative pressure OT's
- > Trainings given to staff on Electrical safety, fire safety & Hand Hygiene
- Maintaining round about with STP treated water.
- FHM Top management committee involved in planting of trees in Hospital premises on world environment day
- Sharing of best practices among the industries
- Implementation of R&R scheme for energy & water conservation project.
- Training /awareness for contract labour/Office staff on energy conservation.











# Long Term Vision On Energy Efficiency

- \* We aim at bringing down our SEC of 111 to double digit figure in the future.
- **\*** Zero CFC gas emissions from any system at the facility.
- Maximum clean Energy use at the facility through renewables
- 100% recycling of paper and plastic waste.
- ✤ Accreditation from IGBC/ISO50001, BEE, AHPI etc.

### **SUPPORT NEEDED:**

### **Technical:**

Further hiring the right consultants for other Energy conservation activities at the facility in any form (Building construction, resource conservation etc.).

### **Financial support:**

The investment, Par of the monetary Energy saving is given to FHM that is further used for sustainable activities at the hospital

### Supplier Engagement:

Need consultant for IGBC/ISO50001 certification Energy managers and technical support available for FHM



# **ENCON EFFORTS: Key Impact**


Area	Key Impact	
Energy Efficiency	<ul> <li>4.64 % KWh/occupied bed reduction achieved in last 3 years</li> </ul>	/
Water Conservation	<ul> <li>4.70 % reduction/occupied bed in last 3 years</li> </ul>	
GHG Reduction	• 4.64% Reduction in GHG Emission since last 3 years	
Waste Management	• 100% Kitchen waste being used to make manure	
Green Supply Chain	<ul> <li>Environment friendly HK/Cleaning agents &amp; Chem.</li> </ul>	
Others	<ul> <li>Started use of Eco friendly HK chemical and paint</li> </ul>	

Special Focus on Reduction of "Energy" and "Water" Consumption




# **Globally Green: Healthcare** BEST PRACTICES FOLLOWED

Natural lighting in patient areas Green house keeping Better Indoor Air Quality Sound Reduction Mercury free hospital □ 5-10% Energy savings □ 5-10% water savings **Good day lighting** No sick building syndrome Faster patient recovery



Ben<sup>40</sup>hmarks 17762kWh/bed (By Bureau of Energy Efficiency, Govt. of India ECO-IIPProject)

## **ENCON Roadmap – Sustaining continual**



## **FHM Awards & Recognition**

