



# CII Energy Excellence Awards 2023-24

## Maithon Power Limited

(A Joint Venture Company of Tata Power & Damodar Valley Corporation)

Lighting up Lives!

# Brief Introduction

## About Us: TATA Power



TATA POWER

**Empower A Billion Lives Through Sustainable, Affordable & Innovative Energy Solutions**



**40% Green Energy**

**Carbon Net Zero by 2045**

**100% Water neutral by 2030**

**1st utility with approved SBTi**

**19 consecutive Quarter PAT growth**

**Conventional Energy**


**Renewable Energy (Hydro/Solar/Wind/Waste Heat)**

**Transmission**

**Distribution**

**Power Trading**

**EZ Charging & EZ Home**



# Brief Introduction


## About Us: Maithon Power Limited



TATA POWER

### Maithon Power Limited (2x525 MW) JV of Tata Power (74%) & DVC (26%)

ISO Certifications
ISO 9001: 2015 13.01.2014 09.01.2026
ISO 14001:2015 13.01.2014 09.01.2026
ISO 45001:2018 13.01.2014 09.01.2026
ISO 22301:2019 31.08.2018 30.08.2024
ISO 50001:2018 11.03.2019 09.03.2025
ISO 27001:2013 10.11.20121 09.11.2024
ISO Standard Inception Validity



Regulatory & Governing Bodies
Central Electricity Authority
Central Electricity Regulatory Commission
Ministry of Power
Ministry of Coal
Ministry of Environment & Forests
Central Pollution Control Board
Jharkhand State Pollution Control Board
Govt Of Jharkhand
National LDC
Eastern Region load Dispatch Centre
Indian Railways

<b>4 Rs/kwh</b> Tariff	<b>3000 Cr</b> Revenue	<b>300 Cr+</b> PAT	<b>2500 +</b> Allied Workforce	<b>104 Ha</b> Afforestation	<b>65K+</b> Individuals
---------------------------	---------------------------	-----------------------	-----------------------------------	--------------------------------	----------------------------

# Energy Consumption Overview

## Current Year Performance




TATA POWER

Energy Data	UoM	FY24	w.r.t FY23
Annual Generation	MUs	8179	8.3% ↑
PLF	%	88.7	6.5% ↑
PAF	%	95.6	4.7% ↑
Station APC	%	5.42	3.8% ↑
Station GHR	kcal/kwh	2339	0.4% ↑
Boiler Efficiency *	%	85.4	
Turbine Cycle Heat Rate *	kcal/kwh	1998	
Specific Oil Consumption	ml/kwh	0.11	20% ↑
Raw Water Consumption	M3/Mwh	2.21	5% ↑
DM Water Consumption	%	0.74	11% ↑


\* Station




Generation



Revenue



EBIDTA





PAT

### Highlights for FY24:

- *MPL featured amongst the **top 10 IPP** power stations across India based on PLF rankings.*
- **5 Golden Star** recommendation by National Safety Council
- **Gold Recognition** by World Safety Organization for Safety & Environment.
- **385 days of continuous operation of Unit 1** without Boiler Tube leakage
- *Effective ash utilization of **105% in FY24** including **59% gainful ash utilization.***
- *CRISIL has revised rating to "**CRISIL AA/Positive**" rating for long-term borrowing.*

# Specific Energy Consumption

## Journey towards Operational Excellence




- Poor Coal Quality & Cyclic Stress**
  - Historical data analysis of zone-wise boiler pressure parts based on previous failure trends & RCA of such failures
- Customized action plan to mitigate the RCA of each area**
- Overheating**
  - In-house developed modified binders for HRH & CRH coils to prevent failures & misalignment
- BTL accounts for 90% FO**
  - Upgradation of HRH & CRH tube material to TP347H
- Provision of 270° shields in vulnerable hangers of Economizer & LTSH

- 2.81**  
Rs/kwh  
**FY24 Energy Charge Rate**
- >10**  
Lakhs  
**Above FSA Coal**
- 2% ↓**  
**LT Beneficiary Forego**
- 5% ↓**  
**Ancillary Scheme**


# Specific Energy Consumption

## Journey towards Operational Excellence


### Station GHR



### Station APC



### Sp Oil Cons



#### ❖ Six Sigma :

**Sustenance of U1 1<sup>st</sup> stage Pressure in FY23**

- 1) **Platinum Award in CII National 6 $\sigma$  Competition**
- 2) **Silver Award in ASQ SATEA Quality Competition**
- 3) **1<sup>st</sup> in generation cluster 6 $\sigma$  Competition**

#### ❖ Innovation through Digitalization :

- 1) **TCS IP2- Digital Twin : Dare to Try**
- 2) **Combustion Optimization Tool (In-house)**

#### ❖ Six Sigma : Improvement of Station APC in FY22

- ❖ **Digitalization : ENMS Dashboard**
- ❖ **Innovation : APC Optimizer Tool (In-house)**

#### ❖ Digitalization : Start-up Oil Tool Kit

#### ❖ Best Practice (Delta) :

- 1) **Judicious charging of HPH6 after HP-LPBP charging**
- 2) **Coal Feeder minimum loading reduced from 15 tph to 9 tph during startup**

**17 kcal/kwh Net Heat Rate** improvement in FY24 w.r.t FY23

# Competitors, National & Global benchmark



## Benchmarking


Gross Heat Rate



- Short Term Action Plan**
- ❖ U2 Turbine module Overhauling
  - ❖ CT Fills replacement
  - ❖ Data Analytics : Soot Blowing Optimization Tool
- Long Term Action Plan**
- ❖ Data Analytics : AI/ML integration
  - ❖ Upgradation of Combustion Optimization Tool


- Action Plan :**
- ❖ HFO to LDO Conversion
  - ❖ Start-up oil press optimization

Specific Oil Cons



- Short Term Action Plan**
- ❖ Upgradation of ID Fan VFD LCI
- Long Term Action Plan**
- ❖ Replacement of existing CT fans FRP blades with high efficiency energy saving E-glass Epoxy FRP blades
  - ❖ Coro-coating of CW Pumps

Aux Power Cons






# Road Map To Achieve National/Global Benchmark



## Major ENCON Project Planned In FY 2024-25

TATA POWER



*(1) Replacement of CT fan FRP blades by efficient E glass Epoxy FRP blades*

*(2) U2 Drive Turbine Overhauling*

*(3) U2 Main Turbine Overhauling*

*(4) U2 APH basket & seal replacement*

*(5) CT Fills replacement in 8 cells*

**ENCON PROJECTS**  
**FY25**

**64.6**  
Million Rs

*FY25 Investment*

**26820**  
Mkcal

*Thermal Savings*

**11.5**  
MUs

*Electrical Savings*





# Energy Savings Projects Summary for Last 3 Years



Year	ENCON Projects (Nos)	Investments (Rs Million)	Electrical Savings (Million kWh)	Thermal Savings (Million kcal)	Total Savings (Rs Million)
2021-22	5	0.00	2.90	6882	7.33
2022-23	7	64.04	12.64	29674	33.97
2023-24	6	24.31	29.29	68526	79.91

**Total Major ENCON Projects Implemented**


**18 Nos**

**Total Investments in 3 years**

**8.84 Rs Crs**

**Total Savings in last 3 years**

**12.12 Rs Crs**



***FY22 all ENCON projects implemented without any investment. All were process improvement carried out through brainstorming and adoption of best practices.***

<i>Title of Project</i>	<i>Annual Electrical Saving (kWh)</i>	<i>Annual thermal Saving - million kCal</i>	<i>Total Annual Savings (Rs million)</i>	<i>Investment Made (Rs million)</i>	<i>Comments/ Project details</i>
<i>Optimization of Coal Mill Operation based on PLF</i>	1000000	2374	<b>2.51</b>	0.00	<i>1419 hrs 4 mills operation @ &lt;65% MLF &amp; 2487 hrs 5 mills operation @ &gt;85% MLF by increasing mill capacity utilization.</i>
<i>Stopping of Hot-well make up pump for 20 hours per day to optimize the power consumption by gravity filling in both units</i>	231000	548	<b>0.58</b>	0.00	<i>Auto stopping &amp; standby of both hotwell make up pump by logic changes has been implemented in both unit &amp; gavity filling line for hotwell make up is lined up in both units resulting in stopping of hotwell makeup pump for 20 hrs per day.</i>
<i>Main plant air compressor power consumption optimization through reduction of header press set point.</i>	348000	826	<b>0.88</b>	0.00	<i>3 nos of compressors were in service with header set point reduced from 6.4 ksc to 6.1 ksc. Receiver drain timer setpoint optimized.</i>
<i>Primary Air header pressure optimization to reduce the PA fan power consumption</i>	956000	2270	<b>2.45</b>	0.00	<i>PA header pressure optimized from 765 to 750 mmwc, resulting in reduction of 5 amps PA Fan motor current for individual unit.</i>
<i>Air handling Unit ( AHU) power consumption optimization</i>	364000	864	<b>0.91</b>	0.00	<i>8 out of 16 Air washery blowers' operation stopped (for TG1/TG2/compressor house/DG house) during low ambient temp (for 2 months during winter)</i>

# Energy Saving Projects Implemented In 2022-23

Title of Project	Annual Electrical Saving (kWh)	Annual thermal Saving - million kCal	Total Annual Savings (Rs million)	Investment Made (Rs million)	Payback (Months)	Comments/ Project details
Arresting air infiltration in Unit#1 Boiler flue gas path & Air Pre-Heater (APH). Energy saving due to reduction in gas load for ID Fan, FD Fan & PA Fan.	1295700	3042.3	<b>3.67</b>	1.82	6.0	Arresting air infiltration in U#1 Boiler's flue gas path and Air Preheater (APH) can indeed result in significant energy savings due to the reduction in (flue gas+air) load. The project was planned during U#1 annual shutdown in Q4 FY23.
Unit#1 APH basket & seal replacement. Energy saving due to reduction in Boiler flue gas exit temperature.	1523412	3577.0	<b>4.07</b>	16.27	48.0	Energy savings primarily by reducing the boiler flue gas exit temperature. It has Improved the Heat Transfer Efficiency and better environmental compliance by lowering emissions of pollutants such as NOx.
Overhauling of Unit#1 Turbine modules. Energy saving due to reduction in 1st stage steam pressure.	5980868	14043.1	<b>15.97</b>	21.69	16.3	Overhauling Unit#1 Turbine modules and reducing the 1st stage steam pressure can result in energy savings through improved efficiency, reduced steam consumption.
Unit-1 TDBFP Cartridge replacement. Energy saving due to reduction in live steam flow in TDBFP.	1013295	2379.2	<b>2.71</b>	4.23	18.7	It results in significant energy savings due to the reduction in live steam flow required for pump operation.
Condenser Cleaning & CT fills replacement of Unit-1 to improve Condenser vacuum	1882577	4420.3	<b>5.03</b>	10.19	24.3	Condenser cleaning & CT fill replacement for Unit-1 can lead to significant improvements in condenser vacuum, energy savings, and overall plant efficiency.
CT fills replacement to improve Condenser vacuum in Unit#2	711388	1670.3	<b>1.90</b>	9.84	62.2	Improvement in condenser vacuum, energy savings, and enhancement of overall plant efficiency.
Unit#1 HP Heater Overhauling. Energy saving due to FW Temp improvement at Economizer inlet	230767	541.8	<b>0.62</b>	0.00	0.0	Energy savings by improving the FW temp at the economizer inlet. This results in reduced fuel consumption, optimized boiler operation.

Title of Project	Annual Electrical Saving (kWh)	Annual thermal Saving - million kCal	Total Annual Savings (Rs million)	Investment Made (Rs million)	Payback (Months)	Comments/ Project details
Unit# 2 ID Fans power consumption reduction by boiler APH water washing and arresting of flue gas duct air ingress	6927107	16203.9	<b>19.39</b>	4.10	2.5	APC Reduction : (1) Reduction of APH DP and (2) Rectification of flue gas duct air in leakages.
Stopping of Unit# 1&2 Cooling Tower ID fans w.r.t. Condenser Vacuum	755526	1767.3	<b>2.11</b>	0.00	0.0	Reduction in APC due to strategic stopping of IDCT fans during low load & winter season.
Reduction of DM Water Make up by Optimization of APRDS Steam Consumption	7608432	17797.6	<b>19.47</b>	0.00	0.0	APRDS Flow optimized from 12 TPH to 9 TPH by decreasing press Set point from 12 to 10 kg/cm <sup>2</sup> .
Unit# 1&2 CT fills replacement (total 12 Nos) to improve the Condenser Vacuum	13221833	30928.5	<b>36.75</b>	20.21	6.6	Improvement in heat rate by 4.57 kcal/kwh.
Optimization of Air washery blowers running hours during winter season when ambient temp below 30 degC	553093	1293.8	<b>1.55</b>	0.00	0.0	Revision of air washery blower running SOP based on brainstorming & past data.
AHP Stage-2 Conveying Air Compressor running hours optimization during MTL operation of units	228741	535.1	<b>0.64</b>	0.00	0.0	Process improvement



# Few Glimpses of Improvement Carried Out



Old CT Fills after removal



Condenser tubes after cleaning

PHE after cleaning



RAPH basket replacement work U/P



RAPH Basket after cleaning



New CT Fills (after replacement) & new water distribution channel with spray nozzles



## (1) Boiler Combustion & (2) APC Optimization Tool

### In House Development of Excel Based Data Analytics

- ❖ Higher Cycle time for real time data analysis
- ❖ Limited data set for comparison.
- ❖ Limited feasibility for Multivariate exploratory data analysis

	Range	
	Max	Min
Load	525	515
Specific Coal Consumption	0.65	0.63
RH metal temp. Limit	575	
<b>Mill Combination (as required)</b>		
Mill 2A	0	Standby
Mill 2B	1	Running
Mill 2C	1	Running
Mill 2D	1	Running
Mill 2E	1	Running
Mill 2F	1	Running
Mill 2G	1	Running
Mill 2H	0	Standby

Set range for Load, SCC and RH metal temp. and select "1" for running mills

Best Combination as per Load/SCC range and RH MTL			
Temp. Limit			
Max. RH Metal temp.	567.0		
Load/SCC	523.07	0.632	
Burner Tilt Position	38.6		
OFA UPPER/LOWER Position	100	100	
Mill 2A Loading	54.4	CAD 2A	1.1
Mill 2B Loading	56.5	CAD 2B	9.6
Mill 2C Loading	56.2	CAD 2C	4.4
Mill 2D Loading	Mill Stopped	CAD 2D	CAD closed
Mill 2E Loading	54.5	CAD 2E	23.3
Mill 2F Loading	53.4	CAD 2F	38.1
Mill 2G Loading	55.2	CAD 2G	9.8
Mill 2H Loading	Mill Stopped	CAD 2H	CAD closed

Expected RH MTM	573.1	574.0	569.7	569.1	567.5	571.6	572.3
Feeder Loading	Combination 1	Combination 2	Combination 3	Combination 4	Combination 5	Combination 6	Combination 7
Coal Feeder 2A	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Coal Feeder 2B	57.0	57.0	55.8	54.2	54.6	56.7	56.7
Coal Feeder 2C	55.2	56.8	54.6	55.1	55.6	57.6	57.8
Coal Feeder 2D	57.0	55.1	52.7	56.1	56.3	55.0	55.2
Coal Feeder 2E	53.0	56.1	55.1	53.9	54.3	53.1	53.0
Coal Feeder 2F	55.8	57.1	55.4	54.8	55.3	54.1	54.0
Coal Feeder 2G	51.9	53.3	52.5	53.7	54.1	48.5	48.5
Coal Feeder 2H	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Burner tilt	21	20	20	20.0	20.0	20.0	20.0
OFA LOWER DMD	100	100	100	100	100	100	100
OFA UPPER DMD	100	100	100	100	100	100	100

- ❖ Python based machine learning model integrated with PI historian for the influencing operational child KPIs
- ❖ Historical trend analysis through the web application for better visualization and review.
- ❖ Compare real time data w.r.t the benchmark data at similar operational conditions for all the operator control parameters to identify the opportunity for improvement and guide the operation team for data driven decision making.

### Process Summary

- ❖ Data Aggregation
- ❖ Data Filtration: Extracted Tags relevant to Boiler & Significant Energy Users (SEUs)
- ❖ Feature Selection : Benchmark data with operational constraints such as RH MTM excursion limit, Mill Combination, AOH Before/After

*"Innovation is taking two things that exist and putting them together in a new way"* - Tom Freston




Real-time Inputs: Load, Coal Flow, Mills non-availability, Before/After AOH & No. of Mill combinations suggested

Comparative Parameters:

Mill Loading & Burner Tilt, Coal SADC & Furnace to Windbox DP, Mills CAD position, RH MTM temperature

Load dependent Significant Energy Users  
 ID Fan, FD Fan, PA Fan, Mill, CEP  
 Operating conditions influencing the individual SEU performance  
 APH FG DP, Duct leakage, Air Flow  
 Enables prioritize Maintenance activities



**Won Platinum Award in 9<sup>th</sup> CII National Competition on Low-Cost Automation (LCA)**





# Utilization of RE Sources (Onsite/Offsite)



RENEWABLE ENERGY - ONSITE	Rooftop solar	Ground mounted solar
Source	Solar	Solar
Year of installation (FY22, FY23, FY24)	FY24	FY24
Installed capacity (MW)	0.0502	0.012
Generation (in Million kWh)	0.0140	0.000044
Consumption from On-site RE (in Million kWh)	0.0140	0.000044
Rooftop panel rated efficiency	15.23	14

RENEWABLE ENERGY - SOLAR THERMAL	Concentrated solar thermal water heater
Source	Solar
Rate capacity (kW or kcal/hr)	1.37
Hot Water capacity (kLPD)	24.94


- ❖ ***MPL has successfully commissioned a grid-connected solar rooftop project with a capacity of 50.22 KW in Feb'2024.***
- ❖ ***The solar project is designed to cater to the entire lighting load of our technical building.***
- ❖ ***Anticipate 1500 T of CO<sub>2</sub> emission reduction over the lifespan.***
- ❖ ***Combined with several other ongoing efforts, it underscores our commitment to playing our part in the initiative of "Duniya Apne Hawale."***



# Environment Management

## Ash Utilization

Particulars	UOM	2021-22	2022-23	2023-24
<b>Ash Stock in Plant ( yard+ pond)</b>	Tons	283436	346397	238884
<b>Ash Generated</b>	Tons	1851817	1811336	2066001
<b>Ash Utilization</b>	%	<b>90</b>	<b>97</b>	<b>105</b>
<i>Ash Utilized in manufacturing of cement</i>	%	23.1	32.7	25.5
<i>Ash Utilized in Fly Ash Bricks</i>	%	5.8	4.7	1.2
<i>Ash Utilized in Mine fillings</i>	%	57.5	54.6	52.2
<i>As Utilized for Roads pavement (NHAI)</i>	%	0.0	1.3	6.0
<b>Ash Utilized in Other Areas - Please mention below</b>				
<i>Captive mines of SAIL and Tata Steel</i>	%	2.4	3.1	2.2
<i>Internal Lowland development</i>	%	0.7	0.0	17.3
<i>Embankment creation</i>	%	0.0	0.0	1.1
<i>Expenditure on Ash Utilization ( Annual)</i>	Lakhs	3042	4398	5946
<b>Ash Handling done through various methods</b>				
<b>Ash Handled (Wet Method) - (Through Slurry Pumps)</b>	%	25	25	26
<b>Ash Handled (Dry Method) - (Through Bulkers)</b>	%	23	23	21
<b>Ash Handled (Semi Method) - (Through Ash Conditioners and dumpers and Rail)</b>	%	52	52	53




**Ash rakes**



**CO2 emissions reduced**

Tata Power –MPL is aligned with UNSGD goal. MPL is committed towards fostering a world of sustainable development by focusing on energy efficiency, resource conservation, and empowering communities by –

1. 40% clean and green energy portfolio
2. Become carbon net zero by 2045
3. Zero waste to landfill before 2030
4. 100% water neutral by 2030



## Real Time Data Acquisition And Monitoring

Site Name: MAITHAN POWER LIMITED

Report: Real Time Report

From Date: 2024-07-01 00:00 To Date: 2024-07-31 23:30

Description	STACK_1_TPP_UNIT1-NOx(mg/Nm3)	STACK_1_TPP_UNIT1-PM(mg/Nm3)	STACK_1_TPP_UNIT1-SO2(mg/Nm3)
Prescribed Standards	0 -	0 - 50	0 -
Maximum Data	1138.04	187.47	2130.09
Minimum Data	0.0	13.12	0.0
Geometric Mean	590.74	27.06	784.5
Median	617.96	26.88	789.36
Standard Deviation	123.36	8.33	133.43
Maximum Value At Time	2024-07-16 15:45:00	2024-07-16 06:00:00	2024-07-16 15:15:00
Minimum Value At Time	2024-07-01 20:45:00	2024-07-27 12:15:00	2024-07-01 20:45:00
Valid Data Points	2975	2975	2975
Total Data Points	2975	2975	2975
Data Availability %	100.0%	100.0%	100.0%





**Short Term Goal**

Enhancement of green power through solar, wind & hydro (pump storage) for reduction of intensity YoY basis

**Long Term Goal**

Zero carbon neutrality by the year 2045

# Environment Management - Emissions



*GHG Emission Intensity (Kg CO2 / Ton of Product) – Comparison with peers/competitors.*

- *Tata Power – MPL is continuously improving its operational performance to reduce the CO2 emissions.*
- *SOx emissions – FGD projects is under progress.*
- *NOx emissions – Low NOx burner installation is planned in upcoming AOH.*
- *SPM level within specified limit & better w.r.t peers.*



Mercury (mg/Nm3)	FY21	FY22	FY23	FY24
Tata Power - MPL	NT *	NT	NT	NT
NTPC - Sipat	0.0010	0.0010	0.0010	
NTPC - Ramagundam	0.0000	0.0000	0.0000	
NTPC - Vindhyachal	0.0078	0.0075	0.0078	

\* NT - Not Traceable



## ENVIRONMENT MANAGEMENT - EMISSIONS MONITORING

	UoM	FY21	FY22	FY23	FY24
Total CO2 Emissions/kW of Generation	Ton/kW	8.0	6.1	8.0	8.6
Current SOx Emissions at Full Load *	mg/Nm3	694	496	500	751
Current NOx Emissions at Full Load *	mg/Nm3	1006	740	677	566
Particulate Matter *	mg/Nm3	32.3	31.8	37.6	35.5
Mercury *	mg/Nm3	Non traceable	Non traceable	Non traceable	Non traceable

## Action Plan to meet the latest emission norms as per Gazette Notification

- *Installation of Flue-Gas Desulfurization (FGD) w.r.t CEA/MoEF notification to meet the SOx target as per new regulation/norms.*
- *Wet limestone based FGD is a set of technologies used to remove sulfur dioxide (SOx) from boiler exit flue gases of fossil-fuel power plants.*
- ***The FGD project work is under progress in MPL for both the units. Same will be completed by 31.12.2026.***
- *Installation of low NOx burners w.r.t CEA/MoEF notification to meet the NOx target as per new regulation/norms.*
- ***The project is taken under Capex for installation of low NOx burner. Same will be completed by 31.03.2026.***

Best Practices in Water Management



Water Consumption	Unit	2021-22	2022-23	2023-24
DM Water #	%	0.76	0.79	0.79
Raw Water	m <sup>3</sup> /Mwh	2.27	2.32 *	2.21 *

# includes Start-up DM water loss; \* includes FGD project construction

Plant Water Dashboard

PI integrated 13 meters installed at strategic locations

Real-time Monitoring


Automated Alert-mail triggered

Plant Storm Water Recovery System

R-R-R

Lower Operating Cost

Sustainability







## **TATA POWER Commitment: Leadership with Care**

- ❖ **Carbon Net Zero by 2045**
- ❖ **Water Neutrality by 2030**
- ❖ **Zero waste to landfill before 2030**
- ❖ **No net loss of biodiversity**

### **Our Thrust Areas in MPL:**

- ❖ **Resource Conservation**
  - Optimize Raw water consumption
  - Rain-water harvesting
  - Re-use of generated Waste-water
  - Utilization of Biodegradable waste
  - Scrap utilization from metal scrap
- ❖ **Habitat Protection**
  - Absolute CO2 generation
  - Afforestation
  - Tree sapling survival rate
- ❖ **Energy Efficiency**
  - Optimization of SHR, APC to Benchmark values
  - Ash Utilization
- ❖ **Promotion of Clean Energy**
  - Providing EV charging station in plant to encourage use of EV.
  - Battery operated Company vehicles

# Sustainability – Net Zero Commitment

## MPL Initiatives



**Water Neutrality  
by 2030**

**Zero waste to  
Landfill by 2030**

**2024-25**


Recovery of  
Rainwater @  
10 KLH in  
rainy season

**2026-27**

Use of Sewage  
water @ 20-50  
MLD

**2028-29**

- Maximize use of FGD wastewater
- Use of residual ash recovery water



# Flexibilization

## Being Ready for Flexi Operation



### Flexibilization Journey

FY18

- Station MTL (Ex-bus): 680 MW
- 69% Machine Loading

FY19

- Station MTL (Ex-bus): 600 MW
- 61% Machine Loading

FY20

- Station MTL (Ex-bus): 541 MW
- 55% Machine Loading
- Participation in RRAS & SCED

FY21

- 50% Machine Loading achieved
- 1% Ramp compliance

FY22

- U2 achieved 36% during IGEF trial.
- U1 achieved 34% during inhouse trial.
- Participation in AGC - quantum 60

### Auto Sequence Operation of Coal Mill & Feeder

#### OLCS Logic

New Logic Developed under OLCS for Sequential Start/Stop of Coal Mill & Feeder and its associated drives ( like operation of Mill & Feeder Seal air valves, Cold air gate, Hot air gate, Feeder outlet gate).

#### CLSC Logic

New Logic developed in CLCS like Mill PA flow control for HAD & Mill o/l temp control for CAD to automatically enable the loops to throw into auto mode with variable set points to PID increment/decrement to achieve desired process variables based on start/stop sequence respectively

#### Protection

Additional protection logics incorporated to throw the system (HAD/CAD) into manual mode during any trouble or interruptions in auto sequence mode, to ensure process and system safety

#### Process Stabilization

PA Flow set point is increased in steps of 10 at a definite rate starting from 10. The SP will increase only when actual air flow is established, so SP will increase from 40 to 50 TPH if actual air flow is >49TPH. In the entire process, if PA header pressure drops  $\leq 730$ mmWC, OUT BLOCK acts and increment of PA Flow output is blocked further and will be in action till PA header pressure is recovered.

#### Safe Shut Down

During shut down sequence, after feeder stop, HAD will become zero as per interlock and PA flow is maintained by CAD by override increment & decrement block with definite rate. CAD opens/closes to maintain air flow of 35-42 TPH

#### Graphical Interface

New graphical configuration developed which enables desk engineers to carry out and monitor auto sequence steps

# Asset Management EnMS System



## Challenges during Implementation

- ❖ Integration of Schneider System into TATA Power Server (Cyber Security Threat).
- ❖ Standalone system with PI integration & no remote access to Schneider.
- ❖ Compare real time data w.r.t the benchmark data at similar operating conditions

- Home
- Real Time
- Equipments
- Communication
- Single Line
- Electrical Health
- KPI Report



**Maithon Power Limited, Dhanbad**

STN POWER [KW] 46,537

Server Reports

Equipment	Station (kW)
CHP	209
AHP	4,716
RWPH	0
PWS	11,233
RO	693
SWYD	1,931

Equipment Name	U1 (KW)	U2 (KW)
UAT-A	9,765.6	10,300.2
UAT-B	7,644.4	6,724.1
ST	18,059.2	15,016.1
UST DAT01	441.4	428.5
UST DAT02	242.4	275.3
SST-1	91.2	537.1
SST-2	460.4	127.6
CW Pump-A	1,214.1	0.0
CW Pump-B	1,484.9	1,563.7
CW Pump-C	1,076.2	0.0
DMCW Pump-A	0.0	224.6
DMCW Pump-B	214.1	0.0
DMCW Pump-C	183.2	211.9
BCW Pump-A	223.0	229.7
BCW Pump-B	0.0	0.0
BCW Pump-C	224.8	229.6
ESPT-DBT-01	139.9	144.9
ESPT-DCT-01	122.3	55.3
ESPT-DDT-01	115.7	87.6
ESPT-DET-01	55.0	146.8
ESPT-DBT-02	139.6	112.3
ESPT-DCT-02	155.8	100.3
ESPT-DDT-02	112.0	74.2
ESPT-DET-02	130.2	107.3

kW	COAL MILL	PA FAN	FD FAN	ID FAN	DMCW PUMP	BCW PUMP	CW PUMP	CEP PUMP	ACW PUMP	TOTAL
U1	2,317	2,257	1,250	5,061	397	448	3,775	1,334	351	17,191
U2	2,313	2,378	1,133	4,899	437	459	1,564	1,285	318	14,785
TOTAL	4,630	4,635	2,383	9,959	834	907	5,339	2,619	669	31,976

Equipment Name	U1 (KW)	U2 (KW)	Equipment Name	U1 (KW)	U2 (KW)
Mill-A	375.0	0.0	VFD TRF (ID Fan-A Ch-1)	1,246.6	1,268.4
Mill-B	409.5	419.0	VFD TRF (ID Fan-A Ch-2)	1,239.2	1,221.7
Mill-C	448.7	278.5	VFD TRF (ID Fan-B Ch-1)	1,287.9	1,218.0
Mill-D	336.2	460.7	VFD TRF (ID Fan-B Ch-2)	1,275.4	1,190.8
Mill-E	391.3	429.1	CEP-A	673.4	643.8
Mill-F	0.0	0.0	CEP-B	0.0	0.0
Mill-G	0.0	437.8	CEP-C	660.9	641.4
Mill-H	336.4	290.6	ACW Pump-A	331.1	317.7
FD FAN-A	583.1	584.7	ACW Pump-B	20.3	0.0
FD FAN-B	667.4	551.3	BFP-A	0.0	0.0
PA FAN-A	1,112.7	1,122.5	TIE-CA Board	0.0	0.0
PA FAN-B	1,144.1	1,259.9	TIE-CB Board	0.0	0.0

**IRCLASS**  
SYSTEMS AND SOLUTIONS PRIVATE LIMITED

**CERTIFICATE OF APPROVAL**

Issued by Indian Register Quality Systems  
(A Division of IRCLASS Systems and Solutions Private Limited)

This is to certify that the Energy Management Systems of

Organisation: Maithon Power Limited

Address: Village - Dambhul,  
P. O. Barbandia, PS: Nirsa  
Dhanbad - 828 205, Jharkhand

has been assessed and found conforming to the following requirement

Standard: ISO 50001:2018

Scope: Generation of Coal based Thermal Power

Certificate No.: IRQS/221000080

Original Certification Date: 11/03/2019  
(ANAB)

Granting of NABCB Certificate: 10/07/2019

Current Date of Granting: 15/01/2022

Expiry Date: 09/03/2025

Shashi Nath Mishra  
Head IRQS

This approval is subject to continued satisfactory maintenance of the Energy Management Systems of the organisation to the above standard which will be monitored by IRQS. This use of the Accreditation Mark indicates compliance with respect to activities covered by the certificate with accreditation no. IRQS/1. Issued on 09/01/2022  
CONFIRMS/IRQS/ENMS/15001/Rev. 03

Head Office: 52A, Adi Shankaracharya Marg, Opp.Powal Lake, Powal, Mumbai - 400 072, India.

# New Initiatives


## Integration of DSM in ABT System



UPCOMING BLOCK	SG	BLOCK TIME	CURRENT TIME	COUNT(+)
Block	SG	Block	SG	
38	541.42	39	541.42	
BLOCK NO.		37		
PLANT PARAMETERS		SG	541.42	INST. AGC #NAME?
UNIT #1 GEN (MW)	#NAME?	SG+AGC	#NAME?	Avg. AGC #NAME?
UNIT #2 GEN (MW)	#NAME?			RRAS/SCED -69/0
STATION GEN (MW)	#NAME?	INST EXPORT	#NAME?	UI MW #NAME?
AUX CONSUMP. (%)	#NAME?	INST FREQ	#NAME?	AVG FREQ 0.02
PROFIT (+)/LOSS (-) (₹)		AVG EXPORT	#NAME?	UI Rate 3.030
UI EARNED	NET PROFIT	%Exp(SG+AGC)	#NAME?	ACP 307.84
0		TIME LEFT	0:14:08	ECR 269.80
CURRENT BLOCK EXPECTED NET	Asking Ramp(%)	#NAME?	Act Ramp(%)	
PROFIT/Loss (₹)	PREVIOUS BLOCK AVG DATA			
0	BLOCK	34	35	36
	SG	984.39	836.73	689.07
NET AGC PROFIT (₹)	(SG+AGC)/EXPORT	#NAME?	#NAME?	#NAME?
Current Block	#NAME?	FREQ/UI MW	#NAME?	#NAME?
Total Day	#NAME?	Exp/Act RAMP(S)	#NAME?	#NAME?

**Won Silver Award in 9th CII National Competition on Low-Cost Automation (LCA) Category**

- ❖ Programming web scrapping loop in Python has minimized the risk of malice data entry.
- ❖ Alarm provided for Schedule variation, over & under injection opportunities & Deviation.
- ❖ Ever evolving DSM norms & regulatory updates can be incorporated without any 3rd party assistance.



- ❖ Time delay to update recent data & system freezing issue with bulk data handling.
- ❖ Unable to fetch data after Captcha introduction in ERLDC site.
- ❖ Macro-enabled Excel & PI integrated system creates cyber security concern.
- ❖ i-Macros security threat :Malware breach probabilities in PI system

Station Data	Block rate from IEX
U#1 GEN 521.16	Curr. Block 6
U#2 GEN 520.2	SG 984.39
U#1 AGC -1.34	AGC -5.21
U#2 AGC -0.99	SG+AGC 979.51
Inst. Freq 49.985	Dev MW -10.98
Exp.Freq. 49.98	Deviation from schedule
Inst. Export 969.51	AVG. Export 968.53
Net AGC Profit(Rs)	AVG. Freq 49.96
Total day: 14680	web scrapping updated 0 minutes ago
Curr. Block: 1360	Time left 02:06

Block rate from IEX
Time 01:27:53
RRAS/SCED 0.0   0.38
RTM/DAM 4.4   4.9
UPCOMING BLOCK
BLOCK 7 984.39
BLOCK 8 984.39
ECR
2.818
Net DSM (Rs)
Total day: 10654
Curr. Block: -7467

DSM Earnings
Net DSM (Rs)
Total day: 10654
Curr. Block: -7467



# Technology Advancement/Digitization



## Innovation : Project Drishti



TATA POWER



- 01 FIRE & SMOKE ALERT
- 02 UNAUTHORIZED ENTRY ALERT
- 03 NO HELMET VIOLATION
- 04 PERSON INSIDE CONFINED SPACE
- 05 NO HARNESS VIOLATION
- 06 PERSON COLLAPSE ALERT
- 07 NO JACKET VIOLATION



- ❖ Integration of AI and Video Analytics in 24 CCTVs
- ❖ Early detection of violations.
- ❖ The system triggers pop-up notifications and voice alarms in the operator room.
- ❖ Designated speakers broadcast pre-recorded messages, while the operator can manually announce through a microphone to specific areas or the entire premises with a single click.

# Awards & Achievements



5 Golden Star for Safety by NSCI



ICC Environmental Awards



CII TCM Award for Cost Management



Best Division Award 2023





“  
Energy efficiency is the  
cleanest, quickest and  
most economical solution  
to reducing energy use.”

*Disclaimer: The contents of this presentation are private & confidential.  
Please do not duplicate, circulate or distribute without prior permission.*



# Thank You!