Nabha Power Limited

25th



National Award for Excellence in Energy Management 2024 10 – 12 September HICC, Hyderabad

2x700 MW Supercritical TPP Rajpura, Punjab



Agenda



1	About the Company	7	Renewable Energy
2	Energy Consumption Overview	8	Environment Management
3	Performance data Y-o-Y	9	Best Practices
4	Energy Benchmarking	10	EnMS System
5	EnCon Projects	11	Net Zero Commitment
6	Innovative Projects	12	Awards and Recognition



Company Profile

First Indigenously Manufactured Supercritical Unit based on MHI-Technology



Certified for ISO 50001:2018 (Energy Management System), ISO 9001:2015 (QMS), ISO 14001:2015 (EMS), ISO 45001:2018 (OHSAS), ISO 17025:2017 (NABL accreditation for Coal lab) and ISO 27001:2013 (ISMS)

EPC PROJECTS | HI-TECH MANUFACTURING | SERVICES



Energy Consumption Overview


Station Performance FY24

Sr. No.	Description	Unit	Values
1	PLF	%	84.12
2	Availability	%	94.31
3	Annual Generation	MUs	10,345
4	Gross Heat Rate	Kcal/kWh	2187
5	Auxiliary Power	%	4.56
6	Boiler Efficiency	%	87.57
7	Turbine Heat Rate	Kcal/kWh	1915
8	DM Water Make-up	%	0.31
9	Sp. Raw Water Cons.	Cum/MWh	1.73
10	Sp. Oil Consumption	ml/kWh	0.08



Performance data (Y-o-Y)

Last 03 years



EPC PROJECTS | HI-TECH MANUFACTURING | SERVICES

C LARSEN & TOUBRO

Energy Benchmarking

Internal Benchmarking:

6

Energy KPIs	Target Value FY25 (@ 86% PLF)
Gross Heat Rate (Kcal/kWh)	2165
Aux Power Consumption(%)	4.65
DM Makeup (%)	0.30

External Benchmarking (Supercritical Technology):

Plant-1	Plant-2	Plant-3
Same OEM	Chinese OEM	Within Punjab
4.66 %	5.86 %	7.06 %
2156 kcal/kWh	2251 kcal/kWh	2235 kcal/kWh



Long-Term Plan

To continually improve the station performance by adopting latest technologies and best O&M Practices





Short-Term Plan

Achieve FY25 Internal targets through:

- 1. Efficient & Reliable Operation
- 2. Increased Energy Mapping and benchmarking
- 3. Implementation of identified EnCON Projects

Roadmap FY25

Steps to achieve sustained Performance



- PADO upgradation for enhanced performance monitoring
- RCM Implementation
- Equipment health & condition monitoring through ERP system
- Optimization of efficiency during Biomass firing



Projects in Implementation Phase

- SCAPH Modification- 0.53 MUs annual savings
- CCW pump energy reduction by optimizing MDBFP oil cooler water flow – 0.02 MUs annual savings
- Unit cold start up time reduction–
 0.5 kcal/kWh annual savings
- Replacement of Conventional lights with LED – 0.4 MUs annual savings



Projects in Feasibility Stage

- Installation of VFD in transport air compressor
- Installation of VFD in CEP
- CW motor speed reduction
- Optimization of Building AHUs & Chiller system running hours
- LDO forwarding pump pressure optimization
- Increased use of Renewable energy



Summary FY22 to FY24

Year	FY '22	FY '23	FY '24
No of Energy saving projects	12	10	10
Investment (INR Million)	173	163	3
Electrical savings (Million kWh)	12	1.4	17
Thermal savings (Million Kcal)	1,50,620	1,79,463	65,562
Total Savings (INR Million)	242	262	86



Major Projects FY22

Sr. No.	Name of Energy saving projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)
1.	RAPH Basket replacement with better design & utilization of available basket height –Unit-2	131.0	-	61,958	84.0
2.	11 Nos. of high energy drain valves replaced with better design valves	6.2	-	41,929	57.0
3.	SCAPH modification (Removal of 01/06 No. of stage)	0.1	0.3	-	0.8
4.	CWP-2B pump impeller replacement & internal coating	0.9	0.8	-	2.4
5.	CWP-2A pump internal coating	0.9	0.2	-	0.7





Major Projects FY23

Sr. No.	Name of Energy saving projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)
1.	RAPH Basket replacement with better design & utilization of available basket height- Unit-1	137.3	-	58,022	82.1
2.	Replacement of TDBFP Recirculation valve's trim by 3D drag type trim	10.5	-	7,266	10.3
3.	Mill seal air fan IGV remote operation	0.5	0.2	-	0.6
4.	Replacement of Existing Fixtures with LED	2.2	0.3	-	0.9
5.	BAHP-A and BALP-C pump internal coating	0.1	0.1	-	0.3





Major Projects FY24

Sr. No.	Name of Energy saving projects	Investment (INR Million)	Electrical savings (Million kWh)	Thermal savings (Million Kcal)	Total Savings (INR Million)
1.	MS and HRH temperature optimization at part load	-	-	20,689	16.2
2.	Isolation of Aux steam common header and optimizing RAPH soot blowing frequency	-	-	10,344	5.2
3.	Unit operation on Single CW, ACW and CCW Pump during winter	-	16.0	-	52.0
4.	Stoppage of MRHS compressor	0.05	0.2	_	0.6
5.	CW reject water utilization for coal dust suppression	0.4	0.04	-	0.1



Air Leakage reduction in RAPH with improvised Control


of Sector Plate Movement with load variation

Typical System Overview:

- RAPH air leakage is a major concern in TPP.
- Typically, 1% increase in air leakage translates to 0.025% to 0.040% impact on heat rate
- APH leakage is typically in the range of 8% to 12%
- Adjustable Sector plates are provided to prevent unwanted mixing and minimize leakages.

Sector Plate Control Mechanism at NPL:

- PLC based Control through temperature measurement.
- The delay in temperature stabilization during load change resulted in heavy motor current hunting, requires frequent manual interventions and affecting overall efficiency.





Air Leakage reduction in RAPH with improvised Control of Sector Plate Movement with load variation



Data Collection

- Reviewed existing PLC logic for sector plate movement setpoint generation
- Collected field data of rotor displacement through manual operations of actuators
- Collected field data at different load condition for rotor displacement and motor current





02/04









Air Leakage reduction in RAPH with improvised Control

of Sector Plate Movement with load variation

Implementation

- Developed a capping signal to maintain optimal gap control
- Logic developed to take care optimum sector plate movement during all operating conditions including emergencies
- Testing and commissioning for final implementation.





Results:

- **Real-Time Data Integration** and Actuator positions are now visible in DCS
- Enhanced Protection Mechanisms:
 - Full retraction of all three actuators in case of load < 280 MW, abnormal inlet/outlet temperatures, or FCB/Runback, or specific actuator abnormalities.
- **Biasing provision for each actuator** enhances operational flexibility.
- **Annunciation alarms** are integrated into the Soft Alarm Screen for better system alerts.



Air Leakage reduction in RAPH with improvised Control

of Sector Plate Movement with load variation

Uniqueness:

- Customized Solution developed in-house
- Integration of Field Data into Control Logic
- Across peer industry adaptability

Air Leakage achieved	Monetary impact (in Rs)	Sustainability impact w.r.t CO2 reductions/plantati on
5.2 % (Design = 5.0 %)	1 Lakhs/day	28 Tons/day
0.07 % improvement in APC	2.4 Crore	~9,240 Tons CO2 3.7 Lakh

Project Cost = 10 Lakhs



Renewable Energy

Total Installed Capacity (Solar)

205 kW


Solar Project in Plan

5 MW

(Under tendering process)

Target date for commissioning March 2025

Generation (Million kWh)





Ash utilization

17

Year	UoM	FY '22	FY '23	FY '24
Ash Stock in Plant (Yard + Pond)	MT	12,665	2,119	0
Ash Generated	MT	19,55,634	21,00,746	26,70,394
Ash Utilization:	%	100	100	100
Manufacturing	%	80.1	80.3	64.9
FA bricks	%	4.5	2.9	2.9
Road Pavements	%	15.5	16.8	32.1

FY 2023-24 Ash Handled (Wet) : 14.84 %

Ash Handled (Dry) : 85.16 %



Best Practices in Ash Management

- Environment-Friendly Operations:
 - Fly ash loading is conducted with zero fugitive emissions using automated processes.
 - Windshields are installed along the boundaries as an additional safeguard to prevent spillage into nearby farms.
- Strategic Partnerships: Contracts with cement manufacturers, local RMC plants, and brick manufacturers
- Automated Packaging for Small Buyers: Produce 45 kg fly ash bags with no leakage, meeting the needs of small-scale buyers and ensuring product integrity.
- CCTV Coverage of entire operating area to ensure safe operation











Emission

Year	UoM	FY '22	FY '23	FY '24
Generation	MUs	9,654	10,380	10,345
CO2 emission	kg/kWh	0.86	0.85	0.85
SOx	mg/Nm3	1,284	1,150	1,069
NOx	mg/Nm3	219	225	249
Particulate Matter	mg/Nm3	42	43	41
Mercury	mg/Nm3	BLQ	BLQ	BLQ



Best Practices in Emission Control



Automatic Weather Monitoring Station







Continuous Effluent Quality Monitoring System




Air and Water Lab





Water Conservation and Best Practices



Best Practices in Water Conservation:

- 100 % recycling of wastewater through ETP-RO plant
- Use of RO reject for AHP make up
- Water Consumption Monitored through
 Dashboard
- AHP vacuum pump open cycle sealing water system substituted with closed cycle clarified water
- Silo Blower cooling water system (Serv. Water) open cycle discharge utilized for CT makeup

Best O&M Practices

• Upgradation of PADO for enhanced

Technology Advancement

Reliability enhancement through Asset Management

Flexibilization <

		performance monitoring	🛛 Vie	w Worl
	L		Hi	istory
			Mea	asure
		• E-Log Book for all operational activities		Poin
J			1408	
		Health Card for all major equipment		1409
		i neath cald for an major equipment		1410
				1411
		[]		1412
				1413
$\left\{ \right.$	 Minimum loading achieved 50 % 	Mea	asure <u>Me</u> 140	
	L		4	-

.ist V	iew A	sset	Spare Parts	Safety	Meters	Specification	6	Relationships	Work	EHC	Asset	Activities	Turbi	ne Health	Card
set:)255(2004	LINI	T # 1 TURBINE			1	Site								
Viev	v Work Ord	ders and	d Tickets that are (open for this	s asset. Addition	al details are avai	lable	in Work Details.	View Work	Details					
	story	NOC	Event Log	RCA	DC Test Day	port Comm	un loo	tion Condition	on Monitori		Abnormal	Measurement	Average Magaura	nast	
	story	NUC	Event Log	RUA	PG Test Rep	port Commi	inica	Condition	on woniton	ng /	ыттопа	weasurement	Average Measurer	nent	
Nea	sure Po	oints	and Meter	Filter	>0	₩ ₩ ♦	1	- 6 of 35 🖨	•						G
	Point	1	Tag Name			Meter		Description		<u>Unit c</u>	of Measure	Upper Warning Limi	Upper Action Limit	Lower Warning Limit	Lower Ac
▶	1408		U1 NO.1 BRG VIE	PICK-UP (X)	BRG-1VIB-X	»	U1 NO.1 BRG VIE	BPICK-UP ()	() UM		125.000	250.000	0.000	
▶	1409	1	U1 NO.1 BRG VIE	B PICK-UP (Y)	BRG-1VIB-Y	»	U1 NO.1 BRG VIE	B PICK-UP (') UM		125.000	250.000	0.000	
▶	1410		U1 NO.2 BRG VIE	B PICK-UP (X)	BRG-2VIB-X	»	U1 NO.2 BRG VI	BPICK-UP ()	() UM		125.000	250.000	0.000	
▶	1411		U1 NO.2 BRG VIE	B PICK-UP (Y)	BRG-2VIB-Y	»	U1 NO.2 BRG VIE	B PICK-UP (') UM		125.000	250.000	0.000	
▶	1412		U1 NO.3 BRG VIE	B PICK-UP ((X)	BRG-3VIB-X	»	U1 NO.3 BRG VIE	BPICK-UP ()	() UM		125.000	250.000	0.000	
	1413		U1 NO.3 BRG VIE	B PICK-UP ((Y)	BRG-3VIB-Y	»	U1 NO.3 BRG VIE	B PICK-UP (') UM		125.000	250.000	0.000	
Vlea	sureme			Filter > 0	. <i>2</i> T	* (1 -		582 📫 G		-				
	Measur	ement	Point Des	scription		Mea	surem	<u>tent Date</u> ≑	Mea	suremen	<u>it</u>				
	1408		U1 I	NO.1 BRG	VIB PICK-UP (X) 18/04	/2022	2 2:31 PM		39.45	50				



Best O&M Practices



EPC PROJECTS | HI-TECH MANUFACTURING | SERVICES



ISO 50001 Certification & Energy Policy

Current lawan data: 26 May 2022 Orginal approvabilit: Eugity adar: 34 May 2025 ISO 50001 - 23 Dac 2014 Cartificate Marity number: 10449139		
Certificate of Approval	LRQA	
This is to certify that the Management System of: Nabha Power Limited	LRQA	
Rajpura, Punjab, India. has been approved by LRQA to the following standards:	LRQA	
ISO 50001:2018 Approval number(s): ISO 50001 – 0060580-001 This certificate forms part of the approval identified by approval number: 0060580	LRQA	
The scope of this approval is applicable to:	LRQA LRQA	
Generation, Operation and Maintenance of Power at 2x700 MW Coal based Supercritical Thermal Power Plant.	LRQA	
	LRQA LRQA	
	LRQA	
	LRQA	
Luis burka	LRQA	
Luis Cunha Area Operations Manager - SAMEA UKAS Issued by LRQA Limited UKAS	LRQA	
IDOA force Limited to diffuse and sublidation and their respective officers, employees or agents are, includedly and solectively referred to in this clause as LDOA. IDOA examines not responsibility and that and be liable to any sense for any less, damage or express caused by relince on the information or advice and in that cause as LDOA. IDOA examines the period has also advice a substrate with the wave and LDOA with for the probation of this information or advice and in that cause any responsability or linear do LLDOA. Linked, 1 mines period. Reliable to advice	LRQA	
laued by URGA United, 1 Tinty Pen, Biolentill Loni, Binninghan 837 TEG, United Kingdon Page 1 of 1	LRQA	

NABHA POWER LIMITED	:
ENERGY POLICY	
We, at Nabha Power Limited, Rajpura, are committed to improve energy performance of our 2X700 MW Supercritical Thermal power plant by adopting best practices in operations, procurement and services on continual basis thus ensuring:	
 Process optimization and adoption of latest technologies Purchase of energy efficient products and services Optimization of Heat Rate & Auxiliary power consumption Use of Renewable Energy sources Awareness at all levels in the organization on conservation of energy 	
We are also committed to comply with all applicable legal and other requirements related to energy performance, providing information and necessary resources for achievement of objectives and targets, including continual improvements in energy performance and Energy Management System (EnMS).	E
S K NARANG 01 January 2022 CHIEF EXECUTIVE	

Sr. No.	Team Member	EA/EM Registration No.
1.	Vivek Trivedi	EA-18454
2.	Alfurqan Jahagirdar	EA-25886
3.	Ashutosh Kumar Anand	EA-20361
4.	Ankur Kashyap	EA-28245
5.	Amol Ashok Patil	EA-25899
6.	Suresh Pal	EA-16368
7.	Mittarpal Singh Sethi	EM-10785





EPC PROJECTS | HI-TECH MANUFACTURING | SERVICES

Energy Monitoring System

Realtime Energy Monitoring System

- PADO and Energy Monitoring system
- Power Bi Dashboard for Energy Monitoring Survey

Energy Benchmarking	Analysis
 Correlation of Input variables Regression Analysis for Correlation Equation Formulation and Benchmarking 	 Heat Rate Evaluation Asset Performance Assessment Reliability Assessment




NET ZERO Commitment

L&T's Net Zero Commitment:

Considering Carbon footprint (Scope 1+2) of diesel and electricity consumption.

Carbon Neutrality by 2040

- Focus on energy efficiency and decarbonization
- Shift to renewable electricity and fuels
- Large-scale tree plantation for carbon offsets (1.5-2 million saplings annually)
- Task forces driving renewable energy sourcing and diesel reduction initiatives





Journey towards Excellence



Certificate Of Merit in NECA 2023



Winner –Best Thermal Power Generator by IPPAI

CII Energy Circle Competition 2024:

- 1. Winner- Effective Implementation of ISO 50001: Energy Management System
- 2. Winner Innovations in Energy Efficiency
- 3. Appreciation Best Energy Efficient Case Study





Winner – Sustainable Performance by CEE



Appreciation – Excellence in Quality System by FICCI





Connect with us





Alfurqan M Jahagirdar

Manager +91-8427269203

Bajrang Lal Kaswan DGM Team Leader +91-8427756955

Shailendra K Mourya

Manager +91-8968313942

