



Odisha Power Generation Corporation

2 X 660 MW




Team Members:

Madhumita Soren (AGM, Energy Manager)
Sandeep Sahu
Braja Kishore Das

CII-25th National Award for Excellence in
Energy Management Sept-2024

Company Profile: About OPGC



PLANT SITE



An ISO 9001, 14001, 55001, 45001
& ISO 50001
Certified Company

- ✓ The only fully owned Government company of State of Odisha in Thermal Sector
- ✓ Total generation capacity of 1740 MW
 - 2x210 MW Subcritical (Stage-I)
 - 2x660MW Supercritical (Stage-II).
- ✓ Units 1 & 2 (OPGC- I) commissioned in Dec'94 & Jun'96 respectively
- ✓ Unit 3 & 4 (OPGC II) commissioned in July'19 & Aug'19 respectively
- ✓ OPGC is the Top Performer/ contributor in Odisha Power Sector - catering >30% load share of the state alone.

Company Profile: OPGC at a Glance..



100% PPA with GRIDCO (State of Odisha)



5.5 Km Long Dedicated Water Intake Channel from Hirakud Reservoir, with Contracted allocation 1.3 L m3/day



Dedicated Coal Mines with Annual Contracted Capacity of 80 LMT from OCPL for OPGC- II



48 Km Long Dedicated MGR Railway Line from OPGC to Manoharpur for Coal Transport

Energy Consumption Overview – FY 23-24

Annual Generation

9293.2 MU

Annual Avg Gen : 1058MW

Plant Load Factor:

80.15%

Plant Availability:

88.23%

Gross Heat Rate

2154 Kcal/Kwh

Auxiliary Power

5.58%

Turbine Heat Rate

1870 Kcal/kwh

Boiler Efficiency

86.8%

Coal Consumption: 6478715 MT

DM Water Consumption

0.7%

DM Consumption: 277726 MT




Specific Oil Cons

0.194 ml/Kwh

Oil Cons: 1799 KL






Energy Consumption Overview: Performance Trend..







- ❖ In FY 21 & 22, PLF% was low mainly due to Ash Evacuation Constraints. After completion of Ash Extraction & Conveying System Modification (in Jan22), PLF improved significantly.
- ❖ Continual improvement in Plant load factor resulting into surpassing avg. PLF of 80% in FY 23-24 (OPGC PLF is among the Top 5 best State utility Power Plants in the Country in FY 2023-24)
- ❖ After the completion of ongoing Ash Augmentation Project in Unit#4, OPGC PLF is projected to be more than >85% in FY 24-25.

Energy Consumption Overview: Performance Trend..



- ❖ Central electricity regulatory commission (CERC) has fixed a normative Heat Rate for OPGC at 2182 kcal/kwhr & APC% at 6.25% based on the technology.
- ❖ OPGC has been able to maintain Gross Heat Rate & APC % below the Norms continuously for last two years even at 80% PLF.
- ❖ Heat Rate Improved by 14 Kcal/kwh & Net Heat Rate improved by 17 Kcal w.r.t Last Year
(Station Heat Rate improved more than > 70 Kcal in last two years due to efficient & reliable Operation, implementation of several improvement projects and adopting best O&M Practices).

Energy Benchmarking: FY 2023-24



OPGC Stance among other Peers:

- OPGC is one of the pioneer company in thermal utility of India and has set a high-performance benchmark among other similar capacity plants.
- The Performance Parameters (like Heat Rate & APC) of OPGC is one of the best in the country among the similar capacity power plants.

❖ Our Short-Term Plan:

- Efficient & Reliable Operation
- Efficient Energy Monitoring and taking remedial measures
- Implementation of ENCON Projects
- Exploring New Opportunities and Using Latest Technologies

❖ Our Long-Term Plan:

- continual improvement by adopting best O&M practices, efficient Operation and by use of energy efficient products and services

Road Map to achieve Global Benchmark:

AVAILABILITY


- **Ash Augmentation project** for FA & BA is under implementation to improve unit availability

GROSS HEAT RATE

- Initiated Heat rate improvement project under **PRAYAS** (APRDS interconnection, TDBFP RC valve replacement, RH Spray CV passing, APH Basket replacement etc..)

SPECIFIC OIL CONSUMPTION

- Zero Forced Outage Program to reduce unit outages
- Reliability centered maintenance (RCM)



PLANT LOAD FACTOR

- **No generation back down as per merit order** from SLDC due to low cost reliable power available by OPGC

AUX POWER CONSUMPTION

- Replacement of less efficient motors with **energy efficient IE4 Motors**
- **New design CT Fan blade** replacement.
- Performance based maintenance practices

SPECIFIC DM CONSUMPTION

- Conversion of HFO to LDO to reduce steam cons.
- Utilization of CT Blowdown water by passing through RO system

Major Encon Projects Planned for FY 24-25

1

Replacement of FRH Inner bend tubes

Benefit: Improve the HRH temp. by 20 deg. (Coal saving of ~7850 MT/Yr)

Payback Period: 4.4 Months

₹ 14.5
Million/Yr

2

APRDS Interconnection between Stage-1 & 2

Benefit: Improving Start up time & reduction of sp. Oil (~60 KL/Yr)

Payback Period: 20.6 Months

₹ 4.1
Million/Yr

3

HFO to LDO Conversion

Benefit: Saving of coal due to reduction in steam cons. (~ coal 19667 MT/Yr)

Payback Period: 3.5 Months

₹ 27.3
Million/Yr

4

Ash Augmentation project

Benefit: Improving unit PLF & Heat rate by 4% & 10kcal/kwh respectively (Coal saving ~15919MT/Yr)

Payback Period: 5.3 Months

₹ 1091.0
Million/Yr

5

Implementation of AIML as a part of Industry 4.0

Benefit: Saving in APC of ~0.7 Mu/Yr and Coal saving ~14460 MT/Yr

Payback Period: 6.5 Months

₹ 29.6
Million/Yr

Major Encon Projects Planned for FY 24-25

6

Installation of Sonic soot blowing system in APH

Benefit: Saving in steam consumption (Steam saving of ~11169 MT/Yr)

Payback Period: 2.5 Months

₹ 6.9 Million/Yr

7

VFD Installation in LP Pump at AHP

Benefit: Saving in Electrical energy (~0.9 MU/Yr)

Payback Period: 10.9 Months

₹ 0.3 Million/Yr

8

Installation of Energy efficient IE4 Motor in 90 nos. of motors

Benefit: Saving of electrical energy by 1.6 MU/Yr

Payback Period: 14.2 Months

₹ 5.7 Million/Yr

9

New profile basket replacement in APH

Benefit: Saving of coal due to reduction in FGET. (~ coal 9159MT/Yr)

Payback Period: 31.0 Months

₹ 16.9 Million/Yr

10

IFC Installation in Compressed air system

Benefit: Saving in APC due to saving of compressed air by ~0.4 Mu/Yr


Payback Period: 19.5 Months

₹ 1.2 Million/Yr


ENCON Projects Summary (Last 3 years):

Year	No. of Energy Saving Project	Investments (INR Million)	Electrical Saving (Million kWh)	Thermal Saving (Million Kcal)	Saving (INR Million)
FY 2021-22	11	18.3	5.33	155,478	136.5
FY 2022-23	11	31.8	10.9	218,193	175.9
FY 2023-24	14	572.7	13.84	278,324	480.1
Total	36	622.8	30.1	651,995	792.5


Saving (INR Million/Year)



Electrical Saving (Million Kwh/Year)



Coal Saving (MT/Year)



ENCON Project Details FY 23-24

SI	Title of Project	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
1	HRH Temp. improvement by replacing FRH inner bend tubes	-	51,361	30.8	5.4	2.1
2	APH Soot blowing line modification	-	27,879	16.7	1.03	0.7
3	Reduction in DFG losses after replacement of new profile APH basket	-	35,953	21.6	13.1	7.3
4	Replacement of Conventional lights with LED	1.1	-	3.6	1.0	3.4
5	Online change over of bunker flap gate to reduce the belt idling time by 2.15 hrs/day	2.6	-	0.9	0	0




Replacement of FRH inner bend tubes

APH Soot blowing line size modification

APH Basket replacement after water washing


ENCON Project Details FY 23-24 cont..

SI	Title of Project	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
6	Energy Efficient CT Fan blades replacement	2.2	-	7.5	10.3	16.5
7	Arresting of APH seal & Duct Leakage to save APC in ID,FD & PA Fan	7.7	-	26.7	15.5	7.0
8	Stoppage of CT Fan during winter	1.5	-	5.1	0	0
9	Repair & replacement of high energy passing valves (TDBFP RC,MAL drn, HWL etc..)	-	28248	16.9	17.0	12.1
10	Cond. vacuum improvement(Jet clean, IDCT nozzle replace,Helium leak test,ceramic coat)	-	15,408	9.2	2.4	3.1




ENCON Project Details FY 23-24

SI	Title of Project	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
11	Online Drain Temp. monitoring	-	17,905	10.7	0.5	0.6
12	Implementation of OSI Pi software along with 6 applications	1.1	37,172	26.1	19.4	8.9
13	Reduction in cycle make-up loss	-	6.420	3.9	5.5	17.3
14	Implementation of Ash augmentation project in Fly ash & Bottom Ash	-	57,974	300.2	481.5	19.2
Total		13.8	278,324	480.1	572.7	



Thermopad connected in all drains
Online drain temp. monitoring



APC monitoring dashboard



Installation of 600 TPH new Intermediate silo
Ash Augmentation project in Fly ash system.



Ash Transport vessel

Major Encon Project Details FY 21-22 & FY 22-23

S No	Title of Project	Annual Electrical Saving (Million kWh)	Annual Thermal Saving (Million Kcal)	Total Annual Saving (Rs Million)	Investment (Rs Million)	Payback (Months)
1	New Energy efficient CT Fan Blade replacement	0.1	-	0.3	0.4	17
2	Replacement of conventional lights with LED	0.9	-	3.1	2.7	11
3	Stoppage of cycle make up pump by using gravity hot well make up	0.2	-	0.7	0	0
4	Stoppage of one HFO forward pump & ACW pump in winter	0.4	-	1.4	0	0
5	RH Temp. improvement by repairing of HPBP Spray CV and RH spray Block & Control valve	-	35,652	21.6	2.7	1.5
6	192 nos. of APH Basket replacement and water washing of the APH in Unit-4	-	50,374	30.8	0.6	0.2
7	Start-up Oil saving due to modified start-up practices and additional drain in atomizing line	-	1,803	6.6	0	0
8	Energy saving in ID, FD , PA Fans & ESP by attending APH seal leak, duct leakage	7.9	-	26.8	0.5	0.2
9	Condenser Heat Loss reduction by vacuum improvement	-	30,224	18.4	1.5	1
10	APH Soot blowing line size modification along with higher valve size in both the APH of Unit-4	-	44,654	27.3	1.0	0.5

Innovation Project-1 : Ash Augmentation Project

1a. FLY ASH AUGMENTATION:

FLY ASH SYSTEM KEY CHALLENGES

Deviation in conveying rate and evacuation rate was causing ash built in buffer hopper

Frequent passing and jamming issues in Air intake vessel & Air discharge vessel of air lock vessels

Frequent failures in ALV vent lines and valve, due to coarse ash from 1st two fields increased downtime

Extraction was getting hampered due to poor ash evacuation from 1st two fields of each pass



MODIFICATION & ACHIEVEMENTS

Installation of **Ash conveying vessel's & New Intermediate Silo** (Common for both units) to accommodate ash collected from 1st & 2nd field hoppers.


Top discharge ALV's were replaced with **bottom discharge ALV's with fluidizing arrangement**

Buffer hopper manual KGV's were replaced by **pneumatic actuated KGV's** which resulted in less maintenance downtime.


- Sizing of Vent line and valves to buffer hopper end was changed **from 65 NB to 100 NB**, resulting in reduced cycle time

Modifying **closing of AIV & ADV-80% fast & 20% slow pace**, resulting in reduced impact of disc on the valve seat which reduced the sys downtime

AVERAGE MONTHLY DEFECTS OF ALV'S VALVES




REDUCTION OF MAINT COST OF VAC PUMP (INR LAKHS)



Innovation Project-1 : Ash Augmentation Project

1b. BOTTOM ASH AUGMENTATION :

BOTTOM ASH SYSTEM KEY CHALLENGES




BOTTOM ASH MODIFICATONS & ACHIEVEMENTS:

Replacement of existing 75 TPH Clinker Grinder & Jet pump with **90 TPH CG** & Jet pump with necessary modifications in the drive mechanism

Replacement of Existing manual slurry duty **high pressure KGV's with MOV**. After replacement, the effective changeover time is reduced from 01 Hrs. 30 mins to 15 mins

Improved performance of refractory achieved after reduction and strengthening of anchor spacing over shorter walls

After modification, time taken for **bottom deashing is reduced from 2.30 hrs. to 1.10 hrs.** Unit-3 is now able to operate at full load



Total Annual Cost Saving of the Project: ₹ 30 Cr

Innovation: Project-2: DSM Software

In House Application for Generation & Export Deviation Monitoring (DSM Software)..

COMPLIANCE

- Helps in complying to CERC DSM Norms, while maintaining "Grid" discipline.
- Helped in minimizing penalties due to Under injection / over Injection

MONITORING

- Software Accurately measure and monitors the real-time export data. Logs, calculates
- Displays Frequency, ADC, ACP, DC, UI charges for each block of the day as well as for 24 HRS

KEY FEATURES





- Displays frequency trends for last 8 blocks for operator action, average export, instantaneous export, required load.
- Daily reports are generated and sent to desired recipients

SOFTWARE/HARDWARE

- Installation of Energy meters at important nodes/ locations (This was the only cost incurred), C and MySQL, HTML5, CSS3 and JavaScript, Python.

REVENUE GENERATION

- Additional revenue was generated, and Coal saving was done with the help of DSM, by regulating load looking at the frequency



Total Investment: ₹ 0

Total Annual DSM Gain in FY 23-24: ₹ 1.97 Cr

Innovation: Project-2: DSM Software



Block: 50 | Time left:455s

Block Time	12:15-12:30
DC	590 MW
Schedule	590 MW
Avg Export	590.64 MW
Inst Export	590.73 MW
Avg fHz	49.989 Hz
Inst fHz	50.054 Hz
Exp UI rate	₹ 1.40
Exp DevCharge	₹ 222.72
Exp Export	590.69 MW
Rule Num	30
Inst LoadU3	631.65 MW
Inst LoadU4	0.00 MW

Decision Aspect

DC	590 MW
Schedule	590 MW
Exp Export	590.69 MW
Exp fHz	50.022 Hz
SG100%	589 MW
SG102%	613 MW
SG 98%	566 MW
Profit/Loss	₹ 25481

Live Generation

Unit#1	191.59 MW
Unit#2	180.58 MW
Unit#3	622.99 MW
Unit#4	618.74 MW
Station	1613 MW

Update Schedule

Select Day:

From Block No: *

To Block No: *

DC(MW): *

Schedule(MW): *

ECR: *

Current block no., generation, export, frequency & other important details

Consolidated DSM DashBoard with Export, Import, DSM Gain, ACP Price

Unit Load Status for Station

Schedule updating screen

Last 8 block frequency

Gen. Capability curve

Block Number	Remaining Time(sec)	Schedule(MW)	Avg Export(MW)
50	422	590	591

Block Number	Remaining Time(sec)	Schedule(MW)	Avg Export(MW)
50	422	590	591

DSM Dashboard OPGC

PERIOD: All | FY: All

1,070
Avg Scheduled(MW)

1,072
Avg Export_SLDC

4,685
Total Export (MU)

₹43.66
Net DSM Profit(in Lakhs)

₹5.39
Avg ACP

₹1.51
AVG ECR

49.99
Avg Frequency

Net DSM Profit (in Lakhs)

Avg ACP by TimeRange

Monthly ECR (Rs/kwh)

Sum of Diff bet SLDC & OPGC Export(MWH) by Year and Month

OPGC-II Station DSM Reports

22-AUG-2024 15:36:09

Auto generated DSM Reports

Date: [21-08-2024] Shift: [24hrs] [Submit]

OPGC-II DSM Report
2024-08-21

Export to xls | Export to csv | Export to txt

Block	Time	DC (MW)	Schedule (MW)	Export (MW)	Frequency	Gen Load (MW)	UI (kWh)	ACP (Rs/MWh)	Rule Number	UI rate (Rs/kwh)	Dev Charges (Rs)	ECR (Rs/MWh)	profit/loss	APC (MW)
1	00:00-00:15	590	590	595.72	50.039	632.51	1431.14	5499.54	40	0.700	1001.80	1400.00	1001.80	36.79
2	00:15-00:30	590	590	595.29	50.017	632.22	1323.64	5499.81	30	1.400	1853.09	1400.00	1853.09	36.92
3	00:30-00:45	590	590	594.75	50.010	631.57	1186.43	5499.01	30	1.400	1661.00	1400.00	1661.00	36.82
4	00:45-01:00	590	590	594.94	50.021	631.75	1235.86	5350.26	30	1.400	1730.20	1400.00	1730.20	36.80
5	01:00-01:15	590	590	594.81	50.006	631.73	1202.96	4422.35	30	1.400	1684.14	1400.00	1684.14	36.92
6	01:15-01:30	590	590	593.93	50.025	630.85	982.03	4141.2	30	1.400	1374.84	1400.00	1374.84	36.92
7	01:30-01:45	590	590	594.36	50.010	631.14	1091.13	4099.53	30	1.400	1527.58	1400.00	1527.58	36.77

Real Time Gen Capability Curve

Renewable Energy:

Solar Generation (MWh/Year)



OPGC Long Term Plan

- Proposed 50 MW Solar power plant at Ash pond area is under pipe line (Tendering will start).
- Another 2 MW Solar power plant feasibility study & DPR under progress at Raw water intake channel



OPGC Green Initiatives



Solar water Heater for Colony & Canteen:

2900 LPD Capacity of Solar water heater installed for 160 families & for canteen



Biogas Plant:

Waste feeding capacity of 1MT/day and releases 3 cylinder of gas/day (42 kg/day), used for cooking in guesthouse



Solar LED installation at Colony & Ash pond:

60 nos. of 50Watt LED's are installed at ash pond with capacity of 3KW



Roof top Solar PV plant installation:

Total 39 KW of solar PV plant installed in plant canteen, Service building, WTP & Switchyard



Wind driven Turbo ventilation fan:

30 nos. of wind driven cooling fans are installed in WH & another 25 will be replaced in CW, IDCT & FOPH area from motor to wind



Rain water Harvesting:

1800 M3 Capacity of rain water harvesting pond to utilize the water in CHP system.




Roof top rain water harvesting:

Roof Top Rain Water Harvesting from all buildings.

Renewable projects implement

Solar water Heater at Canteen & colony.



Solar LED light installation.



Roof top Solar plant at plant canteen




Biogas Plant at Colony




Environment Management: Ash Utilization

Ash Utilization Break up



Ash Utilization Y-O-Y (Lakh MT)



Action Plan for 100% ash utilization



Agreement with M/s Ambuja & M/s Dalmia cement (20 Lakh MT/Year):

Dedicated rake to be deployed for ash transportation from OPGC to Ambuja & DCBL.



Requirement for new NH constructin. (8 Lakh MT):

Estimated ash utilization of 8 Lak MT for the New NH construction from Jharsuguda-Kanaktora



Requirement for NHAI Sambalpur div. (7.9 LMT):

OPGC has received Order from NHAI Sambalpur div for supplying ash to NH-42 (Angul-Sambalpur Sect).



Requirement for Qry & Low lying area(5.75 LMT):

Identified the Kudopali low lying area of 2.75 LMT & quarry filling at Niladunguri Jujomura is ~ 3 LMT



Requirement for Qry & Low lying area(8.8 LMT):

CTE has been obtained from OSPCB for 5 Lakh MT & balance 3.8 Lakh MT is in process for several abandoned quarries/ low lying areas



Ash requirement for Bricks manufacture(0.5 LMT):

OPGC to manufacture and supply of 30 Lakh Bricks through inhouse brick manufacturing plant.



Huge ash utilization potential at OCPL mines:

OPGC initiated feasibility study at OCPL mines for concurrent filling and OB mixing in the mines has the huge potential for long term ash utilization.





Ash Utilization Y-O-Y (Lakh MT)

Ash Parameter	UOM	2021-22	2022-23	2023-24
Ash Stock in Plant (Yard + Pond)	LMT	40.3	62.0	83.3
Ash Generated	LMT	24.2	28.3	26.3
Ash Utilization	%	23.8	23.3	19.2
Ash Utilization Expenditure	INR Lakhs	811	397	333

Best Practices in Ash Utilization



Environment Management: Emissions




Practices adopted for emission control & monitoring

Retrofitting of wet FGD system: Target Dec'25 & 70% work completed



NOx control by Low Nox fuel Burner and COGA & SOFA Dampers



160 ESP fields installed in each unit to control SPM




Public Disclosure :


1. GHG data is submitted to Central Electrical Authority (CEA) **(Scope-1)**.
2. The data is displayed in front of plant gate and on company website for public interest.
3. Refer link :
https://www.opgc.co.in/env/half_comp_powerplant.asp

Environment Management: Water

Raw water Cons. (m3/MW)



DM water Consumption (%)



Best Practices in Water conservation

- Zero liquid discharge plant
- Automation of make up water to all the tanks in plant viz. service water tank, CCW make up tank, Potable water tank to avoid overflowing of water
- Benchmarking with industry leaders & capturing of best practices
- Identification of significant water usage equipment/process
- KPI monitoring for water consumption and recycle & reuse of water


Recycle & Reuse of waste water

- 21000 m3 waste water recycled
- 1000 KLD capacity STP for treatment of Domestic Sewage & reused In horticulture
- ETP capacity of 200m3/hr & 200000m3 of water reuse in CT M/u & to DM plant water i/l.




Utilization of CT Blowdown water

- Utilization of 35 lakh m3/year CTBD water through CTBD RO system is of fresh raw water
- Reduction in DM regeneration frequency from 530 to 180



Water Management system

- Flow meters are installed in all incoming & outgoing water lines, to quickly identify the cons.
- Water audits are conducted by 3rd party for water management.









Rain water harvesting





- 1800 M3 Capacity of rain water harvesting pond to utilize the water in CHP system.
- Rain water harvesting from roof tops are reused in AHP.



Best Practices : Digitization

Digitization

- 
OSI Soft PI
 Historian & Real Time Monitoring system
- 
PADO
 Performance Analysis, Diagnosis & Optimization tool
- 
DSM Software
 Real Time Export, Sch, ACP & Deviation Monitoring
- 
ENMS System
 Energy Mang System for HT Drives Cons tracking
- 
Power BI
 Dynamic & Interactive Dashboard & Monitoring System
- 
Online High Energy Drain Temp & Coal Pipe temp Monitoring



Best Practices :New Technology Initiatives

New Technology



Monitoring Through "Drones"

Smart Surveillance enabling Bird's Eye view of the project/Process, Eliminating Human Risk



Monitoring Through "Robotics"

Boiler Tube, Bunker Inspections




Implementation of "EV Cars"


A Step Towards Energy Efficiency & Renewable Energy."



Rake Movement Tracking Through GPS Tracking Software (In House)




Coal Stockyard Inspection & PV through Drone:




Cooling Tower Inspection, Burner & WB Inspection & Chimney Inspection through Drone



Deployment of EV cars for O&M activities inside the plant



Rake movement, location, speed – tracking through GPS tracking Software.



Coal Bunkers Temp. mapping & Boiler water wall Inspection through Robotics

Coal Bunker 1 Deliverable



Best Practices : Analytics & Industry 4.0

- With the Use of PI Applications like E log Book, PI Vision, PI message Alert, AF tools, PADO Analytical & Diagnosis tools etc, Interactive & Real Time Dash Boards have been created which not only provide real time data, trend & efficiency, but also give instantaneous Alert (through Message & Mail) if any major deviations occur.



Process improvement through critical Parameters Tracking



Reliability improvement through Boiler Metal Temp Excursion Monitoring




Reduction in Aux Power Cons through SEUs & HT equipments cons monitoring



Heat Rate improvement through real time Turb & Boiler Loss deviation Analysis

Best Practices : Asset Optimization

Best Maintenance Practices:



Remote Breaker Operation



NABL Accreditation for Coal Lab



Man-lifter Operation



Eco Friendly Solar Trolley System



QR Codes scanners in Switchgears



ARC Flash Suits

Best Practices: Flexible Operation

GENERATION FLEXIBILITY



MINIMUM POWER LEVEL ✓




FASTER RAMP RATE *



FASTER START-UP TIME *



Minimum power Level (40%)




Achievement of Minimum Power Level

Minimum Power Level

- Determine mill combination
- Check the coal quality
- Flame quality & stability
- Axial fan performance monitoring
- Dynamic response of controller & check the Excursion parameters
- Dead bend & speed response of Turbine controller

Ramp Rate% Vs Load Range



*Note: OEM (Siemens) has been awarded to study & give necessary solutions, Training to O&M Team by Siemens on Flexible operation

Best Practices: Performance Monitoring & Efficiency Testing

Efficiency Best Practices

Isokinetic Coal sampling for coal fineness

Dirty Air Velocity Testing

Water Flow Measurement


Oxygen mapping in Flue Gas path

LOI Testing for FA & BA

Cooling Tower Performance Testing

Monthly Perf Testing of Turb. & Boiler

Equipment Performance Testing



Best Practices: Afforestation

GREEN OPGC

- The Green belt covers 34.73% against the statutory requirement of 33%
- OPGC has developed more than 200 acres of green belt which is additional to the 225 acres natural forest inside the plant (mostly sal tree).
- Strategically chosen species like neem, Bakul, teak, arjun, Kadamb, Karanja etc. for plantation
- OPGC also distributes ~1000 hybrid mango saplings per year for developing afforestation in the community

NATURAL FOREST



GREEN TOWNSHIP



Hybrid mango sapling distribution to nearby community




Plantation on Environment Day



Plantation by school students

Implementation of ISO



OPGC achieved ISO 50001 certification from both M/s Bureau Veritas & M/s BSCIC with successful implementation of Energy Management System in the Year 2023 .

ISO Certifications



ISO 50001 by M/s Bureau Veritas

Bureau Veritas Certification



ODISHA POWER GENERATION CORPORATION LTD.



IB THERMAL POWER STATION, ODISHA POWER GENERATION CORPORATION LTD
P.O. BANHARPALI, DIST. JHARSUGUDA – 768 234, ODISHA, INDIA.

Bureau Veritas Certification Holding SAS – UK Branch certifies that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the Management System Standard detailed below.

Standard

ISO 50001:2018

Scope of certification

THERMAL POWER GENERATION (2 X 210 MW) & (2 x 660 MW)

Original cycle start date: 02 January 2024
 Expiry date of previous cycle: Not Applicable
 Certification Audit date: 10 November 2023
 Certification cycle start date: 02 January 2024

Subject to the continued satisfactory operation of the organisation's Management System, this certificate is valid until: 01 January 2027

Certificate No. IND.23.7670/ENU Version: 1 Issue date: 02 January 2024

For certificate authenticity, click here: <https://openbook.ukas.com>

Signed on behalf of BVC/UK SAS UK Branch
Jagdish N. MAMAN
 Director – CERTIFICATION, South Asia
 Coreondra, Industry & Facilities Division

Certification body address: 8th Floor, 88 Fleet Street, London, E1 3NG, United Kingdom.

Local office: Bureau Veritas India Private Limited (Certification Business)
 T2 Business Park, Metro Industrial Area, MIDC Cross Road 'C',
 Andheri (West), Mumbai – 400 051, India.

Further conditions regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organisation.
 To check this certificate validity please call +91 22 6274 2000.



ISO 50001 by M/s BSCIC



BSCIC

Certificate

ENERGY MANAGEMENT SYSTEM

This is to certify that:

ODISHA POWER GENERATION CORPORATION LIMITED

IB THERMAL POWER STATION, BANHARPALI,
DIST. JHARSUGUDA-768234, ODISHA, INDIA

Hereby granted the certificate number: **BN22605/21391** Rev. 00

Subsequent to the Assessment of the organization, it has been found to be operating an Energy Management System which complies with the requirements of

ISO 50001:2018
 For the following scope:
**Thermal Power Generation
 (2 X 210 MW and 2 X 660 MW)
 IAF Scope: 25**

For **BSCIC CERTIFICATIONS PVT.LTD.** Originally Registered: 20-Oct-2023 1st Surveillance Due on: 19-Oct-2024
 Issue Date: 26-Oct-2023 2nd Surveillance Due on: 19-Oct-2025
 Expiry Date: 19-Oct-2026

Sufay Datta
Managing Director

(In case if Surveillance Audit is not allowed to be conducted, this Certificate shall be Suspended/Withdrawn).

Please Referable the certificate validity at www.bscic.com or @8000991000 (Toll Free)
 This Certificate of Registration is granted subject to annual provision of the BSCIC Certifications PVT. LTD. District Taxes & Statutory Registration Fees. (S/T) Subject to terms. Please see BSCIC for more details on the scope.
 The certificate of Registration remains the property of BSCIC Certifications PVT. LTD. and shall be returned immediately upon expiry.
 BSCIC Registration details: 18 Floor, 62/63A, Green Park Metro, Faridkot - 151 001, Punjab, India.

Page 1 of 1





IMS (ISO 9001,14001 & 45001) by M/s Bureau Veritas



ODISHA POWER GENERATION CORPORATION LTD.



P.O. BANHARDALI, DIST. JHARSUGUDA – 768 234, ODISHA, INDIA.

Bureau Veritas Certification Holding SAS – UK Branch certifies that the Management System of the above organisation has been audited and found to be in accordance with the requirements of the Management System Standards detailed below.

Standards

ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018

Scope of certification

THERMAL POWER GENERATION (2 X 210 MW) & (2 X 660 MW).

Original cycle start date for ISO 9001: 08 January 2016
 Original cycle start date for ISO 14001: 02 June 2014
 Original cycle start date for ISO 45001: 01 January 2021
 Recertification cycle start date: 27 December 2023

Subject to the continued satisfactory operation of the organisation's Management System, this certificate is valid until: 31 December 2026

Certificate No. IND.23.6280/IMU Version: 2 Issue date: 02 January 2024

For certificate authenticity, click here: <https://openbook.ukas.com>

Signed on behalf of BVC/UK SAS UK Branch
Jagdish N. MAMAN
 Director – CERTIFICATION, South Asia
 Coreondra, Industry & Facilities Division

Certification body address: 8th Floor, 88 Fleet Street, London, E1 3NG, United Kingdom.

Local office: Bureau Veritas India Private Limited (Certification Business)
 T2 Business Park, Metro Industrial Area, MIDC Cross Road 'C',
 Andheri (West), Mumbai – 400 051, India.

Further conditions regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organisation.
 To check this certificate validity please call +91 22 6274 2000.



Energy Conservation Week



MOU Signed with EESL for IE4 Motors



Winners

Drawing Competitions



EC Awareness to School Students



EC Awareness to Township Ladies

Awards & Accolades:



National Energy Conservation Award -2023



CII Excellent Energy Efficient Unit Award: 2023



ET Energy Leadership Awards:2023 (CEO of the Year)



Power Generation Company of the Year Award: 2023



British Safety Council Award -2023



State Energy Conservation Award -2023

Thank You

T H A N K Y O U

Sudhakar Swain (Plant Head): sudhakar.swain@opgc.co.in
Madhumita Soren (Energy Manager): madhumita.sore@opgc.co.in
Pravupada Acharya : pravupada.acharya@opgc.co.in
Braja Kishore Das: braja.das@opgc.co.in

