



JINDAL POWER LIMITED, TAMNAR

25th CII National Award for Excellence in Energy Management 2024

Presenting By:

Bagesh Datt Mishra (AGM – C&I)

Sandeep Patel (Manager – Operation)

Shubham Sahu (AM – O&E)



JPL Tamnar At A Glance..



VISION

Building Nations, Empowering Communities



MISSION

An ever-flourishing company focused on nation building, value creation and sustainable development



CORE VALUES

**Extreme Ownership
Respect For People**

**Better Than Before
Sustainability**



JPL Tamnar At A Glance..



Jindal Power Limited



Location : Tamnar, Raigarh, Chhattisgarh



Capacity : 3400 MW (4X250 MW + 4X600 MW)



Pulverised-Fuel (PF) Boiler



Water from Rabo Dam (35 KM) & Kalma Pump house (60 KM)



Coal Mine having Clean coal technology-based Coal Washery



Coal transportation via 7 KM long CCPC



258 KM long 400 KV double circuit line



ISO – 9001, ISO – 14001, ISO 50001 Certified






Plant Performance FY 23-24


| Parameters | UOM | Stage-I (4X250 MW) | Stage-II (4X600 MW) | Station (3400 MW) |
|---------------------------|----------|--------------------|---------------------|-------------------|
| Generation | MU | 7517.44 | 17140.56 | 24658.00 |
| PLF | % | 85.58 | 81.31 | 82.56 |
| Availability | % | 93.21 | 86.91 | 88.76 |
| Gross Heat Rate | kcal/kwh | 2299 | 2295 | 2296 |
| Auxiliary Power | % | 9.61 | 5.25 | 6.58 |
| Boiler Efficiency | % | 86.47 | 86.52 | 86.50 |
| Turbine Heat Rate | kcal/kwh | 1988 | 1986 | 1987 |
| DM Water Consumption | % | 0.76 | 0.76 | 0.76 |
| Raw Water Consumption | m3/MW | - | - | 2.44 |
| Specific Oil Consumption | ml/kwh | 0.090 | 0.181 | 0.153 |
| Specific Coal Consumption | kg/kwh | 0.748 | 0.748 | 0.748 |

Sp. Energy Consumption Trend (Station 3400 MW)

PLF (%)



Availability (%)




- Increasing PLF Trend
- ✓ Coal Availability & Mines Allocation
- ✓ Higher Sales due to Schedule & IEX Price


- Availability
- ✓ Decrease in Availability in FY'24 due to Increase in PO for 5 unit OH

Sp. Energy Consumption Trend (Station 3400 MW)

Gross Heat Rate (kcal/kwh)



Auxiliary Power (%)



Decreasing GHR Trend


- ✓ Comprehensive OH of Units
- ✓ Improved Coal Quality (Imported Coal Blending)
- ✓ Higher PLF & LF

Decreasing APC Trend


- ✓ Increase in Solar Capacity
- ✓ Comprehensive OH of Units
- ✓ Reduced SCC
- ✓ Higher PLF & LF

Sp. Energy Consumption Trend (Station 3400 MW)


Net Heat Rate (kcal/kwh)




Raw Water Consumption (m3/MW)



Specific Oil Consumption (ml/kwh)



Specific Coal Consumption (kg/kwh)






National Benchmarking

| FY 22-23 | | | | FY 23-24 | |
|-------------|--------------|----------|----------------------------|-----------------|------------|
| Vindhyachal | NTPC Farakka | Sipat | Parameters | JPL Tamnar | JPL Tamnar |
| 4760 | 2100 | 2980 | Capacity (MW) | 3400 | 3400 |
| 37337.13 | 12402.33 | 21167.99 | Generation (MU) | 18967.99 | 24658 |
| 89.54 | 67.42 | 81.09 | Plant Load Factor (%) | 63.69 | 82.6 |
| 92.85 | 85.83 | 87.28 | Availability (%) | 93.03 | 88.8 |
| 0.18 | 0.75 | 0.26 | SOC (ml/kwh) | 0.171 | 0.2 |
| 6.58 | 7.74 | 5.73 | Aux Consumption (%) | 6.91 | 6.6 |
| 2368 | 2450 | 2298 | Gross Heat Rate (Kcal/Kwh) | 2326 | 2296 |

Roadmap to Achieve National Benchmark





Major ENCON Projects FY 24-25

| Project Description | Expected Savings (MU) | Energy Savings (TOE) | Expected Savings (INR Million) |
|--|-----------------------|----------------------|--------------------------------|
| Implementation of Artificial intelligence tool for efficiency improvement in 600 MW U#2 & 250 MW U#2 | 34.69 | 7907 | 99.78 |
| Installation of VFD to ID Fans 250 MW U#1 | 2.07 | 472 | 6.82 |
| ID Fan Current Reduction after OH Work : 250 MW U# 1 & 4, 600 MW U#1 | 11.16 | 2546 | 33.52 |
| APH Baskets Replacement in OH : 250 MW U# 1 & 4, 600 MW U#1 | 19.43 | 4430 | 56.85 |
| Condenser Vacuum Improvement : 250 MW U# 1 & 4, 600 MW U#1 | 14.68 | 3349 | 44.09 |

Total Expected Savings of 82 MU, INR 241 Million in FY 24-25



Energy Saving Projects Implemented

| Year | No. of Energy Saving Projects | Investment (INR Million) | Electrical Savings (Million kWh) | Thermal Savings (Million Kcal) | Total Savings (INR Million) |
|------------|-------------------------------|--------------------------|----------------------------------|--------------------------------|-----------------------------|
| FY 2021-22 | 7 | 119.0 | 5.59 | 42200 | 71.0 |
| FY 2022-23 | 13 | 97.4 | 14.54 | 122182 | 166.3 |
| FY 2023-24 | 9 | 145.1 | 18.69 | 69799 | 144.2 |

ENCON Projects

FY: 21-22

CW Pump Operation Optimization

- ✓ 5 CW Pumps for 1 Phase (2 Units) in Summers for Stage-II (4X600 MW)
- ✓ Savings of 3.55 MU & 8.88 INR Million

Energy Saving Projects Implemented

ENCON Projects

FY: 22-23

- ❑ O2 Grid Arrangement at APH Inlet
 - ✓ Optimization of Oxygen % and hence draft power savings (230 KW Savings in 1 Unit)
 - ✓ Savings of 1.16 MU & 3.47 INR Million

- ❑ CW Pump Operation Optimization
 - ✓ 3 CW Pumps for 1 Phase (2 Units) at part loads for Stage-II (4X600 MW)
 - ✓ Savings of 5.45 MU & 16.34 INR Million

FY: 23-24


- ❑ VFD Installation in CEP U#1 Stage-I (4X250 MW)
 - ✓ 10 KW Savings in each CEP
 - ✓ Savings of 0.11 MU & 0.37 INR Million



Innovative Project : AI Project (Real time Performance Monitoring)

| | |
|---|--|
| Project Title | Heat Rate and Coal Consumption Reduction by AI Implementation |
| Analyzes Complex Data Beyond Human Capabilities | Navigator's advanced AI transcends human limitations by processing and analyzing vast, complex data in real-time, offering precise, actionable insights. This intelligent system expertly navigates the intricate web of variables in energy production, ensuring optimal decisions and mitigating human errors caused by fatigue or distraction, thus significantly enhancing operational efficiency and reliability. |
| Heat Rate Online monitoring | Observation of HR trend, losses and remedial action to be taken based on Navigator's suggestion. |
| Sensor Validation System To Increase Plant Reliability | Sensor malfunction alerts, Detection of technological issues, Simulation of broken or missing sensors (sensor digital twin). |
| Early Detection of Anomalies and Sensor Failures | Early Warning System, Reducing Unplanned Downtime & Maintenance Costs, Sensor Malfunction Alerts, Preventing Operational Errors, Leveraging Advanced Simulations. |
| Expected Annual Savings | Minimum INR 1.5 Crore for 250 MW Unit & INR 6.2 Crore for 600 MW Unit. |
| Status | In Process in 600 MW U#2 & 250 MW U#2 (To be implemented in entire Station by FY'25). |

Innovative Project : AI Project (Real time Performance Monitoring)



Why Innovative..?

- ✓ Optimized Combustion Efficiency
- ✓ Enhanced Predictive Maintenance
- ✓ Process Optimization through Real-Time Performance Monitoring & Dynamic Load Management
- ✓ Energy Efficiency Improvements
- ✓ Data-Driven Insights and Continuous Improvement

☐ Replication Potential


- ✓ Reduced fuel consumption, Operational & maintenance costs.



Innovative Project : Biomass Pellet Plant – 2 X 4 TPH Capacity

| | |
|--|--|
| Project Title | 2x4 TPH Biomass Pellet Plant |
| Plant Capacity | 160 TPD, 48000 TPA |
| Feedstock | Paddy Straw, Forest waste, Firewood, Bamboo, Subabool, Rice husk, Horticulture waste etc. |
| Pellet Plant Equipment's | Shredder, Chipper, Rotary Dryer, Hammer Mill, Pellet Machine (Ring Die type), Cooler and material handling equipment's |
| Biomass Pelleting Process | Raw material selection - Shredding/Chipping - Drying with the help of rotary dryer - Grinding with Hammer mill - Pelleting with Pellet machine - Cooling with the help of discharge belt conveyors and coolers – Bagging/Packing |
| Air Pollution Control Equipment | Bag filters are provided to control dust and this dust free air will be sent to atmosphere through 15 meter height chimney |
| Water Requirement | Water Requirement is only 1000 to 1500 Litres per week (Only periodic make up water required as it is recirculated). |
| Pellet Plant Area | 12000 M2 |

Innovative Project : Biomass Pellet Plant – 2 X 4 TPH Capacity



Why Innovative..?

- ✓ Reduction of GHG emissions
- ✓ Utilization of waste and by-products
- ✓ Enhanced energy security
- ✓ Potential for rural development

☐ Replication Potential

Significant potential due to the growing demand for renewable energy sources and the global shift towards sustainability.



Innovative Project : Biomass Pellet Plant – 2 X 4 TPH Capacity



Jindal Power takes a **'Powerful' step!**

“Jindal power ltd becomes the first ever thermal power plant which is going to setup of 100 TPD pellet manufacturing units in its premises”





Call: 0120-4948705 | **Email:** md-biomass-power@gov.in
Address: EOC, Sector-24, Noida-201301 (U.P.)

Innovative Project : Low NOx Burner

| | |
|--------------------------------------|---|
| Project Title | NOx Emission Reduction by Installation of De-NOx Burner & SOFA |
| Requirement | To fulfill requirement of Govt. of Guidelines directed by MOEECC |
| Target | NOx Value less than - 450mg/Nm ³ |
| Technology Used | NOx reduction is achieved by operating the firing zone under sub-stoichiometric firing conditions by reducing Oxygen concentration in the active firing zone. This is accomplished by introducing a portion of the combustion air higher in the furnace through a separated over fire air (SOFA) Windbox. In this a significant portion of the combustion air will be introduced through the SOFA registers, and the rest of the air shall continue to be used through main Windbox as secondary air. |
| Main Equipment/ Component | <ul style="list-style-type: none"> <input type="checkbox"/> De-NOx Burner <input type="checkbox"/> SOFA Duct <input type="checkbox"/> SOFA registers <input type="checkbox"/> Damper controls & Actuators |
| Result | <ul style="list-style-type: none"> ✓ NOx Emission Reduction ✓ Compliance to MOEECC Guidelines ✓ Combustion Improvement. |

Innovative Project : Low NOx Burner



ISOMETRIC VIEW
SCALE - 1:100


LAYOUT OF SOFA DUCT

Why Innovative..?

✓ Combustion Improvement & NOx Reduction

❑ Replication Potential


Significant replication potential due to need of the hour to reduce GHG Emissions & Improved Combustion.



PLAN LAYOUT OF SOFA WITH BOILER CONNECTION

Utilization of Renewable Energy Sources (Onsite)

| Year | Solar Installed Capacity (MW) | Capacity Addition (MW) | Generation (MU) | Share % w.r.t Overall Energy Consumption |
|------------|-------------------------------|------------------------|-----------------|--|
| FY 2021-22 | 0.15 | - | 0.183 | 0.02 |
| FY 2022-23 | 1.15 | 1.0 | 0.944 | 0.07 |
| FY 2023-24 | 9.79 | 8.64 | 2.645 | 0.16 |




Utilization of Renewable Energy Sources (Offsite)

Glimpse of 78 MWp Kasdol Solar Project



Environment Management – Ash Utilization




| Description | UOM | FY 2021-22 | FY 2022-23 | FY 2023-24 |
|--|-----|------------|------------|------------|
| Total Ash generated | Ton | 5390404 | 6737000 | 8021000 |
| Ash Stock in Plant (yard + pond) | Ton | 16150000 | 0 | 0 |
| Ash Utilization | % | 88 | 99 | 101 |
| Ash Utilized in manufacturing of cement/concrete | % | 4.32 | 1.30 | 1.48 |
| Ash Utilized in Fly Ash Bricks | % | 0 | 0.50 | 2.08 |
| Ash Utilized in Mine filling | % | 69.88 | 95.03 | 96.33 |
| Ash Utilization in Other Areas | | | | |
| a) LLA | % | 14.20 | 3.15 | 0.095 |
| b) Gudeli Stone Mine | % | 11.38 | 0 | 0 |



Environment Management – Emission Monitoring

GHG Emissions

| Scope | Description | UOM | FY 2021-22 | FY 2022-23 | FY 2023-24 |
|---------|---------------------------|-------------------|-----------------|-----------------|-----------------|
| Scope-1 | Absolute Emissions | ton CO2 | 13118016 | 16767624 | 21518695 |
| | Emission Intensity | Kg CO2/kWh | 0.8855 | 0.8840 | 0.8727 |
| Scope-2 | Absolute Emissions | ton CO2 | 0 | 0 | 0 |
| | Emission Intensity | Kg CO2/kWh | 0 | 0 | 0 |
| Scope-3 | Absolute Emissions | ton CO2 | 33415 | 42580 | 32145 |
| | Emission Intensity | Kg CO2/kWh | 0.0023 | 0.0022 | 0.0013 |
| Total | Absolute Emissions | ton CO2 | 13151431 | 16810204 | 21550840 |
| | Emission Intensity | Kg CO2/kWh | 0.8878 | 0.8862 | 0.8740 |



| Description | UOM | FY 2021-22 | FY 2022-23 | FY 2023-24 |
|--|-----------|------------|------------|------------|
| Total CO2 Emissions Per kW of Generation | Kg CO2/kW | 0.885 | 0.883 | 0.871 |
| Current SOx Emissions at Full Load | mg/Nm3 | 1454 | 1290 | 955 |
| Current NOx Emissions at Full Load | mg/Nm3 | 395 | 361 | 332 |
| Particulate Matter | mg/Nm3 | 34.3 | 33.7 | 34.2 |

Environment Management – Emission Monitoring

Best Practices adopted for Emission Control & Monitoring

- ✓ Installation of Low NOx Burner in 600 MW U#1 in Aug'24.
- ✓ Limestone blending with Coal to reduce SOx emission implemented in 250 MW U#1.
- ✓ 06 No's of Continuous Ambient Air Quality Monitoring Stations (CAAQMS)
- ✓ Continuous Emission Monitoring System (CEMS) in all stacks
- ✓ Mobile Fog cannon with water sprinkling , Rain guns & sprinklers installed for controlling fugitive emission
- ✓ 07 km long Cross- Country Closed Pipe Conveyor (CCPC) has been installed for transportation of coal .
- ✓ 06 No's of E-vehicles for Local movements for reduction of carbon emission.
- ✓ PUC center at the plant premises for regular monitoring of vehicle emission.
- ✓ Developments of green belt have been done in Plant premises, Ash dyke, Mines, Rabo dam & Catchment area and Colony area. Approximately 27.95 Lakh No's of Saplings has been planted since 2005 to 2024.

Environment Management – Emission Monitoring

GHG Emission Reduction Plan

❑ Short Term Plan

- ✓ Implementation of AI-ET Navigator to reduce Coal consumption and consequently GHG emissions. Under progress in 2 Units and to completed in all Units by FY'25.
- ✓ Use of sustainable fuel sources such as biomass: Biomass Pellet Plant of 160 TPD is in progress.
- ✓ Investing in renewable energy sources like solar: 78 MW Solar Project at Kasdol is in progress.
- ✓ Optimizing thermal plant processes to minimize emissions and improve overall efficiency.

❑ Long Term Plan

- ✓ Transition to low-carbon technologies: Investing in research and development of low-carbon or carbon-neutral technologies for power generation.
- ✓ Carbon capture and storage (CCS): Implementing CCS technology to capture and store CO2 emissions from power plants, reducing their impact on the atmosphere.
- ✓ Advocating for supportive policies and regulations at the national and international levels to incentivize GHG emission reductions and create a level playing field for sustainable practices.

Environment Management – Water

| Description | UOM | FY 2021-22 | FY 2022-23 | FY 2023-24 |
|-----------------------|-------|------------|------------|------------|
| DM Water Consumption | % | 0.60 | 0.47 | 0.76 |
| Raw Water Consumption | m3/MW | 2.55 | 2.44 | 2.44 |



Best Practices in Water Management

Water Conservation and Efficiency

- ✓ Closed Loop Cooling Systems: To minimize freshwater intake and reduce thermal pollution.
- ✓ Cooling Tower Optimization: Advanced cooling tower technologies are employed to enhance efficiency and reduce water loss due to evaporation and drift. Regular maintenance and optimization of cooling towers ensure they operate at maximum efficiency, conserving water resources.
- ✓ Water Reuse and Recycling: Treated effluent is repurposed for cooling, ash handling, and other non-potable uses, thereby reducing the dependency on external water sources.

Environment Management – Water

❑ Water Quality Management

- ✓ Continuous Monitoring: Real-time data collection through installed continuous water quality monitoring system allows for prompt corrective actions to maintain water quality.
- ✓ Advanced Water Treatment Technologies: Reverse osmosis, ultrafiltration, and ion exchange help achieve high levels of water purity, making the treated water suitable for various plant operations.
- ✓ Corrosion and Scale Control: Chemical treatment programs are in place to control corrosion and scaling in boilers and cooling systems. These treatments protect equipment, enhance system efficiency, and reduce water consumption.

❑ Effluent Management

- ✓ Zero Liquid Discharge (ZLD)
- ✓ Efficient Effluent Treatment Plants (ETPs)
- ✓ Sludge Management

❑ Rainwater Harvesting

- ✓ Rainwater harvesting systems to capture and store rainwater hence reducing reliance on external water sources.
- ✓ Systems are in place to recharge groundwater aquifers, ensuring sustainable water use. Excess rainwater is directed into the ground, replenishing local water tables and securing long-term water availability.

Best Practices in the Plant (Non-Energy Efficiency)

Flexibilization

- ✓ Flexible operation demonstrated with 3% ramp-up and 40% technical minimum in 600 MW Unit-2 & in 250 MW Unit-3 will be completed by 25th Aug'24. In other Units will be completed by Mar'25.

Technology Advancement

- ✓ Flame Scanner Up gradation for more accurate Intensity and frequency at low loads.

Maintenance and Reliability


- ✓ Comprehensive overhauling of units on schedule.
- ✓ Replacement of critical components with RLA of ECO coil, CT, PT, CVT.
- ✓ CCPC Capacity enhancement to 40 KT/day.

Digitization

- ✓ GPS based vehicle mapping and tracking from Plant to Mines for improved reliability.
- ✓ Implementation of ISO 27001 Information Security Management System.
- ✓ SAP S/4 HANA on RISE Implementation for better reporting capabilities, enhanced user experience & increased productivity.

Asset Management

- ✓ JPL manages its working capital in very efficient manner, the process starts with maintaining the cash flow statement daily and prepare the projected cash inflow and outflow. Surplus funds invested in various investment options.



Best Practices in the Plant (Non-Energy Efficiency)

CSR, Biodiversity & Afforestation

- ✓ **JPL CSR Coverage:** 70 villages / 80000 people.
- ✓ **Health Projects:** Chiranjivi Project (Curbing malnutrition), Vatsalya Project (Mother & Child health), Shubhangi project (Menstrual health & hygiene), PM TB free India Campaign, Sickle cell Anemia project, Mobile health camp.
- ✓ **Community Education & Skill Development:** Project Yashashvi & Sankalp (Skill training & scholarship to 300 rural girls).
- ✓ **Sustainable Livelihood & Women Empowerment:** Project Akrti (Garment making & stitching), Swashakti (200 SHG) impacting lives of 5000 rural women.
- ✓ **Environment & Agriculture**
 - 500 tribal farmers developed wadi orchard of mango, cashew & lemon in 500 acre of land with NABARD.
 - Rejuvenated around 100 water bodies & planted one lakh tree plantation.
 - One watershed project in 900 hq.
 - Supported 500 marginal farmers for SRI project, vegetable cultivation.



New Initiatives

- ✓ Ash slurry pipeline from Plant to Coal mines – 9340 mtr (In Progress).

Energy Management System

- ❑ **Jindal Power Limited, Tamnar is certified with EN 50001 (Energy Management System)**
- ❑ The inherent energy efficiencies in our plants enable us to achieve higher level of performance.
- ❑ Power consumption is correlated with process or equipment output and energy consumption is used for calculating individual equipment specific power consumption.
- ❑ Better decision making to operator to merit order running of the redundant auxiliaries,





Energy Management System

Glimpse of EnMS System of Stage-I (4X250 MW) & Stage-II (4X600 MW)

Home Administration Configuration Reports Tag Analysis Help Log Out

AREVA e-terra/reports SUBSTATION AUTOMATION SYSTEM REPORT

Report Type :- Daily Active Energy Report Date - 19-Feb-23

Export To Excel

| SL No. | Name of Feeder | Running Hours | MWH Reading | | | | | | Avg. PF | Avg. Current | Avg. KW | Avg. Voltage | Aux. Consn. % |
|--------|--------------------|---------------|-------------|----------|----------|----------|------------|--------|---------|--------------|---------|--------------|---------------|
| | | | Import | | Export | | Difference | | | | | | |
| | | | Previous | Present | Previous | Present | Import | Export | | | | | |
| 1 | 4LSR01 FROM UAT-4A | 00:00 | 30169.87 | 30169.87 | 14553.83 | 14781.57 | 0.00 | 227.74 | - | 2088.96 | - | 0.86 | - |
| 2 | TIE I/C- 02 | 00:00 | 1630.46 | 1630.46 | 1.26 | 1.26 | 0.00 | 0.00 | -1.00 | 0.00 | 0.00 | - | - |
| 3 | UNIT AUX TRF-01 | 00:00 | 27486.23 | 27492.21 | 0.00 | 0.00 | 5.98 | 0.00 | 0.69 | 32.68 | 247.94 | - | 2.62 |
| 4 | ESP AUX TRF-01 | 00:00 | 20088.78 | 20094.23 | 0.00 | 0.00 | 5.45 | 0.00 | 0.97 | 21.17 | 226.08 | - | 2.39 |
| 5 | CT AUX TRF-01 | 00:00 | - | - | - | - | - | - | - | - | - | - | - |
| 6 | BFP 4A | 00:00 | 56064.55 | 56064.55 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | -3.73 | - | 0.00 |
| 7 | BFP 4C (SA) | 00:00 | 61115.89 | 61195.28 | 0.00 | 0.00 | 79.39 | 0.00 | 0.88 | 327.47 | 3310.99 | - | 34.86 |
| 8 | ID FAN 4A | 00:00 | 20493.90 | 20530.02 | 0.00 | 0.00 | 36.13 | 0.00 | 0.80 | 165.73 | 1507.28 | - | 15.86 |
| 9 | PA FAN 4A | 00:00 | 73708.33 | 73727.29 | 0.00 | 0.00 | 18.96 | 0.00 | 0.82 | 84.07 | 789.74 | - | 8.33 |
| 10 | FD FAN 4A | 00:00 | 18389.49 | 18395.09 | 0.00 | 0.00 | 5.60 | 0.00 | 0.67 | 30.49 | 233.79 | - | 2.46 |
| 11 | MILL 4A | 00:00 | 8399.74 | 8410.06 | 0.00 | 0.00 | 10.32 | 0.00 | 0.75 | 7.98 | 23.60 | - | 4.53 |
| 12 | MILL 4C | 00:00 | 13090.33 | 13099.42 | 0.00 | 0.00 | 9.10 | 0.00 | 0.73 | 45.15 | 379.69 | - | 3.99 |
| 13 | MILL 4E | 00:00 | - | - | - | - | - | - | - | - | - | - | - |
| 14 | CE PUMP 4A | 00:00 | 4982.86 | 4988.46 | 0.00 | 0.00 | 5.60 | 0.00 | 0.84 | 24.41 | 232.92 | - | 2.46 |
| 15 | CE PUMP 4C | 00:00 | 5913.87 | 5920.35 | 0.00 | 0.00 | 6.48 | 0.00 | 0.85 | 27.66 | 269.56 | - | 2.84 |
| 16 | CW PUMP 4A | 00:00 | 18899.20 | 18928.38 | 0.00 | 0.00 | 29.18 | 0.00 | 0.70 | 151.66 | 1216.13 | - | 12.81 |
| 17 | ACW PUMP 4A | 00:00 | 6638.24 | 6646.84 | 0.00 | 0.00 | 8.59 | 0.00 | 0.82 | 57.03 | 357.56 | - | 3.77 |
| Total | | | | | 220.78 | | 227.74 | | | | | | |

PREVIOUS JINDAL POWER LTD,4X600MW 08/19/24 09:57:33

Home U1-1 U1-3 U1-5 U3-1 U3-3 U4-1 U4-3 U4-5 U2-1 U2-3 CHP-1 AHP-1 U1-2 U1-4 U3-2 U3-4 U4-2 U4-4 U2-2 U2-4 CHP-2 AHP-2 230

U#1 11KV Station Board(0KSR3) ETG-(10,10.45,100) U#1 11KV Unit Board(2KSR1)

| FEEDERS | A | KW | KWH | FEEDERS | A | KW | KWH |
|--------------------------------------|-----|-------|----------|---|-----|---------|----------|
| 1 U#1 Tie to OKSR1 | 0 | 0.0 | 29531423 | 14 U#1 TIE FRM Stn Swgr 0KSR3 | 0 | 0.0 | 45293044 |
| 2 U#1 Station Serv 0KDT2 | 13 | 212.0 | 20792355 | 15 U#1 Serv Trf 2KDT1 with BPT | 33 | 499.0 | 24040512 |
| 3 U#1 Bottom & ESP Serv Transf 1KDT1 | 15 | 235 | 11463148 | 16 U#1 Unit Serv Trf 2KDT3 | 19 | 225.0 | 8711659 |
| 4 U#1 Geho Pump 1 | 6 | 123.0 | 2969558 | 17 U#1 ESP AUX trafo 2KDT5 | 10 | 152.0 | 3932361 |
| 5 U#1 Spare Traformer | 000 | 000 | 0000 | 18 U#1 ESP AUX trafo 2KDT7 | 7 | 116.0 | 3141162 |
| 6 U#1 Station Aux Trafo | 46 | 647.0 | 42608098 | 19 U#1 ESP AUX trafo 2KDT9 | 10 | 118 | 1983998 |
| 7 U#1 Tie to 11 KV stn SWGR | 0 | 0.0 | 4472560 | 20 U#1 ESP AUX trafo 2KDT11 | 11 | 193.0 | 3921448 |
| 8 U#1 Bunker Serv Trf 1(KBFD)2 | 2 | 21.0 | 3383942 | 21 U#1 Unit Aux trafo 2A 16 MVA (2KSR1) | 286 | 3913.0 | 94595340 |
| 9 U#1 Spare Trafo | 18 | 205 | 5322921 | 22 U#1 Spare Motor (4200 KW) | 000 | 000 | 0000 |
| 10 U#1 INC LV 1 | 122 | 1783 | 52066841 | 23 U#1 ID Fan 2A VFD Ch 1 (5000KVA) | 80 | 1118.0 | 40485428 |
| 11 U#1 Ash WTR Serv Trf 0KAWD1 | 24 | 346.0 | 16768827 | 24 U#1 ID Fan 2B VFD Ch 1 (5000KVA) | 73 | 1007.0 | 3990021 |
| 12 U#1 Spare GT1 | 000 | 000 | 0000 | 25 U#1 PA FAN 2A 4200KW | 90 | 1362 | 52914125 |
| 13 U#1 Tie to 11 KV UNIT Swgr 2KSR1 | 0 | 0.0 | 45283797 | 26 U#1 CW Pump 2A (2250 KW) | 148 | 2192 | 24690138 |
| | | | | 17 U#1 ESP AUX trafo 2KDT5 | 153 | 2275.0 | 81769243 |
| | | | | 28 U#1 Spare trafo | 000 | 000 | 0000 |
| | | | | 29 U#1 INC FRM Unit trans(31.5MVA) | 897 | 12926.0 | 17197865 |

Stage-I (4X250 MW) EnMS is from AREVA
Stage-II (4X600 MW) EnMS is In-house developed system.

Learning



Industry Best Practices



Cost Saving Energy Efficiency Measures



Sustainable Energy Practices



Cutting Edge Technologies



Industry Collaboration

NET ZERO Commitment

Few steps taken by JPL to curb Emissions



Biomass Pellet Plant



Limestone Blending with Coal




78 MWp Solar Plant



Ash Slurry Pipeline



CCPC Capacity Enhancement



Low NOx Burner



Awards and Achievements



10th FICCI Award for Excellence in Safety System 2023



CEE National Energy Efficiency Award 2023



CBIP Award 2022- Best Performing Thermal Power Station



Grow Care India Occupational Health and Safety Award 2023



Power-Gen ESG and Sustainability Awards 2023



Apex India Green Leaf Energy Efficiency Award 2023



Safety Fortnight Awards 2023



IEX Excellence Most Active Generator in Electricity



THANK YOU WE ARE LISTENING....

There must be a better way to make the things we want, a way that doesn't spoil the sky, or the rain or the land." - Paul McCartney

Email: amitpandey@jindalpower.com
Mobile: 7898905225